

SUPPLEMENTAL SCC QUESTIONNAIRE
GAS TRANSMISSION OR LIQUID PIPELINE

1. Pipeline Safety Advisory Bulletin - ADB-03-05 - October 8, 2003
 - Review Bulletin with operator, if operator is not familiar with.
 - Reference also Baker Stress Corrosion Cracking Study at:
http://primis.phmsa.dot.gov/gasimp/docs/SCC_Report-Final_Report_with_Database.pdf

Comments: Operator evaluates for SCC when pipeline is exposed.

2. Has the pipeline system ever experienced SCC (in service, out of service, leak, non-leak)?
 - Type of SCC?
 - Classical - high pH
 - Non-classical – low or near neutral pH
 - What are the known risk indicators that may have contributed to the SCC?

Comments: No SCC has been found on transmission or plant pipelines.

3. Does the operator have a written program in place to evaluate the pipeline system for the presence of SCC? If no, have operator explain. If operator has not considered SCC as a possible safety risk, go to #10.

Comments: Yes.

4. Has/does the operator evaluate the pipeline system for the presence of SCC risk indicators?

Comments: Yes.

5. Has the operator identified pipeline segments that are susceptible to SCC?

Comments: Yes, the operator is considering evaluating the 14" pipeline for SCC.

6. If conditions for SCC are present, are written inspection, examination and evaluation procedures in place?

Comments: Yes.

SUPPLEMENTAL SCC QUESTIONNAIRE
GAS TRANSMISSION OR LIQUID PIPELINE

7. Does the operator have written remediation measures in place for addressing SCC when discovered?

Comments: **Yes.**

8. What preventive measures has the operator taken to prevent recurrence of SCC?
- Modeling?
 - Crack growth rate?
 - Comparing pipe/environ./cp data vs. established factors?
 - Other?
 - Hydrotest program?
 - Intelligent pigging program?
 - Pipe re-coating?
 - Operational changes?
 - Inspection program?
 - Other?

Comments: **SCC has not been identified via exposed pipe and in-line inspections.**

9. Does the operator incorporate the risk assessment of SCC into a comprehensive risk management program?

Comments: **Yes, it's part of the risk assessment tool**

Continue below for those operators who have not considered SCC as a possible safety risk.

10. Does the operator know of pipeline and right of way conditions that would match the risk indicators for either classical or non-classical SCC? See typical risk indicators below.

Comments: **N/A**

High pH SCC Potential Risk Indicators


- Known SCC history (failure, non-failure, in service, and during testing)
- Pipeline and Coating Characteristics
- Steel grades X-52, X-60, X-65, X-70, and possibly X-42
 - Age \geq 10 years
 - Operating stress $>$ 60% SMYS

SUPPLEMENTAL SCC QUESTIONNAIRE
GAS TRANSMISSION OR LIQUID PIPELINE

- Pipe temperature >100 deg. F (typically < 20 miles d/s of compression)
- Damaged pipe coating
- Soil Characteristics
 - Soil pH range: 8.5 to 11
 - Alkaline carbonate/bicarbonate solution in the soil
 - Elevated soil temperature contributing to elevated pipe temperature
- Polarized cathodic potential range: -600 to -750 mV, Cu/CuSO₄

Low or Near-Neutral pH SCC Potential Risk Indicators

- Known SCC history (failure, non-failure, in service, and during testing)
- Pipeline and Coating Characteristics
- Steel grades X-52, X-60, X-65, X-70, and possibly X-42
 - Age ≥ 10 years
 - Frequently associated with metallurgical features, such as mechanical damage, longitudinal seams, etc.
 - Protective coatings that may be susceptible to disbondment
 - Any coating **other than** correctly applied fusion bonded epoxy, field applied epoxies, or coal tar urethane . . .
 - Coal tar
 - Asphalt enamels
 - Tapes
 - Others
- Soil Characteristics
 - Soil pH range: 4 to 8
 - Dissolved CO₂ and carbonate chemicals present in soil
 - Organic decay
 - Soil leaching (in rice fields, for example)
- “Normal” cathodic protection readings (disbonded coating shields the pipe from cp current)



OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Puget Sound Energy

Date(s): June 8 – 11, 2009

Unit: Jackson Prairie Gas Storage

Page 1 of 2

Line & Location		Field Readings										Remarks
		Line Size	In.	P/S	CP Volts Casing	Volts	Rectifier Amps	Pressures Set	Actual			
Rectifier # 4						15.7	32.3					Location: South End of Plant Setting: Course #1, Fine #6
Rectifier #12						12.6	14.3					Location: West End of Plant Setting: C1, F4
Rectifier #13						11.8	22.3					Location: South End of Plant Setting: C1, F4
Rectifier #15						7.6	17.8					Location: North End of Plant Setting: C1, F5
Rectifier #16						7.7	8.7					Diodes are damaged and need replacing. Location: North End of Plant Setting: C2, F5
Test Site #13	8"			-1.256								Need insulator between Piping and support post
Test Site #14	10"			-1.669								
Test Site #16	16"			-1.610								
Test Site #17	20"			-1.084								At Williams Pipeline-Transfer
Test Site #20	20"			-1.288								At PSE-Jackson Prairie Pipe
	16"			-1.333								Corrosion cell at ground-to-air interface
Well No. 906				-1.564								

OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Line & Location	Line Size	Line In.	Field Readings				Pressures		Remarks
			CP Volts	Casing	Rectifier Volts	Amps	Set	Actual	
Olympic Pipeline	24"		-1.429						Page 2 of 2
Xing MP 190	20"		-1.428						
	16"		-1.428						
	14"		-1.427						
"G" Casing	10"		-1.637	-0.421					Good CP separation between pipeline and casing
Inside secured Plant Facility at:									
(a) West end of Plant	24"		-1.44						
(b) NE corner of Plant	24"		-1.45						
(c) East Cooler #1			-0.917						
(d) Triethylene Glycol (TEG) Plant Piping			-0.576						The Glycol lines are not jurisdictional.
(e) Fuel Line to TEG Regen#1	2"		-0.955						
(f) Fuel Line to TEG Regen#1	2"		-1.074						