

**BEFORE THE WASHINGTON  
UTILITIES & TRANSPORTATION COMMISSION**

WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION,

Complainant,

v.

AVISTA CORPORATION d/b/a AVISTA UTILITIES

Respondent.

---

DOCKETS UE-220053, UG-220054, and UE-210854 (Consolidated)

**ANDREA C. CRANE  
ON BEHALF OF THE  
WASHINGTON STATE OFFICE OF THE ATTORNEY GENERAL  
PUBLIC COUNSEL UNIT**

---

**EXHIBIT ACC-5**

Avista Utilities Response to Public Counsel Data Request No. 28

**July 29, 2022**

**AVISTA CORP.  
RESPONSE TO REQUEST FOR INFORMATION**

JURISDICTION:	WASHINGTON	DATE PREPARED:	02/14/2022
CASE NO.:	UE-220053 & UG-220054	WITNESS:	David Howell
REQUESTER:	Public Counsel	RESPONDER:	David James
TYPE:	Data Request	DEPT:	Wildfire Resiliency
REQUEST NO.:	PC – 28	TELEPHONE:	(509) 495-4185
		EMAIL:	dave.james@avistacorp.com

**SUBJECT:** Wildfire Testimony Exhibit PDE-1T

**REQUEST:** Please provide, for each of the last five years, the percentage of non-urban transmission and distribution electric feeder miles that were inspected for tree risk.

**RESPONSE:**

	2017	2018	2019	2020	2021
Distribution (7675 miles)	19%	26%	15%	21%	68%
Transmission (2270 miles)	49.6%	49.6%	49.6%	49.6%	100%

The rural distinction for ground inspection was implemented as part of the 2022 work plan. The numbers in the table above are the percentage of the entire distribution system. There is not a rural/non-rural distinction on transmission work.