Exhibit No. (DMP-29) Docket No. UW-060343 Witness: Derek M. Pell

## BEFORE THE WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION,

DOCKET NO. UW-060343

Complainant,

v.

ILIAD WATER SERVICE, INC.,

Respondent.

## EXHIBIT TO RESPONSE TESTIMONY OF

DEREK M. PELL Assistant Manager, NW Office of Drinking Water Washington State Department of Health

> ON BEHALF OF STAFF OF WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

Letter dated April 3, 2006 from DOH to David Dorland

October 4, 2006



## STATE OF WASHINGTON

## DEPARTMENT OF HEALTH

April 3, 2006

20435 72nd Ave. S., Suite 200, K17-12 • Kent, Washington 98032 -2358

Dave Dorland Sr Alder Lake Community WS PO Box 20098 Seattle WA 98102

Subject:

Alder Lake Community Water System (ID# 26995H)

Pierce County

Design Approval - Need Permanent Disinfection

Dear Mr. Dorland:

Since December 2000, this community water system was required to install a permanent disinfection system in response to the Department of Health's determination that the water system sources were in 'hydraulic connection' to Alder Lake. A designation of hydraulic connection indicates that the water source is vulnerable to surface water pathogens such as Giardia and Cryptosporidium.

The disinfection treatment system has not been installed at this time. DOH understands that you applied to the Washington Utilities and Transportation Commission for approval of a one-time assessment to finance the installation of disinfection treatment. The assessment was denied. Please keep in mind that low-interest loans are available through the Drinking Water State Revolving Fund program. Applications are due by May 8, 2006. Please check our website for more information at <a href="http://www.doh.wa.gov/ehp/dw/our\_main\_pages/dwsrf.htm">http://www.doh.wa.gov/ehp/dw/our\_main\_pages/dwsrf.htm</a>.

Until disinfection treatment is installed and certified complete, DOH assigns a 'blue' operating permit to Alder Lake water system for failure to meet the design approval requirement of WAC 246-290 and Alder Lake Community water system may not add new service connections.

You may contact me at 253/395-6772 or <a href="mailto:lngrid.salmon@doh.wa.gov">lngrid.salmon@doh.wa.gov</a> if you have any questions or concerns.

Sincerely,

Ingrid M. Salmon

Regional Compliance Manager

Moud M. Salmon.

**NW Drinking Water Operations** 

cc: Tacoma-Pierce County Health Department

John Ryding, DOH Regional Engineer
Danny Kermode, Washington Utilities and Transportation Commission