

DMR Copy of Record

Permit					
Permit #:	OR0044687	Permittee:	NORTHWEST NATURAL	Facility:	NW NATURAL GAS SITE REMEDIATION
Major:	No	Permittee Address:	220 NW 2nd Ave Portland, OR 97209-3943	Facility Location:	7900 NW ST/ HELENS RD MULTNOMAH, OR 97210
Permitted Feature:	001 External Outfall	Discharge:	001-A Groundwater 001A		

Report Dates & Status					
Monitoring Period:	From 10/01/23 to 10/31/23	DMR Due Date:	11/15/23	Status:	NetDMR Validated

Considerations for Form Completion

Principal Executive Officer					
First Name:	Kathern	Title:	Vice President	Telephone:	503-226-4211
Last Name:	Williams				

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI		Quantity or Loading			Quality or Concentration			# of Ex.	Frequency of Analysis	Sample Type				
						Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1				Value 1	Qualifier 2	Value 2	Qualifier 3
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.8			=	8.0	12 - SU	WH/DS - When Discharging	GR - GRAB
					Permit Req.					>=	6.5 DAILY MN			<=	8.5 DAILY MX	12 - SU	WH/DS - When Discharging	GR - GRAB
					Value NODI													
00720	Cyanide, total [as CN]	1 - Effluent Gross	0	--	Sample					=	130.0			=	140.0	28 - ug/L	WH/DS - When Discharging	CP - COMPOS
					Permit Req.					<=	510.0 MO AVG			<=	1000.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	CP - COMPOS
					Value NODI													
00980	Iron, total recoverable	1 - Effluent Gross	0	--	Sample					=	160.0			=	220.0	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	820.0 MO AVG			<=	1600.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
01114	Lead, total recoverable	1 - Effluent Gross	0	--	Sample					=	0.0			<	0.11	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	5.0 MO AVG			<=	7.6 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
01119	Copper, total recoverable	1 - Effluent Gross	0	--	Sample					=	2.3			=	5.3	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	15.0 MO AVG			<=	30.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
34247	Benzo[a]pyrene	1 - Effluent Gross	0	--	Sample					=	0.0			<	0.008	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	1.0 MO AVG			<=	1.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
34403	Indeno[1,2,3-cd]pyrene	1 - Effluent Gross	0	--	Sample					=	0.0			<	0.008	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	1.0 MO AVG			<=	1.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
34526	Benzo[a]anthracene	1 - Effluent Gross	0	--	Sample					=	0.0			<	0.008	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	1.0 MO AVG			<=	1.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
34556	Dibenz[a,h]anthracene	1 - Effluent Gross	0	--	Sample					=	0.0			<	0.008	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	1.0 MO AVG			<=	1.0 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													
71901	Mercury, total recoverable	1 - Effluent Gross	0	--	Sample					=	0.0005			=	0.0013	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Permit Req.					<=	0.01 MO AVG			<=	0.02 DAILY MX	28 - ug/L	WH/DS - When Discharging	24 - COMP24
					Value NODI													

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
------	------	------

2023-11-15OCT2023CoverLetter.pdf	pdf	148964.0
October2023DMR-Final.xlsx	xlsx	31935.0

Report Last Saved By

NORTHWEST NATURAL

User: JENAMOTT
Name: Jennifer Mott
E-Mail: jmott@anchorqea.com
Date/Time: 2023-11-15 09:10 (Time Zone: -08:00)

Report Last Signed By

User: JENAMOTT
Name: Jennifer Mott
E-Mail: jmott@anchorqea.com
Date/Time: 2023-11-15 09:10 (Time Zone: -08:00)