

Exhibit No. _____ (DMP-8)

Docket No. UW-060343

Witness: Derek M. Pell

**BEFORE THE WASHINGTON UTILITIES AND TRANSPORTATION
COMMISSION**

**WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION,**

Complainant,

v.

ILIAD WATER SERVICE, INC.,

Respondent.

DOCKET NO. UW-060343

**EXHIBIT TO
RESPONSE TESTIMONY OF**

DEREK M. PELL

**Assistant Manager, NW Office of Drinking Water
Washington State Department of Health**

**ON BEHALF OF STAFF OF
WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION**

Letter dated July 9, 2001 from DOH to David Dorland

October 4, 2006



STATE OF WASHINGTON

DEPARTMENT OF HEALTH

20435 72nd Ave. S., Suite 200, K17-12 • Kent, Washington 98032-2358

July 9, 2001

DAVE DORLAND
ALDER LAKE WATER SYSTEM
PO Box 20429
SEATTLE WA 98102

Subject: Alder Lake Water System (ID#26995H) Pierce County
Groundwater Under the Direct Influence of Surface Water (GWI) Determination
1st MPA Result for Well #1 (S01) and Well #2 (S02)

Dear Mr. Dorland:

My colleague, Jim Nilson, has reviewed the results of the first Microscopic Particulate Analysis (MPA) samples collected from the two Alder Lake wells. The results are summarized in the table below.

Source	MPA Sample Date	MPA Result
Well #1 (south, deepened, S01)	4/7/01	0 - Low Risk
Well #2 (north, not deepened, S02)	5/8/01	0 - Low Risk

The sample results of zero indicate a low risk to direct influence of surface water and satisfy the first MPA sample requirement that was noted in my December 19, 2000 letter to you.

Please plan on collecting the second set of MPA samples this or next month (July or August 2001). Each well must be sampled at the same time with both wells operating.

If you have any questions regarding the requirements in this letter or the GWI program in general please do not hesitate to call me at 253-395-6763 or Jim Nilson at 253-395-6764.

Sincerely,

Derek Pell, PE
Regional Engineer
NW Drinking Water Operations

cc: Tacoma Pierce County Health Department
GWI file
Jim Nilson, DOH

