

April 18, 2013

VIA ELECTRONIC FILING

Washington Utilities and Transportation Commission
1300 S. Evergreen Park Drive SW
P.O. Box 47250
Olympia, WA 98504-7250

Attn: Steven V. King
Acting Executive Director and Secretary

**RE: Docket No. UE-130378 – DO NOT REDOCKET
Advice No. 13-03 – Substitute Tariff Sheet**

Dear Mr. King:

On March 15, 2013, PacifiCorp d/b/a Pacific Power & Light Company (Company) filed Advice No. 13-03 to propose changes to Rule 14, General Rules and Regulations—Line Extensions. After discussions with Washington Utilities and Transportation Commission (Commission) staff, the Company is submitting the following sheet as a substitute tariff sheet under WAC 480-80-111. A redline version reflecting the edits is included with this filing.

First Revision of Sheet No. R14.4 Rule 14 General Rules and Regulations—Line
Extensions

The substitute tariff sheet reflects Commission staff's suggestion to set the residential transformer upgrade threshold at 25 kVA. The new language states that residential transformer facilities upgrades will be treated as a standard line extension if the customer's demand exceeds 25 kVA or if the facilities serve only that customer. Facilities upgrades for customers whose demand does not exceed 25 kVA will be treated as a system improvement and not charged to the customer.

If you have any questions regarding this filing, please contact Bryce Dalley, Director, Regulatory Affairs & Revenue Requirement, at (503) 813-6389.

Sincerely,



William R. Griffith
Vice President, Regulation

Enclosures