



STATE OF WASHINGTON
UTILITIES AND TRANSPORTATION COMMISSION

1300 S. Evergreen Park Dr. S.W., P.O. Box 47250 • Olympia, Washington 98504-7250
(360) 664-1160 • TTY (360) 586-8203

October 31, 2014

Mike Faulkenberry
Director, Natural Gas
Avista Utilities Corporation
1411 E. Mission
P.O. Box 3727
Spokane, WA 99220-3727

Dear Mr. Faulkenberry:

RE: Rescind of Waiver Regarding Formerly Un-odorized HP in Colfax, WA (UG-950940)

Thank you for your letter dated September 26, 2014 informing commission staff (staff) that the existing 4" un-odorized pipeline located in Colfax, WA has been retired and replaced with a new odorized 6" polyethylene pipeline.

Staff conducted a follow-up inspection to confirm the installation of the new pipeline and odorization facilities.

This waiver is considered closed effective October 31, 2014.

Sincerely,

David D. Lykken
Pipeline Safety Director

cc: Randy K. Bareither, P.E., Pipeline Safety Engineer, Avista Utilities Corporation