

**BEFORE THE WASHINGTON
UTILITIES AND TRANSPORTATION COMMISSION**

**WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION,**

Complainant,

v.

PUGET SOUND ENERGY,

Respondent.

DOCKET UE-190882

**EXHIBIT TO
TESTIMONY OF**

David C. Gomez

**STAFF OF
WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION**

PSE's Response to UTC Staff Data Request No. 314

January 10, 2020

BEFORE THE WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

**Dockets UE-190882
Puget Sound Energy
Prudency of Outage and Replacement Power Costs**

WUTC STAFF DATA REQUEST NO. 314:

In the supplemental testimony submitted by Chuck Tack in Docket UE-190882, he states that Area A coal was burned as a way of investigating whether coal from a different location would have any impact on PM levels.

SUBPART A: Please provide the dates on when Area A coal was burned in Units 3 or 4 in the time period between February 2018 through June 2018.

SUBPART B: Was Area A coal used in the Colstrip Unit 3 official MATS PM compliance test conducted on June 21, 2018?

SUBPART C: Was Area A coal used in the Colstrip Unit 4 official MATS PM compliance test conducted on June 26, 2018?

Response:

SUBPART A: Rosebud Mine Area A coal was used as fuel in Colstrip Units 3 and 4 from approximately June 20, 2018 to approximately June 29, 2018.

SUBPART B: Yes, Area A coal was used in the Colstrip Unit 3 official MATS PM compliance test conducted on June 21, 2018.

SUBPART C: Yes, Area A coal was used in the Colstrip Unit 4 official MATS PM compliance test conducted on June 26, 2018.