



STATE OF WASHINGTON

WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

1300 S. Evergreen Park Dr. S.W., P.O. Box 47250 • Olympia, Washington 98504-7250  
(360) 664-1160 • TTY (360) 586-8203

Ref. No. Docket PG-101404

February 4, 2011

John Falk  
Maple Tree Motel  
4824 E Sprague  
Spokane, WA 99031

Dear Mr. Falk:

**RE: 2010 Natural Gas Master Meter Standard Inspection – Maple Tree Motel**

Thank You for your letter of intent dated January 7, 2011. Staff understands that the Maple Tree Motel, located at 4824 E. Sprague, Spokane is going to remain a master meter system.

Staff accepts Maple Tree Motel commitment to have the master meter system's underground steel pipe replaced with plastic pipe by the July 31, 2011 and notify the commission upon completion. A master meter standard inspection will be scheduled at that time.

If you have any questions, or if we may be of any assistance, please contact Patti Johnson at (360) 870-4915 or (360) 664-1266. Please refer to Docket PG-101404 in any future correspondence regarding this inspection.

Thank you for your cooperation and commitment to pipeline safety.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Lykken".

David D. Lykken  
Pipeline Safety Director

cc. Russell J. Dunning

