



STATE OF WASHINGTON  
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

1300 S. Evergreen Park Dr. S.W., P.O. Box 47250 • Olympia, Washington 98504-7250  
(360) 664-1160 • TTY (360) 586-8203

Ref. No. Docket PG-110042

February 10, 2012

Sue McLain  
Senior Vice President Operations  
Puget Sound Energy  
PO Box 90868 M/S PSE-12N  
Bellevue, WA 98009-0868

Dear Ms. McLain:

**RE: 2011 Standard Natural Gas Inspection – Thurston/Lewis County**

We are in receipt of your letter dated February 3, 2012, addressing the findings of our inspection conducted at the Puget Sound Energy (PSE), Thurston/Lewis County facilities from November 8 - December 2, 2011.

We accept PSE's additional supporting documentation provided in the response letter to clear the probable violation of WAC 480-93-110(5)(b) and PSE's commitment to continue the bi-annual leak survey of the Capitol and Legion Way casing and any other casings in PSE's system that have been confirmed to have shorted conditions. Docket PG-110042 will be closed as of February 10, 2012.

Please refer to the above docket number in any future correspondence regarding this inspection. If you have any questions or need any further assistance, please contact Dave Cullom at (360) 664-1141.

Thank you for your cooperation and interest in pipeline safety.

Sincerely,

David D. Lykken  
Pipeline Safety Director

cc. Carol Wallace, Director, Gas Operations  
Cathy Koch, Director, Compliance  
Duane A. Henderson, Manager, Gas System Integrity  
Cheryl McGrath, Manager, Gas Compliance and Regulatory Audit

