

December 26, 2011

Wyatt Pierce, P.E.  
Project Manager  
NID Support and Special Projects  
Pacific Power

Subject: Revision 3 Washington Distribution Efficiency Study  
Contract Release No. 3000071987

---

Wyatt,


Attached to this letter is Commonwealth's Revision 3 report on the distribution efficiency opportunities for 19 distribution circuits in PacifiCorp's service area in Washington State. The attached report is in electronic Adobe pdf form. If you wish, Commonwealth will assemble one full hard copy report and will send it by regular mail. Please let me know if you would find this helpful.

This revision was necessary to address a PacifiCorp request to update the financial factors used in the calculations within the study and to correct the financial results from earlier Nob Hill revisions. As part of this effort you and I agreed to significantly revise the organization of the body of the report. Additionally, Appendices 7 and 12 were updated.

In addition to the full report, a Summary Report is also provided. The Summary Report is Section 1 of the full report.

Please let me know if you have any questions about the revised report. The Commonwealth team looks forward to the opportunity to serve you and PacifiCorp in the future.

Sincerely,



John P. White, P.E.  
Vice President  
Commonwealth Associates, Inc.

# Distribution System Efficiency and Voltage Optimization Study

**Prepared for:**



**Prepared By:**

**COMMONWEALTH ASSOCIATES, INC.**

with

**UTILITY PLANNING SOLUTIONS, PLLC**

**Original: May 27, 2011**  
**Revision 3: December 26, 2011**



# Distribution System Efficiency and Voltage Optimization Study

**Prepared for:**



**Prepared by:**

John P. White, P.E.  
Rick Cook, P.E.  
Robert Fletcher, PhD, P.E. – Utility Planning Solutions, PLLC

**Approved by:**

**Date:**

May 27, 2011  
Revision 3: December 26, 2011

A handwritten signature in black ink that reads "John P. White".

John P. White, P.E.  
Vice President and Regional Manager  
Commonwealth Associates, Inc.



# Table of Contents

Definitions of Terms .....	Page 1
Section 1 – Study Overview, Findings and Recommendations .....	4
Section 1A – Study Overview .....	4
Purpose .....	4
Data .....	5
Assumptions .....	5
Study Basis .....	6
Fielding .....	6
Staged Approach Used to Evaluate the Circuits .....	6
Economic Analysis per Voltage Optimization Protocol .....	7
Implementation Considerations .....	8
Findings and Recommendations .....	8
Section 1B – Summary of Results .....	9
Section 1C – Recommendations .....	14
Viable Energy Savings Projects are Feasible .....	14
Section 1D – Implementation Considerations .....	16
Standards .....	17
Operating Impacts .....	18
Circuits to Consider for Voltage Optimization .....	19
7-Year Capital Plan .....	20
Section 2 – Approach to Analysis .....	22
Circuit Fielding .....	22
Model Verification and Correction .....	22
“As is” Base Case Voltage Profiling .....	22
Pre-VO Compliant .....	23
Stage 1 Analysis .....	23
Stage 2 Analysis .....	24
Stage 3 Analysis .....	24

Secondary System Considerations .....	25
More on Light Load / Heavy Load Scaling.....	30
Section 3 – Existing System Assessment .....	32
Area Overview.....	32
Metering .....	34
Substation .....	34
Line Voltage Regulator Metering.....	34
End of the Line (Voltage Zone) Metering.....	34
Voltage Control.....	34
VO Minimum Threshold Assessment .....	34
Section 4 – System Improvements.....	36
Primary System.....	36
Metering Improvements.....	36
Substation .....	36
Line Voltage Regulator Metering.....	37
End of the Line (Voltage Zone) Metering.....	38
Metering Communications.....	38
Secondary System Considerations .....	39
Location of System Improvements .....	39
Cost Estimating .....	39
Section 5 – References.....	48

# Appendices

1. Washington Rules and Regulations And Utility Distribution Efficiency Measures.....	49
2. Secondary System Voltage Drop Considerations .....	54
3. MW and MVar Histograms by Substation Transformers.....	61
4. PacifiCorp Cost Estimating Spreadsheet and Crew Cost Information.....	74
5. Maps showing System Improvements by Circuit and Stage .....	79
6. Maps showing Voltage Profiles .....	104
7. Detailed Results – All circuits & stages and for LCLC and BCR optimal solutions.....	129
8. Simplified Voltage Optimization (VO) Measurement and Verification Protocol.....	136
9. Summary Circuit Analysis by Stage.....	152
10. Detailed Cost Estimates by Circuits and Stage.....	181
11. High and Low Voltage Reports .....	220
12. Summary of Study Data .....	223
13. Metering and Communication Costs.....	226
14. Circuit VAR Profiles.....	231
15. Circuit Power Factor Profiles.....	252
16. Comparison of Distribution Efficiency Potential .....	273

# Table of Figures

Figure 1-1 Costs and Energy Savings by Stage.....	9
Figure 1-2 Annual Energy Savings, LCLC & BCR by Stage and Optimal Solution.....	12
Figure 1-3 LCLC and BCR for each Stage Alternative .....	13
Figure 2-1 Example Voltage Zone.....	26

# Table of Tables

Table 1-1 Financial Factors Used in the Study.....	8
Table 1-2 Summary Results by Stage with all Circuits Considered.....	10
Table 1-3 Summary of Economically Viable Solutions by Stage and Over-All Optimal Solution .....	11
Table 1-4 Capital Plan.....	21
Table 2-1 Estimated number of customers with potential low voltage and associated transformers .....	28
Table 3-1 Overview of Substations & Circuits Analyzed.....	32
Table 4-1 System Improvement Cost Summary.....	41
Table 4-2 System Improvement Cost by Circuit and Stage.....	42

## DEFINITIONS OF TERMS

Term	Definition
aMW	Average Megawatt – a measure of electric capacity produced continuously for a period of one year. 6 aMW = 6 MW x 8760 hours/year = 52,560 MWh/year.
BCR	<p>Benefit Cost Ratio – the ratio of benefits to cost. For this study</p> $\text{BCR} = \frac{\text{(Present Value of the Energy Savings)}}{\text{(Present Value of the Costs of System Improvements)}}$ <p>This calculation is based on the anticipated 20 year life of the project. The costs include O&amp;M costs and a capital update of the improvement assumed to be ten percent of the initial capital investment at year 15.</p>
CVR	Conservation Voltage Reduction – is a means of reducing energy consumption as a result of reducing the primary voltage on an electric distribution system. Energy saved from CVR include no-load loss savings, distribution line loss savings, and end-use (service entrance) energy savings. See Appendix 1 for more detail.
CVR factor	Conservation Voltage Reduction factor (CVR <sub>f</sub> ) – is the percent change in energy consumption on a distribution system resulting from a one percent reduction in voltage. A positive CVR factor indicates that as the voltage goes down there are resultant energy savings. A CVR factor of 0.6 indicates there is a 0.6% energy savings for a 1% voltage reduction.
IVVO	Integrated Volt VAR Optimization – is the real time optimization of system voltage and reactive power (VAR). It requires a relatively sophisticated metering, communication and control system. Utilities are considering it as part of Smart Grid roll outs. IVVO is not studied in this report, although a Stage 3 implementation would include infrastructure useful for a future IVVO program.



LCLC	<p>Life Cycle Levelized Costs – calculates the present value of an alternative expressed as an equal annual payment divided by the expected annual energy the alternative provides. If a project’s present value is \$500k, it has a 20 year life and it produces 400 MWh of energy per year then its LCLC equals:</p> $((\$500,000/20) / 400 \text{ MWh}) = \$62.5/\text{MWh} = \$0.0625/\text{kWh}$ <p>For this study, LCLC’s are calculated based on the anticipated 20 year life of the project.</p>
LDC	<p>Line Drop Compensation – is a means of setting voltage controls on the LTC for power transformers and voltage regulators so that the voltage regulated point on the circuit is farther out on the circuit than the location of the LTC or regulator. Using LDC is an important aspect of voltage optimization programs.</p>
LTC	<p>Load Tap Changer – is a voltage regulating device attached physically and electrically to a power transformer in a substation. It has the capability and controls to change load side voltage settings to maintain appropriate voltage levels in varying load situations.</p>
M&V	<p>Measurement and verification – Utilities implementing energy conservation programs in compliance with RCW 19.285 must report on expected and actual energy savings. Additional metering may be required to measure and verify actual energy savings. See Appendix 8 for more detail.</p>
No-load loss	<p>No-load loss – Energy losses from electrical devices, commonly transformers, which are energized but without load. It is advantageous to keep these losses as low as economically reasonable because they occur whenever the device is energized.</p>
NPV	<p>Net Present Value – is a means of expressing a time sequence of cash flows, both positive and negative, as a present day value. The NPV is the sum of annual cash flows which have each been discounted by a factor which accounts for the value of money in the future as compared to today.</p>
SI	<p>System Improvements – the changes made to the distribution system in a voltage optimization program in order to gain energy savings. These usually include phase balancing, installing capacitors to correct power factor, site specific reconductoring, and installation of line voltage regulators.</p>

VO	Voltage Optimization – is a combination of CVR and system improvements that together provide more energy savings than CVR alone.
VO factor	Voltage Optimization factor ( $VO_f$ ) – is expressed as the percent change in energy for a one percent change in voltage supplied at the end-use service entrance. VO factors are influenced by the percent of customers with non-electric heat, air-conditioning and the specific climate zone in which a distribution circuit is located. End-use energy savings associated with the VO factor can represent the majority (more than seventy-five percent in some systems) of the total energy saved in a voltage optimization program. The balance of the energy saved is derived from line loss savings and no-load loss savings. See Appendix 1

---

## STUDY OVERVIEW, FINDINGS AND RECOMMENDATIONS

### SECTION 1A – STUDY OVERVIEW

#### Purpose

The purpose of this Distribution System Efficiency Study was to identify the potential energy and monetary savings associated with implementing a distribution system loss reduction and conservation voltage regulation application. Commonwealth Associates, Inc., with Utility Planning Solutions, PLLC, was contracted by PacifiCorp to provide a Distribution System Efficiency Study on 19 distribution feeders. Energy savings are determined for PacifiCorp's distribution system based on the Simplified Voltage Optimization (VO) Measurement and Verification (M&V) Protocol approved on May 4, 2010, by the Northwest Power and Conservation Council Regional Technical Forum committee. This report summarizes the assessment findings on the feeders, which are located in PacifiCorp's Walla Walla, Yakima and Sunnyside service areas.

The Simplified VO M&V Protocol provides a simple means to estimate end-use energy savings as a result of system improvements that allow the electric distribution system to operate more efficiently and within the lower band of the ANSI Standard voltage level. The protocol covers utility electric distribution systems serving mostly residential and light commercial loads. System loads do not need to be uniformly distributed throughout the distribution system. This protocol identifies the procedure to determine the average annual voltage for a distribution primary system with source voltage regulation. Minimum system stability thresholds, system data requirements, and measurement and verification formulations are included as part of this protocol.

The study addresses the level of effort and system improvement (SI) necessary to comply with minimum VO thresholds and estimates the potential for SI and VO efficiency energy savings. For this report, 19 PacifiCorp circuits served from 12 substations were studied. They included circuits in the Yakima, Walla Walla and Sunnyside areas. Ideally, all distribution feeders that are common to one substation power transformer voltage control zone should be evaluated. This was not the case for all of these selected circuits.

The study is a starting point and potential guide for PacifiCorp as it considers implementing distribution efficiency programs for all of its Washington distribution circuits.

The study provides information for use in developing recommendations for PacifiCorp's Integrated Resource Plan (IRP).

---

## Data

Data provided by PacifiCorp is assumed to be accurate and up to date. Modeling and data fielding verification was performed by Commonwealth. The following data was provided via on-site visits, phone conversation and e-mail. Data gathered included:

- GIS detailed AutoDesk Map files
- ABB FeederAll software, including PacifiCorp's Washington distribution circuit model
- Substation hourly peak kW and kVAR load history for 2009
- Summer and winter peak kW and kVAR loading for circuits in the study and for the adjacent circuits, those served by the same LTC or voltage regulator
- Locations and size of customers with large electrical demands
- Connected distribution transformer phase kVA for each feeder line section
- Line conductor sizes and phase configurations for each feeder
- Customer load characteristics used to determine VO factor
- Substation voltage control settings
- Financial and economic factors and marginal purchase power costs
- System planning criteria, system expansion guidelines and voltage standards
- Completed utility overview and scoping questionnaire
- Fully loaded hourly labor costs for crew labor, including transportation
- Block Cost Estimating Spreadsheet for system improvements

## Assumptions

The GIS data received was assumed to be preliminary and may need further investigation if additional study is required. The data reported in the Commonwealth Data Request Questionnaire, as well as additional data provided, was used in this analysis. In some cases, requested data was unavailable at the time or was unknown. Feeder load factors are based on PacifiCorp's measured data. Feeder maps used to prepare the system electric connectivity model using ABB FeederAll software were revised based on the information gained by Commonwealth's fielding efforts.

Heavy loads for the study are peak summer MW with a MVAR load level representative of the 95th percentile on the MVAR Histogram based on the annual transformer hourly data. This can be seen in Appendix 3. These loads were used in the study because they represent reasonably high loads and, together, they result in a greater voltage drop than what would happen at the recorded winter peak when the MVAR loading is less.

The light loads are at the 5th percentile, from the MW and MVAR Histograms. These loading levels were chosen because they represent reasonably low-load levels without considering lighter loads on the Histogram, which occur with near zero probability.

The PacifiCorp system information was assessed for compliance with the entire set of VO minimum system thresholds identified by the NWPCC RTF Simplified VO Protocol. Substation power transformer load losses were not considered in this study. In the third stage, the 3-step staged approach results in a VO design with a minimum primary voltage of 119 volts on 120 volt basis.

The cost of system improvements, including engineering, material and labor, were based on information provided by PacifiCorp and supplemented by Commonwealth's knowledge and understanding of industry costs.

The Simplified VO Protocol methodology is an accepted approach to estimating the savings available from voltage optimization. Its approach to estimating the energy savings is accurate for the purpose of this planning study. This document provides the study results of implementing possible VO improvements on the 19 PacifiCorp feeders identified. This study is not a detailed plan of action; further studies will be required before implementing voltage optimization and system improvements.

All model development and engineering assessments were performed using the ABB FeederAll engineering analysis tool. It is assumed this model accurately models voltage drops, losses, etc.

The LTC and voltage regulator "R" set points were changed in 0.5 volt increments.

### Study Basis

This study is based on information provided by PacifiCorp and circuit fielding by Commonwealth. PacifiCorp has an ABB FeederAll application that includes spatial location of feeder conductor sizes, phases and installed transformer kVA that is routinely maintained. Substation metering is installed on power transformers with feeder MW and MVAR demand. The PacifiCorp FeederAll application model has been updated to include up-to-date fielding information (i.e., wire sizes, transformer kVA sizes, phase connections, etc.) from Commonwealth fielding.

### Fielding

As the system data and other information was being assembled and reviewed, the first major step of the project was to field the 19 circuits and note differences between field observations and the maps. This was necessary to make the starting model as accurate as possible for the analysis. Commonwealth staff went into the field to record existing conditions and worked with PacifiCorp staff as needed. Marked-up maps were sent back to Commonwealth's office, where they were scanned and electronically stored and made available to the modeling staff.

### Staged Approach Used to Evaluate the Circuits

The study used a staged approach to evaluate the circuits. It started with an "As-is" base case and then moved through three evaluation stages for each circuit. For the As-is case, Commonwealth

---

made corrections to the system model based on the changes found during fielding. From this model of the existing system, Commonwealth used FeederAll to examine the voltage and losses during heavily loaded conditions and lightly loaded conditions. Heavy loads for all stages are the peak summer MW with a MVAR load level equal to the 95th percentile of the transformer histogram. The light loads are at the 5th percentile of the transformer histogram for both MW and MVAR. For the As-is voltage profile analysis, Commonwealth modeled the primary system on a 120 volt basis in an effort to keep the voltage from dropping below 121 volts (band center) on any spot on each of the modeled circuits. This was not always attainable, but it was the goal.

From the As-is case, Commonwealth stepped through the three stages of changes. In Stage 1, the LTC control in FeederAll was set to hold the end of the line (EOL) voltage at, or near, 120 volts; the phase loadings were balanced; and existing capacitors were optimized. Included in the Stage 1 costs are funds for metering improvements in the substations and at the end of the line necessary to verify the circuit is operating consistently with the VO protocol.

In Stage 2, the modeling included new capacitors, mostly switched, reconductoring and voltage regulators. If voltage regulators are added, then funds are included to provide the necessary metering for the newly created voltage control zone downstream of the regulator. In Stage 2, the EOL voltage was left at 120 volts.

In Stage 3, the EOL voltage was set to 119 volts. Also in Stage 3, communication between the EOL metering to the substation was included, as was communication between line voltage regulators and substations. The results would have been significantly improved for Stage 3 Benefit-Cost Ratios (BCRs) and Life Cycle Levelized Costs (LCLCs) without the costs of the communication infrastructure. This communication is both for monitoring and voltage control for energy efficiency gains and power quality.

### **Economic Analysis per Voltage Optimization Protocol**

The costs and results from the system analysis were then used to complete the economic analysis consistent with the VO protocol and PacifiCorp's economic factors. This included analyzing the results from a Benefit-Cost Ratio (BCR) and Life Cycle Levelized Cost (LCLC) approach.

The financial and economic factors used in this study are shown in Table 1-1, below. It is important to note the assumed economic life of the energy savings is 20 years. Commonwealth has included funding capital, at year 15, equal to 10% of the initial capital investment to provide for modifications of the improvements near the end of the economic life. The economic analysis was performed using principles described in D.G. Newnan, T.G. Eschenbach, J.P. Lavelle, *Engineering Economic Analysis, Ninth Edition*, Oxford University Press, Inc., New York, 2004.

**Table 1–1: Financial Factors Used in the Study**

Retail Energy Rate Weighted Annual (\$/kWh)	\$0.08
Minimum Permissible Benefit-Cost-Ratio BCR (p.u.)	1.0
Capital Equipment Life Expectancy (yr)	48
Planned life of Energy Savings (yr)	20
Capitalized Annual Fixed Charged Rate (p.u.)	11.21%
Annual Inflation Rate for kW Demand (%/yr)	1.80%
Annual Inflation Rate for kWh Energy (%/yr)	1.80%
Annual Inflation Rate for Investment (%/yr)	1.80%
Annual Inflation Rate for O&M (%/yr)	1.80%
Maximum Permissible LCLC (\$/kWh)	\$0.10591
Marginal Purchase Demand Rate (\$/kW/yr)	\$0.00
Marginal Purchase Energy Rate (\$/kWh)	\$0.10591
Annual Operation & Maintenance Expense (%/yr)	2.00%
Present Worth Rate for Cost of Energy & Losses (%/yr)	7.17%
Present Worth Rate for Cost of Investment (%/yr)	7.20%
Maintenance Lump Sum Amount in Future Year (%)	10.00%
Maintenance Lump Sum in Future Year (yr)	15

## Implementation Considerations

The team then developed implementation considerations, risks and mitigation alternatives. These were developed using the results from the system analysis, the economic analysis, conversations and input from PacifiCorp staff and the utility operating experience of the Commonwealth team members.


## Findings and Recommendations

Considering all of the above, Commonwealth then developed the conclusions, findings and recommendations included in this report. These follow next in the report.

**SECTION 1B – SUMMARY OF RESULTS**

Figure 1-1 shows the costs and energy savings for each stage for all circuits regardless if a particular stage or circuit met the BCR and LCLC thresholds: 1.0 and \$105.91/MWhr, respectively.

**Figure 1-1 Costs and Energy Savings by Stage:**



The overall energy saved drops in stage two because the system improvements tend to raise and flatten voltage. The flattening tends to raise the voltage at the end of the impacted circuits. This is preparing the circuits for the voltage reduction which takes place in the third stage.

Table 1-2, below, provides an overview of the results for the studies associated with these 19 circuits.



Table 1-2 Summary Results by Stage with all Circuits Considered

General Information	Stage 1	Stage 2	Stage 3
Total Customers Served (#)	30,747	30,747	30,747
Feeder Annual Peak MW	138.33	138.33	138.33
Total Annual Energy Consumed (MWh/yr)	627,608	627,608	627,608
Average Customer Voltage Change (%)	1.35%	1.09%	2.01%
Average Reduction in Annual Energy Delivered from Sub (%)	0.94%	0.82%	1.40%
Total SI&VO Installed Cost	\$1,640,691	\$2,999,482	\$6,518,722
<u>Utility Energy Savings Potential</u>			
Line Loss Reduction (MWh/y)	282.7	712.7	678.8
No-load Loss Reduction (MWh/y)	252.5	199.8	357.1
VO Energy Savings (MWh/y)	5,337.9	4,235.4	7,744.8
Total Energy Savings (MWh/y)	5,873.1	5,147.8	8,781
Total Energy Savings (MWa)	0.6704	0.5877	1.0024
Total Coincidental Demand Reduction (kW)	1142.6	1,093.2	1,766.9
Average Customer Energy Reduction (kWh/yr)	174	138	252
<u>Benefit Cost Projections</u>			
Overall Utility Levelized Cost per kWh Saved	\$0.0434	\$0.0906	\$0.1155
Overall Utility Benefit Cost Ratio	2.52	1.21	0.95
Overall Net Utility PV Savings (\$)	\$4,734,832	\$1,194,119	(\$618,263)

Stage 1 has the lowest LCLC, which is to be expected given the limitation of actions (reducing voltage, phase balancing and redeploying capacitors) for the energy saved. Stage 2 provides slightly less energy than Stage 1; however, it is at more than double the cost. This is the impact of the system improvements, which become fully beneficial when the voltage is lowered in Stage 3. Stage 3 offers the greatest energy savings as a result of the system modifications made and the reduction of the EOL voltage to 119 volts (on a 120 volt basis). A large part of the Stage 3 cost, approximately \$2.7M, is due to the communication infrastructure required to provide real-time monitoring of voltage and energy at the substation and regulators, and EOL volt meters. At a total summary level the Stage 3 results do not meet the LCLC and BCR thresholds of \$105.91/MWh and 1.0 respectively. However, the total results are close to the limits indicating that some of the individual results likely do meet the thresholds.


After analyzing all the circuits and stages, two things became clear. One, the individual circuit results in each stage should be considered from an economic perspective; and second, a valuable point of view could be gained if the results were considered from a total energy savings view while ensuring the circuits and stages selected also met the 1.0 BCR and the \$105.91 LCLC thresholds. The goal of this second review was to get the most energy savings while staying within the economic thresholds. The results from this review are shown below by stage and from an optimal solution perspective.

**Table 1-3 Summary of Economically Viable Solutions by Stage and Over-All Optimal Solution**

General Information	Stage 1	Stage 2	Stage 3	Optimal Solution
Total Customers Served (#)	22,225	22,958	18,665	27,909
Feeder Annual Peak MW	95.08	103.58	76.01	125.50
Total Annual Energy Consumed (MWh/yr)	438,826	476,160	357,575	574,046
Average Customer Voltage Change (%)	1.12%	1.11%	2.07%	1.73%
Average Reduction in Annual Energy Delivered from Sub (%)	0.80%	0.85%	1.45%	1.23%
Total SI&VO Installed Cost	\$863,209	\$1,893,973	\$2,826,294	\$3,854,835
<u>Utility Energy Savings Potential</u>				
Line Loss Reduction (MWh/y)	198.0	565.0	371.5	643.1
No-load Loss Reduction (MWh/y)	129.5	146.4	187.1	267.5
VO Energy Savings (MWh/y)	3,185.9	3,347.2	4,621.5	6,127.4
Total Energy Savings (MWh/y)	3,513.4	4,058.5	5,180.1	7,038.0
Total Energy Savings (MWa)	0.4011	0.4633	0.5913	0.8034
Total Coincidental Demand Reduction (kW)	685.2	856.4	1,027.0	1,423.9
Average Customer Energy Reduction (kWh/yr)	143	146	248	220
<u>Benefit Cost Projections</u>				
Overall Utility Levelized Cost per kWh Saved	\$0.0382	\$0.0726	\$0.0849	\$0.0852
Overall Utility Benefit Cost Ratio	2.87	1.51	1.29	1.29
Overall Net Utility PV Savings (\$)	\$3,056,420	\$1,832,787	\$1,565,127	\$2,098,324


The numbers in the table above can be distilled down to the figure below. Figure 1-2 shows the annual energy saved, LCLC and BCR for by each stage when individual stage solutions that don't meet the BCR and LCLC thresholds are excluded from a given stage solution. The Optimal Solution includes the stage solution of each circuit which provides the most energy while meeting the economic thresholds. For each stage and for the Optimal Solution there are circuits which do not meet the economic considerations. For example, in the Optimal Solution the two circuits excluded are Pomeroy 5W342 and North Park 5Y356.

**Figure 1-2 Annual Energy Savings, LCLC & BCR by Stage and Optimal Solution:**  
 (Circuit solutions that do not meet the economic thresholds are excluded from that Stage.)



In addition to the roll up results described above Commonwealth reviewed the study results to determine the savings associated with each circuit for all three stages for all 19 circuits. In Figure 1-3, below, the LCLC and BCR results of each of the 19 circuits in all three stages are shown. The shaded area represents the area of the graph with an LCLC of less than \$105.91 and a BCR  $\geq 1$ .

Figure 1 – 3 LCLC and BCR



The figure clearly shows there a number of individual solutions within the shaded economic zone. Included are most Stage 1 results, and a good number Stage 2 and Stage 3 results. This is consistent with Table 1-3 above which shows the Optimal Solution as having the greatest number of customers served and largest peak load.

The results, as summarized, above indicate there is an opportunity for PacifiCorp to implement a Voltage Optimization and System Improvement program that provides energy savings within its economic thresholds.

---

## SECTION 1C – RECOMMENDATIONS

The results of this distribution system study for 19 Tier 1 circuits on PacifiCorp's Washington system are favorable and demonstrate that sustainable and potentially viable VO savings can be obtained. Commonwealth recommends that PacifiCorp consider the Optimal Solution scenario. This scenario provides the greatest amount of energy, as compared to the stage scenarios considered, within the utility's economic thresholds. The next step may be to analyze the results of the Optimal Scenario in the utility's Production Cost Model to further consider its cost effectiveness.

Commonwealth recommends such Voltage Optimization improvement efforts should be consistent with PacifiCorp's implementation strategy outlined in its Smart Grid Technology Report. This report was filed with the Washington Utilities and Transportation Commission in September 2010, in compliance with WAC 480-100-505. If, in the future, other Smart Grid initiatives are pursued by the company on these Tier 1 circuits, the Stage 3 implementation costs could reasonably be expected to be shared among additional Smart Grid programs. Sharing the communication infrastructure costs would have a direct impact on the Stage 3 BCR and LCLC values derived in this report.

### Viable Energy Savings Projects Are Feasible

The study indicates viable energy savings projects are feasible by implementing system improvements and voltage optimization. Based on the study results, Commonwealth's recommendation is:

- PacifiCorp should analyze the Integrated Resource Plan (IRP) data provided by Commonwealth for the Optimal Scenarios in PacifiCorp's Production Cost Model.

Should the results of the Production Cost Model be favorable, Commonwealth further recommends:

- Complete the voltage optimization studies on all circuits originating on a substation/power transformer that is included in the selected group.
- Select the final implementation group based on the findings of this study and the results of the study described in the preceding bullet.
- Develop an implementation and budget schedule such as is shown in Table 1-4.
- Field verify:
  - Loading on taps to be changed for phase balancing; select other taps if necessary
  - Locations selected for voltage regulators, capacitors, metering, etc., having usable pole, space, etc., for equipment to be installed. If necessary, find suitable alternative locations.
- Engineer system improvements – capacitor installations, regulators, line reconductoring, etc.
- Brief/train Field Engineers, Estimators and other appropriate field staff on voltage optimization and potential issues.

- Complete construction of needed system improvements.
- Closely follow operational implications, if any, of implementing voltage optimization.
- Install some recording volt meters on a temporary basis to respond to low-voltage reports and monitor end of control zone line voltages.
- Consider installing the Stage 3 communication infrastructure consistent with any Smart Grid effort undertaken by the utility. This approach will demonstrate if the metering is necessary to operate a voltage optimized system and to determine if there are other benefits that could help offset this investment if implemented for future Stage 3 VO circuits.
- If PacifiCorp decides to reduce the primary voltage on one or more of the circuits to 119 volts (on a 120 volt basis):
  - Follow a process similar to what is described in Section 1D in the bullets following the paragraph starting with: *“What if additional work is needed to address potential low voltage issues”*
  - Develop a service standard for the 119 volt voltage optimization zones
  - Complete communication infrastructure engineering and installation
- Follow the energy savings verification steps described in the Simplified Voltage Optimization Measurement and Verification Protocol, to measure and record savings.
- As PacifiCorp considers implementing a voltage optimization program, Commonwealth suggests, its staff stay current with this developing field. Studies continue which may guide PacifiCorp’s implementation decisions and approaches.

During this study, Commonwealth’s team noted that PacifiCorp’s general operating approach on these 19 circuits – for example, setting the EOL voltage to 121 volts, using line drop compensation appropriately and utilizing both fixed and switched line capacitors – results in a relatively efficient system as a starting point. This reduces the amount of energy that might otherwise be available from a voltage optimization program on distribution circuits without this operating approach.

---

## SECTION 1D – IMPLEMENTATION CONSIDERATIONS

Commonwealth considered potential operational risks and other considerations for implementation. The most significant concern is the potential of customers having service entrance voltages below the ANSI C84.1 Range A acceptable level of 114 volts; 117 volts for primary metered customers.

In reviewing the work in this report, Commonwealth thinks the cost and response impacts of secondary voltage problems as noted in the report are a maximum probable amount. We also believe the likely level of impacts over the projected life cycle of these improvements are 25% to 50% less than what is calculated. We believe this because the actual number of customers reporting low-voltage issues is extremely low even though the As-is base case modeling shows that, on the end of some primary distribution circuits, the voltages are as low as 119 volts. This seems to indicate the secondary system voltage drops are not going to result in as many potential customer issues as estimated in the report. However, the value was not reduced because, as a PacifiCorp staff member indicated, it is hard to know where the system is compared to the knee of the curve. So, Commonwealth has left the estimate as is and recognizes it as a likely worst case impact from the two perspectives: cost impacts and customer issues.

Commonwealth has considered the “*What if additional work is needed to address potential low voltage issues?*” question and recommends the following as an approach to address the potential issue of customers experiencing low service entrance voltage due to a voltage optimization program that moves the end of the line primary voltage to 119 volts:

- Determine voltage zones on each distribution circuit where the voltage may drop below 120 volts. Use FeederAll to model each circuit in light load and heavy load conditions to determine where on each circuit the primary voltage will drop below 120 volts. Commonwealth completed this for the Tier 1 circuits.
- Determine customer kW loading. For some customers, PacifiCorp likely has kW demand information. For residential and small commercial, it is likely that PacifiCorp does not have this information. Commonwealth understands that PacifiCorp has customer kwh usage data by month or billing cycle. This information can be used to calculate average kW loads and, from this, it is possible to estimate the customer’s normal peak demand.
- Determine transformer kW loading. Commonwealth understands PacifiCorp’s GIS or similar system can determine which customers are connected to each transformer. If this is so, it should be possible to estimate the kW demand on each distribution transformer. Then, the ratio for each transformer’s ‘peak demand to name plate rating’ can be determined. This ratio would need to be estimated for both heavy and light load conditions.
- Screen the customer loading and transformer loading. It should be possible to set up a spreadsheet or data base that considers the customer loading and transformer loading and provides a report when the transformer loading and customer loading are both at or above some threshold. The threshold for the transformer loading is probably a relatively high per-

centage (perhaps 90%) and the customer loading threshold will be in kW. Commonwealth recommends considering 10 kW as a starting point. This amount of load will cause approximately a 1% voltage drop in 100 feet of #2 Al Triplex (overhead or underground). It is also probably a good idea to screen at higher thresholds without the “and” requirement described above. This would flag excessive loading on transformers and services for the fielding described in the next bullet.

- Field-visit the transformers and services that do not pass the screening described above. In this step, a knowledgeable field person (engineer, field technician, service line worker, etc.) would check the transformer to ensure the loads are actually connected to the transformer as the records indicate. The same person would visually verify the conductor size and length of the service conductor for the customer(s) that have triggered the “large load” level.
- Consider the field visit data. In this step, the field findings are considered to determine if the customer(s) may have the potential for having a secondary system voltage drop of 5 or more volts. From this analysis, a judgment will be necessary to decide the next steps. It could range from doing nothing to installing temporary recording volt meters, changing taps on the distribution transformer, replacing services or installing a new distribution transformer.
- The field engineering and operational effort described above is included in the system improvement cost estimate.
- Consider installing some recording volt meters, even if they are not thought to be necessary, on the early fielding situations to confirm what has been modeled and calculated.
- Continue to respond appropriately to customers who call and ask about suspected low voltage.

The Commonwealth team working on this project has found the PacifiCorp team members to be highly knowledgeable and qualified to address distribution system issues as a result of training of PacifiCorp staff, such as estimators, line workers and other field staff, to help resolve issues that may arise due to implementing a voltage optimization program.

### Standards

If PacifiCorp selects a solution set with Stage 3 voltage optimization, Commonwealth recommends that PacifiCorp consider developing a Stage 3 VO Service Standard. This standard would include guidelines for selection of transformers, use of secondary taps and sizing of service conductors for the Stage 3 VO circuits.



---

## Operating Impacts

Commonwealth has considered the impacts of voltage optimization on a number of operational aspects of an electrical distribution system. There is nothing noted below that appears to be significant enough to cause PacifiCorp to stop considering the implementation of VO on the Tier 1 circuits studied.

- **Safety:** The introduction of voltage optimization into a distribution system does not materially change the operation of the distribution system, its equipment or complexity. As such, there is no reason to think it will impact the safe operation of PacifiCorp's system.
- **Power Quality:** With the exception of potential low voltage, the VO protocol as designed and as considered in this study will have a neutral or positive impact on the power quality of the circuits on which it is implemented. In regard to potential low voltage, Commonwealth recommends that PacifiCorp implement the steps described above in this section, or similar steps, to address this issue. Also, the end of the line voltage metering will provide PacifiCorp with additional voltage information for use with planning, engineering and operational responses.
- **System Complexity:** For Stage 1 circuits, there are no significant changes to the equipment on the circuits. The phase balancing and redeployment of capacitors does not materially alter the distribution system's complexity. The installation of switched capacitors and regulators, for stages 2 and 3, will require the field staff to be made aware of these devices. These are each well-proven distribution components that PacifiCorp currently has standard on its system. Their addition provides more to the overall quality of service than it contributes to operational or engineering complexity. Devices such as switched capacitors and voltage regulators as "active" devices do inherently increase the possibility of failures and related outages. However, they are well-proven devices that PacifiCorp has on its system and their use is not expected to negatively impact a circuit's reliability.
- **Impacts to Substation Capacitors:** Substation capacitors are used to improve power factor, losses and voltages on the bulk power system servicing the distribution substation transformers. To a lesser extent, they also help the distribution LTC regulators stay within their  $\pm 10$  percent limits, but mostly the LTC regulators are responsible for maintaining the proper feeder voltages (so long as they are operating within their control range).
  - The application of switched capacitors in stages 2 and 3 will, in general, act to reduce the net reactive flow seen by the both the LTC and at the transformer high-side where the substation capacitors act. The additional reactive support added to each circuit is small compared to the substation capacitors in service at Bowman (3600 kVAR), Dodd Road (3000 kVAR), Mill Creek (3060 kVAR), and Nob Hill (4950 kVAR) and should not significantly impact their operation. The most likely outcome is that there will be a small decrease in the quantity of substation MVAR that is needed.

However, existing capacitors and settings should still fulfill their functions for the bulk power system and need not be changed. Future substation capacitor designs for circuits using voltage optimization may require slightly smaller sizes.

- Overall, Commonwealth does not see a need to change or adjust the existing substation capacitors or control settings. There may be a small reduction in the cost of future designs for substation capacitors where the tighter reactive control from the more extensive use of switched distribution capacitors reduces the reactive demand on the bulk electric system. It is possible that detailed analysis of the changed reactive requirements on the bulk electric system may call for reducing or eliminating some substation capacitors, but we would recommend that such changes be delayed until the intention to apply voltage optimization on all of the feeders emanating from the substation have been determined so that a complete picture of the impacts can be reviewed.
- Impacts to Substation LTC: The operation of the load tap changer (LTC) is impacted by the addition of switched distribution capacitors. The LTC may see a small increase in the frequency of operation caused by the added operation of switched capacitors. These impacts should be less significant than those seen for the switching of the larger and closer substation capacitor banks. The increased frequency of LTC operation should be minimal and cause negligible problems since the application of switched distribution capacitors is a common utility practice for which LTC transformers are designed.

### Circuits to Consider for Voltage Optimization

As PacifiCorp considers primary circuits to determine if they are good candidates for voltage optimization, Commonwealth recommends that PacifiCorp look for circuits with the following characteristics:

1. A good power factor. The feeder-source minimum power-factor must be greater than 0.96.
2. Balanced loads at the start of a voltage control zone – the feeder exit and at line voltage regulators. Phase-load-unbalance should be less than 0.15 per unit on 3 $\phi$  lines. Also feeder-source neutral-current must be less than 40 amps on 3 $\phi$  lines.
3. Circuits with relatively flat voltage profiles. This applies to both voltage control zones originating at substations and at line voltage regulators.
4. Consistency of voltage drop between feeders. Maximum voltage drop variance between multiple feeders served within a substation VO voltage control zone must be less than 2 volts (on a 120 volt base).

5. Circuits with significant residential and light commercial loads, in comparison to industrial loads, and which are relatively highly loaded.

As Commonwealth found in this study, some circuits fit these guidelines “naturally” and some required remedial action to make them VO compliant. This is a normal situation for electric utilities.

### 7-Year Capital Plan

PacifiCorp requested a capital spending plan be prepared as part of this study. Based on the Optimal Solution alternative, the capital spending plan in Table 1-4 was developed. These circuits are, based on this study, the most viable for consideration for voltage optimization. The circuits in the Optimal Solution were arranged by Stage, from Stage 1 to Stage 3. Then they were grouped by substation. This ordering seems logical because it allows PacifiCorp to implement the Voltage Optimization on a Stage by Stage approach and substation by substation sequence. It provides time for the additional engineering that will be needed for Stage 2 and Stage 3 work as compared to Stage 1. The resultant spending plan is shown below in Table 1-4.

Commonwealth acknowledges there are other ways of prioritizing the work. For example it could be prioritized by energy saved or greatest BCR. PacifiCorp may want to examine these alternative priorities before starting the implementation process.

Table 1-4 Circuits for Capital Plan

Based on Optimal Solutions having BCR  $\geq$  1.0 & LCLC  $\leq$  \$105.91

Service Area	Substation	Circuit	Implementation Stage	Estimated Cost	Annual Estimated Cost
Walla Walla	Bowman	5W154	Stage 1	\$29,526	
Yakima	Wiley	5Y434	Stage 1	\$100,248	
Walla Walla	Dodd Rd	4W22	Stage 2	\$288,415	
Yakima	Orchard	5Y456	Stage 2	\$124,802	\$542,991 Year 1
Yakima	River Road	5Y444	Stage 2	\$264,201	
Lower Valley	Grandview	5Y351	Stage 2	\$221,349	\$485,550 Year 2
Walla Walla	Bowman	5W150	Stage 3	\$345,514	Part of Year 6 total
Walla Walla	Mill Creek	5W116	Stage 3	\$318,157	
Walla Walla	Mill Creek	5W127	Stage 3	\$256,139	\$574,296 Year 3
Yakima	Clinton	5Y608	Stage 3	\$281,975	
Yakima	Clinton	5Y610	Stage 3	\$260,606	\$542,581 Year 4
Yakima	Nob Hill	5Y194	Stage 3	\$297,023	
Yakima	Nob Hill	5Y197	Stage 3	\$154,291	
Yakima	Nob Hill	5Y273	Stage 3	\$241,604	\$692,918 Year 5
Yakima	Orchard	5Y498	Stage 3	\$230,336	\$575,850 Year 6
Lower Valley	Sunnyside	5Y313	Stage 3	\$240,890	
Lower Valley	Sunnyside	5Y317	Stage 3	\$203,759	\$444,649 Year 7

---

## SECTION 2 – APPROACH TO ANALYSIS

### Circuit Fielding

To start the study, using printouts of the GIS detailed AutoDesk Maps, Commonwealth staff field verified each circuit. This included starting at the substation, noting the phasing leaving the station and following the circuit to the end of each lateral. The phasing for all transformers, corners and laterals was noted. The circuit conductor sizes and the location of line voltage regulators and capacitors were recorded. This information was captured on paper copies of the maps and then scanned and saved on CDs or DVDs and on Commonwealth's internal electronic network.

### Model Verification and Correction

Using the information gathered during the circuit fielding, Commonwealth corrected and verified the modeling in the ABB FeederAll system. After the models were corrected and verified, Commonwealth used FeederAll to analyze the circuits. This work included the 3-stage approach described below.

#### ***“As is” Base Case Voltage Profiling***

Commonwealth made corrections to the system model based on the changes found during fielding and from follow-up conversations with PacifiCorp staff. From this work, Commonwealth used the FeederAll model of the updated existing system to examine the voltage during heavy load conditions and light load conditions. Heavy loads for all stages are the peak summer MW with a MVAR load level representative of the 95th percentile. The light loads are at the 5th percentile for both MW and MVAR. These load levels were chosen because they represent reasonably possible high- and low-load levels without the “peak” loads or loads at near zero probability, both of which happen infrequently.

For the As-is voltage profile analysis, Commonwealth's modeling found that 12 of 19 circuits had primary low voltages at the end of the line in the range of 119 to 120 volts, on a 120 volt basis. The remainder of the circuits had As-is low voltages that were 120 volts or higher at the end of the line.

Commonwealth reviewed PacifiCorp-provided customer data for the 19 circuits regarding low voltage for the years 2001 to 2011. The small number of low-voltage complaints (eight) is consistent with the findings of this stage of the study. Approximately half of these issues appear to be the result of load increases made without the customer notifying PacifiCorp. See Appendix 11 for the reported customer voltage issues. This small number also provides some confidence to the assumptions associated with the expected low number of transformers and customers who may experience low voltage due to secondary system loading after implementing voltage optimization.

Commonwealth also found the Grandview circuit 5Y351 may have had substation settings contributing to the potential of customers having high-voltage conditions. PacifiCorp field engineers have

---

taken steps to investigate and address this situation. As a result, the settings for the substation transformer were modified. This situation required revising the analysis for Grandview.

### ***Pre-VO Compliant:***

The voltage optimization protocol requires that voltage control zones meet or exceed certain performance thresholds during normal operating conditions. In some situations, it may be necessary to perform system improvements to bring the system to within the thresholds. This was the case for some PacifiCorp circuits that had distribution system voltage drops greater than the 3.3% provided for in the protocol guidelines. The distribution system voltage drop is the reduction in voltage on the primary system from the regulated point to the lowest voltage point at the end of the line. In most cases, the circuits were compliant with all performance thresholds by Stage 2. Please see Appendix 8, Section 2.3, for more about the minimum operating performance thresholds.

### ***Stage 1 Analysis:***

For the Stage 1 analysis, Commonwealth used the system model corrected from the fielding results. The work for this stage included balancing phasing and redeployment of in-place fixed capacitor banks on the circuit to achieve an improved power factor profile. The redeployment of capacitors was considered on a circuit-by-circuit basis. Commonwealth did not consider it in its analysis, but it understands that PacifiCorp would normally do this within a given service district. There could be a small reduction in the cost estimates for this effort if the capacitors were redeployed on this approach.

The circuit-specific changes are outlined in more detail in Section 4, below, and are shown on circuit maps in Appendix 6. Once these “O&M” type changes were made to the model, the end of the line voltage was reduced to no less than approximately 120 volts. For some circuits, the primary voltage did dip slightly below 120 volts. Keeping the voltage at or very near to 120 volts provides for the potential of a 6 volt drop on the secondary system. The analysis included primary voltages during both heavy and light load conditions.

Commonwealth also:

- Used the established VO protocol to calculate the energy savings associated with lowering the end of the line primary voltage to 120 volts for each circuit between the base case and the studied stage case.
- Developed cost estimates to complete the work to get the circuit into a Stage 1 configuration, including: metering, planning, engineering and construction; efforts to address potential increased low-voltage customer issues; and any ongoing maintenance and costs associated with the improvements. The estimated funding should be sufficient to research and develop an approach, complete fielding and develop solutions for specific transformers and services.
- Determined the additional O&M costs for Stage 1 should be low, due to the minimal additional investment. The annual O&M costs were increased by 2% of the capital investment

and the funding for Stage 1 should be adequate for meter data acquisition, which will be the major additional O&M work effort over the life of implementation for this stage.

- Performed an economic benefit-cost analysis for Stage 1 improvements, including the secondary system improvements described below.

### **Stage 2 Analysis:**

For the Stage 2 analysis, using the modifications from Stage 1 as a starting point, Commonwealth made system model modifications to include: new capacitors (switched and fixed), reconductoring, voltage regulators, etc. The circuit changes are outlined in more detail in Section 4, below, and are shown on circuit maps in Appendix 6. Using this model of the system, Commonwealth used FeederAll to analyze the circuit for heavy and light load conditions.

Commonwealth also:

- Used the established VO protocol to calculate the energy savings associated with operating the end of the line voltage at or near 120 volts for each circuit's respective Stage 2 configuration.
- Developed cost estimates to complete the work to get the circuit into a Stage 2 configuration. This included planning, engineering and construction; efforts to address potential increased low voltage customer issues; and any ongoing maintenance and costs associated with the improvements. For Stage 2, it is possible that the number of distribution transformers with primary voltages of 121 volts or less could be fewer than what would be expected for Stage 1. If this was the situation, the estimated costs for Stage 2 work were reduced, or negative, as the costs from stage to stage are cumulative. This situation would be created from the system improvements included in Stage 2.
- Considered the likely O&M costs in comparison to the 2% included in the financial analysis. The O&M funding for Stage 2 appears sufficient.
- Performed an economic benefit-cost analysis for Stage 2 improvements, including the secondary system improvements described below.

### **Stage 3 Analysis:**

For Stage 3 analysis, Commonwealth started with the circuit improvements from the Stage 2 work and modeled the system with an end of the line primary voltage of 119 volts.

Commonwealth then:

- Used the established VO protocol to calculate the change in average voltage for each circuit between the Pre-VO Compliant base case and the studied stage case.
- Used the established protocol to estimate the energy savings from this system configuration as compared to the base case.

- Developed cost estimates to complete the work to get the circuit into a Stage 3 configuration, including: metering, planning, engineering and construction and efforts to address potential increased low-voltage customer issues.
- Included 250 hours of PacifiCorp staff time in the cost estimates to develop new service standards for VO zones operating with end of the line voltages set to 119 volts
- Considered the likely O&M costs in comparison to the 2% included in the financial analysis. The O&M funding for Stage 3 appears sufficient.
- Performed an economic benefit-cost analysis for Stage 3 improvements, including the secondary system improvements described below.
- Using the stage-appropriate system, used FeederAll output as an input to ArcGIS to prepare circuit maps showing the voltage along each circuit. This included the circuits in heavy load and light load conditions.

### Secondary System Considerations

Commonwealth has considered the potential likelihood of customers having secondary system voltage drops of a large enough value to cause the service entrance voltage to drop below 114 volts. PacifiCorp's standards provide for secondary voltage drops of up to 5% (6 volts on a 120 volt basis). As the system's primary distribution voltage drops below 121 volts (leaving one volt for the downside bandwidth of the voltage regulator), it is possible that customers may have low-voltage scenarios develop. The probability of this happening is small. From the circuit information provided by PacifiCorp (see Appendix 11), it is clear there are infrequent customer inquiries about low voltage, even though the modeling indicates the primary voltage for a number of these 19 circuits drops below 120 volts (on a 120 volt basis) during normal operations. The data provided by PacifiCorp indicates that only 8 customers, over the last 10 years, have asked to have low-voltage issues investigated. There are a number of reasons that PacifiCorp may have such a small number of customers inquiring about low voltage, but the most likely reason is the load diversity at the distribution transformer level. The loading on the distribution transformers is approximately 39% of installed nameplate capacity during peak loads. This indicates the voltage drop of most transformers is not a major issue. For the vast majority of the transformers, the loading and voltage drop is going to be less during lightly loaded periods.

It is still possible that customers could experience low voltage, less than 114 volts, at the service entrance when the primary voltage (on 120 volt scale) is less than 120 volts or even between 120 and 121 volts. It is possible to determine, for a large group of distribution transformers and associated customers, the maximum probable number of transformers that may have a secondary voltage drop of more than a given value.

The secondary system voltage drop will have a Gaussian (normal) distribution. Based on this, it is possible to estimate the number of customers in the population that have secondary voltage drops of a particular amount or more. Commonwealth's approach to making these estimations is described in Appendix 2. From this approach, for heavy load, approximately 10.6% of the customers




may have secondary voltage drop of more than 5 volts. Commonwealth used the same approach to determine there is a probability of 26.8% for transformers to have a secondary voltage drop greater than 4 volts during heavy load periods.

Figure 2-1, below, shows three voltage zones: greater than 121 volts, 120 to 121 volts and 119 to 120 volts. These are primary voltages on a 120 volt basis.

For the voltage zone of 119 to 120 volts, transformers at the 119.01 point of the zone with a secondary voltage of 4.02 volts will, allowing one volt for the downside bandwidth of the regulator, have a potential of causing service voltages to drop to below 114 volts. This same secondary voltage drop on a transformer with a primary voltage of 119.99 (or 119.03) would not have low voltage. To determine the potential number of impacted transformers, one must use the statistics found in Appendix 2 of this report. From Appendix 2, you will see that it is assumed there are 3% of the customers that have a secondary system voltage drop of 6 volts (5% on a 120 volt basis). Appendix 2 also shows that the number of customers expected to have a 5 volt or greater secondary system voltage drop is calculated to be 10.6%. Using the same methodology, the percentage of customers with a secondary system voltage drop of 4 or greater volts is 26.8%.

**Figure 2-1 Example Voltage Zone**



To determine the number of transformers that may have low voltage, it is necessary to know the voltage zone of interest: either the 119 to 120 or the 120 to 121 volt zone and the number of transformers in the zone of interest. For example, if there are 50 transformers in the 119 to 120 volt

zone, then the number of transformers that may have low voltage =  $(50) \times (.03 + .106)/2 = 3.4$  transformers. For this study, the number of transformers was always rounded up. In this example, then, the number of transformers with potential low voltage would be 4.

To resolve the issues associated with these situations, Commonwealth suggests the following options:

1. Adjust distribution transformer taps
2. Replace distribution transformers
3. Replace service conductors

The costs for this work are included in the estimates.

To estimate the number of customers and transformers that may have secondary system voltage concerns in light load conditions, an additional step is taken. For this estimate, the result from above is multiplied by the ratio of each circuit's light load to heavy load. For this example, if the heavy load is 7500 kW and the light load is 3000 kW, then the ratio is 0.4 (3000/7500) multiplied by 3.4, or 1.4; again rounding up, the maximum expected number of transformers with secondary system voltage drops resulting in potential low voltage is 2. This approach recognizes that the distribution transformer and individual service loads would have a reduced probability of experiencing coincident voltage drops sufficient to cause a secondary system to have a low-voltage condition during a light load period.

Table 2-1, below, (from FeederAll results) shows the number of transformers on each circuit by stage that could, due to the primary voltage dropping below 120 volts, have low voltage at their service entrance. This number includes customers who may, at times, have secondary voltage drops in excess of 5% (6 volts) but who, due to the primary voltage being above 120 volts, are not currently experiencing voltages below 114 volts. These customers are included in the total number of customers whose secondary system (transformer and service) may require work to maintain the customer's service entrance voltage at 115 volts or greater.

Note: The numbers of transformers shown in the table are the maximum expected number if the voltage optimization would be implemented to that particular stage. This means the total number of transformers shown is not additive, stage to stage. In fact, it is common for the number to go down between Stage 1 and Stage 2.

**Table 2-1 Estimated Number of Customers with Potential Low Voltage and Associated Transformers**

Circuit	Controlling Case	Number of Transformers at or below 120 volts	Number of Transformers from 120 to 121 volts	Estimated total number of transformers that may have customers with low voltage at Service Entrance**
<b>Bowman 5W150</b>				
Stage 1	Heavy	184	99	42
Stage 2	Heavy	184	99	42
Stage 3	Heavy	35	143	17
<b>Bowman 5W154</b>				
Stage 1	Heavy	0	6	1
Stage 2	Light	0	350	8
Stage 3	Light	350	22	21
<b>Dodd Road 4W22</b>				
Stage 1	Heavy	229	78	49
Stage 2	Light	35	189	14
Stage 3	Light	189	147	33
<b>Mill Creek 5W116</b>				
Stage 1	Light	91	294	10
Stage 2	Light	0	319	6
Stage 3	Heavy	63	98	19
<b>Mill Creek 5W127</b>				
Stage 1	Light	32	300	8
Stage 2	Light	32	300	8
Stage 3	Light	321	0	18
<b>Pomeroy 5W342</b>				
Stage 1	Heavy	83	27	16
Stage 2	Light	0	398	8
Stage 3	Heavy	64	197	26
<b>Clinton 5Y608</b>				
Stage 1	Light	38	341	12
Stage 2	Light	0	161	5
Stage 3	Light	161	218	17
<b>Clinton 5Y610</b>				
Stage 1	Light	16	277	7
Stage 2	Light	0	95	2
Stage 3	Light	95	198	10

Circuit	Controlling Case	Number of Transformers at or below 120 volts	Number of Transformers from 120 to 121 volts	Estimated total number of transformers that may have customers with low voltage at Service Entrance**
<b>Orchard 5Y456</b>				
Stage 1	Light	0	215	4
Stage 2	Light	0	215	4
Stage 3	Heavy	46	34	11
<b>Orchard 5Y498</b>				
Stage 1	Light	0	322	6
Stage 2	Light	0	322	6
Stage 3	Heavy	63	96	19
<b>Wiley 5Y434</b>				
Stage 1	Heavy	53	69	15
Stage 2	Heavy	53	69	15
Stage 3	Heavy	150	17	30
<b>Nob Hill 5Y197</b>				
Stage 1	Heavy	0	0	0
Stage 2	Heavy	0	0	0
Stage 3	Heavy	0	96	7
<b>Nob Hill 5Y194</b>				
Stage 1	Light	164	65	12
Stage 2	Light	164	65	12
Stage 3	Light	355	65	24
<b>Nob Hill 5Y273</b>				
Stage 1	Light	463	0	25
Stage 2	Light	0	420	9
Stage 3	Light	420	43	24
<b>North Park 5Y356</b>				
Stage 1	Heavy	158	73	35
Stage 2	Light	0	232	6
Stage 3	Light	232	244	23
<b>River Road 5Y444</b>				
Stage 1	Light	43	406	12
Stage 2	Light	43	406	12
Stage 3	Heavy	57	251	28
<b>Sunnyside 5Y313</b>				
Stage 1	Light	21	198	7
Stage 2	Light	21	198	7
Stage 3	Light	209	18	15

Circuit	Controlling Case	Number of Transformers at or below 120 volts	Number of Transformers from 120 to 121 volts	Estimated total number of transformers that may have customers with low voltage at Service Entrance**
<b>Sunnyside 5Y317</b>				
Stage 1				0
Stage 2				0
Stage 3	Light	135	19	9
<b>Grandview 5Y351</b>				
Stage 1	Heavy	19	20	5
Stage 2	Light	155	174	12
Stage 3	Heavy	63	111	20
<p>**The numbers shown is the maximum expected number if the Voltage Optimization would be implemented to that particular stage. This means the total shown is not additive stage to stage. In fact, it is common for the number to go down between Stage 1 and Stage 2.</p>				

The output of the system study was then analyzed from an economic perspective using the financial factors in Section 1b.

### More on Light Load / Heavy Load Scaling

For this work, Commonwealth considered how the probability of a particular distribution transformer and the services off of it may have a low-voltage situation during light load after voltage optimization is implemented. This question is important because, during lightly loaded conditions, the voltage profile of the distribution circuit is “flatter” (has less voltage drop from the substation to the end of the line). The result is the potential for more transformers to have a lower primary source voltage during light loads than during heavy loads. The greater number of transformers is considered in the calculations for light load situations. The question to consider is: During light load periods, what is the change to the heavy load probability of having a secondary system with a specific, or greater, voltage drop? In this case, the voltage drops of concern are 4 volts or greater and 5 volts or greater. These are secondary system voltage drops that could, if the primary distribution system voltage were low enough, cause one or more customers being served from a particular transformer to have a service voltage of 115 volts or less.

Consider the components of the secondary system voltage drop. The voltage drop in the distribution transformer + the voltage drop in a shared secondary + the voltage drop in the service equals the secondary system voltage drop. In an equation:

$$V_{d\text{-sec sys}} = V_{d\text{ trans}} + V_{d\text{ sec}} + V_{d\text{ svc}}$$

where:

$$V_{d\text{ trans}} = (I_{\text{trans}})(Z_{\text{trans}}); V_{d\text{ sec}} = (I_{\text{sec}})(R_{\text{sec cond}}); \text{ and } V_{d\text{ svc}} = (I_{\text{svc}})(R_{\text{svc cond}})$$

In this example, the impedances do not change appreciably as the current changes, so the voltage drop change is proportional to the change in the current. The sum of the transformer loadings on the distribution system is equal to the system load; therefore, as the system load drops, on average, so does the loading on an average transformer. As the loading on the transformer is the sum of the individual loads, the voltage drop would be expected to diminish as the current from the loads diminishes. The change in the voltage drop is proportional to the change in the load current, and on average, the system load changes with the transformer loadings. So, the likelihood of excessive voltage drop in an average transformer's secondary system at a given load level can be estimated by multiplying the ratio of the load at a given level to the peak load by the probability of the voltage drop at the peak level. This indicates that, for an average distribution transformer system, the probability, at light load, of the secondary voltage drop being equal to or more than a given amount is equal to the probability of that voltage drop scenario at peak load times the ratio of light load to heavy load. In equation form:

$$\text{Prob}(V_{d\text{ sec sys LL}}) = \text{Prob}(V_{d\text{ sec syst HL}}) \times ((\text{Light Load})/(\text{Heavy Load}))$$

The estimated probability of the voltage drops for four or more volts is 26.8%, and for five or more volts it is 10.6%, as calculated via the methodology in Appendix 2. If the heavy load is known, for any given light load the probability of these voltage drops occurring on a distribution transformer's secondary system can be also be estimated with the equation above. This is the approach used in this study.

## SECTION 3 – EXISTING SYSTEM ASSESSMENT

### Area Overview

The 19 PacifiCorp feeders evaluated in this study serve approximately 30,747 customers. The total system peak demand for the 19 feeders is 138 MW, delivering approximately 627,612 MWh annually. The average PacifiCorp customer on the 19 feeders has an annual consumption of approximately 20,412 kWh. There is 354,360 kVA of connected distribution transformer nameplate capacity. The average distribution transformer is loaded to approximately 39% of its nameplate when comparing the peak load for all circuits and the connected distribution transformer nameplate capacity. Table 3-1 summarizes the substations and circuits analyzed for this study.

**Table 3-1 Overview of Substations and Circuits Analyzed**

Station	Circuits in Study	Total Customers	Annual Peak (MW)	Comments
Bowman	2	3,619	14.92	One of the circuits has three capacitors installed and the other four. These circuits serve 68% residential load, 29% commercial load and small amounts of industrial and irrigation.
Dodd Rd	1	1,181	8.7	No capacitors are on this circuit. This circuit serves 45% residential load, 31% commercial, 13% industrial and 11% irrigation.
Mill Creek	2	4,021	14.32	One of the circuits has two capacitors installed and the other none. These circuits serve 76% residential load and 23% commercial.
Pomeroy	1	1,204	6.04	One capacitor is installed on this circuit. This circuit serves 70% residential and 29% commercial load with a very small amount of industrial load.
Clinton	2	3,438	17.45	One circuit has one capacitor installed and the other two. These circuits serve 62% residential and 38% commercial load.
Nob Hill	3	5,661	22.07	One circuit has two capacitors installed, one circuit has one capacitor installed and one circuit has no capacitors installed. These circuits serve 71% residential and 29% commercial load.
North Park	1	1,634	6.79	Two capacitors are installed on this circuit. This circuit serves 85% residential and 15% commercial load with a very small amount of irrigation.
Orchard	2	3,172	13.58	One of the circuits has one capacitor in-

Station	Circuits in Study	Total Customers	Annual Peak (MW)	Comments
Wiley	1	1,332	6.99	stalled and the other none. These circuits serve 81% residential with the balance essentially commercial. No capacitors are on this circuit. This circuit serves 87% residential load, 11% commercial and the balance industrial.
River Road	1	2,201	10.6	One capacitor is installed on this circuit. This circuit serves 60% residential load and 39% commercial.
Grandview	1	1,286	7.7	There is one capacitor installed on this circuit. This circuit serves 62% residential load, 28% commercial, 5% irrigation and the balance industrial.
Sunnyside	2	1,998	9.0	One capacitor is installed on each circuit. These circuits serve 54% residential load and 45% commercial load.

The Simplified Voltage Optimization (VO) Measurement and Verification (M&V) Protocol provides a basic approach to determine end-use energy savings when operating the electric distribution system more efficiently and within the lower band of the ANSI Standard voltage level. The protocol covers utility electric distribution systems serving mostly residential and light commercial load as defined by the utility. System loads do not need to be uniformly distributed throughout the distribution system.

Appendix 12 includes the summary information for each circuit. The appendix shows the following:

- 70% to 95% of the customers on each circuit have air conditioning.
- There is a large penetration of natural gas in the area, which results in non-electric heat providing the majority of consumer heating needs on most circuits.
- The heating and cooling zones for this area are classified as 1.
- The expected VO factor for end use savings ranges from 0.51 to 0.65.

The 19 primary distribution circuits use a variety of primary conductor types. The overhead primary conductors were found to range from #6Cu and #2ACSR up to 795 kcm AAC. Underground conductor sizes ranged from #2CU to 1000 kcm AL cable.



## Metering

**Substation:** To meet the VO protocol verification requirements, it is necessary to have interval data for the MW, MVAR, phase amps and bus voltage for each circuit operated with voltage optimization. Most of the metering infrastructure is available to meet the protocol requirements. Metering is present in each substation for each power transformer. Potential transformers are available to be used for the feeder metering. The substation feeders are being protected with circuit breakers. The circuit breakers have current transformers that can be used for feeder metering. A control enclosure is available in which to mount a new meter. Additionally, PacifiCorp Tech Ops managers indicate most remote terminal units (RTU) and analog lines are available to get feeder ampere readings into RANGER.

**Line Voltage Regulator Metering:** Because a line voltage regulator is the start of a separate voltage control zone, it is required that the same information be monitored and recorded at or near a voltage regulator as at a substation. It is likely that metering will need to be added to existing regulators.

**End of the Line (Voltage Zone) Metering:** There is currently no end of the line voltage monitoring in place on these 19 PacifiCorp circuits. This will require only the equipment necessary to measure the end of the line voltage on one phase.

The necessary metering is outlined in Section 4, with details of the equipment and the expected installation costs for the required metering described in Appendix 13.

## Voltage Control

PacifiCorp's standards for voltage control are consistent with ANSI/IEEE C84.1. For this study, it was assumed PacifiCorp's customers will most generally have a secondary system voltage drop of less than or equal to 5% (6 volts on 120 volt base). This provides for the primary voltage to drop to 120 volts (1 per unit, on a 120 volt base) and still ensure a service entrance voltage of 114 volts.

In general, the substations have power transformer load tap changers (LTC) used for voltage regulation. For all stations the As-is, or base case, voltage controls apply line drop compensation settings with a base voltage setting, for most circuits, of 121 volts with a 2 volt bandwidth (plus or minus 1 volt). This approach to voltage regulation is consistent with the Simplified VO protocol.

## VO Minimum Threshold Assessment

The system was assessed to determine compliance with VO M&V Protocol minimum threshold limits for primary voltage, amperage unbalance, primary voltage drop and power factor. A number of the circuits required remedial action to come into the protocol criteria. At the end of Stage 1, a number of the circuits were not compliant with the protocol requirements to start voltage optimi-

zation. However, by Stage 2 all circuits were compliant with the protocol. It is not uncommon for a utility to need to make some adjustments to its system to bring some of its circuits into the acceptable range for the VO protocol. Refer to Appendix 8, Simplified VO M&V Protocols, Section 2.3, for the definition of minimum threshold limits.

---

## SECTION 4 – SYSTEM IMPROVEMENTS

### Primary System

System improvements (SI) are necessary to ensure compliance with minimum VO thresholds, improve distribution system efficiency, achieve lower end-user average voltages and reduce the risk of abnormal voltage. For the most part, the improvements considered were consistent with PacifiCorp's standard materials and approaches and are meant to be consistent with the work as described in PacifiCorp's Block Cost Estimating Spreadsheet.

The system improvements include:

- Phase changes to balance load and reduce neutral current.
- Installation of switched or fixed capacitors to improve power factor. From Commonwealth's examination of the current PacifiCorp application of capacitors, it is noted that switched distribution capacitors are used sparingly (only one was found on the 19 Tier 1 feeders). Using only fixed banks, the existing capacitors on the distribution primary, for the most part, appear designed to seek to balance reactive needs between heavy and light load conditions. In redesigning the banks to include both fixed and switched capacitors, the fixed capacitor banks were used to satisfy light load reactive needs within 300 to 600 kVAR. Then, switched banks were used to serve the added reactive needs during heavy load, also generally within the range of 300 to 600 kVAR. This resulted in a tighter control of net feeder power factor, holding it close to unity power factor. A tighter power factor reduces feeder losses and it also results in flattening the voltage profile on the feeder, providing improved opportunity for voltage optimization. The results of installing these capacitors are shown in Appendix 14 and Appendix 15. The VAR profiles are noted in Appendix 14, and the power factor profiles are shown in Appendix 15. Both appendices show base case and system improvement modeling results.
- Reconductoring some sections of conductor where the existing wire is reaching the limit of its current carrying capacity.
- Installing line voltage regulators to reduce the voltage drop on the circuit.

With system improvements, the voltage profile along each feeder is flattened. With a smaller voltage drop along the feeder, the average feeder voltage can be reduced, which reduces system no-load loss and provides end-use energy savings.

### Metering Improvements

**Substation:** To meet the VO protocol verification requirements, it is necessary to have the MW, MVAR, phase amperage and bus voltage for each circuit operated with voltage optimization. Most of the metering infrastructure is available to meet the protocol requirements. Metering is present in each substation for each power transformer. Potential transformers are available to be used for

the feeder metering. The substation feeders are being protected with circuit breakers. The circuit breakers have current transformers that can be used for feeder metering. A control enclosure is available in which to mount a new meter. Additionally, PacifiCorp Tech Ops managers indicate most remote terminal units (RTU) and analog lines are available to get feeder ampere readings into RANGER.

In most cases, the installation of the meters in the substation should be relatively straightforward. The process for the substation installation will be to remove the existing demand meter and replace it with an SEL 751A relay, mounted on the panel in place of the existing meter. The overcurrent and reclosing relays will be maintained as backups. A test switch will be mounted adjacent to (below) the relay. The appropriate voltage quantities will be routed from the existing metering voltage transformer circuits, probably already in the control enclosure. The voltages will be wired to the test switch and relay. Current quantities will be wired to the test switch and relay from the feeder breaker current transformers. The relaying and metering settings will be installed in the relay, and a functional check of the relay will be performed. While it is likely the potential and current transformers will not be revenue accuracy metering, relay level accuracy is considered acceptable by the Simplified Voltage Optimization Protocol. PacifiCorp typically specifies an accuracy rating of 0.6% for relay and monitoring devices and 0.3% for revenue devices.

An accuracy class of 0.3 (or 0.6) indicates the device is certified by the manufacturer to be accurate to within 0.3% (or 0.6%) when operating at its rated value. When the current (for a current transformer) or voltage (for a potential transformer) drops significantly below the rated value, the error is allowed to increase without violating the accuracy standard. IEEE C57.13 allows that current transformers may have greater errors at lower currents. The standard permits twice the error at 10% current than is permitted at 100% current. So, a current transformer with an accuracy rating of 0.3% may have errors of 0.6% when the load is 10% of the rated amount. This means a current transformer in the 0.6 accuracy class may have permissible errors of 1.2% at the 10% load level. This greater error at such low current does not usually represent significant error in total registration of kilowatt hours.

For potential transformers, IEEE C57.13 requires the accuracy also be met at 90% voltage; this drop in voltage is greater than the voltage swing on PacifiCorp's distribution system. The 0.6% to 1.2% error range is not significant in determining the effects of voltage optimization and is why relay accuracy metering provides sufficient accuracy to determine if the implemented voltage optimization is acquiring the energy anticipated. It also provides the necessary data and information to appropriately control a distribution system being operated in a voltage optimization mode. For these reasons, Commonwealth does not recommend that PacifiCorp replace its relay accuracy current and potential transformers for voltage optimization.

**Line Voltage Regulator Metering:** Because a line voltage regulator is the start of a separate voltage control zone, it is required that the same information be monitored and recorded at or near a line voltage regulator as is monitored and recorded at a substation. It is likely that metering will be needed to be added to existing regulators. What is described here provides for this. It is possible to

---

order regulators with the metering necessary for voltage optimization, but to keep the costs consistent, this approach is what was included in the cost estimates for this work. The metering set for use at a 3-phase line regulator will be installed on a pole, as close to the load side of the regulators as practical. Three current transformers and three voltage transformers will be mounted on an instrument transformer cluster rack near the top of the pole. The voltage transformers will be connected to the line conductors through cutouts and hot clamps. The current transformers will be connected to the line across insulators added to the line, or at a deadend structure. The meter will be mounted to the pole near the base and connected to the voltage transformers using control cable. Since the meter will be exposed to public access, the control cable will be installed in conduit, up the pole, until the cable reaches 10 feet above the ground. After the wiring is complete, the meter will be installed in the meter base and the installation will be energized and verified.

**End of the Line (Voltage Zone) Metering:** There is currently no end of the line voltage monitoring in place on these 19 PacifiCorp circuits. Equipment will be required to measure only the voltages. The installation at the end of the line will be different than the substation installation. One voltage transformer will be provided and mounted on a convenient pole. The transformer will be mounted on a cluster rack at the top of the pole and connected to the line using a fused cutout and hot clamps. The meter will be mounted to the pole near the base and connected to the voltage transformers using control cable. Since the meter will be exposed to public access, the control cable will be installed in conduit, up the pole, until the cable reaches a minimum of 10 feet above the ground. After the wiring is complete, the meter will be installed in the meter base and the installation energized and verified. This installation will require a line crew to install the instrument transformers at the top of the pole and a meter worker to install and verify the meter.

The details of the equipment and the expected installation costs for the above metering are described in Appendix 13. Commonwealth has increased the estimated costs for the substation and end of the line metering by 20% to provide a contingency for this work effort.

The VO protocol would consider the metering described above sufficient for implementation of the voltage optimization plan included in this report. However, PacifiCorp is concerned that implementing to Stage 3 could result in operational issues, such as low voltage. In an effort to more closely monitor and manage the system in a Stage 3 level of voltage optimization, PacifiCorp has requested that Commonwealth include real-time communication and monitoring with the metering equipment. The metering for stages 1 and 2 should be compatible with the communication and metering infrastructure, so there will be no lost investment if implementation for Stage 3 lags stages 1 and 2.

**Stage 3 Metering Communications:** PacifiCorp is concerned that a Stage 3 implementation could result in customers having low voltage and asked that equipment and the associated costs for real-time monitoring and control be included in Stage 3 options. To do this, communications will be necessary between:

- Substations and the end of the line metering locations
- Substations and line voltage regulators
- Line voltage regulators and end of the line metering
- Substations to a central location for monitoring and data storage

The substation to the central monitoring and data storage location is communications gear, links, central equipment and software to support voltage optimization, IVVO, FDIR, AMI, DR and other Smart Grid services. It would be secure, real-time and always on communication. This is an accepted approach in the Voltage Optimization protocol. See Appendix 8, Simplified Voltage Optimization (VO) Measurement and Verification Protocol, for more information.

The communication between the stations and line metering equipment for both regulators and end of the line voltage metering would be wireless radio links.

The costs to provide this level of communication, which may be needed for full Smart Grid applications but may be more than is required for voltage optimization, will add approximately \$2.7M to the project, or about 40% of all costs, if every circuit in the study is developed to a Stage 3 level. If voltage optimization is implemented, Commonwealth believes that experience may demonstrate that there is less need for and fewer benefits to the communication than PacifiCorp expects. If this turns out to be true, it may mitigate the need for this level of metering and communication, at least until there are other uses for the system, such as Smart Grid applications, that could also share the cost burden.

### Secondary System Considerations

For most circuits, it is possible that, as a result of voltage optimization, some number of distribution transformers, and hence customers, may have secondary voltage drops of sufficient magnitude to cause service entrance voltages to drop below 115 volts. Commonwealth's approach to addressing this is described in Section 2. Each of the circuits was analyzed based on this approach for each stage and for heavy and light load; the summary findings are included in Table 4-1, below.

### Location of System Improvements

The installation of capacitors, regulators and reconductoring are shown on the circuits map in Appendix 6. Additionally, the locations for the primary system improvements for each circuit are noted in Appendix 9, Summary of Analysis.

### Cost Estimating

The estimated costs by circuit and stage are shown in total in Table 4-1. In Table 4-2, the work is described in summary fashion with the respective cost for the work noted. Additional details

showing the cost estimates are in Appendix 10. The costs are based on PacifiCorp's Block Cost Estimating Sheet and PacifiCorp's loaded hourly labor rates. Both of these are shown in Appendix 4. Where needed, Commonwealth has supplemented the PacifiCorp cost information with its knowledge of industry equipment and installation costs.

In addition to the system improvements described and included in the costs, Commonwealth has included costs for the following project related tasks:

- Engineering and analysis for phase swapping
- Planning, engineering and analysis to prepare for and respond to potential low-voltage problems.

The actions of implementing Stage 2 and Stage 3 voltage optimization are generally dependent on the previous stage or stages. For example, a Stage 3 model relies on the phase balancing completed in the Stage 1 model and the capacitors installed in the Stage 2 model. This approach allowed Commonwealth to add the estimated costs from Stage 1 to Stage 2 and the Stage 1 + Stage 2 total to the Stage 3 cost estimate. Following this approach did, at times, result in an anomaly when working with the solutions associated with addressing the potential low-voltage problems. It was possible that, after the system improvements for Stage 2 were completed, there would be fewer transformers potentially at risk of low voltage than would be at risk in the Stage 1 solution. Since the Stage 1 cost estimate included more transformers at risk than were at risk in the Stage 2 configuration, this required giving Stage 2 a cost credit for this component of the estimate.

The Financial Model assumes the increased operating and maintenance (O&M) cost for the voltage optimization effort will be 2% of the installed (capital) cost for each year of the life of the VO effort. For the BCR optimal solution with installed costs of approximately \$520k, PacifiCorp should expect to have related O&M costs of \$10,400 each year for the 20-year life of these VO projects. Assuming the 2% per year, the LCLC optimal solution with installed costs of approximately \$1.25M, the O&M funding would be \$25,000/year. These costs are included in the economic modeling for both the LCLC and BCR solutions. These funding levels seem appropriate, given the differences between the two solutions.

This amount of funding seems appropriate to support the work load for this level of VO programming. The work expected includes:

- Staff time to check and record voltage levels, either in field or via SCADA or similar system data transmission
- Incremental engineering time to review circuit parameters and make adjustments such as:
  - Phase balancing
  - Voltage control settings due to system modifications
  - Address post implementation questions regarding service voltages
- Engineering review to check and document system savings

- Incremental crew resource time to support engineering with field work associated with the above review of circuit parameters and related adjustments

Additional funding is included in the cost estimate for the development of a new standard for the selection of service conductors and distribution transformers on circuits implementing voltage optimization with end of the line primary voltages set to 119 volts. This is necessary if implementation includes any of the circuits to the Stage 3 level. The funding for the standard is included in the Optimal LCLC estimate for the effort to remedy potential low voltages.

**Table 4-1 System Improvement Cost Summary**

Service Area	Substation	Circuit	Stage1	Stage 1 and Stage 2	Stage 1, Stage 2, and Stage 3
Walla Walla	Bowman	5W150	\$180,378	\$329,870	\$341,514
Walla Walla	Bowman	5W154	\$29,526	\$102,929	\$272,600
Walla Walla	Dodd Road	4W22	\$219,622	\$288,415	\$583,960
Walla Walla	Mill Creek	5W116	\$58,178	\$150,565	\$318,157
Walla Walla	Mill Creek	5W127	\$83,645	\$106,799	\$256,139
Walla Walla	Pomeroy	5W342	\$107,846	\$317,873	\$622,153
Yakima	Clinton	5Y608	\$73,614	\$123,639	\$281,975
Yakima	Clinton	5Y610	\$53,438	\$118,025	\$260,606
Yakima	Orchard	5Y456	\$49,098	\$124,802	\$267,123
Yakima	Orchard	5Y498	\$44,502	\$65,499	\$230,336
Yakima	Wiley	5Y434	\$100,248	\$123,402	\$402,516
Yakima	Nob Hill	5Y197	\$23,910	\$47,064	\$154,291
Yakima	Nob Hill	5Y194	\$95,448	\$128,436	\$297,023
Yakima	Nob Hill	5Y273	\$128,058	\$107,026	\$241,604
Yakima	North Park	5Y356	\$166,286	\$231,435	\$522,300
Yakima	River Road	5Y444	\$85,444	\$264,201	\$552,570
Sunnyside	Sunnyside	5Y313	\$60,508	\$98,309	\$240,890
Sunnyside	Sunnyside	5Y317	\$26,690	\$49,844	\$203,759
Sunnyside	Grandview	5Y351	\$54,252	\$221,349	\$469,211
Total			\$1,640,691	\$2,999,482	\$6,518,727



Table 4-2 System Improvement Costs by Circuit and Stage

Circuit	Action	Cost	Total Stage Cost
<b>Bowman 5W150</b>			
Stage 1	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 162,708	
			\$ 180,378
Stage 2	900 kVAR switched capacitor addition	\$ 20,997	
	Rotate phases	\$ 4,820	
	Regulator addition	\$ 72,594	
	Metering	\$ 51,080	
			\$ 149,492
Stage 3	Install feeder metering package	\$ 108,833	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (97,188)	
			\$ 11,645
<b>Bowman 5W154</b>			
Stage 1	Remove existing capacitors	\$ 5,200	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 6,656	
			\$ 29,526
Stage 2	Two 900 kVAR switched capacitor addition	\$ 41,995	
	Transformer change out, tap changes and service change outs	\$ 31,408	
			\$ 73,403
Stage 3	Install metering package	\$ 115,748	
	Transformer change out, tap changes and service change outs	\$ 53,924	
			\$ 169,672
<b>Dodd Road 4W22</b>			
Stage 1	900 kVAR fixed capacitor addition	\$ 5,912	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 196,040	
			\$ 219,622
Stage 2	1,800 kVAR switched capacitor addition	\$ 18,667	
	Two 300 kVAR switched capacitor additions	\$ 24,802	
	447 feet reconductoring	\$ 59,133	
	Regulator addition	\$ 74,187	
	Metering	\$ 25,540	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (133,536)	
			\$ 68,793
Stage 3	Install metering package	\$ 221,029	
	Transformer change out, tap changes and service change outs	\$ 74,516	
			\$ 295,545

Circuit	Action	Cost	Total Stage Cost
<b>Mill Creek 5W116</b>			
Stage 1	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 40,508	
			\$ 58,178
Stage 2	900 kVAR switched capacitor addition	\$ 20,997	
	Regulator addition	\$ 63,842	
	Metering	\$ 25,540	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (17,992)	
			\$ 92,387
Stage 3	Install metering package	\$ 115,748	
	Transformer change out, tap changes and service change outs	\$ 51,844	
			\$ 167,592
<b>Mill Creek 5W127</b>			
Stage 1	Phasing change	\$ 8,400	
	Phasing swaps	\$ 14,460	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 35,828	
	600 kVAR fixed capacitor addition	\$ 7,287	\$ 83,645
Stage 2	600 kVAR switched capacitor addition	\$ 23,154	
			\$ 23,154
Stage 3	Install metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 40,508	
			\$ 149,341
<b>Pomeroy 5W342</b>			
Stage 1	Phasing change	\$ 4,200	
	Phasing swaps	\$ 9,640	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 76,336	
			\$ 107,846
Stage 2	300 kVAR switched capacitor addition	\$ 17,333	
	355 feet reconductoring	\$ 39,349	
	71 feet reconductoring	\$ 10,930	
	Regulator additions	\$ 127,683	
	Metering	\$ 51,080	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (36,348)	
			\$ 210,027
Stage 3	Install metering package	\$ 227,944	
	Transformer change out, tap changes and service change outs	\$ 76,336	
			\$ 304,280

Circuit	Action	Cost	Total Stage Cost
<b>Clinton 5Y608</b>			
Stage 1	Phasing change	\$ 2,280	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 53,664	
			\$ 73,614
Stage 2	900 kVAR switched capacitor addition	\$ 20,997	
	564 feet reconductoring	\$ 62,515	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (33,488)	
			\$ 50,025
Stage 3	Install feeder metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 49,504	\$ 158,337
<b>Clinton 5Y610</b>			
Stage 1	Phasing change	\$ 2,280	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 33,488	
			\$ 53,438
Stage 2	600 kVAR switched capacitor addition	\$ 23,154	
	576 feet reconductoring	\$ 63,845	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (22,412)	
			\$ 64,587
Stage 3	Install feeder metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 33,748	\$ 142,581
<b>Orchard 5Y456</b>			
Stage 1	Phasing change	\$ 4,456	
	Phasing swap	\$ 4,820	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 22,152	
			\$ 49,098
Stage 2	600 kVAR switched capacitor addition	\$ 23,154	
	1,023 feet reconductoring	\$ 52,550	
			\$ 75,704
Stage 3	Install metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 33,488	\$ 142,321

SECTION 4

Circuit	Action	Cost	Total Stage Cost
<b>Orchard 5Y498</b>			
Stage 1	Transformer change out, tap changes and service change outs	\$ 26,832	
	Metering	\$ 17,670	
			\$ 44,502
Stage 2	900 kVAR switched capacitor addition	\$ 20,997	
			\$ 20,997
Stage 3	Install metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 56,004	
			\$ 164,837
<b>Wiley 5Y434</b>			
Stage 1	600 kVAR fixed capacitor addition	\$ 7,287	
	300 kVAR fixed capacitor addition	\$ 10,292	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 65,000	
			\$ 100,248
Stage 2	600 kVAR switched capacitor addition	\$ 23,154	
			\$ 23,154
Stage 3	Install metering package	\$ 214,114	
	Transformer change out, tap changes and service change outs	\$ 65,000	
			\$ 279,114
<b>Nob Hill 5Y197</b>			
Stage 1	Transformer change out, tap changes and service change outs	\$ 6,240	
	Metering	\$ 17,670	
			\$ 23,910
Stage 2	900 kVAR switched capacitor addition	\$ 23,154	
			\$ 23,154
Stage 3	Install metering package	\$ 73,739	
	Transformer change out, tap changes and service change outs	\$ 33,488	
			\$ 107,227
<b>Nob Hill 5Y194</b>			
Stage 1	Metering	\$ 17,670	
	Install 3 fixed capacitor banks (300, 600 & 1200 kVAR)	\$ 26,194	
	Transformer change out, tap changes and service change outs	\$ 51,584	
			\$ 95,448
Stage 2	Install 3 switched Capacitor banks (300, 600 & 1200 kVAR)	\$ 70,706	
	Credit for fixed capacitors from Stage 1	\$ (26,194)	
	313 feet reconductoring	\$ 24,790	
	119 feet reconductoring	\$ 13,190	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (49,504)	
			\$ 32,988
Stage 3	Install metering package	\$ 73,739	
	Transformer change out, tap changes and service change outs	\$ 94,848	
			\$ 168,587

Circuit	Action	Cost	Total Stage Cost
<b>Nob Hill 5Y273</b>			
Stage 1	Phasing swaps	\$ 2,280	
	600 kVAR capacitor removal	\$ 2,600	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 105,508	\$ 128,058
Stage 2	600 kVAR switched capacitor addition	\$ 46,308	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (67,340)	\$ (21,032)
Stage 3	Install metering package	\$ 73,739	
	Transformer change out, tap changes and service change outs	\$ 60,840	\$ 134,579
<b>North Park 5Y356</b>			
Stage 1	Remove 900 kVAR capacitor	\$ 2,600	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 146,016	\$ 166,286
Stage 2	900 kVAR switched capacitor addition	\$ 20,997	
	607 feet reconductoring	\$ 67,282	
	Voltage regulator addition	\$ 72,594	
	Metering	\$ 25,540	
	Credit for fewer transformer change out, tap changes and service change outs	\$ (121,264)	\$ 65,149
Stage 3	Install metering package	\$ 221,029	
	Transformer change out, tap changes and service change outs	\$ 69,836	\$ 290,865
<b>River Road 5Y444</b>			
Stage 1	Swap phasing	\$ 6,840	
	Reduce capacitor size 1200 kVAR to 600 kVAR	\$ 9,350	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 51,584	\$ 85,444
Stage 2	Addition of two 600 kVAR switched capacitors	\$ 46,308	
	668 feet of reconductoring	\$ 34,314	
	Voltage regulator addition	\$ 72,594	
	Metering	\$ 25,540	\$ 178,757
Stage 3	Install metering package	\$ 221,029	
	Transformer change out, tap changes and service change outs	\$ 67,340	\$ 288,369

**SECTION 4**

<b>Circuit</b>	<b>Action</b>	<b>Cost</b>	<b>Total Stage Cost</b>
<b>Sunnyside 5Y313</b>			
Stage 1	Reduce capacitors from 1200 KVAR to 900 kVAR	\$ 9,350	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 33,488	
			\$ 60,508
Stage 2	600 kVAR switched capacitor addition	\$ 23,154	
	300 kVAR switched capacitor addition	\$ 14,647	
			\$ 37,801
Stage 3	Install metering package	\$ 108,833	
	Transformer change out, tap changes and service change outs	\$ 33,748	
			\$ 142,581
<b>Sunnyside 5Y317</b>			
Stage 1	Phase swapping	\$ 4,200	
	Three phase swap	\$ 4,820	
	Metering	\$ 17,670	
			\$ 26,690
Stage 2	600 kVAR switched capacitor installation	\$ 23,154	
			\$ 23,154
Stage 3	Install metering package	\$ 115,748	
	Transformer change out, tap changes and service change outs	\$ 38,168	
			\$ 153,916
<b>Grandview 5Y351</b>			
Stage 1	Phase swapping	\$ 4,820	
	Change 600 kVAR capacitor to 300 kVAR	\$ 9,350	
	Metering	\$ 17,670	
	Transformer change out, tap changes and service change outs	\$ 22,412	
			\$ 54,252
Stage 2	Add two 600 kVAR switched capacitors	\$ 46,308	
	Voltage Regulator addition	\$ 63,842	
	Metering	\$ 25,540	
	Transformer change out, tap changes and service change outs	\$ 31,408	
			\$ 167,097
Stage 3	Install metering package	\$ 214,114	
	Transformer change out, tap changes and service change outs	\$ 33,748	
			\$ 247,862
<b>Total</b>			<b>\$ 6,518,727</b>

---

## SECTION 5 – REFERENCES

1. *ANSI Electrical Power Systems and Equipment – Voltage Ratings (60Hz)*, ANSI Standard C84.1-1995, August 1995.
2. T. Gönen, *Electric Power Distribution System Engineering*, McGraw-Hill, New York, 1986.
3. D.G. Newnan, T.G. Eschenbach, J.P. Lavelle, *Engineering Economic Analysis, Ninth Edition*, Oxford University Press, Inc., New York, 2004.
4. *IEEE Distribution System Practices for Industrial Plants*, IEEE Standard 141-1993, Red Book, August 1993.
5. IEEE Tutorial Course “Engineering Economic Analysis: Overview and Current Applications 1991,” *IEEE Trans. 91 EHO 345-9-PWR*, IEEE Service Center 445 Hoes Lane, P.O.Box1331, Piscataway, NJ 08855-1331.
6. W.H. Kersting, *Distribution System Modeling and Analysis*, CRC Press LLC, New York, 2002.
7. S. Mandal, A. Pahwa, “Optimal Selection of Conductors for Distribution Feeders,” *IEEE Trans. Power Systems*, vol. 17, issue 1, February 2002, pp 192-197.
8. *National Electrical Code 2005*, ANSI/NFPA 70-2005 Standard, National Fire Protection Association, Quincy, MA.
9. NWPCC ProCost model used for development of the *wholesale power price forecast* for the 6<sup>th</sup> Power Plan “DEI ProCost RTF Template 257e-V2\_with measure table\_USEME\_VO\_20100706-cg-2” and companion 6<sup>th</sup> Power Plan Mid C Load Shapes “MC\_AND\_LOADSHAPE\_6P\_USEME.”
10. Simplified Voltage Optimization (VO) Measurement and Verification Protocol, May 4, 2010. [http://www.nwcouncil.org/energy/rtf/measures/protocols/ut/VoltageOptimizationProtocol\\_v1.pdf](http://www.nwcouncil.org/energy/rtf/measures/protocols/ut/VoltageOptimizationProtocol_v1.pdf)
11. T.A. Short, *Electric Power Distribution Handbook*, CRC Press, New York, 1997.
12. *BPA Energy Efficiency Implementation Manual*, October 2010.
13. [www.bpa.gov/energy/n/pdf/FINAL\\_October\\_2010\\_Implementation\\_Manua\\_REV\\_2l.pdf](http://www.bpa.gov/energy/n/pdf/FINAL_October_2010_Implementation_Manua_REV_2l.pdf)
14. R.H. Fletcher, and K. Strunz, “Optimal Distribution System Horizon Planning Part I Formation, and Part II Application,” *IEEE Trans. Power Systems Journal*, Vol. 5, May 2007.
15. Department of Energy, Distribution Transformers Rulemaking, Liquid-immersed Engineering Analysis Results; September 2007.
16. [http://www1.eere.energy.gov/buildings/appliance\\_standards/commercial/distribution\\_transformers\\_finalrule.html](http://www1.eere.energy.gov/buildings/appliance_standards/commercial/distribution_transformers_finalrule.html)

**Appendix 1: Washington State Rules and Regulations and  
Utility Distribution System Efficiency Measures**



Washington State Rules and Regulations  
And  
Utility Distribution System Efficiency Measures

Prepared by R. H. Fletcher, PhD, P.E.  
Utility Planning Solutions, PLLC  
January 20, 2011

Washington State voters passed Initiative 937 on Nov. 7, 2006. This initiative imposes targets for energy conservation and use of eligible renewable resources on the state's electric utilities that serve more than 25,000 customers. Specifically, these utilities, both public and investor owned, must secure 15 percent of their power supply from renewable resources by 2020. Initiative 937, also called the Washington Energy Independence Act (WEIA) was codified at RCW Title 19 Chapter 285.

Beginning Jan. 1, 2010, the WEIA requires utilities with 25,000 customers or more to acquire all conservation that is cost-effective, reliable and feasible as stated in the Energy Financing Voter Approval Act, RCW 80.52.030. Each utility is required to set an annual target which may be based on their integrated resource plan or a proportion of their regional share of achievable cost-effective conservation potential. Conservation can include increases in the efficiency of energy use, production, or distribution. Each utility must pursue all available cost-effective, reliable, and feasible conservation consistent with methodologies used by the Pacific Northwest Electric Power and Conservation Planning Council in its most recently published regional power plan.

Investor Owned Electric companies in Washington State are regulated in accordance with Washington Administrative Code, WAC, Title 480 Chapter 109 regarding acquisition of minimum quantities of conservation and renewable energy and describes implementation requirements to comply with RCW 19.285. There is no mention of "distribution system efficiency" conservation measures, however, RCW 480.109.007 does provide definitions for the "Conservation Council" which is defined as the Northwest Electric Power and Conservation Council which implies Council approved measures are acceptable. The WAC Title 194 Chapter 37 was created for Public Owned electric utilities and describes implementation requirements for energy independence and can be used as a guide for Investor Owned Electric companies as well.

WAC 194.37.090 provides additional documentation of efficiency from distribution system loss reduction improvements, including peak demand management and voltage regulation not specific address in RCW 480.109. For example, WAC 194.37.060-090 defines acceptable conservation measures or programs if they meet NWPC (Council) measures or programs in its power plan which is based on methodologies and protocols established by the Regional Technical Forum. In Section 194.37.090 (2)(a)(i...iv) documentation requirements for distribution system improvements are as follows

(i) For distribution system upgrades, the utility will prepare a distribution flow analysis to compare the annual energy losses of the system being replaced or upgraded to the final system as installed.

(ii) For conservation voltage regulation, the utility will prepare a distribution flow analysis to compare the annual energy losses of the system before and after the implementation of a voltage regulation program. The difference in annual kilowatt-hour requirement at the utility point(s) of

receipt (for distribution utilities) or net energy for load for generating utilities may be counted as conservation savings.

(iii) For peak demand management, the utility will prepare a distribution flow analysis to compare the annual energy losses of the system before and after implementation of the peak demand management program. The change in net energy losses may be counted as conservation savings. Any net reduction in energy sales (economic curtailment) shall not be included in conservation savings.

(iv) The distribution flow analysis conducted for (b)(i), (ii), or (iii) of this subsection shall be prepared under the direction of, and carry the stamp of a registered professional electrical engineer licensed by the Washington department of licensing.

The Pacific Northwest Electric Power Planning and Conservation Act, P.L. 96-501, 16 U.S.C. 839 et seq. in Section 4 authorizes the Pacific Northwest Electric Power and Conservation Planning Council to “. . . establish such other voluntary advisory committees as it determines are necessary or appropriate to assist it in carrying out its functions and responsibilities . . .”. The Regional Technical Forum committee (RTF) was created in 1999 in this regard.

The four goals adopted by the Council for the Regional Technical Forum committee (RTF) corresponding to its original charge from Congress and the Comprehensive Review are to:

1. Develop standardized protocols for verification and evaluation of energy savings and the performance of renewable resources.
2. Track regional progress toward the achievement of the region's conservation and renewable resource goals.
3. Provide feedback and suggestions for improving the effectiveness of the conservation and renewable resource development programs and activities in the region.
4. Conduct periodic reviews of the region's progress toward meeting its conservation and renewable resource goals at least every 5 years, acknowledging changes in the market for energy services and the potential availability of cost-effective conservation opportunities.

The distribution system conservation savings assessment used in the NWPCC 6<sup>th</sup> Power Plan was based on the estimates from measured data on 33 utility feeders, and analytical methods developed in a NEEA Distribution Efficiency Initiative study initiated in 2001 and completed in December 2007. The study was prepared by R.W. Beck, Inc. in association with five subcontractors and guided by the NEEA Technical Advisory Committee made up of NW electric utilities. The Council's 6<sup>th</sup> Power Plan estimate potential of distribution efficiency savings is 400 Mwa by 2029 (7% of the total regional sector savings) as reported in Table E-1 “Estimated Cost-Effective Conservation Potential in Average Megawatts 2010-2014 and 2010 – 2029” of NWPCC 6<sup>th</sup> Power Plan Appendix E.

Costs and savings for four major distribution system measures in the 6<sup>th</sup> Power Plan were identified and applied to a descriptive data set of the region's distribution system. The measures are: Reduced System Voltage (LDC, Light System Improvements (capacitors and load balancing), Major System Improvements (reconductor, rephrasing, and regulators), and Enhanced Voltage Control (end-of-line feedback). The dataset contains system loads by customer class and load patterns, substation counts, feeder counts, customer counts, and climate zones for 137 regional utilities used to generate the units estimates.

To simplify the determination of distribution efficiency savings from voltage reduction and to encourage acceptance and adoption of distribution system efficiency, BPA worked with a newly formed Energy Smart Utility Efficiency Technical Workgroup in 2009 and 2010 to develop a simplified measurement and verification protocol. The NWPCC and RTF adopted this new voltage reduction and distribution system efficiency methodology titled “Simplified Voltage Optimization (VO) Measurement and Verification Protocol” approved on May 4<sup>th</sup>, 2010. [http://www.nwcouncil.org/energy/rtf/measures/protocols/ut/VoltageOptimization\\_Protocol\\_v1.pdf](http://www.nwcouncil.org/energy/rtf/measures/protocols/ut/VoltageOptimization_Protocol_v1.pdf)

The Simplified Voltage Optimization (VO) Measurement and Verification (M&V) Protocol provides a basic approach to determine end-use energy savings when operating the electric distribution system more efficiently and within the lower band of the ANSI Standard voltage level and is consistent with WAC 194.37.090 reporting requirements. The protocol covers utility electric distribution systems serving mostly residential and light commercial load as defined by the utility. System loads do not need to be uniformly distributed throughout the distribution system.

The VO Protocol identifies the procedure to determine the average annual voltage for a distribution primary system with source voltage regulation. Minimum system stability thresholds (e.g., max voltage drops, min power factors, max phase unbalance, etc.), system data requirements, and measurement and verification formulations are included as part of this Protocol. To meet the minimum thresholds, utilities generally achieve distribution efficiency and the ability to lower the customer’s average voltage. The Protocol defines a VO factor that is used to estimate the end-use energy savings from reduced voltage and is based on the NEEA DEI Study. BPA has successfully applied this protocol to many NW electric utilities.

The CVR factor was used for the past 30 years to define the relationship between either annual demand or energy at the source of a distribution feeder and the average change in voltage at the source. The CVR factor includes the savings from system no load loss savings and end use savings and was derived via length field tests. Based on the NEEA DEI Study work and the “Simplified Voltage Optimization (VO) Measurement and Verification Protocol” approved on May 4<sup>th</sup>, 2010 by the RTF, a new industry voltage and energy savings factor has been developed to better represent the change in energy use at the end-use customer. The end-use VO Factor is a ratio of expected % change in energy delivered for each 1% change in average voltage supplied at the end-use service entrance.

The end-use VO Factor is given as a p.u. ratio for a given system and is determined from VO Factor Tables in Appendix A of the Protocol. The VO factor does not include savings from line or no-load loss savings. The no-load loss savings can be easily determined knowing the distribution transformer total connected kVA. The line loss savings can be determined using accurate distribution load flow models to simulate line losses before and after system improvements. The CVR factor has been replaced with the VO factor.

To determine the VO factor, you must enter the table identified for the Heating and cooling climate zone associated for each substation and select the appropriate VO Factor using the percent customers with Non-Electric Heating (and Heat Pumps) and percent of customers with Air-conditioning. The protocol further discusses the formulation to calculate the average voltage change on the feeder and is used with the VO factor to yield the total change in energy at the

end-use customer. The line loss savings and no-load (core) distribution transformer loss savings are calculated separately from the VO savings.

### Background Information Regarding the NWPCC 6<sup>th</sup> Power Plan

The Council uses its portfolio model to determine how much conservation is cost-effective to develop. The Pacific Northwest Electric Power Planning and Conservation Act defines regional cost-effectiveness as follows: "Cost-effective", when applied to any measure or resource referred to in this chapter, means that such measure or resource must be forecast to be reliable and available within the time it is needed, and to meet or reduce the electric power demand, as determined by the Council or the Administrator, as appropriate, of the consumers of the customers at an estimated incremental system cost no greater than that of the least-cost similarly reliable and available alternative measure or resource, or any combination thereof.

Under the Act the term "system cost" means an estimate of all direct costs of a measure or resource over its effective life, including, if applicable, the cost of distribution and transmission to the consumer and such quantifiable environmental costs and benefits as are directly attributable to such measure or resource. The Council has interpreted the Act's provisions to mean that in order for a conservation measure to be cost-effective the discounted present value of all of the measure's benefits should be compared to the present value of all of its costs. The NWPCC 6<sup>th</sup> Power Plan describes the conservation supply curves development in Appendix E of the 6<sup>th</sup> Power Plan. The NW annual distribution efficiency savings load factor is 0.558.

[http://www.nwcouncil.org/energy/powerplan/6/final/SixthPowerPlan\\_Appendices.pdf](http://www.nwcouncil.org/energy/powerplan/6/final/SixthPowerPlan_Appendices.pdf)

The estimated savings potential for distribution system efficiency in the northwest is given in Table E-1 "Estimated Cost-Effective Conservation Potential in Average Megawatts 2010-2014 and 2010 – 2029" of NWPCC 6<sup>th</sup> Power Plan Appendix E as follows:

Distribution Sector	MWa by 2014	MWa by 2029	
Reduced system voltage	47	160	Reduce system voltage w/LDC voltage control method
Light system improvements	8	80	VAR management, phase load balancing, and feeder load balancing
Major system improvements	9	90	Voltage regulators on 1 of 4 substations
Voltage control	4	40	End of Line (EOL) voltage control method
Unique system improvements	5	30	Seattle City Light system implements EOL w/ major system improvements
All Distribution Efficiency Measures	72	400	
<b>Total for All Sectors</b>	<b>1308</b>	<b>5740</b>	
	5.5%	7.0%	

# Appendix 2: Secondary System Voltage Drop Considerations

## Secondary System Voltage Drop Considerations

R.H. Fletcher, PhD, P.E.

Utility Planning Solutions, PLLC

April 22, 2011 (v8)

Generally, most secondary systems are radial-designed except for specific service areas (downtown areas, business districts, and some military and hospital installations) where reliability considerations are far more important than cost and economic considerations. The secondary radial systems include distribution transformers, secondary main conductors, and service conductors. The secondary facilities can be overhead or underground. The secondary design (size of transformer, secondary conductor, and services) objective is to minimize costs while still meeting the Utility's standard guidelines.

The goal for each secondary design is to provide satisfactory performance for voltage-drop (i.e., less than 5%) at minimum costs. There is a variety of system designs for one distribution transformer; some serve only one customer having only one span of conductor, while others serve six to 10 customers with multiple secondary connections. In the practice some voltage-drops maximums exceed design objectives (i.e. greater than 5%). The following provides a methodology describing how to estimate the number of potential secondary connections that many have voltage drops greater than any design guideline (i.e., greater than 4%). This information will help determine the impact of lowering the distribution voltage.

The ANSI C84.1 defines the maximum and minimum voltage favorable zone for service entrance voltage. In addition, the voltage level for a tolerable zone is provided. The favorable zone includes the majority of the existing operating voltages, and the voltages within this zone (i.e. Range A) provide satisfactory operation of the customer's equipment. PacifiCorp, in Section 3.3.1.1 Service Voltage of its Planning Standards for Voltage, states: "PacifiCorp's supply systems are to be designed and operated so that most service voltage levels are within the limits specified for Range A. The occurrence of service voltage outside of these limits is to be infrequent." This is consistent with how most electric utilities plan and operate their electric systems.

### Customer Coincident Loading - Considerations

The utility voltage guidelines are applied to a large range of customer connection possibilities. As more customers are served by one transformer, the individual customer maximum loading coincident with the system load becomes less. Utilities periodically evaluate customer coincident loading patterns by conducting sample Load Surveys. Customer loading patterns can vary greatly between utilities depending on the climate zone, saturation electric heat and air-conditioning, and number of customers connected to a secondary system. For an example, see the load data example below.

No of customers being served from one transformer	$CF$	30 min annual maximum diversified demands kVA per customer		
		Class 1	Class 2	Class 3
1	1.0000	18.0	10	2.5
2	0.7500	13.5	7.5	1.9
4	0.6250	11.3	6.3	1.6
12	0.5416	9.7	5.4	1.4

Reference Turan Gönen, “Electric Power Distribution System Engineering” Dec 2007

As the number of customers served by a transformer or secondary conductor increases, the effective load impact on capacity requirement is decreased. The duration of sustained peak can also vary among utilities. The coincident factor (CF) is determined at each level of the distribution system and is a function of the total system coincidence and the number of similar loads. The average maximum diversified demand (AMDD) for any level is determined by multiplying the average maximum demand (AMD) for customers or components by  $CF$ . The coincident factor formulation used to determine the impact of customer or component loads on the next higher level in the distribution system where  $N$  is the number of parallel components given below. A typical formulation assumes that the total system coincidence is  $CF_{TOTAL} = 0.50$  “IEEE Standard 141(TM)-1993, *IEEE Recommended Practice for Electric Power Distribution for Industrial Plants*, Red Book.”

$$CF_N = CF_{TOTAL} \cdot \left[ 1 + \frac{1}{N} \right] \quad \text{Eq 1}$$


The typical distribution secondary system design voltage drop across the secondary system is highest during customer peak loading periods. If distribution system modeling includes secondary modeling, the voltage drop is the absolute difference between the voltage magnitude on the high side of the distribution transformer minus the voltage at the lowest voltage customer. It is not the arithmetic sum of the transformer voltage drop and the secondary conductor voltage drop. The voltage drop determination requires the use of coincident factors applied at each level of system equipment to determine the maximum diversified voltage drop.

It is very unlikely that the transformer’s customer coincident peak load will be sustained for 30 minutes or longer and occur at the same time as the system peak primary voltage. Customers have peak demand at different times, and this is why capacity and voltage drops are calculated by taking coincidence factors into account. Coincident factors and typical customer load patterns are typically obtained from residential load surveys.

### Secondary Voltage Drop Normal Distribution - Example

As shown, the determination of expected voltage drops for the secondary systems involves a variety of random variables (i.e., number of customer connected to one transformer, common service connections, maximum non diversified customer loads, coincidence probabilities, and physical design attributes.) These variables suggest a random distribution of coincidental secondary voltage drops. For example, given maximum voltage drop constraint of 5% or 6 Volts, the diversified average voltage drop across a large number of transformer populations may be only 2.5% while the maximum voltage drop observed may be greater than 5%.

The following is a real world example of secondary voltage drops on one feeder for a distribution Blackman Hurst feeder in Jackson, MI. Coincidental hourly peak load data for the secondary systems was collected from customer AMR data and assigned to end-use nodes on a distribution feeder model. The peak hourly voltage drops for customers on the secondary system across the feeder illustrates the random nature of the secondary system peak voltage drops during peak load conditions. Load Flow simulations were performed and included the modeling of distribution transformers, secondary conductors, service conductors, and spot coincident customer loads. There are 727 customers served by 418 distribution transformers/secondary systems. The peak hourly load flow analysis included determination of the secondary system voltage drop. Figure 1 shows the probability distribution for transformer/secondary voltage drops during peak conditions as determined from the load flow simulations. The mean secondary voltage drop at peak hourly conditions is 1.9% (2.3V) with a Std. Dev. of 2.2%. There are 33 (7.9%) transformer/secondary systems that have voltage drops greater than 5.0% (6.0V). There are 42 (10.0%) transformers with voltage drops greater than 4.2% (5.0V) needed to maintain 114V service voltage if the primary voltage is 119V. The maximum voltage drop is 15.0% or 18.0V.




**Figure 1 - Distribution transformer/secondary max voltage drops**



The secondary systems seen in this example are heavily loaded with an average distribution transformer utilization of 220% of rated kVA at peak load conditions. This example illustrates poorly managed and designed secondary systems. The secondary voltage drop probability distribution will vary among utilities depending on their secondary design practices.

In addition to evaluating maximum secondary voltage drops for the example feeder, the load flow assessment also determined the secondary low voltages during peak load conditions. The minimum primary voltage is 119.8 Volts. There are 24 transformer/secondary installations that have customer service voltages less than 114V at peak loading conditions. Figure 2 shows a scatter diagram that illustrates the number of transformer/secondary systems that are below 114V. The average is service voltage is 118.8V. The minimum voltage is 103.0V during peak conditions. These customer low voltages are included as part of the 33 secondary systems having greater than 5% voltage drop at peak conditions.



**Figure 2 - Lowest service voltage for each distribution transformer/secondary**

The example feeder illustrates the random nature of secondary system voltage performance during peak load conditions and that it closely resembles a Normal Distribution.

#### Normal Distribution Probability Function – Basics

The Normal Distribution function is defined as

$$f(X) = \frac{1}{\sigma \cdot \sqrt{2\pi}} \cdot e^{-\frac{1}{2} \left( \frac{x-\sigma}{\sigma} \right)^2}$$

Where,

$\sigma$  = Std Dev and  $x$  = variable.

Given  $\sigma$ , the plot of  $f(X)$  is a bell shaped curve similar to the curve shown in Figure 1. The total area under the curve represents 100% probability. The probability of an event occurring between

$X_1$  and  $X_2$  is the area under the Normal Distribution curve from  $X_1$  and  $X_2$  given  $\sigma$ . The values of  $X$  can be converted to a Z Score which is the number of  $\sigma$  separation from the Mean  $\bar{X}$ . The Normal Distribution function is symmetrical allowing the calculation of probability by using the Z Score Table 1. The probability for the positive half of the distribution function where the  $\bar{X}$  is zero is 0.50 or 50%. The probability of having a value of  $X < 1.88 \sigma$  is  $0.5000 + 0.4699 = 0.9699$  or 97.0%. The probability of having  $X > 1.88 \sigma$  is 3.0%.

### Secondary Voltage Drop Normal Distribution –Feeder Example

Consider a feeder with 1000 customers served from 150 transformers (6.7 customers per transformer) with 120 Volts on the high-side of each distribution transformer. The distribution system is better designed, monitored, and maintained than the example given above. This feeder example shows the probability of the number of customers (or transformers) that are likely to have voltage drops greater than 5Volt (4.167%) when the primary voltage is lowered by 1 Volt from 121V to 120V. It is assumed for secondary systems that there are few customers with maximum secondary voltages drops greater than the 5% or 6 Volts limit. Customers who exceed 5% are assumed to have lower than 114 Volts at their service.

Although it is unlikely that there are any customers with greater than 5% voltage drop, it is assumed here that **3%** or 30 customers (4.5 transformers) have maximum voltages greater than 5% limit. The average maximum voltage drop is assumed to be **2.5%** based on the field experience example give above. The value of Z that yields 97% probability or  $0.5000 + 0.4700$  is  $Z=1.88$ . If  $\bar{X}=2.5\%$  and upper limit is  $X_1=5.0\%$ , then  $\sigma = (X_1 - \bar{X}) / Z = \mathbf{1.335\%}$ .

Given the assumptions above, if the design limit is reduced to 4.167% or **5 Volts**, the probability of customers having maximum voltage drops greater than the 4.167% limit is determined with  $\sigma = 1.335\%$ ,  $\bar{X}=2.5\%$ , and upper limit  $X_2=4.167\%$ , then  $Z = [(X_2 - \bar{X}) / \sigma] = 1.25$ . Entering this value into the Z Score Table yields a probability of  $0.5000+0.3944$  or 89.44% of customer with less than 4.167% voltage drop. The number of customers having greater than 4.167% voltage drop is  $100\% - 89.4\%$  or 10.6%. Therefore, the number of customers having greater than 4.167% voltage drop is 106 (or 15.9 transformers).

The true impact is much less than 15.9 transformer secondary systems having service voltages less than 114V because not all of the high-side transformer voltages are at 119 Volts. The number of transformers impacted can therefore be assumed to be 50% or 8 transformers.




Given the assumptions above, if the design limit is reduced to 119.0V, the maximum secondary voltage drop 3.33% or **4 Volts**. The probability of customers having maximum voltage drops greater than the 3.33% limit is determined with  $\sigma = 1.335\%$ ,  $\bar{X}=2.5\%$ , and upper limit  $X_2=3.333\%$ , then  $Z = [(X_2 - \bar{X}) / \sigma] = 0.62$ . Entering this value into the Z Score Table yields a probability of  $0.5000+0.2324$  or 73.24% of customer with less than 3.33% voltage drop. The number of customers having greater than 3.33% voltage drop is  $100\% - 73.24\%$  or 26.8%.

Table 1 - Normal Distribution Z Score

Probability Area from central to Z Score (Z = # of Std. Dev. mean)										
Z	0.00	0.01	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09
0.0	0.0000	0.0040	0.0080	0.0120	0.0160	0.0199	0.0239	0.0279	0.0319	0.0359
0.1	0.0398	0.0438	0.0478	0.0517	0.0557	0.0596	0.0636	0.0675	0.0714	0.0753
0.2	0.0793	0.0832	0.0871	0.0910	0.0948	0.0987	0.1026	0.1064	0.1103	0.1141
0.3	0.1179	0.1217	0.1255	0.1293	0.1331	0.1368	0.1406	0.1443	0.1480	0.1517
0.4	0.1554	0.1591	0.1628	0.1664	0.1700	0.1736	0.1772	0.1808	0.1844	0.1879
0.5	0.1915	0.1950	0.1985	0.2019	0.2054	0.2088	0.2123	0.2157	0.2190	0.2224
0.6	0.2257	0.2291	0.2324	0.2357	0.2389	0.2422	0.2454	0.2486	0.2517	0.2549
0.7	0.2580	0.2611	0.2642	0.2673	0.2704	0.2734	0.2764	0.2794	0.2823	0.2852
0.8	0.2881	0.2910	0.2939	0.2967	0.2995	0.3023	0.3051	0.3078	0.3106	0.3133
0.9	0.3159	0.3186	0.3212	0.3238	0.3264	0.3289	0.3315	0.3340	0.3365	0.3389
1.0	0.3413	0.3438	0.3461	0.3485	0.3508	0.3531	0.3554	0.3577	0.3599	0.3621
1.1	0.3643	0.3665	0.3686	0.3708	0.3729	0.3749	0.3770	0.3790	0.3810	0.3830
1.2	0.3849	0.3869	0.3888	0.3907	0.3925	0.3944	0.3962	0.3980	0.3997	0.4015
1.3	0.4032	0.4049	0.4066	0.4082	0.4099	0.4115	0.4131	0.4147	0.4162	0.4177
1.4	0.4192	0.4207	0.4222	0.4236	0.4251	0.4265	0.4279	0.4292	0.4306	0.4319
1.5	0.4332	0.4345	0.4357	0.4370	0.4382	0.4394	0.4406	0.4418	0.4429	0.4441
1.6	0.4452	0.4463	0.4474	0.4484	0.4495	0.4505	0.4515	0.4525	0.4535	0.4545
1.7	0.4554	0.4564	0.4573	0.4582	0.4591	0.4599	0.4608	0.4616	0.4625	0.4633
1.8	0.4641	0.4649	0.4656	0.4664	0.4671	0.4678	0.4686	0.4693	0.4699	0.4706
1.9	0.4713	0.4719	0.4726	0.4732	0.4738	0.4744	0.4750	0.4756	0.4761	0.4767
2.0	0.4772	0.4778	0.4783	0.4788	0.4793	0.4798	0.4803	0.4808	0.4812	0.4817
2.1	0.4821	0.4826	0.4830	0.4834	0.4838	0.4842	0.4846	0.4850	0.4854	0.4857
2.2	0.4861	0.4864	0.4868	0.4871	0.4875	0.4878	0.4881	0.4884	0.4887	0.4890
2.3	0.4893	0.4896	0.4898	0.4901	0.4904	0.4906	0.4909	0.4911	0.4913	0.4916
2.4	0.4918	0.4920	0.4922	0.4925	0.4927	0.4929	0.4931	0.4932	0.4934	0.4936
2.5	0.4938	0.4940	0.4941	0.4943	0.4945	0.4946	0.4948	0.4949	0.4951	0.4952
2.6	0.4953	0.4955	0.4956	0.4957	0.4959	0.4960	0.4961	0.4962	0.4963	0.4964
2.7	0.4965	0.4966	0.4967	0.4968	0.4969	0.4970	0.4971	0.4972	0.4973	0.4974
2.8	0.4974	0.4975	0.4976	0.4977	0.4977	0.4978	0.4979	0.4979	0.4980	0.4981
2.9	0.4981	0.4982	0.4982	0.4983	0.4984	0.4984	0.4985	0.4985	0.4986	0.4986
3.0	0.4987	0.4987	0.4987	0.4988	0.4988	0.4989	0.4989	0.4989	0.4990	0.4990

# Appendix 3: Histograms

Bowman Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009






5W150	238310	49.23%
5W154	24580.5	50.77%
	<u>48411.5</u>	

5W150	Q05	(1,575)	(856)
5W154	Q05	(1,625)	(2,027)
		<u>(3,200)</u>	<u>(2,883)</u>
	Adj	4800	1,917
			<u>5,850</u>

5W150	P05	2,433	(856)
5W154	P05	2,510	(2,027)
		<u>4,943</u>	
	Light Load Model		
			<u>12,306</u>

	P95	6,058	
		<u>6,248</u>	
	Winter Peak	8,720	9,280

Clinton Area Load Models Based On  
Transformer Hourly Data and Annual Histograms for 2009



5Y608	22603.5	52.97%
5Y610	20066.0	47.03%
	<u>42669.5</u>	


Connected kVA	
5Y608	(68)
5Y610	(262)
	<u>(330)</u>
	3600
	<u>3,270</u>

Heavy Load Model	
Summer Peak Model	
Q05	Q95
5Y608	8,200
5Y610	9,250
	<u>2,063</u>
	3600
	<u>5,663</u>


Light Load Model	
P05	Q05
5Y608	3,050
5Y610	2,707
	<u>5,757</u>
	12,911
	<u>12,911</u>

Winter Peak	
P95	10,400
	<u>8,400</u>


Dodd Road Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009



4W22  
Connected kVA  
29034.5  
100.00%




4W22  
Q05 855  
Summer Peak Model 8,700 3,552  
Heavy Load Model Q95



4W22  
Light Load Model P05 6,236 Q05 855  
P95 16,907  
Winter Peak 9,000


Grandview Area Load Models Based On  
Transformer Hourly Data and Annual Histograms for 2009

Grandview T859 Hourly Data




5Y351	19929.8	43.94%
5Y302	25422.5	56.06%
	45352.3	

Grandview T859 MVAR Histogram



5Y351	Q05	Summer Peak Model	Q95
	(367)	7700	996
5Y302	(468)	7440	1,271
	(834)		2,267


Grandview T859 MW Histogram




5Y351	P05	Light Load Model	P95	Winter Peak
	2,171	(367)	5,806	8,900
5Y302	2,770	(468)	7,406	10,640
	4,941		13,211	




Mill Creek Area Load Models Based On  
Transformer Hourly Data and Annual Histograms for 2009




Connected kVA	
5W116	177260
5W127	151050
	<u>328310</u>
	53.99%
	46.01%




Heavy Load Model	
Summer Peak Model	
Q05	60
Q95	1,068
5W116	8,100
5W127	6,220
	<u>1,421</u>
	2,489
	600
	<u>1,222</u>
	3,089




Light Load Model	
P05	2,148
Q05	60
5W116	1,830
5W127	<u>3,978</u>
	562
	11,203
	<u>6,049</u>
	7,750
	<u>7,120</u>




	Connected kVA	
5Y197	12613.5	26.07%
5Y272	14398.0	29.75%
5Y338	21380.5	44.18%
	48392.0	




	Q05	Adj. Q05	Heavy Load Model Sum Pk	Q95
5Y197	(1,599)	397	5,900	1,130
5Y272	(1,826)	(147)	5,500	690
5Y338	(2,711)	73	7,750	1,315
	(6,136)	323	3,135	1,200
		1,523	4,335	




	P05	Light Load Model Q05	Q95	Winter Peak
5Y197	1,625	397	4,407	7,000
5Y272	1,855	(147)	5,030	8,400
5Y338	2,755	73	7,470	8,700
	6,236		16,907	



	Connected kVA	
5Y194	19095.5	43.46%
5Y195	8463.0	19.26%
5Y273	16377.52	37.28%
	43936.0	




	Q05	Summer Peak Model Q05	Q95
5Y194	(263)	8200	1,529
5Y195	(451)	3,920	343
5Y273	(911)	8080	626
	(1,624)	2,497	
	2400	2400	4,897
	776		




	P05	Light Load Model Q05	Q95	Winter Peak
5Y194	2,710	(263)	7,348	7,400
5Y195	1,201	(451)	3,257	3,560
5Y273	2,324	(911)	6,302	8,120
	6,237		15,436	


North Park Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009



Connected kVA	
5Y356	20180.0
5Y398	29702.51
	<u>49882.5</u>
	40.46%
	59.54%




Q05	(1,433)
5Y356	(1,433)
5Y398	(1,101)
	(2,533)
	<u>2700</u>
	167
Summer Peak Model	Q95
	6,800 (43)
	9,400 945
	903
	<u>2700</u>
	3,603




Light Load Model	P05	Q05
	2,496	(1,433)
	3,674	(1,101)
	<u>6,170</u>	
	5Y356	5,284
	5Y398	7,777
		<u>13,061</u>
		8,900
		<u>10,200</u>
		Winter Peak


Orchard Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009





	Connected kVA	
5Y456	16682.0	27.75%
5Y458	22817.5	37.96%
5Y637	20613.0	34.29%
	60112.5	




	Q05	Q95
5Y456	(327)	772
5Y458	(6)	7,200
5Y637	(453)	7,600
	3,600	3,504
	3,147	3,600
		7,104




	PO5	Q05	Q95	Winter Peak
5Y456	1.837	(327)	4,711	6,700
5Y458	2,512	(6)	6,443	8,800
5Y637	2,270	(121)	5,821	8,440
	6,619		16,975	




	Connected kVA	
5Y498	12638.0	22.98%
5Y454	24210.0	44.02%
5Y639	18148.5	33.00%
	54996.6	



	Q05	Q95
5Y498	188	1,150
5Y454	(841)	9,800
5Y639	269	7,720
	(384)	1,651
	1,200	3,803
	816	1,200
		5,003




	PO5	Q05	Q95	Winter Peak
5Y498	1.446	188	3,944	6,480
5Y454	2,769	(841)	7,555	10,000
5Y639	2,076	269	5,663	7,480
	6,291		17,162	




Pomeroy Area Load Models Based On  
Transformer Hourly Data and Annual Histograms for 2009

Pomeroy T944 MVA% of Winter Histogram



Pomeroy T944 Hourly Data



MVA05	1596	MVA05	4330	Summer Peak	254
5W342		5W342		KW	3,538
				KVAR	

Heavy Load Model		Light Load Model	
Winter Peak Model	6,045 (435)	KW *	1596
		KVAR *	(556)

\* Light Load kW=Winter Load x MVA05  
and KVAR \* at same power factor as Winter Load


$$\text{Caps} = \frac{600}{1596 / 7498} = 0.2640$$

$$\text{Load kVAR LL} = \frac{44}{44} = 1$$


$$\text{Caps} = \frac{(600)}{(556)}$$

Connected kVA	16801.0	100.00%
5W342		


River Road Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009



Connected kVA	44.91%
5Y444	25987.0
5Y446	11730.5
5Y448	20141.0
	<u>57858.5</u>




Q05	Q95
5Y444	(786)
5Y446	(249)
5Y448	(512)
	<u>1,547</u>
	1800
	253
	<u>1,822</u>
	1800
	3,622




Light Load Model	Q05	Q95	Winter Peak
5Y444	3,314	(786)	11,800
5Y446	1,496	(249)	9,900
5Y448	2,568	(512)	8,720
	<u>7,378</u>		
		<u>19,586</u>	


Sunnyside Area Load Models Based On Transformer Hourly Data and Annual Histograms for 2009



	1/1	2/1	3/1	4/1	5/1	6/1	7/1	8/1	9/1	10/1	11/1	12/1
Connected kVA	11258.9	22.01%										
5Y313	9096.5	17.79%										
5Y317	30786.7	60.20%										
5Y314	51142.1											




	Q05	Q95
5Y313	(220)	619
5Y317	(178)	500
5Y314	(601)	2,814
	(998)	




	P05	Q05	P95	Winter Peak
5Y313	1,583	(220)	3,298	5,500
5Y317	1,279	(178)	2,664	4,600
5Y314	4,328	(601)	9,017	11,000
	7,190		14,979	


Wiley Area Load Models Based On  
Transformer Hourly Data and Annual Histograms for 2009



Connected kVA	
5Y434	18624
5Y164	25936
5Y380	34519.49
	<u>79079.5</u>



Heavy Load Model	
Q05	1,044
Sum Pk	7,000
5Y434	1,044
5Y164	(646)
5Y380	(764)
	<u>(365)</u>
	4,800
	4,435
	8,425



Light Load Model	
P05	1,642
Q05	1,044
5Y434	1,642
5Y164	2,286
5Y380	3,043
	<u>6,971</u>
	4,421
	6,157
	8,194
	<u>18,772</u>

Winter Peak	
	7,800
	12,600
	9,600



**Appendix 4: PacifiCorp Cost Estimating Spreadsheet and Crew Cost Information**

Description	UOM	Labor	Material	AFUDC
Primary Re-Conductor Urban 4/0 AAC Medium	feet	\$ 41.09	\$ 41.84	\$ 10.37
Primary Re-Conductor Urban 4/0 AAC Easy	feet	\$ 27.22	\$ 25.65	\$ 6.61
Primary Re-Conductor Urban 4/0 AAC Difficult	feet	\$ 75.27	\$ 81.76	\$ 19.63
Primary Re-Conductor Rural 4/0 AAC Medium	feet	\$ 35.09	\$ 40.80	\$ 9.49
Primary Re-Conductor Rural 4/0 AAC Easy	feet	\$ 20.78	\$ 20.73	\$ 5.19
Primary Re-Conductor Rural 4/0 AAC Difficult	feet	\$ 64.59	\$ 78.31	\$ 17.86
Primary Re-Conductor Urban 477 AAC Medium	feet	\$ 44.24	\$ 45.33	\$ 11.20
Primary Re-Conductor Urban 477 AAC Easy	feet	\$ 28.73	\$ 28.89	\$ 7.20
Primary Re-Conductor Urban 477 AAC Difficult	feet	\$ 79.60	\$ 86.54	\$ 20.77
Primary Re-Conductor Rural 477 AAC Medium	feet	\$ 38.08	\$ 44.06	\$ 10.27
Primary Re-Conductor Rural 477 AAC Easy	feet	\$ 22.19	\$ 23.32	\$ 5.69
Primary Re-Conductor Rural 477 AAC Difficult	feet	\$ 68.89	\$ 82.81	\$ 18.96
Primary Re-Conductor Urban 795 AAC Medium	feet	\$ 54.93	\$ 51.97	\$ 13.36
Primary Re-Conductor Urban 795 AAC Easy	feet	\$ 38.40	\$ 34.29	\$ 9.09
Primary Re-Conductor Urban 795 AAC Difficult	feet	\$ 92.44	\$ 95.82	\$ 23.53
Primary Re-Conductor Rural 795 AAC Medium	feet	\$ 48.70	\$ 50.46	\$ 12.40
Primary Re-Conductor Rural 795 AAC Easy	feet	\$ 31.79	\$ 28.47	\$ 7.53
Primary Re-Conductor Rural 795 AAC Difficult	feet	\$ 81.67	\$ 91.77	\$ 21.68
Primary Cable #2 Al 15 kV 1 Ph Medium In Conduit	feet	\$ 23.67	\$ 36.70	\$ 7.55
Primary Cable #2 Al 15 kV 1 Ph Easy In Conduit	feet	\$ 18.55	\$ 36.70	\$ 6.91
Primary Cable #2 Al 15 kV 1 Ph Difficult In Conduit	feet	\$ 28.79	\$ 36.70	\$ 8.19
Primary Cable 1/0 25 kV Medium In Conduit	feet	\$ 19.88	\$ 33.07	\$ 6.62
Primary Cable 1/0 25 kV Easy In Conduit	feet	\$ 11.68	\$ 23.72	\$ 4.43
Primary Cable 1/0 25 kV Difficult In Conduit	feet	\$ 30.20	\$ 49.09	\$ 9.91
Primary Cable 1000 Medium In Conduit	feet	\$ 22.13	\$ 41.87	\$ 8.00
Primary Cable 1000 Easy In Conduit	feet	\$ 13.93	\$ 32.53	\$ 5.81
Primary Cable 1000 Difficult In Conduit	feet	\$ 32.45	\$ 57.90	\$ 11.29
Primary Cable 4/0 Medium In Conduit	feet	\$ 21.16	\$ 32.58	\$ 6.72
Primary Cable 4/0 Easy In Conduit	feet	\$ 12.97	\$ 23.23	\$ 4.53
Primary Cable 4/0 Difficult In Conduit	feet	\$ 31.49	\$ 48.60	\$ 10.01
OH Switch-Unitized-Hookstick Operated 25 kV 600 A	each	\$ 2,225.30	\$ 3,904.59	\$ 766.24
Capacitor - Fixed 12000 V 600 kVar	each	\$ 3,070.58	\$ 2,817.85	\$ 736.05
Capacitor - Fixed 19920 V 600 kVar	each	\$ 2,011.92	\$ 2,361.48	\$ 546.68
Capacitor - Fixed 14400 V 900 kVar	each	\$ 2,011.92	\$ 2,451.55	\$ 557.93
Capacitor - Fixed 14400 V 600 kVar	each	\$ 2,011.92	\$ 2,158.51	\$ 521.30
Capacitor - Fixed 12000 V 1200 kVar	each	\$ 3,070.58	\$ 3,610.71	\$ 835.16
Capacitor - Fixed 12000 V 900 kVar	each	\$ 3,070.58	\$ 2,687.98	\$ 719.82
Capacitor - Fixed 7200 V 1200 kVar	each	\$ 3,070.58	\$ 4,684.04	\$ 969.33
Capacitor - Fixed 7200 V 600 kVar	each	\$ 3,070.58	\$ 2,748.50	\$ 727.39
Capacitor - Fixed 19920 V 900 kVar	each	\$ 2,011.92	\$ 2,765.52	\$ 597.18
Capacitor - Fixed 7200 V 900 kVar	each	\$ 3,070.58	\$ 2,845.52	\$ 739.51
Capacitor - Fixed 2400 V 150 kVar	each	\$ 2,011.92	\$ 1,897.76	\$ 488.71
Capacitor - Fixed 19920 V 1200 kVar	each	\$ 2,011.92	\$ 2,765.52	\$ 597.18
Capacitor - Fixed 14400 V 1200 kVar	each	\$ 2,011.92	\$ 2,673.55	\$ 585.68
Capacitor - Switched 19920 V 1200 kVar	each	\$ 4,772.71	\$ 10,311.79	\$ 1,885.56
Capacitor - Switched 12000 V 900 kVar	each	\$ 6,574.70	\$ 10,392.83	\$ 2,120.94
Capacitor - Switched 19920 V 900 kVar	each	\$ 4,772.71	\$ 9,544.78	\$ 1,789.69
Capacitor - Switched 12000 V 600 kVar	each	\$ 6,574.70	\$ 12,135.53	\$ 2,338.78
Capacitor - Switched 19920 V 600 kVar	each	\$ 4,772.71	\$ 9,233.98	\$ 1,750.84
Capacitor - Switched 12000 V 1200 kVar	each	\$ 6,574.70	\$ 10,769.21	\$ 2,167.99

Capacitor - Switched 2400 V 150 kVar	each	\$ 4,772.71	\$ 8,395.13	\$ 1,645.98
Capacitor - Switched 7200 V 900 kVar	each	\$ 6,574.70	\$ 10,796.58	\$ 2,171.41
Capacitor - Switched 7200 V 600 kVar	each	\$ 6,574.70	\$ 10,219.74	\$ 2,099.31
Capacitor - Switched 7200 V 1200 kVar	each	\$ 6,574.70	\$ 8,313.73	\$ 1,861.05
Capacitor - Switched 14400 V 1200 kVar	each	\$ 4,772.71	\$ 11,230.88	\$ 2,000.45
Capacitor - Switched 14400 V 600 kVar	each	\$ 4,772.71	\$ 9,189.59	\$ 1,745.29
Capacitor - Switched 14400 V 900 kVar	each	\$ 4,772.71	\$ 9,502.61	\$ 1,784.42
Regulator - 3 Ph 19920 V 200 A	each	\$ 11,202.63	\$ 39,521.26	\$ 6,340.49
Regulator - 3 Ph 7620 V 219 A	each	\$ 11,109.54	\$ 40,479.69	\$ 6,448.65
Regulator - 3 Ph 7620 V 328 A	each	\$ 11,109.54	\$ 47,552.68	\$ 7,332.78
Regulator - 3 Ph 14400 V 100 A	each	\$ 11,160.58	\$ 42,561.56	\$ 6,715.27
Regulator - 3 Ph 14400 V 200 A	each	\$ 11,160.58	\$ 47,859.89	\$ 7,377.56
Regulator - 3 Ph 19920 V 100 A	each	\$ 11,202.63	\$ 35,858.26	\$ 5,882.61
Regulator - 3 Ph 7620 V 100 A	each	\$ 11,109.54	\$ 36,053.62	\$ 5,895.40
Regulator - 1 Ph 19920 V 50 A	each	\$ 2,775.05	\$ -	\$ 346.88
Regulator - 1 Ph 14400 V 100 A	each	\$ 2,775.05	\$ 13,209.42	\$ 1,998.06
Regulator - 1 Ph 14400 V 50 A	each	\$ 2,775.05	\$ -	\$ 346.88
Regulator - 1 Ph 7620 V 50 A	each	\$ 2,775.05	\$ -	\$ 346.88
Regulator - 1 Ph 7620 V 100 A	each	\$ 2,775.05	\$ 11,039.64	\$ 1,726.84
OH Switch-Unitized-Handle Operated 35 kV 1200 A	each	\$ 2,176.19	\$ 5,748.14	\$ 990.54
OH Switch-Unitized-Handle Operated 25 kV 600 A	each	\$ 2,225.30	\$ 5,841.36	\$ 1,008.33
OH Switch-Unitized-Handle Operated 35 kV 600 A	each	\$ 2,225.30	\$ 5,841.36	\$ 1,008.33
Riser Pole	each	\$ 3,070.33	\$ 2,275.25	\$ 668.20

**From:** [Pierce, Wyatt](#)  
**To:** [John P. White](#)  
**Subject:** FW: Crew costs  
**Date:** Friday, January 14, 2011 3:09:51 PM

---

John,

I had pulled some numbers out of the efficiency calculator spreadsheet, and received the following information from our Operations department when I asked about it.

Wyatt W. Pierce, PE

Desk: 541•633•2481

Cell: 541•848•7970

---

**From:** Ooten, Chad  
**Sent:** Friday, January 14, 2011 2:22 PM  
**To:** Pierce, Wyatt  
**Subject:** RE: Crew costs

The way we figure labor and equipment for a job is a little different than what you have in your spreadsheet. We have a set price per hour per man and that gives you a tooled up journeyman. All are the same from journeyman lineman to foremen as far as job costs. The per hour price will fluctuate from time to time, but right now today it is \$129.05 per hour for one man tooled up with whatever tools and trucks needed on the job. The only time equipment would be an adder is if we have to rent something like a crane or taller highline bucket or something along the specialty equipment lines that we don't have already. We don't get into equipment per hour as extra charges like contractors do. With them you pay the per hour for each man along with a per hour charge for all the equipment they have also. We don't do that. Our cost is a tooled up man with a truck.

The cost per different crews below is just 129.05 per hour times the number of people and hours. These costs include whatever equipment and tools they need.

Journeyman \$129.05 per hr.

2 man crew per hr    \$258.10  
 3 man crew per hour \$ 387.15  
 4 man crew per hr    \$ 516.20

Journeyman per 8 hr day \$1032.40  
 2 man crew per 8 hr day \$ 2064.80  
 3 man crew per 8 hr day \$ 3097.20  
 4 man crew per 8 hr day \$ 4129.60

Let me know if you have any questions.

Thanks - Chad

---

**From:** Pierce, Wyatt  
**Sent:** Friday, January 14, 2011 12:02 PM  
**To:** Ooten, Chad  
**Subject:** Crew costs

Chad,

Could you please take a look at the attached spreadsheet. This is part of what our CVR contractors are using to determine feasibility of capital improvements. I feel like the values for crew and equipment costs may be listed lower than our company's reality. I would appreciate it if you could update any numbers you have at your disposal and return this to me.

Thank you,

Wyatt W. Pierce, PE  
**Pacific Power**  
**NID Support & Special Projects**  
**Desk:** 541•633•2481  
**Cell:** 541•848•7970

# Appendix 5: Circuit Changes

Washington Distribution Efficiency Study: 4W22  
Improvements For Stage 01 Dodd Road

Scale: 1" = 1.5 m (1:95,040)


**Commonwealth Associates, Inc.**




May 16, 2017

**Map Area**

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line
- BE Branch End
- EOL End of Line
- Changes





Washington Distribution Efficiency Study: 4W22  
Improvements For Stage 02 Dodd Road

Commonwealth CONSULTING

Scale: 1" = 1.5 m (1: 95,040)


0 7,900 15,800 23,700 31,600 Feet

Map Features

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconducted Circuit
- BE
- Branch End
- EOL
- End of Line
- Changes

Reconducting Table	Changes
Color Key	%
Green	50-60
Yellow	60-70
Red	70-100
Blue	100+

May 12, 2011





Washington Distribution Efficiency Study: 5W116 & 5W127  
Improvements For Stage 01 Millcreek

Scale: 1" = 2400' (1: 28,800)



Commonwealth Associates, Inc.


Map Area

Map Features

- Structure
- Transformer
- Substation
- Structure & Phase Changes
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line
- BE
- Branch End
- EOL
- End of Line
- Changes

May 16, 2017





Washington Distribution Efficiency Study: 5W116 & 5W127 Improvements For Stage 02 Mill Creek


Scale: 1" = 2,400' (1: 28,800)




### Map Features

	Pole
	Transformer
	Substation
	Underground
	Existing Capacitor
	Phase Change
	Overhead Circuit Line
	Underground Circuit Line
	New Cap
	Regulator
	Reconstructed Circuit
	Branch End
	EOL
	End of Line

Reconducting Table	
Color Key	%
	50
	60-70
	70-100
	100+





**Washington Distribution Efficiency Study: 5W150 & 5W154 Improvements For Stage 01 Bowman**

Scale: 1" = 3,100' (1: 37,200)

**Commonwealth CONSULTING**

**Map Features**

Structure	BE	Branch End
Transformer	EOL	End of Line
Substation	○	Changes
Structure & Phase		
Existing Capacitor		
Phase Change		
Overhead		
Circuit Line		
Underground		
Circuit Line		

0 3,100 6,200 9,300 12,400 Feet


Quincy Moses Lake Pullman Richland Kennewick Walla Walla Hermiston Pendleton La Grange Dalles

Map Area

Yakima County

Page 84

May 16, 2011



**Washington Distribution Efficiency Study: 5W150 & 5W154 Improvements For Stage 02 Bowman**

Scale: 1" = 3,100' (1: 37,200)

**Commonwealth CONSULTING**


0 3,100 6,200 9,300 12,400 Feet


**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconstructed Circuit
- BE Branch End
- EOL End of Line
- Changes

Reconducting Table Color Key	%
Blue	50-60
Green	60-70
Yellow	70-100
Red	100+

May 12, 2011





**Washington Distribution Efficiency Study: 5Y194 & 5Y197 & 5Y273  
Improvements For Stage 01 Nob Hill**

Scale: 1" = 1000' (1: 12,000)

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Features**

- BE Branch End
- EOL End of Line
- Changes

Commonwealth CONSULTANTS


0 1000 2000 3000 4000 Feet

Map Area

Quincy Moses Lake Pullman  
Yakima County  
Yakima Richland Kennewick  
Hermiston Pendleton La Grange  
Dalles


Page 86

May 16, 2017



Washington Distribution Efficiency Study: 5Y194 & 5Y197 & 5Y273  
Improvements For Stage 02 Nob Hill

Scale: 1" = 1000' (1: 12,000)



**Commonwealth CONSULTING**


**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconstructed Circuit
- Branch End
- End of Line
- Changes

**Reconducting Table**

Color Key	%
Green	50
Yellow	50-70
Orange	70-100
Red	100+

May 12, 2011



**Washington Distribution Efficiency Study: 5Y313 & 5Y317 Improvements For Stage 01 Sunnyside**

Commonwealth Associates, Inc.


Scale: 1" = 700' (1: 8,400)

0 700 1,400 2,100 2,800 Feet

May 16, 2011

**Map Features**

●	Structure	BE	Branch End
▲	Transformer	EOL	End of Line
■	Substation	○	Changes
○	Structure & Phase		
○	Existing Capacitor		
○	Phase Change		
○	Overhead		
○	Circuit Line		
---	Underground		
---	Circuit Line		



**Washington Distribution Efficiency Study: 5Y313 & 5Y317**  
**Improvements For Stage 02 Sunnyside**

Scale: 1" = 700' (1: 8,400)


Commonwealth Associates, Inc.

May 12, 2011


**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconducted Circuit
- BE Branch End
- EOL End of Line
- Changes

Reconducting Table	
Color Key	%
Green	< 50
Yellow	50-50
Orange	70-100
Red	100+







Washington Distribution Efficiency Study: 5W342  
Improvements For Stage 01 Pomeroy

Commonwealth CONSULTING INC.

Scale: 1" = 1 m (1: 63,360)

0 5,250 10,500 15,750 21,000 Feet




**Map Features**

Structure	BE	Branch End
Transformer	EOL	End of Line
Substation	○	Changes
Structure & Phase	○	Existing Capacitor
Existing Capacitor	□	Phase Change
Phase Change	—	Overhead
Overhead	---	Circuit Line
Circuit Line	---	Underground
Underground	---	Circuit Line

Map Area: Pullman, Richland, Hermiston, Dalles, Quincy, Moses Lake, Wainwright, Kennewick, Walla Walla, Pendleton, La Grapes

Page 90

May 16, 2011



**Washington Distribution Efficiency Study: 5W342 Improvements For Stage 02 Pomeroy**

Commonwealth CONSULTING

Scale: 1" = 1 m (1:63,360)


0 5,250 10,500 15,750 21,000 Feet

**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconducted Circuit
- BE Branch End
- EOL End of Line
- Changes

Reconducting Table	
Color Key	%
Green	50-60
Yellow	60-70
Red	70-100
Blue	100+



May 12, 2011



Washington Distribution Efficiency Study: 5Y351  
Improvements For Stage 01 Grandview

Commonwealth  
Associates, Inc.


Scale: 1" = 1000' (1: 12,000)



Map Features

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line
- BE Branch End
- EOL End of Line
- Changes

May 16, 2017



Washington Distribution Efficiency Study: 5Y351  
Improvements For Stage 02 Grandview

Commonwealth  
Associates, P.C.

Scale: 1" = 1000' (1: 12,000)




**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconducted Circuit
- BE Branch End
- EOL End of Line
- Changes

Reconducting Table	
Color Key	%
Green	< 50
Yellow	50-50
Orange	50-100
Red	70-100
Black	100+



May 12, 2017



Washington Distribution Efficiency Study: 5Y356  
Improvements For Stage 01 North Park

Commonwealth Associates, Inc.

Scale: 1" = 1400' (1: 16,800)


0 1,400 2,800 4,200 5,600 Feet


**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

- BE Branch End
- EOL End of Line
- Changes

May 16, 2011





**Washington Distribution Efficiency Study: 5Y356**  
**Improvements For Stage 02 North Park**

Scale: 1" = 1400' (1: 16,800)

**Commonwealth CONSULTANTS**

0 1,400 2,800 4,200 5,600 Feet

**Map Features**


- Regulator
- Reconducted Circuit
- Branch End
- End of Line
- Changes
- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap

Reconducting Table	
Color	Key
Green	50-60%
Yellow	60-70%
Orange	70-100%
Red	100+

May 12, 2011

**Map Area**

Wenatchee, Quincy, Pullman, Richland, Hermiston, Pendleton, La Grange, Moses Lake, Yakima, Kennewick, Walla Walla, Dalles



**Washington Distribution Efficiency Study: 5Y434**  
**Improvements For Stage 01 Wiley**

Scale: 1" = 1500' (1: 18,000)

**Commonwealth CONSULTING**

**Map Features**

●	Structure	BE	Branch End
▲	Transformer	EOL	End of Line
○	Substation	○	Changes
□	Structure & Phase		
○	Existing Capacitor		
○	Phase Change		
—	Overhead		
---	Underground		
---	Circuit Line		


**Map Area**

Quincy, Moses Lake, Pullman, Richland, Hermiston, Pendleton, La Grange, Walla Walla, Kennewick, Yakima County, Dalles

Map Area

Page 96

May 16, 2011



**Washington Distribution Efficiency Study: 5Y434**  
**Improvements For Stage 02 Wiley**

Scale: 1" = 1500' (1: 18,000)

**Commonwealth CONSULTANTS**

0 1,500 3,000 4,500 6,000 Feet

**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconstructed Circuit
- BE
- Branch End
- EOL
- End of Line
- Changes


Reconducting Table	
Color	%
Green	50-60
Yellow	60-70
Red	70-100
Blue	100+

May 12, 2011

**Map Area**

Page 97





**Washington Distribution Efficiency Study: 5Y444  
Improvements For Stage 01 River Road**

Scale: 1" = 800' (1:9,600)

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

BE Branch End  
EOL End of Line  
Changes

A->C

Commonwealth CONSULTING


0 800 1600 2400 3200 Feet

Quincy Moses Lake Pullman  
Yakima  
Richland  
Hermiston  
Dalles  
Walla Walla  
Pendleton  
La Gr

Map Area

Yakima County

May 16, 2011



**Washington Distribution Efficiency Study: 5Y444**  
**Improvements For Stage 02 River Road**

Commonwealth Associates, Inc.

Scale: 1" = 800' (1: 9,600)


0 800 1,600 2,400 3,200 Feet

**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconstructed Circuit
- BE
- EOL
- End of Line
- Changes

Reconducting Table	
Color Key	%
Green	< 50
Yellow	50-50
Orange	50-100
Red	70-100
Black	100+

May 12, 2017



**Washington Distribution Efficiency Study: 5Y456 & 5Y498  
Improvements For Stage 01 Orchard**

Scale: 1" = 1000' (1: 12,000)

**Commonwealth ELECTRIC**

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

BE Branch End  
EOL End of Line  
Changes

1200


CBA-CAB  
A-B  
C-B

0 1000 2000 3000 4000 Feet

Quincy Moses Lake Pullman  
Yakima  
Richland  
Hermiston  
Pendleton  
La Grange  
Walla Walla  
Kennewick  
Yakima County  
Map Area

Page 100

May 16, 2011



**Washington Distribution Efficiency Study: 5Y456 & 5Y498**  
**Improvements For Stage 02 Orchard**

Scale: 1" = 1000' (1: 12,000)

**Commonwealth ELECTRIC**

0 1,000 2,000 3,000 4,000 Feet

**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconstructed Circuit
- BE
- EOL
- End of Line
- Changes

Reconducting Table	
Color Key	%
Blue	50-60
Green	60-70
Yellow	70-100
Red	100+


**Map Area**

Wenatchee, Quincy, Moses Lake, Pullman, Richland, Hermiston, Pendleton, La Grange, Walla Walla, Kennewick, Yakima County, Yakima, Dalles

May 12, 2017

Washington Distribution Efficiency Study: 5Y608 & 5Y610  
 Improvements For Stage 01 Clinton


Scale: 1" = 1500' (1: 18,000)



**Map Features**

●	Structure
▲	Transformer
■	Substation
○	Structure & Phase Changes
○	Existing Capacitor
○	Phase Change
○	Overhead Circuit Line
---	Underground Circuit Line

May 16, 2011



**Washington Distribution Efficiency Study: 5Y608 & 5Y610 Improvements For Stage 02 Clinton**

Scale: 1" = 1500' (1: 18,000)


**Commonwealth ASSOCIATES, P.C.**

May 12, 2015


**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead Circuit Line
- Underground Circuit Line
- New Cap
- Regulator
- Reconducted Circuit
- BE Branch End
- EOL End of Line
- Changes

Reconducting Table	
Color Key	%
Green	< 50
Yellow	50-50
Orange	50-75
Red	75-100
Black	100+



## Appendix 6: Circuit Voltages



Washington Distribution Efficiency Study: 4W22  
Voltage Profile For Stage 01 HL & LL Dodd Road

Commonwealth Associates, Inc.

Scale: 1" = 1.5 m (1:95,040)

0 7,900 15,800 23,700 31,600 Feet


Map Area

Map Features

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

May 16, 2017





**Voltage Profile Stage 02 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-122 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 4W22**  
**Voltage Profile For Stage 02 HL & LL Dodd Road**

Scale: 1" = 1.5 m (1: 95,040)

**Commonwealth CONSULTING**

0 7,900 15,800 23,700 31,600 Feet

**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconstructed Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line

**Map Area**

May 12, 2011

Washington Distribution Efficiency Study: 5W116 & 5W127  
Voltage Profile For Stage 01 HL & LL Millcreek

Commonwealth Associates, Inc.

Scale: 1" = 2400' (1: 28,800)


0 2,400 4,800 7,200 9,600 Feet

Map Area

Map Features

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

May 16, 2011



Voltage Profile Stage 01 HL & LL Key

- HL (and LL)
- LL
- 120V or Less
- 121 - 120V
- 120V or Less - LL
- 121 - 120V - HL
- 125 - 122V

Washington Distribution Efficiency Study: 5W116 & 5W127  
Voltage Profile For Stage 02 HL & LL Millcreek


Scale: 1" = 2400' (1: 28,800)

**Commonwealth**  
ASSOCIATES, INC.

**Map Features**


	Pole		New Cap
	Transformer		Regulator
	Substation		Reconducted Circuit
	Underground		
	Existing Capacitor		
	Phase Change		
	Overhead		
	Circuit Line		
	Underground		
	Circuit Line		

May 12, 2015



**Voltage Profile Stage 02 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-122 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 5W150 & 5W154  
Voltage Profile For Stage 01 HL & LL Bowman**

Scale: 1" = 3,100' (1: 37,200)



**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Area**




Commonwealth CONSULTING, INC.


May 16, 2011



Washington Distribution Efficiency Study: 5W150 & 5W154  
Voltage Profile For Stage 02 HL & LL Bowman

Scale: 1" = 3,100' (1: 37,200)





**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-125 - 122V

**Washington Distribution Efficiency Study: 5Y194 & 5Y197 & 5Y273  
Voltage Profile For Stage 01 HL & LL Nob Hill**

Scale: 1" = 1000' (1: 12,000)


**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Area**

Commonwealth CONSULTING

May 16, 2011



**Voltage Profile Stage 02 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-122 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V


Washington Distribution Efficiency Study: 5Y194 & 5Y197 & 5Y273  
Voltage Profile For Stage 02 HL & LL Nob Hill

Scale: 1" = 1000' (1: 12,000)

**Commonwealth**  
CONSULTANTS

**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconducted Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line



**Washington Distribution Efficiency Study: 5Y313 & 5Y317**  
**Voltage Profile For Stage 01 HL & LL Sunnyside**


Scale: 1" = 700' (1: 8,400)

**Commonwealth**  
 associates, inc.

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

May 16, 2017





**Washington Distribution Efficiency Study: 5Y313 & 5Y317**  
**Voltage Profile For Stage 02 HL & LL Sunnyside**


Scale: 1" = 700' (1: 8,400)


**Commonwealth**  
ASSOCIATES, P.C.

May 12, 2015

**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconducted Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Circuit Line






Washington Distribution Efficiency Study: 5W342  
Voltage Profile For Stage 01 HL & LL Nob Hill

Scale: 1" = 1 m (1: 63,360)




**Map Features**

- Structure
- ▲ Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V



Washington Distribution Efficiency Study: 5W342  
Voltage Profile For Stage 02 HL & LL Pomeroy


Commonwealth ELECTRICITY

Scale: 1" = 1 m (1: 63,360)

0 5,250 10,500 15,750 21,000 Feet


**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconducted Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line



**Voltage Profile Stage 02 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-122 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V

Washington Distribution Efficiency Study: 5Y351  
 Voltage Profile For Stage 01 HL & LL Grandview

Commonwealth Associates, Inc.

Scale: 1" = 1000' (1: 12,000)

0 1,000 2,000 3,000 4,000 Feet

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

Map Area

May 10, 2017

Washington Distribution Efficiency Study: 5Y351  
Voltage Profile For Stage 02 HL & LL Grandview

Commonwealth  
Associates, Inc.

Scale: 1" = 1000' (1: 12,000)


0 1,000 2,000 3,000 4,000  
Feet

Map Area

Map Features



	Pole		New Cap
	Transformer		Regulator
	Substation		Reconductored Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line

May 10, 2011



Voltage Profile Stage 02 HL & LL Key

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V



**Washington Distribution Efficiency Study: 5Y356  
Voltage Profile For Stage 01 HL & LL North Park**

Scale: 1" = 1400' (1: 16,800)



**Commonwealth CONSULTING**

**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Area**

May 16, 2011



**Washington Distribution Efficiency Study: 5Y356**  
**Voltage Profile For Stage 02 HL & LL North Park**

Scale: 1" = 1400' (1: 16,800)

**Commonwealth ELECTRIC**

0 1,400 2,800 4,200 5,600 Feet


**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconducted Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line

**Map Area**

Page 120

May 12, 2011



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 5Y434**  
**Voltage Profile For Stage 01 HL & LL Wiley**

Scale: 1" = 1500' (1: 18,000)

**Commonwealth CONSULTING, INC.**


Map Features

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

Map Area

May 16, 2011





**Voltage Profile Stage 02 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-122 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-120V or Less - LL
	-122 - 121V - HL
	-121 - 120V - LL
	-122 - 121V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 5Y434**  
**Voltage Profile For Stage 02 HL & LL Wiley**

Scale: 1" = 1500' (1: 18,000)

**Commonwealth CONSULTING**


0 1,500 3,000 4,500 6,000 Feet

**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconstructed Circuit
	Underground		Existing Capacitor
	Existing Capacitor		Phase Change
	Phase Change		Overhead Circuit Line
	Overhead Circuit Line		Underground Circuit Line
	Underground Circuit Line		

**Map Area**

May 12, 2011



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 5Y444**  
**Voltage Profile For Stage 01 HL & LL River Road**

Scale: 1" = 800' (1:9,600)


**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Area**

Commonwealth CONSULTING


May 18, 2011



Washington Distribution Efficiency Study: 5Y444  
Voltage Profile For Stage 02 HL & LL River Road





Scale: 1" = 800' (1: 9,600)



**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconstructed Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line





**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V

**Washington Distribution Efficiency Study: 5Y456 & 5Y498**  
**Voltage Profile For Stage 01 HL & LL Orchard**

Scale: 1" = 1000' (1: 12,000)



**Map Features**

- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

**Map Area**

Commonwealth CONSULTING

May 16, 2017



**Washington Distribution Efficiency Study: 5Y456 & 5Y498**  
**Voltage Profile For Stage 02 HL & LL Orchard**

Scale: 1" = 1000' (1: 12,000)

**Map Features**

	Pole		New Cap
	Transformer		Regulator
	Substation		Reconstructed Circuit
	Underground		Existing Capacitor
	Phase Change		Overhead Circuit Line
	Underground Circuit Line		Underground Circuit Line

**Map Area**

Commonwealth CONSULTING

Page 126

May 12, 2011

**Washington Distribution Efficiency Study: 5Y608 & 5Y610**  
**Voltage Profile For Stage 01 HL & LL Clinton**

Scale: 1" = 1500' (1: 18,000)


**Commonwealth**  
 associates, inc.

0 1,500 3,000 4,500 6,000  
 Feet

**Map Features**


- Structure
- Transformer
- Substation
- Structure & Phase
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line

May 16, 2011



**Voltage Profile Stage 01 HL & LL Key**

	HL (and LL)
	LL
	-120V or Less
	-121 - 120V
	-120V or Less - LL
	-121 - 120V - HL
	-125 - 122V



**Washington Distribution Efficiency Study: 5Y608 & 5Y610**  
**Voltage Profile For Stage 02 HL & LL Clinton**

Scale: 1" = 1500' (1: 18,000)

Commonwealth Associates, Inc.

0 1,500 3,000 4,500 6,000 Feet

Map Area: Quincy, Moses Lake, Pullman, Richland, Hermiston, Pendleton, La Grange, Walla Walla, Kennewick, Gifford, Yakima County, Walla Walla

**Map Features**

- Pole
- Transformer
- Substation
- Underground
- Existing Capacitor
- Phase Change
- Overhead
- Circuit Line
- Underground
- Circuit Line
- New Cap
- Regulator
- Reconductored Circuit

May 12, 2017

**Voltage Profile Stage 02 HL & LL Key**

- HL (and LL)
- LL
- 120V or Less
- 121 - 120V
- 122 - 120V
- 120V or Less - LL
- 121 - 120V - HL
- 120V or Less - LL
- 122 - 121V - HL
- 121 - 120V - LL
- 122 - 121V - HL
- 125 - 122V

**Appendix 7: Detailed Results by Stage and Circuit**



Appendix 7-1 Summary of Results by Stage with all Circuits Included

General Information	Stage 1	Stage 2	Stage 3
<b>Total Customers Served (#)</b>	30,747	30,747	30,747
<b>Feeder Annual Peak MW</b>	138	138	138
<b>Total Annual Energy Consumed (MWh/yr)</b>	627,608	627,608	627,608
<b>Average Customer Voltage Change (%)</b>	1.35%	1.09%	2.01%
<b>Average Reduction in Annual Energy Delivered from Sub</b>	0.94%	0.82%	1.40%
<b>Total SI&amp;VO Installed Cost</b>	\$1,640,691	\$2,999,482	\$6,518,727
<b><u>Utility Energy Savings Potential</u></b>			
<b>Line Loss Reduction (MWh/y)</b>	282.7	712.7	678.8
<b>No-load Loss Saved (MWh/y)</b>	252.5	199.8	357.1
<b>VO Energy Savings (MWh/y)</b>	5337.9	4235.4	7744.8
<b>Total Energy Savings (MWh/y)</b>	5873.1	5147.8	8780.7
<b>Total Energy Savings (MWa)</b>	0.6704	0.5877	1.0024
<b>Total Coincidental Demand Reduction (kW)</b>	1142.6	1093.2	1766.9
<b>Average Customer Energy Reduction (kWh/yr)</b>	174	138	252
<b><u>Benefit Cost Projections</u></b>			
<b>Overall Utility Levelized Cost per kWh saved</b>	\$0.0434	\$0.0906	\$0.1154
<b>Overall Utility Benefit Cost Ratio</b>	2.52	1.21	0.95
<b>Overall Net Utility PV Savings (\$)</b>	\$4,734,832	\$1,194,119	(\$618,263)

Appendix 7-2 Summary of Economically Viable Solutions by Stage and Overall Optimal Solution

General Information	Stage 1	Stage 2	Stage 3	Optimal Solution
<b>Total Customers Served (#)</b>	22,225	22,958	18,665	27,909
<b>Feeder Annual Peak MW</b>	95.08	103.58	76.01	125.50
<b>Total Annual Energy Consumed (MWh/yr)</b>	438,826	476,160	357,575	574,046
<b>Average Customer Voltage Change (%)</b>	1.12%	1.11%	2.07%	1.73%
<b>Average Reduction in Annual Energy Delivered from Sub</b>	0.80%	0.85%	1.45%	1.23%
<b>Total SI&amp;VO Installed Cost</b>	\$863,209	\$1,893,973	\$2,826,294	\$3,854,835
<b><u>Utility Energy Savings Potential</u></b>				
<b>Line Loss Reduction (MWh/y)</b>	198.0	565.0	371.5	643.1
<b>No-load Loss Saved (MWh/y)</b>	129.5	146.4	187.1	267.5
<b>VO Energy Savings (MWh/y)</b>	3185.9	3347.2	4621.5	6127.4
<b>Total Energy Savings (MWh/y)</b>	3513.4	4058.5	5180.1	7038.0
<b>Total Energy Savings (MWha)</b>	0.4011	0.4633	0.5913	0.8034
<b>Total Coincidental Demand Reduction (kW)</b>	685.2	856.4	1027.0	1423.9
<b>Average Customer Energy Reduction (kWh/yr)</b>	143	146	248	220
<b><u>Benefit Cost Projections</u></b>				
<b>Overall Utility Levelized Cost per kWh saved</b>	\$0.0382	\$0.0726	\$0.0848	\$0.0852
<b>Overall Utility Benefit Cost Ratio</b>	2.87	1.51	1.29	1.29
<b>Overall Net Utility PV Savings (\$)</b>	\$3,056,420	\$1,832,787	\$1,565,127	\$2,098,324







Appendix 7-6 Optimal Solutions by Circuit and Total Viable

Optimal Solution (Greatest Savings and BCR >= 1 and LCLC <= \$105.91)	Walla Walla Bowman	Walla Walla Bowman	Walla Walla Dodd Rd	Walla Walla Mill Creek	Walla Walla Mill Creek	Walla Walla Pomeroy	Yakima Clinton	Yakima Clinton	Yakima Nob Hill	Yakima Nob Hill	Yakima Nob Hill	Yakima North Park	Yakima Orchard	Yakima Orchard	Yakima Wiley	Yakima River Road	Lower Valley Grandview	Lower Valley Sunnyside	Lower Valley Sunnyside	Optimal Summary	
	5W150	5W154	4W22	5W116	5W127	5W342	5Y608	5Y610	5Y194	5Y197	5Y273	5Y356	5Y456	5Y498	5Y434	5Y444	5Y351	5Y313	5Y317		
<b>General Information</b>																					
Total Customers Served (#)	1,796	1,823	1,181	2,053	1,968	NC	2,037	1,401	1,572	1,873	2,216	NC	1,421	1,751	1,332	2,201	1,286	1,020	978	27,909	
Feeder Annual Peak MW	6.72	8.20	8.70	8.10	6.22	NC	8.20	9.25	8.37	5.90	7.98	NC	7.30	6.28	6.99	10.60	7.70	5.00	4.00	125.50	
Total Annual Energy Consumed (MWh/yr)	33,096	37,064	39,920	34,127	29,178	NC	41,300	43,296	42,555	30,679	35,323	NC	28,933	27,290	27,726	49,558	33,272	20,865	19,868	574,046	
Average Customer Voltage Change (%)	2.27%	0.83%	1.59%	2.84%	2.15%	NC	1.36%	2.10%	2.41%	1.55%	2.10%	NC	0.83%	2.10%	0.83%	1.22%	1.33%	2.26%	2.38%	1.73%	
Reduction in Annual Energy Delivered from Sub (%)	1.77%	0.56%	1.21%	1.95%	1.49%	NC	1.01%	1.01%	1.55%	1.61%	1.04%	NC	0.76%	1.37%	0.68%	0.81%	1.07%	1.85%	1.80%	1.23%	
<b>Utility Energy Savings Potential</b>																					
Line Loss Reduction (MWh/y)	78.163	0.299	126.960	21.470	16.457	NC	43.637	41.508	70.630	3.457	-3.944	NC	57.439	-5.093	33.510	-2.250	55.648	65.827	39.429	643.147	
VO Energy Savings (MWh/y)	480.0	197.7	330.4	620.1	400.7	NC	359.6	381.5	567.4	474.5	357.9	NC	154.3	366.2	147.9	388.2	287.4	306.8	306.8	6127.4	
Total Energy Savings (MWh/y)	585.7	208.6	481.1	666.9	433.6	NC	419.1	437.2	658.3	493.4	367.3	NC	219.0	374.6	189.4	402.4	357.4	386.3	357.7	7038.0	
Total Energy Savings (MWa)	0.0669	0.0238	0.0549	0.0761	0.0495	NC	0.0478	0.0499	0.0751	0.0563	0.0419	NC	0.0250	0.0428	0.0216	0.0459	0.0408	0.0441	0.0408	0.8034	
Total Coincidental Demand Reduction (kW)	117.4	38.9	107.1	128.9	84.5	NC	88.0	86.8	128.6	93.2	68.2	NC	53.7	69.3	42.8	74.9	79.5	88.3	73.8	1423.9	
Customer Average Energy Reduction (kWh/yr)	267	108	280	302	204	NC	177	272	361	253	162	NC	109	209	111	176	223	301	314	220	
<b>Distribution Line Losses</b>																					
Existing Base System Line Loss (kW)	325.2	98.8	288.9	122.6	65.7	NC	113.0	128.8	165.1	44.7	150.2	NC	124.3	91.7	144.8	186.1	106.0	86.8	49.6	2292.3	
Baseline Pre-VO System Line Loss (kW)	302.3	98.7	247.4	114.6	59.3	NC	95.2	116.2	146.8	43.5	151.6	NC	100.8	93.6	131.1	186.9	82.8	58.4	35.5	2064.7	
Line Loss Reduction (kW)	22.9	0.1	41.5	8.0	6.4	NC	17.8	12.6	18.3	1.2	-1.4	NC	23.5	-1.9	13.7	-0.8	23.2	28.4	14.1	227.6	
Line Loss Reduction (MWa)	0.0089	0.0000	0.0145	0.0025	0.0019	NC	0.0050	0.0047	0.0081	0.0004	-0.0005	NC	0.0066	-0.0006	0.0038	-0.0003	0.0064	0.0075	0.0045	0.0734	
<b>End-Use Energy Consumption</b>																					
Average Volts Pre-VO (V)	122.3	121.6	122.1	123.2	122.3	NC	121.8	121.8	122.4	123.3	122.1	NC	122.1	122.6	122.0	122.2	122.3	122.2	122.9	122.3	
Average Volts Post-VO (V)	119.6	120.6	120.2	119.8	119.7	NC	120.2	120.2	119.9	120.4	120.2	NC	121.1	120.1	121.0	120.8	120.7	119.5	120.0	120.2	
VO Factor (for End-Use) from VO Protocol	0.640	0.640	0.520	0.640	0.640	NC	0.640	0.640	0.640	0.640	0.640	NC	0.640	0.640	0.640	0.640	0.650	0.650	0.650	0.635	
Total End-Use Demand Reduction (kW)	91.3	37.6	62.9	118.0	76.2	NC	68.4	72.6	108.0	90.3	68.1	NC	29.4	69.7	28.1	73.9	54.7	58.4	58.4	1165.8	
VO Energy Savings (MWa)	0.0548	0.0226	0.0377	0.0708	0.0457	NC	0.0411	0.0435	0.0653	0.0540	0.0400	NC	0.0176	0.0418	0.0169	0.0443	0.0328	0.0350	0.0350	0.6990	
Change in Voltage (pu)	0.0227	0.0083	0.0159	0.0284	0.0215	NC	0.0136	0.0138	0.0208	0.0242	0.0158	NC	0.0083	0.0210	0.0083	0.0122	0.0133	0.0226	0.0238	0.0173	
<b>Distribution Transformer No-Load Losses</b>																					
Distribution Transformer Connected kVA	23,831	24,581	29,035	17,726	15,105	NC	22,604	20,066	19,096	12,614	16,378	NC	16,682	12,638	18,624	25,987	20,980	11,852	9,580	317,376	
Total No-Load Loss (kW)	71.5	73.7	87.1	53.2	45.3	NC	67.8	60.2	57.3	37.8	49.1	NC	50.0	37.9	55.9	78.0	62.9	35.6	28.7	952.1	
Change in No-Load Loss (%)	4.38%	1.65%	3.11%	5.45%	4.16%	NC	2.67%	2.70%	4.04%	4.66%	3.09%	NC	1.65%	4.07%	1.65%	2.40%	2.61%	4.38%	4.59%	3.38%	
Total No-Load Loss Reduction (kW)	3.1	1.2	2.7	2.9	1.9	NC	1.8	1.6	2.3	1.8	1.5	NC	0.8	1.5	0.9	1.9	1.6	1.6	1.3	30.5	
No-Load Loss Saved (MWh/yr)	27.5	10.6	23.7	25.4	16.5	NC	15.8	14.2	20.3	15.5	13.3	NC	7.2	13.5	8.1	16.4	14.4	13.6	11.5	267.5	
No-Load Loss Reduction (MWa)	0.0031	0.0012	0.0027	0.0029	0.0019	NC	0.0018	0.0016	0.0023	0.0018	0.0015	NC	0.0008	0.0015	0.0009	0.0019	0.0016	0.0016	0.0013	0.0305	
<b>Utility Energy Efficiency Costs and Benefits</b>																					
VO Improvement Installation Cost	\$341,514	\$29,526	\$288,415	\$318,157	\$256,139	NC	\$281,975	\$260,606	\$297,023	\$154,291	\$241,604	NC	\$124,802	\$230,336	\$100,248	\$264,201	\$221,349	\$240,890	\$203,759	\$3,854,835	
Energy Efficiency Incentives																					
VO Improvement First Year Cost	\$341,514	\$29,526	\$288,415	\$318,157	\$256,139	NC	\$281,975	\$260,606	\$297,023	\$154,291	\$241,604	NC	\$124,802	\$230,336	\$100,248	\$264,201	\$221,349	\$240,890	\$203,759	\$3,854,835	
PV Annual Fixed Capital Charges	\$512,824	\$44,337	\$433,089	\$477,751	\$384,623	NC	\$423,419	\$391,331	\$446,015	\$231,686	\$362,797	NC	\$187,405	\$345,877	\$150,534	\$396,729	\$332,382	\$361,725	\$305,968	\$5,788,494	
PV Annual Remaining Salvage Value	\$0	\$0	\$0	\$0	\$0	NC	\$0	\$0	\$0	\$0	\$0	NC	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	
PV Operations & Maintenance Expense	\$133,720	\$11,561	\$112,929	\$124,574	\$100,291	NC	\$110,407	\$102,040	\$116,299	\$60,413	\$94,600	NC	\$48,866	\$90,188	\$39,252	\$103,448	\$86,669	\$94,320	\$79,782	\$1,509,357	
Total Utility PV Costs	\$646,543	\$55,898	\$546,018	\$602,325	\$484,914	NC	\$533,826	\$493,371	\$562,315	\$292,099	\$457,397	NC	\$236,271	\$436,065	\$189,786	\$500,177	\$419,051	\$456,045	\$385,750	\$7,297,852	
Utility Annual Levelized Cost per kWh Saved	\$0.0907	\$0.0220	\$0.0932	\$0.0742	\$0.0918	NC	\$0.1046	\$0.0927	\$0.0701	\$0.0486	\$0.1023	NC	\$0.0886	\$0.0956	\$0.0823	\$0.1021	\$0.0963	\$0.0970	\$0.0886	\$0.0852	
Utility Levelized Annual Cost per kW Reduction	\$452	\$118	\$419	\$384	\$471	NC	\$498	\$467	\$359	\$257	\$551	NC	\$361	\$517	\$365	\$548	\$433	\$424	\$429	\$421	
Utility Benefit / Cost Ratio	1.21	4.98	1.18	1.48	1.19	NC	1.05	1.18	1.56	2.26	1.07	NC	1.24	1.15	1.33	1.07	1.14	1.13	1.24	1.29	
<b>Utility Revenue Requirements</b>																					
Avoided PV of Purchase Power Costs	\$781,889	\$278,500	\$642,293	\$890,364	\$578,917	NC	\$559,511	\$583,692	\$878,875	\$658,736	\$490,381	NC	\$292,328	\$500,127	\$252,909	\$537,218	\$477,151	\$515,681	\$477,604	\$9,396,175	
Net Utility PV Savings	\$135,346	\$222,603	\$96,274	\$288,040	\$94,003	NC	\$25,685	\$90,321	\$316,560	\$366,637	\$32,984	NC	\$56,057	\$64,062	\$63,123	\$37,041	\$58,100	\$59,636	\$91,854	\$2,098,324	
<b>Customer Impact / Substation</b>																					
Customer kWh/yr (before SI & VO)	18,428	20,331	33,802	16,623	14,826	NC	20,275	30,903	27,071	16,379	15,940	NC	20,361	15,585	20,815	22,516	25,872	20,456	20,315	20,568	
Customer kWh/yr (after SI & VO)	18,160	20,223	33,522	16,321	14,622	NC	20,098	30,631	26,710	16,126	15,779	NC	20,252	15,376	20,704	22,340	25,649	20,155	20,001	20,349	
Optimal Recommended Solution	Stage 3	Stage 1	Stage 2	Stage 3	Stage 3	NC	Stage 3	Stage 3	Stage 3	Stage 3	Stage 3	NC	Stage 2	Stage 3	Stage 1	Stage 2	Stage 2	Stage 3	Stage 3		

NC = No stage solution is economically compliant

**Appendix 8: Simplified Voltage Optimization (VO)  
Measurement and Verification Protocol**

# Simplified Voltage Optimization (VO) Measurement and Verification Protocol

## 1.0 Introduction

### 1.1 Purpose

The Simplified Voltage Optimization (VO) Measurement and Verification (M&V) Protocol provides a basic approach to determine end-use energy savings when operating the electric distribution system more efficiently and within the lower band of the ANSI Standard voltage level. The protocol covers utility electric distribution systems serving mostly residential and light commercial load as defined by the utility. System loads do not need to be uniformly distributed throughout the distribution system. This Protocol identifies the procedure to determine the average annual voltage for a distribution primary system with source voltage regulation. Minimum system stability thresholds, system data requirements, and measurement and verification formulations are included as part of this Protocol.

#### 1.1.1 Attachments

- End-use VO Factors are identified in tables for use with this Protocol in Appendix A.
- Examples of data collected are included with this document to provide an understanding of the level of effort and detail to perform VO Assessments. See Examples: Data Collection Templates.

#### 1.1.2 Clarification of issues throughout this document.

The items in **bold** will appear frequently throughout the document.

- When **adjusted annual kW peak demand** is mentioned, 'adjusted' refers to common efforts by the utility to adjust for temperature, abnormal switching, or unusual loading conditions that would cause artificial peak demand information. Unusual loading conditions could, for example, be due to outage or maintenance.
- When **system modeling** is mentioned, it refers to using industry accepted distribution system power flow simulation tools for analysis of distribution system electric characteristics.
- When **end-use VO Factor** is mentioned, it refers to the tables in Appendix A that are derived from the 2007 NEEA Distribution Efficiency Initiative Study for end-use consumption (Load Research Project) and included 395 randomly selected residential homes throughout the Northwest using 12 plus months of day VO-On/ day VO-Off recordings. This information was presented to the NWPC Regional Technical Forum (RTF) in 2008.
- When **voltage control zone** is mentioned, it consists of all distribution lines that are controlled by a tap changing source voltage regulator. Several voltage-control-zones may exist within one substation area



- When **minimum operating performance thresholds** are mentioned, they refer to a set of specifications to achieve higher efficiency. These specifications, called performance thresholds, are described in the NEEA Distribution Efficiency Guidebook, January 2008, which provides guidelines for industry best practices for distribution system efficiency based on the research performed during the NEEA Distribution Efficiency Initiative Study.
- **Annual estimated or historical annual peak kW demand data** may be used for estimation of end use VO savings during study/assessment periods; however, actual metered annual kW peak demand data is used during the verification process.
- Calculations of all system improvements (reduction of line losses and no-load losses) will be made using industry accepted engineering methodologies. This Protocol does not propose new methods of calculating reduction of losses due to system improvements nor are Appendix A Tables used for non end-use VO calculations.
- Metering periods must not occur during a holiday or unusual circumstance that would lead to abnormal patterns in residential use.

## ***1.2 Simplified Voltage Optimization Overview***

The Simplified VO Protocol encompasses three basic source voltage regulation techniques described below:

**Voltage Fixed Reduction (VFR):** The Voltage Fixed Reduction methods require that the distribution substation source voltage regulator and line regulators voltages be lowered by a fixed amount. It is assumed that the pre-installation voltage is fixed at a known value. No remote automated voltage feedback controls are applied.

**Line Drop Compensation (LDC):** The Line Drop Compensation methods require that the distribution substation source voltage regulator and line regulators apply automatic voltage controls to control voltage up and down based on line load levels. When the feeder or substation load is changing, the voltage regulator simulates (calculates) an EOL voltage level and adjusts the regulator voltage to hold the EOL voltage constant. The voltage is locally sensed at the substation and line voltage regulator locations.

**Automated Voltage Feedback Control (AVFC):** The Automated Voltage Feedback Control methods require that the distribution substation source voltage regulator and line regulators voltages apply automatic voltage controls to control voltage up and down based on remote EOL voltage sensing. When the EOL voltage rises or falls below the pre-determine set point, the substation and line voltage regulators raise or lower their voltages as necessary to hold the remote EOL voltage constant. The voltage is locally and remotely sensed at the substation and line voltage regulator locations. Continuous voltage monitoring is required at EOL to feedback voltage.

All methods require voltage monitoring by the utility to periodically check that the end-of-line (EOL) voltages do not fall below a pre-determined set point.

All methods must be maintained annually in order to meet performance thresholds and VO guidelines.

## **2.0 Simplified VO M&V Approach**

### **2.1 FEMP Measurement and Verification**

The Simplified VO M&V Protocol follow Option D as described in “Measurement & Verification for Federal Energy Projects, Version 2.2

[www.eere.energy.gov/femp/financing/superespcs\\_mvresources.html](http://www.eere.energy.gov/femp/financing/superespcs_mvresources.html)

and “International Performance Measurement & Verification Protocol (IPMVP)”, Volume I, March 2002 ([www.ipmvp.org](http://www.ipmvp.org)).

Option D is utilized because the VO M&V Protocol is applied to a single whole facility (substation or feeder) with many subparts requiring a collective approach and where the energy savings will be less than 10 percent. Option D allows for a minimum of pre and post metered data points, and includes some simulation modeling and/or calculations to arrive at the energy saved for each chosen facility or system.

### **2.2 Simplified VO M&V; Four Stages**

The Simplified VO M&V Protocol approach has four stages. The general steps of each stage are identified below. Processes that will be used throughout the stages are explained in 2.3 through 4.0.

1. Stage One - *Existing Performance Assessment and VO Implementation Plan*
  - a. Gather actual or estimated distribution system historical data that is readily available including voltage settings and voltage operational standards.
  - b. Perform preliminary assessment of distribution system’s existing level of performance using system modeling.
  - c. Develop a preliminary improvement plan describing the system improvements needed to meet minimum operating performance thresholds for VO.
  - d. Develop preliminary plan for implementation of VO.
  - e. Estimate costs and propose preliminary schedules.
  - f. Calculate VO Factor from the VO Factor Tables.
  - g. Estimate potential savings of VO application.
  - h. Document all activities and results.
2. Stage Two - *System Improvements and Baseline Pre-VO measurements*
  - a. Implement cost effective system improvements necessary to meet performance thresholds.
  - b. Install source voltage regulating equipment necessary for operation of VO with controls set to mimic pre-VO average voltage conditions (non-VO operation). Pre-VO control settings are determined using system modeling. Perform pre-VO baseline measurements for 7-day period (168 hours). The detailed measurements are averaged over each hour.

- c. Each voltage control zone must meet performance thresholds during this Pre-VO measurement period.
  - d. Determine baseline pre-VO overall average voltage for all VO voltage control zones included as part of the VO plan.
  - e. Identify final installation cost of system improvements including VO equipment.
  - f. Document all activities and results.
3. Stage Three - *VO Implementation and Post-VO Measurements and Verification*
- a. Prepare an initial estimate of end-use energy savings resulting from VO using results of pre-VO baseline measurements, planned post-VO conditions, and distribution system known or estimated customer load characteristics.
  - b. Initiate post-VO operational voltage controls.
  - c. Perform post-VO measurements for 7-day period (168 hours). The detailed measurements are averaged over each hour.
  - d. Each voltage control zone must meet performance thresholds during this Post-VO measurement period.
  - e. Determine post-VO overall average voltage for the voltage control zone. Prepare a final post-VO verified estimate of energy savings resulting from change in average annual voltage for baseline pre-VO and post-VO.
  - f. Document all activities and results
4. Stage Four – Persistence of Energy Savings
- a. Complete annual self-certification checklist to ensure;
    - i. Voltage settings are still in operation as prescribed within all VO voltage control zones.
    - ii. Voltage control zones continue to meet performance thresholds. The annual VO performance self-certification is measured over a 12-month period.

### **2.3 About Minimum Operating Performance Thresholds**

The voltage control zones must meet or exceed performance thresholds during normal system switching configurations for the measurement periods; 7 days and/or 168 hours in Stage 2, 7 days and/or 168 hours in Stage 3, and there after during the Persistence period in Stage 4. All measurements during the measurement period are averaged over a one hour period.

In some cases it may be needed to perform system improvements to comply with performance thresholds (i.e. addition of line regulators, shunt capacitors, phase upgrades, line reconfigurations, and line reconductoring). If multiple VO voltage control zones are included as part of a substation system, the performance thresholds apply to each VO voltage control zone. System performance is determined from measurements at each VO voltage control zone source. Performance thresholds do not apply for non-VO voltage control zones.

For calculation purposes, load adjustment for temperature, abnormal switching configuration, or seasonal load anomalies may be performed to reflect normal annual loading operations.

1. The feeder-source minimum power-factor must be greater than 0.96. Power-factor

is total 3 $\phi$  kW divided by total 3 $\phi$  kVA.

2. The average of feeder-source power-factor must be greater than 0.98. Power-factor is defined in item 1 above.
3. Feeder-source phase-load-unbalance per unit (p.u.) must be less than 0.15 on 3 $\phi$  lines. The p.u. unbalance is the average of  $(1 - [\text{Average } 3\phi \text{ peak hourly demand Amps}] / [\text{maximum } 1\phi \text{ hourly demand Amps}])$  over the measurement-period. Phase-load-unbalance is determined for each VO voltage-control-zone. Maximum 1 $\phi$  hourly demand Amps is measured for each line phase (e.g. line phases A, B, or C). Feeder-source neutral-current must be less than 40 amps on 3 $\phi$  lines.
4. Substation VO voltage-control-zone maximum adjusted voltage-drop must be less than 3.3%. The calculation uses voltage measurements over the period and adjusts them for peak load periods. For pre-VO and post-VO assessments, the maximum adjusted voltage-drop is the average of all voltage-drops over the measurement period multiplied by the ratio [annual 3 $\phi$  peak kW hourly demand / average 3 $\phi$  kW demand for measurement period]. Primary voltage-drop is difference between regulator bus and EOL (lowest voltage location).  
*Note: Voltage-drop is the reduction in voltage on primary line between regulator source and lowest voltage points. The voltage-drop % is the reduction in volts divided by source volts times 100. Substation VO regulator or VO line regulator annual 3 $\phi$  peak kW hourly demand for a 12 month historical data period may be used with power flow simulations to determine the annual maximum voltage-drop for use with system assessment (Stage One) and self-certification monitoring (Stage Four). The peak kW demand is allocated across the VO voltage-control-zone feeder system.*
5. Line Regulator voltage-control-zone maximum adjusted voltage-drop must be less than 3.3%. The calculation uses voltage measurements over the period and adjusts them for the peak load periods. For pre-VO and post-VO assessments, the maximum adjusted voltage-drop is the average of voltage-drops over the measurement-period multiplied by the ratio [annual 3 $\phi$  peak kW hourly demand / average 3 $\phi$  kW demand for measurement period]. Primary voltage-drop is difference between regulator bus and EOL (lowest voltage location).
6. Secondary maximum allowed voltage-drop must be less than 4.0% for all VO voltage control zones. This value is difficult to obtain, and therefore, it may be established from utility standards and design guidelines. Any time the secondary voltage-drop exceeds 4.0%, the solution should be to fix the problem and not to increase the source voltage. Secondary systems include the distribution transformer, secondary conductors, and service wires.
7. Maximum voltage-drop variance between multiple feeders served within a substation VO voltage-control-zone must be less than 2 volts (on a 120V base). The voltage-drop p.u. variance is determined by comparing the maximum voltage-drops of each feeder measured over the measurement-period.
8. The VO primary line minimum hourly voltage must be greater than [114 Volts +  $\frac{1}{2}$  the voltage regulation bandwidth + secondary maximum allowed voltage-drop]. Acceptable voltage regulation bandwidth is in the range of 2V to 3V (on 120V base.) Primary line minimum-voltage must be measured near the expected lowest voltage location on the primary line at EOL.

9. The VO primary line maximum hourly voltage must be less than [126 Volts -  $\frac{1}{2}$  the voltage regulation bandwidth]. Acceptable voltage regulation bandwidth is in the range of 2V to 3V on 120V base. Primary line maximum voltage must be measured near the expected highest voltage location on the primary line at or near the voltage-control-zone regulator measured over the measurement-period averaged over each hour.

*Note: The Customer Service Voltage must be between 126 Volts to 114 Volts for normal system switching configuration measured line to ground on a 120 Volt base over the measurement period integrated over the interval period of one hour. For infrequent abnormal operating conditions, the customer service voltage range is 127 Volts to 110 Volts.*

## **2.4 About Distribution System Load and Operating Data Collection**

Additional system data is collected for all VO voltage control zones from annual historical data, during the pre-VO and post-VO measurement periods, and through annual certification measurement periods. The system data is needed to determine the average voltage reduction and resultant energy savings for each VO voltage control zone.

Annual load peak demand or annual energy adjustments for temperature, abnormal switching configuration, or seasonal load anomalies may be performed to reflect normal annual loading operations.

This data is determined for each VO voltage control zone and includes:

1. Annual 3 $\phi$  peak kW hourly demand and annual energy kWh. The VO assessment must also include an actual or adjusted annual kW peak demand and energy delivered by substation and assigned to each VO feeder and voltage control zone. This data is used to calculate annual load factor [annual 3 $\phi$  kWh energy delivered / [maximum annual 3 $\phi$  peak kW hourly demand \* 8760 h]]
2. Hourly demand phase Amps for each VO voltage control zone source over the measurement period averaged over each hour.
3. Hourly demand kW over the measurement period for each VO voltage control zone, adjusted for normal conditions as required.
4. Hourly demand kvar over the measurement period for each VO voltage control zone, adjusted for normal conditions as required.
5. Maximum primary voltage-drop at the time of the 3 $\phi$  peak kW demand (on 120V base). The voltage-drop is the average value measured over the peak hour. Distribution system modeling may be performed to determine system maximum primary voltage-drop. Source substation and line regulator Set-Point-Voltage settings on 120V base (in Volts)
6. Source substation and line regulator Current Transformer (CT) Primary Rating (in Amps)
7. Source substation and line regulator Potential Transformer (PT) Ratio (line-to-ground)
8. Source substation and line regulator real volts 'R' and reactive volts 'X' control setting on 120V base (in Volts)

9. Calculated regulator maximum voltage-rise at maximum 3 $\phi$  peak kW hourly demand on 120V base (in Volts). Distribution system modeling and simulation may be performed to determine system maximum voltage-rise at maximum peak demand.

*Note: The VO regulator voltage-rise is based on the peak load, control zone power factor and regulator control settings. For example, for most common conditions with average power factor greater than 0.98 and a 'X' setting equal to zero, the regulator maximum voltage-rise is [ $R$  setting (Volts) \* average annual power factor (p.u.) \* maximum annual 3 $\phi$  peak hourly demand (Amps) / Current Transformer Primary Rating (Amps)]. All measurements are averaged over each hour.*

## **2.5 About Distribution System Equipment Data**

In addition to the measured or determined system parameters, additional information must be available to ensure correct system modeling, power flow simulations, and determine maximum voltage-drops and maximum voltage rises for all VO voltage control zones. The electric utility distribution system data is collected for system preliminary assessments, baseline pre-VO, post-VO, and annual self-certification M&V assessments for each VO application. The modeling data set includes:

1. Primary kV line-to-line voltage class (typically identified as the Distribution Transformer primary line-to-ground kV voltage rating.)
2. Distribution system maps and/or models depicting conductor sizes, phase configuration, and connected kVA size and location of distribution transformers.
3. Location, size, and type of all station regulators and line regulators including control settings for each (e.g., set-point-voltage, R & X settings, time delay, CT Rating and PT ratio, regulator bandwidth, and regulator first house protection settings.)
4. Location and size of Shunt Capacitor banks and control settings (if applicable). For simplified VO application, switch capacitor control must be 'var' control only.
5. Overall utility characteristics, design guidelines, construction standards, historical system studies, customer information, and equipment data.

## **2.6 About Metering Requirements**

Metering equipment is required to provide the measurement and verification of data for all VO voltage control zones for pre-VO, post-VO, and annual self-certification monitoring. Meters must collect kW demand, kvar demand, ampere demand, and volts measured over the measurement-period with measurements averaged over each hour. Metering locations include:

- Substation power transformer (on regulated voltage side).
- Substation feeder breakers.
- Line Regulator equipment (on regulated voltage side).
- Remote primary line EOL low voltage point locations (voltage recording meters only) for each VO voltage control zone.

Metering installations and calibration must be performed by qualified personnel. If feasible, it is desirable that all metering instrumentation complies with ANSI Standard C57.13

metering accuracy specifications. Substation and regulator metering data can be collected from energy/demand meters, electronic relays, or controllers provided they provide data on all phases present. Utility field self-verification and inspections are required to verify correct meter installation and correct register readings.

For VFR and LDC systems, one remote primary line EOL voltage-recording meter must be installed at the lowest voltage point locations on each of the primary feeders for each voltage-control-zone. For AVFC systems, there must be three-volt recording meters and volt remote feedback-sensing devices installed on each primary feeder at independent locations. The meters should measure voltage on all phases present for VRF, LDC, and AVFC systems.

### **3.0 About VO Factor and Energy Savings Calculations**

#### **3.1 Customer Data**

Customer load information is required for each distribution substation where VO may be applied. This customer information is used to determine the end-use VO Factor from Appendix A Tables, which are used in energy savings calculations. Based on known customer information available for the electric utility (e.g. customer information systems, utility mapping records, and customer billing system) the customer load characteristics are determined. It may be necessary to provide an estimate of customer load characteristics using typical load research data or other similar analysis. The required customer load characteristics are as follows:

1. Heating and cooling climate zone classification for each substation area.
2. Percentage of substation area total annual load (kWh) that is classified as residential class load.
3. Percentage of existing residential class consumers that have electric heat (hot water, space heating, and/or heat pump). Non electric heat is typically provided by gas, oil, or wood.
4. Percentage of existing residential class consumers that have any type of electric air conditioning.

#### **3.2 About End Use VO Factor**

The end-use VO Factor is a ratio of expected % change in energy delivered for each 1% change in average voltage supplied at the end-use service entrance. The end use VO Factor is given as a p.u. ratio for a given system and is determined from VO Factor Tables in Appendix A of this Protocol. Enter the table identified for the Heating and cooling climate zone associated for each substation and select the appropriate VO Factor using the percent customers with Non-Electric Heating (and Heat Pumps) and percent of customers with Air-conditioning.

#### **3.3 About Determination of Average Voltage Reduction**

For each VO voltage control zone (pre-VO and post-VO conditions), the average voltage formulation depends upon the voltage control method chosen (e.g., VFR, LDC, or AVFC.) The normalized average annual voltages are determined at the baseline pre-VO measurements (Stage 2) and post-VO measurements (Stage 3) from 168 metered-hours emulating a 7-day period as follows:

A = Calculated Feeder Maximum Annual Volt-Drop

$$= \text{Average\_of\_all\_Volt-Drop(hourly)} * [\text{maximum\_annual\_3}\phi\text{\_peak\_kW\_demand(hourly)} / \text{average\_kW\_demand(hourly)}]$$

B = Calculated Regulator Maximum Annual Volt-Rise

$$= [\text{Average\_of\_all\_Regulator\_Output\_Voltages(hourly)} - (\text{Regulator\_Set\_Point\_Voltage\_Setting})] * [\text{maximum\_annual\_3}\phi\text{\_peak\_kW\_demand(hourly)} / \text{average\_kW\_demand(hourly)}]$$

*Note: The Volt-Drop (hourly) is the metered Regulator Output Voltage minus the lowest EOL voltage averaged over each hour. All values are calculated over the measurement-period. Variables A and B may be determined via system modeling simulations for initial VO average voltage estimates and annual self-certification assessments.*

The final post-VO verified average annual voltage reduction is the difference between the adjusted pre-VO and post-VO average annual voltages weighted by VO voltage control zone kW load and depends on the pre-VO and the post-VO voltage control techniques applied.

The annual 3 $\phi$  peak kW hourly demand and Annual Load Factor are known from the measured historical data.

The baseline pre-VO overall average voltage for all VO voltage control zones is determined by applying the existing non-VO control settings and applying control setting adjustments to mimic pre-VO average voltage conditions (non-VO operation). Pre-VO control settings are determined using system modeling.

The adjusted average voltage calculation formulation for pre-VO and post-VO measurements for each voltage-control-zone is described as follows:

**\*\*\*\* VFR Methods\*\*\*\***

For VFR applications, the regulator R and X control settings are zero.

$$\text{Adjusted Average Voltage for VFR} = [\text{Regulator\_Set\_Point\_Voltage\_Setting} - \frac{1}{2} * A * \text{Annual\_Load\_Factor}]$$

**\*\*\*\* LDC and AVFC Methods\*\*\*\***

For LDC applications, the regulator R and X control settings should be set so that the maximum voltage rise B is equal to or greater than the maximum annual voltage-drop A.

$$\text{Adjusted Average Voltage for LDC or AVFC} = [\text{Regulator\_Set\_Point\_Voltage\_Setting} + \text{Annual\_Load\_Factor} * [B - \frac{1}{2} * A]]$$

### **3.4 About Determination of Average Annual Energy Reduction**

For each voltage-control-zone, the average voltage is calculated as shown in Section 3.3 above for the baseline pre-VO and post-VO conditions. If there are multiple voltage-control-zones within each VO application area, the overall system average annual voltage



is the average of the control zone voltages weighted by control zone loads. All average annual voltages are on a 120V base.

Variables A and B can be determined via system modeling for initial VO average voltage estimates and annual self-certification assessments. The VO energy savings used for determining the initial VO estimate, final post-VO verification, or annual assessment is calculated as follows:

$$\begin{aligned} \text{Overall Average Voltage Reduction (in volts)} &= \\ &[\text{Weighted Average Voltage (pre-VO)} - \text{Weighted Average Voltage (post-VO)}] \\ \text{Overall Average Voltage Reduction (p.u.)} &= \\ &[\text{Overall Average Voltage Reduction (in volts)} / 120] \\ \text{Energy Change (p.u.)} &= \text{Overall Average Voltage Reduction (p.u.)} * \text{VO Factor} \\ \text{VO Energy Change (MWh)} &= \text{Annual } 3\phi \text{ kWh energy load} * \text{Energy Change (p.u.)} \end{aligned}$$

The VO design should not yield voltages for customers outside the nominal ANSI C84.1 Standard Voltage Range of 126-114 Volts (on 120V base). In practice it is desired to achieve an overall average voltage for primary lines in the range of 122-118 Volts and depends on the secondary maximum allowed voltage-drop. At the residential and light commercial customer service meter, the goal is to have an average voltage between 120-114 Volts.

#### **4.0 Recommendations for Ensuring Persistence of Energy Savings**

System improvements typically have a useful life exceeding 35 years. However, control settings are easily altered over time unless they are integrated into utility operating and design standards. For new operating design standards to become entrenched, a three-year monitoring and documentation period is recommended. Standards that become entrenched tend to extend the life of VO perpetually.

This 3-year period includes the following:

1. On a monthly basis, a utility must document that voltage control settings within each the VO voltage control zone are maintained as necessary to be consistent with those determined during the original VO project.
2. On an annual basis, provide total kWh usage on the voltage control zone and provide average voltage at Substation and EOL.
3. A utility must maintain this documentation (or provide it to the appropriate organization) annually for a 3-year period.
4. During this three year period, if the voltage control settings have been off-line, either intentionally or unintentionally for a period of 30 days or longer, the utility must continue to maintain the voltage control setting documentation for a period equal to 30 days or longer beyond the original 3 year documentation period.
5. Verify performance thresholds for each voltage-control-zone and corrective actions taken if any. Thresholds include:
  - a. Feeder power factor – Average hourly > 0.98 from metered data

- b. Feeder power factor – Maximum hourly > 0.96 from metered data
- c. EOL primary voltage must be > [114 Volts +  $\frac{1}{2}$  the voltage regulation bandwidth + secondary maximum allowed voltage-drop] from metered data
- d. Regulator primary voltage must be < [126 Volts -  $\frac{1}{2}$  the voltage regulation bandwidth + secondary maximum allowed voltage-drop] from metered data
- e. Feeder load unbalance must be < 0.15 from system modeling
- f. Feeder Source 3 $\phi$  feeder neutral current < 40 Amps from metered data
- g. Feeder maximum adjusted primary voltage-drops < 3.3% from system modeling
- h. Feeder maximum voltage-drop variance < 2.0 V on a 120V base.

## APPENDIX A

### VO FACTOR TABLES

#### FOR USE WITH SIMPLIFIED VO M&V PROTOCOL

Source of VO Factors is 2007 NEEA DEI Project Load Research Survey Reported Results

**Instructions:** These End-Use VO Factors are for use with the Simplified VO M&V Protocol. The End-Use VO Factor Tables are for use with distribution system customers classified as residential and small commercial as defined by the utility. To identify the appropriate VO Factor, locate the VO Factor Table for the known heating and cooling zone. The end-use VO Factor is derived by selecting the percent of customers with non-electric heat (and heat pumps) and percent of customers with air-conditioning. VO Factors are shown as percent of change in energy to percent change in average annual voltage. The tables are obtained from the NEEA Distribution Efficiency Initiative project 2003-2007, which performed VO load research evaluation on end-use loads throughout the Northwest for different climate zone.

Table 1 – End-Use VO Factors for Climate Zone Heating 1 and Cooling 1

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.38	0.42	0.46	0.51	0.56	0.63	0.70
10	0.27	0.30	0.33	0.36	0.39	0.43	0.47	0.51	0.57	0.63	0.70
20	0.27	0.31	0.33	0.36	0.40	0.43	0.47	0.52	0.57	0.63	0.70
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.52	0.57	0.63	0.69
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.58	0.63	0.69
50	0.30	0.33	0.36	0.39	0.42	0.45	0.49	0.54	0.58	0.63	0.69
60	0.31	0.34	0.36	0.39	0.43	0.46	0.50	0.54	0.59	0.63	0.69
70	0.32	0.35	0.37	0.40	0.44	0.47	0.51	0.55	0.59	0.64	0.69
80	0.33	0.36	0.38	0.41	0.44	0.48	0.51	0.55	0.59	0.64	0.68
90	0.34	0.37	0.39	0.42	0.45	0.49	0.52	0.56	0.60	0.64	0.68
100	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.56	0.60	0.64	0.68

Table 2 – End-Use VO Factors for Climate Zone Heating 1 and Cooling 2

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.38	0.42	0.46	0.51	0.56	0.63	0.70
10	0.27	0.30	0.33	0.36	0.39	0.43	0.47	0.51	0.57	0.63	0.70
20	0.28	0.31	0.33	0.36	0.40	0.43	0.47	0.52	0.57	0.63	0.69
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.52	0.57	0.63	0.69
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.58	0.63	0.69
50	0.30	0.33	0.36	0.39	0.42	0.45	0.49	0.53	0.58	0.63	0.69
60	0.31	0.34	0.37	0.40	0.43	0.46	0.50	0.54	0.58	0.63	0.69
70	0.32	0.35	0.37	0.40	0.44	0.47	0.51	0.55	0.59	0.63	0.68
80	0.33	0.36	0.38	0.41	0.44	0.48	0.51	0.55	0.59	0.64	0.68
90	0.34	0.37	0.39	0.42	0.45	0.49	0.52	0.56	0.60	0.64	0.68
100	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.56	0.60	0.64	0.68

Table 3 – End-Use VO Factors for Climate Zone Heating 1 and Cooling 3

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.39	0.42	0.46	0.51	0.55	0.61	0.66
10	0.27	0.30	0.33	0.36	0.39	0.43	0.47	0.51	0.56	0.61	0.66
20	0.28	0.31	0.34	0.37	0.40	0.44	0.47	0.52	0.56	0.61	0.66
30	0.29	0.31	0.34	0.37	0.41	0.44	0.48	0.52	0.56	0.61	0.66
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.57	0.61	0.66
50	0.30	0.33	0.36	0.39	0.42	0.46	0.49	0.53	0.57	0.61	0.66
60	0.31	0.34	0.37	0.40	0.43	0.46	0.50	0.54	0.57	0.62	0.66
70	0.32	0.35	0.38	0.41	0.44	0.47	0.50	0.54	0.58	0.62	0.66
80	0.33	0.36	0.39	0.42	0.45	0.48	0.51	0.55	0.58	0.62	0.66
90	0.34	0.37	0.40	0.42	0.45	0.49	0.52	0.55	0.59	0.62	0.66
100	0.35	0.38	0.41	0.43	0.46	0.49	0.52	0.56	0.59	0.62	0.66

Table 4 – End-Use VO Factors for Climate Zone Heating 2 and Cooling 1

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.34	0.38	0.42	0.46	0.51	0.58	0.66	0.75
10	0.27	0.30	0.32	0.35	0.38	0.42	0.47	0.52	0.58	0.66	0.75
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.66	0.74
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.59	0.66	0.74
40	0.29	0.32	0.35	0.37	0.41	0.44	0.49	0.54	0.59	0.66	0.73
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.66	0.73
60	0.31	0.34	0.36	0.39	0.42	0.46	0.50	0.55	0.60	0.66	0.73
70	0.32	0.34	0.37	0.40	0.43	0.47	0.51	0.55	0.60	0.66	0.72
80	0.33	0.35	0.38	0.41	0.44	0.48	0.52	0.56	0.61	0.66	0.72
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.61	0.66	0.71
100	0.35	0.37	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.66	0.71

Table 5 – End-Use VO Factors for Climate Zone Heating 2 and Cooling 2

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.34	0.38	0.42	0.46	0.51	0.58	0.66	0.75
10	0.27	0.30	0.32	0.35	0.38	0.42	0.47	0.52	0.58	0.66	0.75
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.66	0.74
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.59	0.66	0.74
40	0.29	0.32	0.32	0.37	0.41	0.44	0.49	0.54	0.59	0.66	0.73
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.66	0.73
60	0.31	0.34	0.36	0.39	0.42	0.46	0.50	0.55	0.60	0.66	0.73
70	0.32	0.34	0.37	0.40	0.43	0.47	0.51	0.56	0.60	0.66	0.72
80	0.33	0.35	0.38	0.41	0.44	0.48	0.52	0.56	0.61	0.66	0.72
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.61	0.66	0.71
100	0.35	0.37	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.66	0.71

Table 6 – End-Use VO Factors for Climate Zone Heating 2 and Cooling 3

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.34	0.38	0.42	0.46	0.51	0.58	0.65	0.75
10	0.27	0.30	0.32	0.35	0.39	0.42	0.47	0.52	0.58	0.65	0.75
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.65	0.74
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.59	0.66	0.74
40	0.29	0.32	0.35	0.37	0.41	0.45	0.49	0.54	0.59	0.66	0.73
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.66	0.73
60	0.31	0.34	0.36	0.39	0.42	0.46	0.50	0.55	0.60	0.66	0.72
70	0.32	0.34	0.37	0.40	0.43	0.47	0.51	0.55	0.60	0.66	0.72
80	0.33	0.35	0.38	0.41	0.44	0.48	0.52	0.56	0.60	0.66	0.72
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.61	0.66	0.71
100	0.35	0.37	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.66	0.71

Table 7 – End-Use VO Factors for Climate Zone Heating 3 and Cooling 1

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.38	0.42	0.46	0.51	0.57	0.64	0.73
10	0.27	0.30	0.32	0.35	0.39	0.42	0.47	0.52	0.58	0.64	0.73
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.65	0.72
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.58	0.65	0.72
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.59	0.65	0.72
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.65	0.71
60	0.31	0.34	0.36	0.39	0.43	0.46	0.50	0.54	0.59	0.65	0.71
70	0.32	0.35	0.37	0.40	0.43	0.47	0.54	0.55	0.60	0.65	0.71
80	0.33	0.35	0.38	0.41	0.44	0.48	0.51	0.56	0.60	0.65	0.70
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.60	0.65	0.70
100	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.65	0.70

Table 8 – End-Use VO Factors for Climate Zone Heating 3 and Cooling 2

%AC	% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)										
	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.38	0.42	0.46	0.51	0.57	0.64	0.73
10	0.27	0.30	0.32	0.35	0.39	0.42	0.47	0.52	0.58	0.64	0.73
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.65	0.72
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.58	0.65	0.72
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.59	0.65	0.72
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.65	0.71
60	0.31	0.34	0.36	0.39	0.43	0.46	0.50	0.54	0.59	0.65	0.71
70	0.32	0.35	0.37	0.40	0.43	0.47	0.51	0.55	0.60	0.65	0.71
80	0.33	0.35	0.38	0.41	0.44	0.48	0.51	0.56	0.60	0.65	0.70
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.60	0.65	0.70
100	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.65	0.70

Table 9 – End-Use VO Factors for Climate Zone Heating 3 and Cooling 3

% of Customers with Non Electric Heat and Heat Pumps (e.g. gas, oil, or wood heat)											
%AC	0%	10%	20%	30%	40%	50%	60%	70%	80%	90%	100%
0	0.27	0.29	0.32	0.35	0.38	0.42	0.46	0.51	0.57	0.64	0.73
10	0.27	0.30	0.32	0.35	0.39	0.42	0.47	0.52	0.58	0.64	0.73
20	0.28	0.30	0.33	0.36	0.39	0.43	0.47	0.52	0.58	0.65	0.72
30	0.29	0.31	0.34	0.37	0.40	0.44	0.48	0.53	0.58	0.65	0.72
40	0.29	0.32	0.35	0.38	0.41	0.45	0.49	0.53	0.59	0.65	0.72
50	0.30	0.33	0.35	0.38	0.42	0.45	0.49	0.54	0.59	0.65	0.71
60	0.31	0.34	0.36	0.39	0.43	0.46	0.50	0.54	0.59	0.65	0.71
70	0.32	0.35	0.37	0.40	0.43	0.47	0.51	0.55	0.60	0.65	0.71
80	0.33	0.35	0.38	0.41	0.44	0.48	0.51	0.56	0.60	0.65	0.70
90	0.34	0.36	0.39	0.42	0.45	0.49	0.52	0.56	0.60	0.65	0.70
100	0.35	0.38	0.40	0.43	0.46	0.49	0.53	0.57	0.61	0.65	0.70

####

# Appendix 9: Summary of Circuit Analysis by Stage

Bowman Substation T3853  
Summary of Distribution Power Flow Results

Bowman 5W150 & 154

Bowman		T3853	Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5W150	A		2065.6	193.4							R = 4.0	123.3	118.0	118.0
	B		2278.6	283.1			Cust/Load	3.59		X = 0.0	123.3	117.4	117.4	
	C		2370.8	388.1			kVA/Cust	10.20		CT = 1200.0	123.3	114.7	114.7	
				Ineut =	37.6		Cust =	2334		Vset = 121.0				
										PT = 60.0				
	T	33,096,331	6715.0	864.6	5.9%	1800.0	99.2%	23831.0	325.2	381.6	1.0276	0 V	Δ = 3.3 V	Δ = 8.6 V
	LL		2431.6	-855.5							1.0147	121.8	120.3	120.3
5W154	A		2728.8	-4.8							R =	123.3	120.9	120.9
	B		2841.6	39.0			Cust/Load			X =	123.3	121.5		
	C		2629.1	-46.2			kVA/Cust			CT =	123.3	122.4		
				Ineut =	27.0		Cust =	2074		Vset =				
										PT =				
	T	37,063,709	8199.5	-12.0	4.0%	3000.0	100.0%	24580.5	98.8	247.7		0 V	Δ = 1.5 V	Δ = 2.4 V
	LL		2507.5	-2018.1								121.8	123.1	123.1

Existing Regulator	Settings	Regulator Flow HL	Regulator Flow LL		Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
R =	3.5	2683.2	988	HL	A	125.5	123.2
X =	0.0	124.2 A			B	124.7	120.3
CT =	250.0				C	121.7	117.1
Vset =	120.0	HL V = 1.0145		LL		120.5	119.5
PT =	60.0	LL V = 1.0053					

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5W150 S01a	Spot Load Changes	TR_230303_593050171 TR_245000_1540700183 TR_249380_593050811 TR_361980_456710504	291, 0.961 0, 1 153, 0.985 13, 0.997		None
5W154 S01a					None
5W150 S01b	Remove Caps	FP269902_302080200	-900 kVAr		To avoid further dropping the 8.6 V drop to EOL to 9.3 V we did not remove 900 kVAr
5W154 S01b	Remove Caps Remove Caps	FP357704_369970265 FP300602_1540121947	- 900 kVAr - 900 kVAr		

Bowman		T3853	Stage-01										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5W150	A	2042.2	171.9							R = 7.0	125.0	119.9	119.9
	B	2288.4	279.5							X = 0.0	125.0	119.1	119.1
	C	2379.0	385.1							CT = 1200.0	125.0	116.5	116.5
				Ineut =	41.5					Vset = 121.0			
										PT = 60.0			
	T	6709.6	836.5	6.4%	1800.0	99.2%	23831.0	334.3	394.8	1.0420	0 V	Δ = 3.4 V	Δ = 8.5 V
	LL	2431.4	-874.8							1.0195	122.3	120.9	120.9
5W154	A	2728.6	610.0							R =	125.0	120.8	120.8
	B	2839.9	659.4							X =	125.0	121.5	
	C	2628.7	579.0							CT =	125.0	122.2	
				Ineut =	25.2					Vset =			
										PT =			
	T	8197.2	1848.4	3.9%	3000.0	97.6%	24580.5	98.7	256.1		0 V	Δ = 1.3 V	Δ = 4.1 V
	LL	2496.4	-138.3								122.3	121.8	121.8

Existing Regulator	Settings	Regulator Flow HL	Regulator Flow LL		Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
R =	3.5	2683.2	988	HL	A	125.2	122.8
X =	0.0	124.2 A			B	124.3	119.7
CT =	250.0				C	121.4	116.6
Vset =	120.0	HL V = 1.0145		LL		121.1	119.9
PT =	60.0	LL V = 1.0053					



Changes for Stage-2	Node	Line	Load	Losses	Swap Phases
5W150 S02a	FP269903_302080452	5W150_302080024			CAB->ABC
S02b	Add Sw Cap FP249363_593050816		+ 900 kVAr		
S02c	No reconductoring needed				

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5W154 S02b	Add Sw Cap FP357704_369970265 Add Sw Cap FP300602_1540121947		+ 900 kVAr + 900 kVAr		
S02c	No reconductoring needed				

5W150 S02e FP239002 5W150\_593050032-SP1 [ld = 602] 328 A 3Ph 16 step 3x180 kVA

Add Regulator	Settings	Regulator Flow HL	Regulator Flow LL
R =	4.5	5202.3	2225
X =	0.0	240.9 A	
CT =	400.0		
Vset =	120.0	HL V = 1.0226	
PT =	60.0	LL V = 1.0097	

HL 122.7  
LL 121.2

Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
120.0	123.1	119.9
122.0	122.8	120.9
120.3	122.6	120.2
120.0	120.8	120.1

Δ = 3.1 V

Bowman		T3853	Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Volt pu Balance	Regulator Voltage Pri	Min Volt pu
5W150	A	2292.1	-7.5						R = 9.0	124.1	120.0	120.0	
	B	2211.2	-78.9						X = 0.0	124.2	122.0	122.0	
	C	2188.9	-84.5						CT = 1200.0	124.2	120.3	120.3	
				Ineut = 17.3					Vset = 119.0				
									PT = 60.0				
	T	6692.2	-170.9	2.8%	1800.0	100.0%	23831.0	302.3	359.7	1.0350	0 V	Δ = 2 V	Δ = 4.1 V
	LL	2429.6	-839.9							1.0060	120.7	120.0	120.0
5W154	A	2728.2	-22.7						R =	124.1	121.9	121.9	
	B	2841.2	20.3						X =	124.2	122.5		
	C	2628.8	-64.5						CT =	124.2	123.3		
				Ineut = 26.9					Vset =				
									PT =				
	T	8198.2	-66.9	4.0%	3000.0	100.0%	24580.5	97.6	241.9		0 V	Δ = 1.5 V	Δ = 2.3 V
	LL	2496.6	-100.6								120.7	120.1	120.1

Existing Regulator	Settings	Regulator Flow HL	Regulator Flow LL
R =	14.0	2683.2	988
X =	0.0	124.2 A	
CT =	250.0		
Vset =	118.0	HL V = 1.0413	
PT =	60.0	LL V = 1.0047	

HL  
LL

Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
119.9	124.3	119.7
120.9	125.5	
120.2	124.7	120.1
120.1	120.4	119.4

Δ = 4.6 V

Dodd Road Substation T1202  
Summary of Distribution Power Flow Results

Dodd Road 4W22

Dodd Road		T1202		Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
4W22	A		2729.8	1077.0						R =	6.0	128.2	121.2	121.2	
	B		3052.6	1262.0			Cust/Load	3.02		X =	0.0	128.2	119.5	119.5	
	C		2917.0	1193.0			kVA/Cust	20.00		CT =	400.0	128.2	119.7	119.6	
					Ineut =	24.7		Cust =	1451		Vset =	121.0			
										PT =	100.0				
	T		39,919,839	8699.4	3532.0	5.3%	600.0	92.7%	29034.5	288.9	-13.5	1.0587	0 V	Δ = 1.7 V	Δ = 8.7 V
LL			6235.6	845.0							1.0444	126.2	121.0	121.0	

Changes for Stage-1

<b>Node</b>	<b>Line</b>	<b>Load</b>	<b>Losses</b>	<b>Swap Phases</b>
4W22 S01a				none
S01b Add Cap FP017006_682660347		+ 900 kVAr		

Dodd Road		T1202		Stage-01											
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage		
4W22	A		2726.1	793.2						R =	5.0	125.0	118.8	118.8	
	B		3049.2	984.6						X =	0.0	125.0	117.1	117.1	
	C		2913.4	916.1						CT =	400.0	125.0	117.2	117.2	
					Ineut =	25.4				Vset =	120.0				
										PT =	100.0				
	T		8688.7	2693.9	5.3%	600.0	95.5%	29034.5	278.3	-12.0	1.0420	0 V	Δ = 1.7 V	Δ = 7.9 V	
LL			6235.8	-41.5							1.0301	123.6	119.3	119.3	

Changes for Stage-2

<b>Node</b>	<b>Line</b>	<b>Load</b>	<b>Conductor</b>	<b>Length (ft)</b>
4W22 S02b Add Sw Cap FP179040_776390396		+ 1800 kVAr		
Add Sw Cap FP289361_423450417		+ 300 kVAr		
Add Sw Cap FP340061_1540847160		+ 300 kVAr		
S02c 1 from FP289003_1540261624			1780 [20.8 #6 CU 3F	447.0
to FP339960_423450423			1690 [20.8 795AAC3PLn 8xa]	

S02e1 FP187200 4W22\_776390096-SP2 [ld = 1033] [20.8 3-ph 347A]

Regulator	Settings	Regulator Flow HL	Regulator Flow LL
R =	4.5	2006.7	1342
X =	0.0	92.9 A	
CT =	120.0		
Vset =	120.0	HL V =	1.0290
PT =	60.0	LL V =	1.0194

Regulator	Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
HL A	120.8	123.8	120.6
B	121.4	123.6	122.1
C	121.0	123.3	121.1
LL	120.4	122.0	119.9

S02e2 FP172640 4W22\_776390081-SP1 [ld = 1033] [20.8 3-ph 347A]

APPENDIX 9

Regulator Settings		Regulator Flow HL	Regulator Flow LL
R =	6.0	2814.2	2047
X =	0.0	130.3 A	
CT =	150.0		
Vset =	118.0	HL V =	1.0268
PT =	60.0	LL V =	1.0149

	Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
HL A	121.6	123.1	120.5
B	120.9	123.2	119.8
C	120.8	123.0	119.9
LL	120.4	121.6	119.9

Dodd Road		T1202	Stage-02												
Circuit ID	Ph		Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
4W22	A		2716.5	-65.1						R =	4.0	124.0	121.9		
	B		3038.2	119.1						X =	0.0	124.0	121.3		
	C		2903.2	55.4						CT =	400.0	124.0	121.2	119.8	
					Ineut =	25.1					Vset =	120.0			
											PT =	100.0			
	T		8657.9	109.4	5.3%	600.0	100.0%	29034.5	247.4	-33.0	1.0336	0 V	Δ = 0.7 V	Δ = 4.2 V	
	LL		6236.4	-9.2							1.0241	122.9	120.8	119.9	

Mill Creek Substation T3406  
Summary of Distribution Power Flow Results

Mill Creek 5W116 & 127

Mill Creek		T3406		Base Case (w/ Fielding)										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5W116	A		2618.1	326.9						R =	0.0	123.9	121.3	120.0
	B		2704.0	345.6			Cust/Load	6.24		X =	0.0	123.9	120.0	118.5
	C		2775.2	387.3			kVA/Cust	7.40		CT =	900.0	124.0	120.6	118.9
				Ineut =	17.8		Cust =	2402		Vset =	124.0			
	T	34,126,578	8097.3	1059.7	2.8%	600.0	99.2%	17726.0	122.6	193.9	1.0333	0 V	Δ = 1.3 V	Δ = 5.4 V
	LL		2147.5	59.4							1.0333	124.0	123.1	122.7
5W127	A		2103.5	479.1								123.9	118.8	118.8
	B		2734.4	649.5			Cust/Load	6.53				123.9	121.2	121.2
	C		1380.5	287.7			kVA/Cust	7.00				124.0	123.9	123.9
				Ineut =	163.1		Cust =	2169						
	T	29,177,609	6218.4	1416.2	31.9%	0.0	97.5%	15105.0	65.7	190.4		0.1 V	Δ = 5.1 V	Δ = 5.1 V
	LL		1830.5	562.2								124.0	122.4	122.3

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5W116 S01a					None
5W127 S01a	FP288803_544871716 FP219405_242020779 FP283816_544870486 FP291702_717550718 FP294700_717550725 FP285903_544870459	5W127_544870102 5W127_242020295 5W127_544870085 5W127_717550132 5W127_1540944656 5W127_544870096			CBA->CAB B->C B->C CBA->BAC B->C CBA->BAC
5W116 S01b					
5W127 S01b	New Cap	FP282811_544870470	+ 600 kVAr		

Mill Creek		T3406		Stage-01									
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5W116	A	2617.4	314.0						R =	8.0	124.8	122.3	121.0
	B	2703.1	336.8						X =	0.0	124.9	121.0	119.5
	C	2775.0	381.0						CT =	900.0	124.9	121.5	119.8
				Ineut =	18.0				Vset =	119.0			
	T	8095.5	1031.8	2.8%	600.0	99.2%	17726.0	120.8	189.2	1.0408	0 V	Δ = 1.4 V	Δ = 5.3 V
	LL	2148.0	98.5							1.0053	120.6	119.7	119.3
5W127	A	2101.1	268.7								124.8	121.5	121.4
	B	2158.7	273.9								124.9	122.9	122.9
	C	1950.5	209.4								124.9	123.5	123.5
				Ineut =	27.9								
	T	6210.3	752.0	4.3%	0.0	99.3%	15105.0	57.8	163.0		0 V	Δ = 2.1 V	Δ = 3.4 V
	LL	1830.0	-42.6								120.6	119.7	119.7

Changes for Stage-2	Node	Line	Load
5W116 S02b	Add Sw Cap	FP166061_755430427	+ 900 kVAr

Node	Line	Load	Conductor	Length (ft)
S02c	No reconductoring needed			

Node	Load
------	------

APPENDIX 9

5W127 S02b Add Sw Cap FP289805\_544870439 +600 kVAr

**Node**  
**S02c** No reconductoring needed  
**S02e** FP165101  
**Line** 5W116\_755430072-SP1  
**Load** [ld = 63] 219 A 3Ph 16 step 3x180 kVA  
**Conductor**  
**Length (ft)**

Add Regulator	Settings	Regulator Flow HL	Regulator Flow LL
R =	7.0	3316	878
X =	0.0	153.5 A	
CT =	400.0		
Vset =	120.0	HL V =	1.0224
PT =	60.0	LL V =	1.0059

122.7  
120.7

HL  
LL

	Regulator Voltage Pri	Regulator Voltage Sec	Reg. Min Voltage
A	122.0	124.1	121.6
B	120.5	122.5	120.0
C	121.2	123.3	120.2
	120.2	120.9	120.3

Mill Creek		T3406		Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5W116	A	2615.3	123.4							R = 4.0	122.9	122.0	122.0	
	B	2701.1	155.5							X = 0.0	122.9	120.5	120.5	
	C	2772.9	198.3							CT = 900.0	122.9	121.2	121.2	
				Ineut = 19.4							Vset = 120.0			
											PT = 60.0			
	T	8089.3	477.2	2.8%	600.0	99.8%	17726.0	114.6	192.2	1.0246	0 V	Δ = 1.5 V	Δ = 2.4 V	
	LL	2147.9	95.4							1.0068	120.8	120.2	120.2	
5W127	A	2102.0	70.5								122.9	119.6	119.6	
	B	2159.4	73.3								122.9	121.1	121.1	
	C	1950.4	6.8								122.9	121.8	121.7	
				Ineut = 28.7										
		T	6211.8	150.6	4.3%	0.0	100.0%	15105.0	59.3	167.8		0 V	Δ = 2.1 V	Δ = 3.3 V
	LL	1830.0	-44.6								120.8	119.9	119.9	

Pomeroy Substation T944  
Summary of Distribution Power Flow Results

Pomeroy 5W342

Pomeroy		T944		Base Case (w/ Fielding)										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE1: Branch Voltage Balance	LE1: Control Zone Min Voltage
5W342	A		1821.1	-165.4						R =	2.0	124.7	123.3	122.3
	B		1926.8	-171.6			Cust/Load	3.40		X =	0.0	124.7	121.5	119.0
	C		2292.4	-108.3			kVA/Cust	11.0		CT =	400.0	124.7	121.2	122.3
				Ineut =	55.4		Cust =	1528		Vset =	123.0			
										PT =	60.0			
	T	22,784,281	6040.3	-445.3	13.9%	600.0	99.7%	16801.0	194.1	135.5	1.0367	0 V	Δ = 2.1 V	Δ = 5.6 V
LL		1595.6	-558.6							1.0281	123.5	122.6	121.4	
												122.3	122.2	

BE2: Branch Voltage Balance	LE2: Control Zone Min Voltage
119.7	118.5
120.4	
116.6	
Δ = 3.7 V	Δ = 6.3 V
	Δreg = 3.1 V

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5W342 S01a	FP171860_420450094 FP310600_463490170 FP325202_761212279	5W342_420450011 5W342_1540118006 5W342_761210085			BAC->BCA BAC->BCA BC->CB
Spot Load Changes	TR_314380_761210523 TR_315100_1540376750 TR_317080_761210594 TR_317180_761210375 TR_329402_761210710		281, 0.997 184, .997 216, .936 459, .997 0, 1		
S01b					None

Pomeroy		T944		Stage-01										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE1: Branch Voltage Balance	LE1: Control Zone Min Voltage	
5W342	A	1918.6	-170.8						R =	2.5	124.7	121.7	117.6	
	B	2150.5	-139.9						X =	0.0	124.7	122.5	121.2	
	C	1965.1	-153.8						CT =	400.0	124.8	122.6	120.8	
				Ineut =	27.2					Vset =	123.0		Trial 1 R =	3.0
										PT =	60.0		Trial 2 R =	4.0
	T		6034.2	-464.5	6.9%	600.0	99.7%	16801.0	187.9	129.6	1.0396	0 V	Δ = 0.8 V	Δ = 7.2 V
LL		1595.3	-558.9							1.0288	123.5	122.6	121.4	
												122.8	122.8	

6.1

BE2: Branch Voltage Balance	LE2: Control Zone Min Voltage
119.2	118.1
119.8	
119.5	
Δ = 0.6 V	Δ = 6.6 V
	Δreg = 3.3 V

Changes for Stage-2

Node

5W342 S02b Add Sw Cap FP312104\_761212376 Switched 300 kVAr

		Node	Line	Load	Conductor	Length (ft)
S02c	1 from	MP_463490150	Reconductor	existing	1/0 CU	355.0
	to	FP365261_463490189		new	477 AAC	
	2 from	FP311103_761210762	Reconductor	existing	#6 CU	71.0
	to	FP311104_761210780		new	1/0 CU	

FP044303A 5W342\_1540871261-SP2 [ld = 63] 219 A 3Ph 16 step 3x180 kVA

S02e1	Regulator	Settings	Regulator Flow HL	Regulator Flow LL
	R =	10.5	439	131
X =	0.0	20.3		
CT =	50.0			
Vset =	120.0	HL V =	1.0356	
PT =	60.0	LL V =	1.0106	

	Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
HL A	120.3	124.0	119.9
B	121.1	124.9	123.6
C	121.1	124.9	123.1
LL	120.0	121.5	120.3

FP321102A 5W342\_761210113 [ld = 63] 219 A 3Ph 16 step 3x180 kVA

S02e2	Regulator	Settings	Regulator Flow HL	Regulator Flow LL
	R =	7.0	1708	793
X =	0.0			
CT =	100.0			
Vset =	118.0	HL V =	1.0294	
PT =	60.0	LL V =	1.0048	

	Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
HL A	120.5	123.9	121.2
B	120.0	123.4	
C	120.7	124.1	
LL	120.4	120.7	120.2

Pomeroy		T944	Stage-02											
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE1: Branch Voltage Balance	LEL: Control Zone Min Voltage	
5W342	A	1923.9	-172.7							R = 4.5	123.1	121.6		
	B	2129.5	-146.6							X = 0.0	123.1	121.9	121.9	
	C	1957.6	-155.2							CT = 400.0	123.1	122.0		
				Ineut = 24.3						Vset = 120.0				
										PT = 60.0				Δreg = 0 V
	T	6011.0	-474.5	6.3%	600.0	99.7%	16801.0	164.9	126.0	1.0262	0 V	Δ = 0.4 V	Δ = 1.3 V	
	LL	1594.1	-531.1							1.0069	120.8	120.4	120.5	
											0.0	120.4	120.4	

23.0

BE2: Branch Voltage Balance	LE2: Control Zone Min Voltage
120.5	120.5
120.0	120.0
120.7	120.7
Δ = 0.7 V	Δ = 3.1 V
	Δreg = 0 V

Clinton Substation T3716  
Summary of Distribution Power Flow Results

Clinton 5Y608 & 610

Clinton		T3716		Base Case (w/ Fielding)										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y608	A		2995.4	482.3						R =	2.0	122.1	116.2	116.0
	B		2711.8	404.5			Cust/Load	5.51		X =	4.0	122.2	119.5	
	C		2490.5	303.3			kVA/Cust	10.80		CT =	2000.0	122.2	120.7	
				Ineut =	60.6		Cust =	2088		Vset =	121.0			
										PT =	60.0			
T		41,300,182	8197.7	1190.1	9.6%	900.0	99.0%	22603.5	113.0	241.6	1.0167	0 V	Δ = 4.5 V	Δ = 6.2 V
	LL		3049.0	-67.8							1.0103	121.3	119.8	119.8
5Y610	A		3376.8	387.3								122.1	119.0	118.1
	B		2848.0	197.5			Cust/Load	5.07				122.2	120.6	
	C		3022.7	270.5			kVA/Cust	13.50				122.2	119.6	
				Ineut =	69.0		Cust =	1485						
T		43,295,527	9247.5	855.2	9.5%	1800.0	99.6%	20066.0	128.8	213.7		0 V	Δ = 1.7 V	Δ = 4 V
	LL		2707.4	-262.4								121.3	120.5	120.2

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y608 S01a	FP055861_389072157	5Y608_389070384			A->C
5Y610 S01b	FP278203_479410700	5Y610_479410265			A->B

Clinton		T3716		Stage-01										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y608	A		2870.7	417.6					R =	13.0	124.4	120.0	120.0	
	B		2718.2	388.4					X =	4.0	124.4	121.0		
	C		2602.5	330.3					CT =	2000.0	124.4	122.2		
				Ineut =	30.3				Vset =	119.0				
									PT =	60.0				
T		8191.4	1136.3	5.1%	900.0	99.1%	22603.5	107.2	225.7	1.0370	0 V	Δ = 2.2 V	Δ = 4.4 V	
	LL		3049.3	-28.2							1.0058	119.0	118.0	118.0
5Y610	A		3068.3	271.0					R =		124.4	121.4	120.5	
	B		3158.1	261.0					X =		124.4	122.7		
	C		3018.2	243.6					CT =		124.4	122.1		
				Ineut =	19.3				Vset =					
									PT =					
T		9244.6	775.7	2.5%	1800.0	99.6%	20066.0	127.5	207.5		0 V	Δ = 1.4 V	Δ = 3.9 V	
	LL		2708.0	-189.9								119.0	118.2	117.9

Changes for Stage-2	Node	Load
5Y608 S02b	Add Sw Cap FP274441	+ 900 kVAr
	<b>Node</b>	<b>Conductor</b>
S02c	1 from FP280201_984800474 to FP280103_984800473	943 [12.5 #4 ACS3PSn 8xa] 1055 [12.5 477AAC3PLn 8xa]
		<b>Length (ft)</b>
		564.0
Changes for Stage-2	Node	Load
5Y610 S02b	Add Sw Cap FP278510_460481740	+ 600 kVAr
	<b>Node</b>	<b>Conductor</b>
S02c	1 from FP279560_460480611 to FP279609_460480657	1083 [12.5 4/OAAC3PMn 8xa] 1055 [12.5 477AAC3PLn 8xa]
		<b>Length (ft)</b>
		576.0



Clinton		T3716		Stage-02									
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y608	A	2867.0	93.9						R =	13.0	124.4	120.7	120.6
	B	2714	62.8						X =	4.0	124.4	121.8	
	C	2598.7	3.9						CT =	2000.0	124.4	122.9	
			Ineut =	30.4					Vset =	119.0			
									PT =	60.0			
	T	8179.7	160.6	5.2%	900.0	100.0%	22603.5	95.2	220.8	1.0370	0 V	Δ = 2.2 V	Δ = 3.8 V
	LL	3048.9	-58.2							1.0058	120.7	119.8	119.8
5Y610	A	3064.4	53.6						R =		124.4	121.6	120.8
	B	3155.9	44.1						X =		124.4	122.9	
	C	3014.6	25.6						CT =		124.4	122.3	
			Ineut =	19.5					Vset =				
									PT =				
	T	9234.9	123.3	2.5%	1800.0	100.0%	20066.0	116.2	201.2		0 V	Δ = 1.3 V	Δ = 3.6 V
	LL	2707.7	-243.8								120.7	120.0	119.7

Nob Hill 5Y194 & 5Y197

Nob Hill Substation T2430  
Summary of Distribution Power Flow Results

Nob Hill		T2430		Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	Branch Voltage Balance	Control Zone Min Voltage	
5Y197	A		1809.5	347.6						R =	4.0	123.2	121.8		
	B		1982.4	372.5				Cust/Load 6.59		X =	2.0	123.3	122.2	121.0	
	C		2107.5	408.1				kVA/Cust 6.40		CT =	2000.0	123.3	121.5		
				Ineut =	33.9			Cust = 1970		Vset =	121.0				
										PT =	60.0				
	T		30,678,758	5899.4	1128.3	7.2%	0.0	98.2%	12613.5	44.7	91.9	2.47%	0 V	Δ = 0.7 V	Δ = 2.2 V
LL			1625.6	396.9							1.32%	121.7	121.2	121.1	
5Y194	A		2894.9	668.4								122.9	118.3	117.9	
	B		2819.0	635.7				Cust/Load 8.76				122.9	119.6		
	C		2652.4	562.3				kVA/Cust 9.50				122.9	120.3		
				Ineut =	31.8			Cust = 2005							
	T		42,555,015	8366.3	1866.3	3.8%	1200.0	97.6%	19095.5	165.1	329.2	1.0247	0 V	Δ = 2 V	Δ = 5 V
	LL			2727.4	8.0							1.0132	121.6	120.5	120.3
5Y272	**		5500	690		600.0		14398.0							
	LL		1855	-147											

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y197	S01a				None
	S01b				
5Y194	S01a				None
	S01b	Add Fixed Cap FP243305_991160290	600 -> 1200 kVAr		
		Add Fixed Cap FP242209_991162198	+ 300 kVAr		
		Add Fixed Cap FP239013_556790634	+ 600 kVAr		

Nob Hill		T2430		Stage-01											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	Branch Voltage Balance	Control Zone Min Voltage	
5Y197	A		1809.5	347.4						R =	7.5	123.5	122.0		
	B		1982.3	372.4						X =	2.0	123.5	122.5	121.3	
	C		2107.4	408.0						CT =	2000.0	123.5	121.8		
				Ineut =	34.3					Vset =	120.0				
										PT =	60.0				
	T		5899.2	1127.8	7.2%	0.0	98.2%	12613.5	44.2	91.0	2.96%	0 V	Δ = 0.7 V	Δ = 2.2 V	
LL			1628.8	397.5							0.91%	121.1	120.6	120.4	
5Y194	A		2891.0	146.5								123.5	119.9	119.5	
	B		2817.1	107.6								123.5	121.2		
	C		2649.3	29.3								123.5	121.9		
				Ineut =	32.6										
	T		8357.4	283.4	3.8%	1200.0	99.9%	19095.5	156.3	311.1		0 V	Δ = 2 V	Δ = 4 V	
	LL			2732.9	-1520.1								121.1	120.9	120.8
5Y272	**		5500	690				14398.0							
	LL		1855	-147											

Changes for Stage-2

Node

Load

5Y197 S02b Add Sw Cap FP243305\_991160290 + 900 kVAr

Node

Line

Load

Conductor

Length (ft)

S02c No changes

Changes for Stage-2

Node

Load

5Y194 S02b Add Sw Cap FP243305\_991160290 600 kVAr fixed, 600 kVAr switched \*  
 Add Sw Cap FP242209\_991162198 + 300 kVAr \*  
 Add Sw Cap FP239013\_556790634 + 600 kVAr \*

\* Add switching mechanism for fixed capacitors added in Stage 01.

Node

Line

Load

Conductor

Length (ft)

S02c 1 from MP\_931350832 1050 [12.5 500 AL3 313.0  
 to FP999999\_931350864 1049 [12.5 1000AL3PUGCond]  
 2 from FP999999\_931350864 1097 [12.5 2/0ACS 119.0  
 to FP269312\_931350900 1055 [12.5 477AAC3PLn 8xa]

Nob Hill		T2430		Stage-02										
Circuit ID	Ph	kW	kVAr	%	kVAr	Factor	kVA	kW	kVAr	%	Balance	Voltage	Zone Min	
5Y197	A	1809.1	31.0						R =	7.5	123.5	122.2		
	B	1982	56.0						X =	2.0	123.5	122.6	121.4	
	C	2107.3	91.6						CT =	2000.0	123.5	122.0		
				Ineut =	34.3					Vset =	120.0			
	T	5898.4	178.6	7.2%	0.0	100.0%	12613.5	43.5	89.2	2.96%	0 V	Δ = 0.7 V	Δ = 2.1 V	
LL		1628.8	397.5							0.91%	121.1	120.6	120.4	
5Y194	A	2887.6	143.3								123.5	120.0	119.7	
	B	2813.9	104.5								123.5	121.3		
	C	2646.5	26.5								123.5	122.0		
				Ineut =	32.5									
	T	8348.0	274.3	3.8%	1200.0	99.9%	19095.5	146.8	308.5		0 V	Δ = 2 V	Δ = 3.8 V	
LL		2727.6	18.4								121.1	120.0	119.8	
5Y272	**	5500	690				14398.0							
LL		1855	-147											

Nob Hill 5Y273

Nob Hill Substation T2402  
Summary of Distribution Power Flow Results

Nob Hill		T2402	Base Case (w/ Fielding)												
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y273	A		2450.5	126.1							R = 4.0	123.9	120.9		
	B		2650.1	174.4			Cust/Load 4.95			X = 0.0	123.9	120.3	119.7		
	C		2884.2	260.7			kVA/Cust 7.10			CT = 1200.0	123.9	121.3			
				Ineut =	51.1		Cust = 2292			Vset = 121.0					
	T		7984.8	561.1	8.4%	1200.0	99.8%	16377.5	150.2	324.5	1.0337			Δ = 0 V	
	LL		2324.6	-911.4							1.0164	121.8	121.3	121.1	
5Y195	**		3920	343		600.0		8463.0							
	LL		1201	-451											
5Y338	**		7750	1315		600.0		21380.5							
	LL		2755	73											

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y273 S01a	FP264901_656800698	5Y273_656800259			C->A
S01b Remove Cap	FP239106_556790602			- 600 kVar	

Nob Hill		T2402	Stage-01												
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y273	A		2833.4	539.6							R = 8.5	124.6	120.3	120.0	
	B		2761.0	509.8						X = 0.0	124.6	121.7			
	C		2598.2	444.1						CT = 1200.0	124.6	122.2			
				Ineut =	30.3					Vset = 118.0					
	T		8192.6	1493.4	3.8%	1200.0	98.4%	16377.5	151.6	301.4	1.0373	0 V	Δ = 1.9 V	Δ = 4.6 V	
	LL		2710.7	-222.3							1.0005	119.9	118.9	118.8	
5Y195	**		3920	343				8463.0							
	LL		1201	-451											
5Y338	**		7750	1315				21380.5							
	LL		2755	73											

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5Y273 S02b	Add Sw Cap FP239106_556790602 Add Sw Cap FP268700		+ 600 kVar + 600 kVar		
S02c	None				

APPENDIX 9

Nob Hill		T2402		Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y273	A	2828.8	119.7						R =	5.5	124.2	120.7	120.4	
	B	2757.5	85.7						X =	0.0	124.3	122.0		
	C	2594.2	17.2						CT =	1200.0	124.3	122.7		
				Ineut =	30.9					Vset =	120.0			
										PT =	60.0			
	T	8180.5	222.6	3.7%	1200.0	100.0%	16377.5	139.6	293.0	1.0349	0 V	Δ = 1.9 V	Δ = 3.9 V	
	LL	2709.3	-252.4							1.0111	121.2	120.3	120.2	
5Y195	**	3920	343				8463.0							
	LL	1201	-451											
5Y338	**	7750	1315				21380.5							
	LL	2755	73											

North Park 5Y356

North Park Substation T3536  
Summary of Distribution Power Flow Results

North Park		T3536		Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	EOL: Cntl Zone Min Voltage	
5Y356	A		2330.4	-9.9						R =	5.0	125.5	120.5		
	B		2109.2	-96.0			Cust/Load	3.81		X =	0.0	125.5	122.7	122.5	
	C		2350.4	25.9			kVA/Cust	11.10		CT =	1000.0	125.5	119.1	118.9	
					Ineut =	36.7		Cust =	1814		Vset =	121.0			
										PT =	60.0				
	T		30,777,644	6790.0	-80.0	3.8%	1500.0	100.0%	20180.0	231.7	394.2	1.0396	0 V	Δ = 3.6 V	Δ = 6.6 V
LL			2494.6	-1436.3							1.0202	122.7	122.0	122.0	
5Y398	**		9400.0	945.2		1200.0		29702.5							
	LL		3673.8	-1100.7											

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y356	S01a				None
S01b	Remove Cap	FP219900_826650557	-900 kVar		

North Park		T3536		Stage-01										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	EOL: Cntl Zone Min Voltage	
5Y356	A	2330.8	309.3						R =	12.0	125.0	118.8		
	B	2111.8	232.1						X =	0.0	125.0	120.9	120.7	
	C	2353.2	342.5						CT =	1000.0	125.0	117.3	117.1	
				Ineut =	36.0				Vset =	116.0				
									PT =	60.0				
	T		6795.8	883.9	3.9%	1500.0	99.2%	20180.0	237.4	405.1	1.0417	0 V	Δ = 3.6 V	Δ = 7.9 V
LL		2487.2	-452.0							0.9952	119.4	117.4	117.3	
5Y398	**	9400.0	945.2											
	LL	3673.8	-1100.7											

Changes for Stage-2	Node	Line	Load	Losses	Swap Phases
5Y356	S02b	Add Sw Cap	FP219900_826650557	+900 kVar	

Node	Line	Load	Conductor	Length (ft)
S02c	1 from FP178002_640300540 to FPUNK_640300538		1083 [12.5 4/0AAC3	607.0
			1055 [12.5 477AAC3PLn 8xa]	
S02e	FP160001_274180881	5Y356_274180328-SP1	[Id = 602] 328 A 3Ph 16 step 3x180 kVA	

Regulator	Settings	Reg Flow kVA HL	Reg Flow kVA LL
R =	5.5	6650.6	2508.7
X =	0.0		
CT =	500.0		
Vset =	120.0	HL V = 1.0282	123.3869
PT =	60.0	LL V = 1.0106	

Regulator	Regulator Voltage Sec	Branch Volt pu Balance	Reg. Min Voltage
HL	A 123.6	120.9	
	B 123.1	121.5	121.3
	C 123.4	120.4	120.2
LL	121.1	120.4	120.3

North Park		T3536		Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Volt pu Balance	Regulator Voltage Pri	Min Volt pu	
5Y356	A	2328.8	-7.7							R = 6.0	123.5	121.2	121.2	
	B	2108.8	-77.5							X = 0.0	123.5	122.3	122.3	
	C	2347.5	21.3							CT = 1000.0	123.5	120.3	120.3	
				Ineut = 35.6							Vset = 119.0			
											PT = 60.0			
	T	6785.1	-63.9	3.8%	1500.0	100.0%	20180.0	229.5	389.2	1.0292	0 V	Δ = 2 V	Δ = 3.1 V	
	LL	2485.0	-479.2							1.0059	120.7	119.8	119.8	
5Y398	**	9400.0	945.2											
	LL	3673.8	-1100.7											

Orchard Substation T5035  
Summary of Distribution Power Flow Results

Orchard 5Y456

Orchard		T5035		Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y456	A		2747.4	371.1						R =	5.0	126.0	120.0	119.7	
	B		1943.0	88.2				4.07		X =	2.0	126.1	125.2		
	C		2607.3	306.2				10.50		CT =	1300.0	126.0	121.9		
				Ineut =	102.4			Cust =	1582		Vset =	121.0			
										PT =	60.0				
	T	28,932,545	7297.7	765.5	12.9%	1200.0	99.5%	16682.0	124.3	172.5	1.0432	0 V	Δ = 5.2 V	Δ = 6.3 V	
LL		1837.2	-324.2							1.0179	122.4	121.0	120.9		
5Y458	**		7200	1497		1200.0		22817.5							
	LL		2512	-6											
5Y637	**		7600	1236		1200.0		20613.0							
	LL		2270	-121											

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y456 S01a	FP168004_306160613	5Y456_306160060			C->B
	FP213700_738390496	5Y456_738390191			A->B
	FP163200_306160581	5Y456_306160113			CBA->CAB
S01b					

\*At EOL A & C phases end, B phase continues.

Orchard		T5035		Stage-01										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y456	A		2417.4	258.9						R =	6.0	124.9	120.6	120.6
	B		2401.2	248.0						X =	2.0	124.9	122.4	122.3
	C		2471.5	271.1						CT =	1300.0	124.9	122.8	122.8
				Ineut =	8.2					Vset =	120.0			
										PT =	60.0			
	T		7290.1	777.9	1.7%	1200.0	99.4%	16682.0	116.7	161.3	1.0414	0 V	Δ = 2.2 V	Δ = 4.3 V
LL		1836.6	-303.6							1.0115	121.4	120.3	120.3	
5Y458	**		7200	1497										
	LL		2512	-6										
5Y637	**		7600	1236										
	LL		2270	-121										

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5Y456 S02b	Add Sw Cap	FP215411	+600 kVAr		
S02c	1 from	FP167000_306160615		1256 [12.5 #6 CU 3f	812.0
	to	FP167101_306161294		1243 [12.5 #2AAC3PSn 8xa]	
	2 from	FP167101_306161294		943 [12.5 #4ACS	211.0
	to	FP167102_306160572		1243 [12.5 #2AAC3PSn 8xa]	



APPENDIX 9

Orchard		T5035		Stage-02									
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y456	A	2423.0	50.1						R =	5.5	124.5	120.2	120.2
	B	2384.7	30.2						X =	2.0	124.6	122.0	121.9
	C	2466.5	56.7						CT =	1300.0	124.6	122.4	122.4
			Ineut =	9.0					Vset =	120.0			
	T	7274.2	137.0	1.7%	1200.0	100.0%	16682.0	100.8	160.7	1.0382	0 V	Δ = 2.2 V	Δ = 4.3 V
	LL	1836.6	-301.1							1.0105	121.2	120.2	120.2
5Y458	**	7200	1497										
	LL	2512	-6										
5Y637	**	7600	1236										
	LL	2270	-121										



APPENDIX 9

Orchard		T3797	Stage-02												
Circuit ID	Ph		Feeder kW	Feeder kVA	Unbalance %	Cap Banks kVA	Power Factor %	Connected kVA	Losses kW	Losses kVA	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y498	A		2299.7	111.3						R =	3.5	123.7	121.1		
	B		2076.3	47.1						X =	2.0	123.8	121.4		
	C		1902.9	39.7						CT =	1100.0	123.8	120.6	120.2	
				Ineut =	50.3					Vset =	120.0				
	T		6278.9	198.0	9.9%	0.0	100.0%	12638.0	93.6	181.7	PT =	60.0			
	LL		1445.3	187.9							1.0319	0 V	Δ = 0.8 V	Δ = 3.2 V	
											1.0075	120.9	120.1	120.0	
5Y454	**		9800	1003											
	LL		2769	-841											
5Y639	**		7720	1651											
	LL		2076	269											

River Road Substation T3453  
Summary of Distribution Power Flow Results

River Road 5Y444

River Road		T3453		Base Case (w/ Fielding)										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y444	A		3986.7	362.2						R =	3.0	125.3	120.3	120.1
	B		3556.9	284.7				Cust/Load 5.57		X =	7.0	125.3	121.4	
	C		3051.2	51.0				kVA/Cust 10.40		CT =	1000.0	125.3	123.4	
					Ineut =	105.8		Cust =	2502	Vset =	121.0			
										PT =	60.0			
	T		49,558,070	10594.8	697.8	12.9%	1200.0	99.8%	25987.0	186.1	519.3	1.0382	0 V	Δ = 3.1 V
LL			3313.5	-787.3							1.0127	121.6	120.7	120.7
5Y446	**		6600	434		300.0		11730.5						
	LL		1496	-249										
5Y448	**		4360	661		600.0		20141.0						
	LL		2568	-512										

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
<b>5Y444 S01a</b>	FP150014_154241218 FP157000_154241204 FP156080_154241134	5Y444_154240243 5Y444_154240477 5Y444_154240377			A -> C A -> C A -> C
<b>S01b</b>	Reduce Cap FP237905_419030342		1200 kVAr -> 600 kVAr		

River Road		T3453		Stage-01										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y444	A		3661.1	453.6						R =	5.0	125.5	121.9	
	B		3580.4	501.1						X =	7.0	125.6	120.3	120.0
	C		3351.1	378.7						CT =	1000.0	125.6	122.8	
					Ineut =	30.7				Vset =	120.0			
										PT =	60.0			
	T			10592.6	1333.4	3.7%	1200.0	99.2%	25987.0	184.0	512.4	1.0465	0 V	Δ = 2.5 V
LL			3311.4	-157.4							1.0101	121.2	120.0	119.9
5Y446	**		6600	434										
	LL		1496	-249										
5Y448	**		4360	661										
	LL		2568	-512										

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
<b>5Y444 S02b</b>	Add Sw Cap FP232945 Add Sw Cap FP147243		+ 600 kVAr + 600 kVAr		
<b>S02c</b>	1 from FP158001_80630559 to FP158002_154241123			1256 [12.5 #6 CU 3F 17 [12.5 1/0ACS3PSn 8xa]	106.0
	2 from FP158002_154241123 to FP158104_154241172			938 [12.5 #2 ACS 3P 17 [12.5 1/0ACS3PSn 8xa]	562.0
<b>S02e</b>	Add Regulator FP141001_33500763	5Y444_1031038802-SP1	[Id = 602] 328 A 3Ph 16 step 3x180 kVA		

APPENDIX 9

Regulator	Settings	Reg Flow kVA HL	Reg Flow kVA LL
R =	5.5	6189.1	1944.5
X =	0.0	286.5 A	
CT =	500.0		
Vset =	120.0	HL V =	1.0263
PT =	60.0	LL V =	1.0083

123.1519

HL  
LL

	Regulator Voltage Pri	Regulator Voltage Sec	Reg. Min Voltage
A	120.7	123.0	
B	120.5	122.8	119.9
C	121.5	123.1	
	120.0	120.7	120.4

River Road		T3453		Stage-02											
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Volt pu Balance	Regulator Voltage Pri	Min Volt pu		
5Y444	A	3662.1	61.6							R =	2.0	122.5	120.7	120.7	
	B	3582	113.7							X =	7.0	122.6	120.5	120.5	
	C	3351.5	-12.2							CT =	1000.0	122.6	121.5	121.5	
				Ineut =	31.1						Vset =	120.0			
											PT =	60.0			
	T	10595.6	163.1	3.7%	1200.0	100.0%	25987.0	186.9	526.8	1.0216	0 V	Δ = 1 V	Δ = 2.1 V		
	LL	3311.0	-147.4							1.0015	120.2	120.0	120.0		
5Y446	**	6600	434												
	LL	1496	-249												
5Y448	**	4360	661												
	LL	2568	-512												

Wiley Substation T3676  
Summary of Distribution Power Flow Results

Wiley 5Y434

Wiley		T3676		Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y434	A		2253.7	626.0						R =	4.0	122.3	116.1	116.1	
	B		2493.4	716.0				Cust/Load	3.8	X =	1.0	122.4	117.0		
	C		2245.0	619.5				kVA/Cust	11.7	CT =	2000.0	122.4	118.8		
					Ineut =	35.9			Cust =	1588	Vset =	120.0			
										PT =	60.0				
	T		27,725,682	6992.1	1961.5	7.0%	0.0	96.3%	18624.0	144.8	345.9	1.0172	0 V	Δ = 2.8 V	Δ = 6.2 V
LL			1641.9	1045.2							1.0053	120.7	118.5	118.5	
5Y164	**		5900	663				2100.0		25936.0					
	LL		2286	-646											
5Y380	**		8500	978				2700.0		34519.5					
	LL		3043	-764											

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y434 S01a					None
S01b	Add Cap Add Cap	FP301903_506870503 FP254905_47582199	600 kVar 300 kVar		

Wiley		T3676		Stage-01											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y434	A		2246.8	307.4						R =	9.5	124.6	119.7	119.7	
	B		2488.8	395.5						X =	1.0	124.7	120.5		
	C		2242.1	291.9						CT =	2000.0	124.7	122.4		
					Ineut =	36.5				Vset =	120.0				
										PT =	60.0				
	T			6977.7	994.8	7.0%	0.0	99.0%	18624.0	131.1	308.1	1.0399	0 V	Δ = 2.7 V	Δ = 4.9 V
LL			1639.1	119.9							1.0127	121.5	120.5	120.5	
5Y164	**		5900	663											
	LL		2286	-646											
5Y380	**		8500	978											
	LL		3043	-764											

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5Y434 S02b	Add Sw Cap	FP365800	+ 600 kVar		
S02c	No Conductor Changes				

Wiley		T3676		Stage-02									
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y434	A	2246.0	92.3						R =	9.5	124.6	120.0	120.0
	B	2488.7	179.8						X =	1.0	124.7	120.7	
	C	2241.8	74.0						CT =	2000.0	124.7	122.7	
			Ineut =	36.9					Vset =	120.0			
									PT =	60.0			
	T	6976.5	346.1	7.0%	0.0	99.9%	18624.0	130.1	304.5	1.0399	0 V	Δ = 2.7 V	Δ = 4.6 V
	LL	1639.2	133.2							1.0127	120.7	119.7	119.7
5Y164	**	5900	663										
	LL	2286	-646										
5Y380	**	8500	978										
	LL	3043	-764										

Grandview Substation T859  
Summary Of Distribution Power Flow Results

Grandview 5Y351

Grandview		T859		Base Case (w/ Fielding)										
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y351	A		2230.7	241.2						R =	6.5	134.2	131.3	
	B		2964.0	443.6			Cust/Load	4.19		X =	0.0	134.3	130.2	129.2
	C		2504.7	308.1			kVA/Cust	14.10		CT =	500.0	134.3	132.5	
				Ineut =	83.6		Cust =	1377		Vset =	121.0			
										PT =	104.0			
	T	33,271,598	7699.4	993.0	15.5%	600.0	99.2%	20980.4	106.0	199.0	1.0843	0 V		Δ = 5.1 V
	LL		2170.9	-367.2							1.0331	124.6	123.8	123.5
5Y302	**		7440	1271				26760.5						
	LL		2770	-468										

Changes for Stage-1	Node	Line	Load	Losses	Swap Phases
5Y351 S01a	FP274501_564110792	5Y351_564110009			BAC --> ABC
5Y351 S01b	Reduce Cap FP227502_728880503	Fixed	600 kVAr --> 300 kVAr		

Grandview		T859		Stage-01									
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y351	A	2462.0	454.5						R =	4.0	125.4	120.5	119.4
	B	2737.1	526.9						X =	0.0	125.5	123.5	
	C	2513.5	458.5						CT =	500.0	125.5	122.4	
				Ineut =	35.9				Vset =	120.0			
									PT =	104.0			
	T	7712.6	1439.8	6.5%	300.0	98.3%	20980.4	75.2	128.9	1.0467	0 V		Δ = 6 V
	LL	2170.9	-26.8							1.0152	121.8	120.6	120.4
5Y302	**	7440	1271										
	LL	2770	-468										

Grandview Substation T859  
Summary Of Distribution Power Flow Results

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5Y351 S02b	Add Sw Cap FP229907_1040375491		Switched	600 kVAr	
	Add Sw Cap FP226502_728882270		Switched	600 kVAr	
S02c	No Reconductoring needed				
S02e	Add Regulator FP226205_728880766	5Y351_728880260-SP1			
	[Id = 63] 219 A 3Ph 16 step 3x180 kVA		Flow (kVA) =	855.1	

Regulator	Settings	Regulator Flow HL	Regulator Flow LL
R =	2.5	855.05	237
X =	0.0		
CT =	50.0		
Vset =	120.0	HL V = 1.0165	
PT =	60.0	LL V = 1.0046	

Regulator Voltage Pri	Regulator Voltage Sec	Control Zone Min Voltage
HL A	120.0	122.1
B	121.5	123.8
C	121.8	124.1
LL	119.6	120.3
		119.6
		Δ = 2.4 V



Grandview		T859		Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y351	A	2461.8	50.1							R = 3.0	123.1	120.0	120.0	
	B	2738.4	118.0							X = 0.0	123.1	121.5	121.5	
	C	2513.3	45.7							CT = 500.0	123.1	121.8	121.8	
			Ineut =	37.6						Vset = 119.0				
										PT = 104.0				
	T	7713.5	213.8	6.5%	1500.0	100.0%	20980.4	83.0	147.6	1.0267	0 V		Δ = 3.1 V	
	LL	2171.0	-17.4							1.0031	120.4	119.6	119.6	
5Y302	**	7440	1271											
	LL	2770	-468											

Sunnyside 5Y313 & 317

Sunnyside Substation T3570  
Summary Of Distribution Power Flow Results

Sunnyside		T3570	Base Case (w/ Fielding)											
Circuit ID	Ph	Annual Energy kWhr	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y313	A		1385.6	159.1							R = 4.0	125.7	123.3	
	B		1593.8	243.2			Cust/Load	4.97		X = 2.0	125.7	123.6		
	C		1519.6	213.7			kVA/Cust	10.20		CT = 1000.0	125.7	123.0	121.5	
				Ineut =	26.0			Cust =	1172		Vset = 121.0			
										PT = 104.0				
	T	20,864,708	4499.0	616.0	6.3%	1200.0	99.1%	11851.5	86.8	94.1	1.0381	0 V		Δ = 4.2 V
LL		1584.4	-205.1							1.0172	122.5	121.6	121.0	
5Y314	T		9400	1694		3000.0		32407.1						
	LL		4328	-601										
5Y317	A		1148.1	106.0			Cust/Load	8.29				125.6	123.7	
	B		1782.0	306.0	Ineut = 93.4		kVA/Cust	7.60				125.6	123.0	122.8
	C		1069.7	86.9				Cust =	1277			125.7	125.3	
	T	19,867,620	3999.8	498.9	33.7%	600.0	99.2%	9579.6	49.6	60.4		0 V		Δ = 2.8 V
	LL		1279.3	-129.0								122.5	121.7	121.6

Changes for Stage-1	Node	Line	Load	Swap Phases
5Y317 S01a	FP257504_823200895	5Y317_823200406 5Y317_823200313		B-->A ABC-->ACB
			TR_257501_823200453	A-->B
5Y313 S01b	1. Reduce Cap FP251510_823200918		1200 kVAr --> 900 kVAr	

\*\*\* Losses prior to redistribution of fixed caps

Sunnyside		T3570	Stage-01										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW	Losses kVAr	Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage
5Y313	A	1386.6	275.1							R = 4.0	124.2	121.7	
	B	1594.9	358.9							X = 2.0	124.2	122.0	
	C	1520.7	329.7							CT = 1000.0	124.2	121.4	119.9
				Ineut =	26.3					Vset = 121.0			
								***	74.2	PT = 104.0			
	T	4502.2	963.7	6.3%	900.0	97.8%	11851.5	77.0	64.7	1.0357	0 V		Δ = 4.3 V
LL		1584.3	121.9							1.0128	121.5	120.5	119.9
5Y314	**	9400	1694										
	LL	4328	-601										
5Y317	A	1409.6	192.9								124.2	121.9	121.7
	B	1378.5	182.9	26.3							124.2	122.5	
	C	1209.2	133.5					***	35.3		124.2	123.0	
	T	3997.3	509.2	5.8%	600.0	99.2%	9579.6	35.5	42.6		0 V		Δ = 2.5 V
	LL	1279.0	-162.9								121.5	120.9	120.8

Sunnyside Substation T3570  
 Summary Of Distribution Power Flow Results

Changes for Stage-2	Node	Line	Load	Conductor	Length (ft)
5Y313	S02b	1 New Switched	FP251902_823200877		+SW 600 kVAr
		2 New Switched	FP269202_42390692		+SW 300 kVAr
	S02c	No reconductoring			
5Y317	S02b	New Switched	FP256511_937580500		+SW 600 kVAr
	S02c	No reconductoring			

Sunnyside		T3570		Stage-02										
Circuit ID	Ph	Feeder kW	Feeder kVAr	Unbalance %	Cap Banks kVAr	Power Factor %	Connected kVA	Losses kW		Rise at LTC %	Feeder Voltage Balance	BE: Branch Voltage Balance	LE: Control Zone Min Voltage	
5Y313	A	1381.5	-43.2							R = 3.5	123.9	122.1		
	B	1587.6	39.4							X = 2.0	123.9	122.5		
	C	1514.5	10.9							CT = 1000.0	123.9	121.8	120.4	
				Ineut = 26.1							Vset = 121.0			
											PT = 104.0			
	T	4483.6	7.0	6.2%	900.0	100.0%	11851.5	58.4	61.0	1.0331	0 V			Δ = 3.6 V
LL	1584.3	121.4							1.0131	121.6	120.6	120.0		
5Y314	**	9400	1694											
	LL	4328	-601											
5Y317	A	1409.5	-15.6								123.9	123.9	121.7	
	B	1378.6	-27.2	Ineut = 26.6							123.9	122.5		
	C	1208.9	-77.4								123.9	123.0		
	T	3997.0	-120.2	5.8%	600.0	100.0%	9579.6	35.3	42.3	0 V			Δ = 2.2 V	
	LL	1279.0	-163.3								121.6	120.9	120.8	

**Appendix 10: Cost Estimates**

**Bowman 5W150**

**Changes for Stage 1**

Node Line Load Losses Swap Phases

No phase changes were necessary

<b>Metering</b>	
Substation	\$8,130
<b>End of Line</b>	<u>\$9,540</u>
	\$17,670

**Stage 1 Costs to address Potential Low Voltages**

Heavy Load is the Controlling Case

Assumed Solution:

Number of Transformers at or below 120 volts 184  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 99  
 Estimated percent with secondary Vd > 5 volts 10.6%

Qty. (ea)	Work Description	Assumptions	Total
13	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$59,488
29	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$45,240
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$51,740

Total estimated cost to resolve low voltage concerns: \$162,708

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 42

**Total Stage 1 = \$180,378**

**Changes for Stage 2**

Add Sw Cap Node Line Load Losses Swap Phases

FP249363\_593050816

+ 900 kVAr

<b>Labor</b>	<b>Material</b>	<b>AFUDC</b>	<b>Total</b>	
\$6,575	\$10,393	\$2,121	\$19,088	
			<u>\$1,909</u>	Engineering = 10% of Total
			\$20,997	

FP269903\_302080452

5W150\_302080024

Rotate phases CAB->ACB

<b>Three Phase swap</b>				
Engineer	4	\$130	\$520	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	4	\$100	\$400	Notify customers of outage
SVC Crew (4 person + 2 flaggers)	6	\$650	\$3,900	Make phase changes
<b>Total</b>	<b>14</b>		<b>\$4,820</b>	

FP243261

5W150\_593050046-SP2

328 A 3Ph 16 step 3x180 kVA

\$11,110	\$47,553	\$7,333	\$65,995	Per Block Estimate
			<u>\$6,599</u>	Engineering = 10% of total
			\$72,594	

<b>Metering</b>	
Regulator	\$32,000 x 2 for new and existing
<b>End of Line</b>	<u>\$19,080</u> x 2 for new and existing
	\$51,080

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is slightly less in stage 2 than in stage 1. No additional costs

Stage 2 Modification Total = \$149,492

**Stage 1 + Stage 2 Modification Total = \$329,870**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5W154
			Subtotal:	\$108,833

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is the Controlling Case

25 less transformers will be impacted.

Number of Transformers at or below 120 volts 35  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 143  
 Estimated percent with secondary Vd > 5 volts 10.6%

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-8	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$36,608)
-17	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$26,520)
-2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$3,120)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$30,940)

Total estimated cost to resolve low voltage concerns: (\$97,188)

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 17

Stage 3 Modification Total = \$11,645

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$341,514**

**Bowman 5W154**

Remove Caps	FP357704_369970265	- 900 kVAr	<b>Estimate to remove both capacitors</b>				
			Engineer	8	130	1040	Engineering & Admin
Remove Caps	FP300602_1540121947	- 900 kVAr	SVC Crew (3 person + 2 flaggers)	8	520	4160	Remove Cap Bank
						5200	
No phase adjustments required for balancing			<b>Metering</b>				
			Substation			\$8,130	
			End of Line			\$9,540	
						<u>\$17,670</u>	

**Stage 1 Costs to address Potential Low Voltages**  
Heavy Load is the Controlling Case

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	6
Estimated percent with secondary Vd > 5 volts	10.6%

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
1	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$4,576
0	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$0
0	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$0
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$2,080

Total estimated cost to resolve low voltage concerns: \$6,656

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 1

**Total Stage 1 = \$29,526**

**Changes for Stage 2**

Node	Load	Cost to install both Capacitors				
		Labor	Material	AFUDC	Total	
Add Sw Cap	FP357704_369970265	+ 900 kVAr	\$13,149	\$20,786	\$4,242	\$38,177
Add Sw Cap	FP300602_1540121947	+ 900 kVAr				\$3,818
						<u>\$41,995</u>

Engineering = 10% of Total

Node	Line	Load	Conductor	Length (ft)
No reconductoring needed				

**Stage 2 Costs to address Potential Low Voltages**  
Light Load is Controlling Case.

7 more transformers will be impacted.

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	350
Estimated percent with secondary Vd > 5 volts	10.6%

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$9,880

Total estimated cost to resolve low voltage concerns: \$31,408

Light Load = 2510  
Heavy Load = 8200  
Light Load / Heavy Load = 0.31

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 8

Stage 2 Modification Total = \$73,403

**Stage 1 + Stage 2 Modification Total = \$102,929**

Changes for Stage 3

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5W150
Subtotal:			\$115,748	

Stage 3 Costs to address Potential Low Voltages

Light Load is Controlling Case.

13 more transformers will be impacted.

Number of Transformers at or below 120 volts 350  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 22  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2510  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.31  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 21

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
9	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$14,040
3	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$4,680
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$16,900

Total estimated cost to resolve low voltage concerns: \$53,924

Stage 3 Modification Total = \$169,672

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$272,600**





**Stage 2 Costs to address Potential Low Voltages**

Light Load is Stage 2 Controlling Case.

35 less transformers will be impacted.

Number of Transformers at or below 120 volts 35  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 189  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 6236  
 Heavy Load = 8700  
 Light Load / Heavy Load = 0.72  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 14

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-11	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$50,336)
-24	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$37,440)
-2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$3,120)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$42,640)

Total estimated cost to resolve low voltage concerns: (\$133,536)

Stage 2 Modification Total= \$68,793

**Stage 1 + Stage 2 Modification Total = \$288,415**

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	

Subtotal: \$221,029

**Stage 3 Costs to address Potential Low Voltages**

Light Load is Stage 3 Controlling Case.

19 more transformers will be impacted.

Number of Transformers at or below 120 volts 189  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 147  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 6236  
 Heavy Load = 8700  
 Light Load / Heavy Load = 0.72  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 33

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
6	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$27,456
13	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$20,280
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$23,660

Total estimated cost to resolve low voltage concerns: \$74,516

Stage 3 Modification Total = \$295,545

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$583,960**

**Mill Creek 5W116**

Changes for Stage 1	Node	Line	Load	Losses	Swap Phases	Metering	
					None	Substation	\$8,130
						End of Line	\$9,540
							\$17,670

**Stage 1 Costs to address Potential Low Voltages**

Light Load is Controlling Case

Assumed Solution:

Number of Transformers at or below 120 volts	91
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	294
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2148
Heavy Load =	8100
Light Load / Heavy Load =	0.27
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	10

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
7	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$10,920
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$12,740

Total estimated cost to resolve low voltage concerns: \$40,508

**Total Stage 1 = \$58,178**

**Stage 2 Improvements**

Node	Load	Labor	Material	AFUDC	Total	
Add Sw Cap	FP166061_755430427	+ 900 kVAR	\$6,575	\$10,393	\$2,121	\$19,088
						\$1,909
						\$20,997
						Engineering = 10% of Total
<b>S02e</b>	FP165101	5W116_755430072-SP1	[ld = 63] 219 A 3Ph 16 step 3x180 kVA	\$11,110	\$40,480	\$6,449
						\$58,038
						\$5,804
						\$63,842
						Engineering = 10% of Total
						<b>Metering</b>
						Regulator
						End of Line
						\$16,000
						\$9,540
						\$25,540

**Stage 2 Costs to address Potential Low Voltages**

Light Load is Stage 2 Controlling Case.

4 less transformers will be impacted.

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	319
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2148
Heavy Load =	8100
Light Load / Heavy Load =	0.27
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	6

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-2	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$9,152)
-2	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$3,120)
0	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$0
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$5,720)

Total estimated cost to resolve low voltage concerns: (\$17,992)

Stage 2 Modification Total= \$92,387

**Stage 1 + Stage 2 Modification Total = \$150,565**

Changes for Stage 3

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Share cost with 5W127
			Subtotal:	\$115,748

Stage 3 Costs to address Potential Low Voltages

Heavy Load is the Controlling Case.

13 more transformers will be impacted.

Number of Transformers at or below 120 volts 63  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 98  
 Estimated percent with secondary Vd > 5 volts 10.6%

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
9	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$14,040
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$16,380

Total estimated cost to resolve low voltage concerns: \$51,844

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 19

Stage 3 Modification Total = \$167,592

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$318,156**

**Mill Creek 5W127**

**Changes for Stage 1**

Item ID	Node	Load	Staff	hours	rate	total	Work Description
FP288803_544871716	5W127_544870102	CBA->CAB	Three (3) Single Phase changes				
FP219405_242020779	5W127_242020295	B->C	Engineer	12	\$130	\$1,560	Engineering and Analysis
FP283816_544870486	5W127_544870085	B->C	Svc Line Worker	0	\$130	\$0	Install /Remove metering
FP291702_717550718	5W127_717550132	CBA->BAC	Notifier	6	\$100	\$600	Notify customers of outage
FP294700_717550725	5W127_1540944656	B->C	SVC Crew (3 person + 2 flaggers)	12	\$520	\$6,240	Make phase changes
FP285903_544870459	5W127_544870096	CBA->BAC	Total	30		\$8,400	

**Three (3) x Three Phase swaps**

Staff	hours	rate	total	Work Description
Engineer	12	\$130	\$1,560	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	12	\$100	\$1,200	Notify customers of outage
SVC Crew (4 person + 2 flaggers)	18	\$650	\$11,700	Make phase changes
<b>Total</b>	<b>42</b>		<b>\$14,460</b>	

**Metering**

Substation	\$8,130
End of Line	\$9,540
<b>Total</b>	<b>\$17,670</b>

Item	Node	Load	Labor	Material	AFUDC	Total	Notes
Add Cap	FP282811_544870470	600 kVar	\$3,071	\$2,818	\$736	\$6,624	
						\$662	Engineering = 10% of Total
						<b>\$7,287</b>	

**Stage 1 Costs to address Potential Low Voltages**

Light Load is Controlling Case

Number of Transformers at or below 120 volts	32
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	300
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	1830
Heavy Load =	6220
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	8

**Assumed Solution:**

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
5	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$7,800
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$11,180
Total estimated cost to resolve low voltage concerns:			\$35,828

**Total Stage 1 = \$83,645**

**Changes for Stage 2**

Item	Node	Load	Labor	Material	AFUDC	Total	Notes
S02b Add Sw Cap	FP289805_544870439	+600 kVAR	\$6,575	\$12,136	\$2,339	\$21,049	
						\$2,105	Engineering = 10% of Total
						<b>\$23,154</b>	

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is less in stage 2 than in stage 1. No additional costs

Stage 2 Modification Total= \$23,154

**Stage 1 + Stage 2 Modification Total = \$106,799**

Changes for Stage 3

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Share cost with 5W116
Subtotal:			\$108,833	

Stage 3 Costs to address Potential Low Voltages

Light Load is Controlling Case.

10 more transformers will be impacted.

Number of Transformers at or below 120 volts 321  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 0  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 1830  
 Heavy Load = 6220  
 Light Load / Heavy Load = 0.29  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 18

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
7	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$10,920
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$12,740

Total estimated cost to resolve low voltage concerns: \$40,508

Stage 3 Modification Total = \$149,341

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$256,139**

**Pomeroy SW342**

**Changes for Stage 1**

**S01a**

**Node**

FP171860_420450094	5W342_420450011
FP310600_463490170	5W342_1540118006
FP325202_761212279	5W342_761210085

**Swap Phases**

BAC->BCA
BAC->BCA
BC->CB

One (1) Two Phase changes

Staff	hours	rate	total	Work Description
Engineer	6	\$130	\$780	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	3	\$100	\$300	Notify customers of outage
SVC Crew (3 person + 2 flaggers)	6	\$520	\$3,120	Make phase changes
<b>Total</b>	<b>15</b>		<b>\$4,200</b>	

**Two (2) x Three Phase swaps**

Engineer	8	\$130	\$1,040	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	8	\$100	\$800	Notify customers of outage
SVC Crew (4 person + 2 flaggers)	12	\$650	\$7,800	Make phase changes
<b>Total</b>	<b>28</b>		<b>\$9,640</b>	

**Metering**

Substation	\$8,130
End of Line	\$9,540
	<u>\$17,670</u>

**Stage 1 Costs to address Potential Low Voltages**

Heavy Load is the Controlling Case

Number of Transformers at or below 120 volts	83
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	27
Estimated percent with secondary Vd > 5 volts	10.6%

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
6	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$27,456
12	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$18,720
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$23,920

Total estimated cost to resolve low voltage concerns: \$76,336

Estimated total number of transformers that may have customers with low voltage at Service Entrance = 18

**Total Stage 1 = \$107,846**

**Changes for Stage 2**

**Node**

**S02b**

Add Sw Cap

FP312104\_761212376

Switched 300 kVar

Cost for 300 kVAR Installations (based on 600 kVAR cost in block estimate)

Labor	Material	AFUDC	Total
\$4,773	\$9,234	\$1,751	\$15,758
			<u>\$1,576</u>
			\$17,333

Engineering = 10% of Total

**S02c**

1 from  
to

Node  
MP\_463490150  
FP365261\_463490189

Line  
Reconductor  
existing 1/0 CU 355.0  
new 477 AAC

Per-foot costs:

Labor	Material	AFUDC	Total
\$44	\$45	\$11	\$101
			\$35,772
			<u>\$3,577</u>
			\$39,349

Engineering = 10% of Total

2 from  
to

FP311103\_761210762  
FP311104\_761210780

Reconductor  
existing #6 CU 71.0  
new 1/0 CU  
4/0 AAC for pricing

\$41	\$42	\$10	\$93
			\$6,624
			<u>\$662</u>
			\$7,286
			\$3,643
			<u>\$10,930</u>

Engineering = 10% of Total

50% Small Job mark up  
Total Estimate

Costs are for both units installed

\$22,219	\$80,959	\$12,897	\$116,076
			<u>\$11,608</u>
			\$127,683

Engineering = 10% of Total

Costs are for metering at both Regulators and end of line metering

Metering	
Regulator	\$32,000
End of Line	\$19,080
	<u>\$51,080</u>

**Stage 2 Costs to address Potential Low Voltages**

Light Load is Stage 2 Controlling Case.

10 less transformers will be impacted.

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	398
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	1596
Heavy Load =	6045
Light Load / Heavy Load =	0.26
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	8

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$13,728)
-7	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$10,920)
0	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$0
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$11,700)

Total estimated cost to resolve low voltage concerns: (\$36,348)

Stage 2 Modification Total= \$210,027

**Stage 1 + Stage 2 Modification Total = \$317,873**

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	3	\$3,551	\$10,653	
Line regulator: wireless 'radio' link to the substation	2	\$3,364	\$6,728	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	

Subtotal: \$227,944

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is the Controlling Case.

18 more transformers will be impacted.

Number of Transformers at or below 120 volts	64
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	197
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	26

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
6	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$27,456
12	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$18,720
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$23,920

Total estimated cost to resolve low voltage concerns: \$76,336

Stage 3 Modification Total = \$304,280

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$622,153**



**Clinton 5Y608**

**Changes for Stage 1**

Node	Line	Load	Losses	Swap Phases	Staff	hours	rate	total	Work Description
5Y608 S01a	FP055861_389072157	5Y608_389070384		A->C	Engineer	4	\$130	\$520	Engineering and Analysis
					Svc Line Worker	0	\$130	\$0	Install /Remove metering
					Notifier	2	\$100	\$200	Notify customers of outage
					SVC Crew (3 person + 2 flaggers)	3	\$520	\$1,560	Make phase changes
					<b>Total</b>	<b>9</b>		<b>\$2,280</b>	
<b>Metering</b>									
								Substation	\$8,130
								End of Line	\$9,540
									<b>\$17,670</b>

**Stage 1 Costs to address Potential Low Voltages**

Light Load is Controlling Case

Number of Transformers at or below 120 volts 38  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 341  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 3050  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.37  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 12

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
8	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$12,480
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$16,640

Total estimated cost to resolve low voltage concerns: \$53,664

**Total Stage 1 = \$73,614**

**Changes for Stage 2**

Node	Load	Labor	Material	AFUDC	Total	
S02b Add Sw Cap FP274441	+ 900 kVAR	\$6,575	\$10,393	\$2,121	\$19,088	Engineering = 10% of Total
					\$1,909	
					\$20,997	
Node	Conductor	Length (ft)				
S02c 1 from FP280201_984800474	943 [12.5 #4 ACS3PSn 8xa]	564.0	\$44.24	\$45.33	\$11.20	Per foot cost - Urban Average
to FP280103_984800473	1055 [12.5 477AAC3PLn 8xa]					Labor, Material, AFUDC, Total
					\$5,683	Engineering = 10% of total
					\$62,515	Total

**Stage 2 Costs to address Potential Low Voltages**

Light Load is Controlling Case.

7 less transformers will be impacted.

Number of Transformers at or below 120 volts 0  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 161  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 3050  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.37  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 5

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$13,728)
-4	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$6,240)
-2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$3,120)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$10,400)

Total estimated cost to resolve low voltage concerns: (\$33,488)

The number of impacted transformers is less in stage 2 than in stage 1. No additional costs

**Stage 2 Modification Total = \$50,025**

**Stage 1 + Stage 2 Modification Total = \$123,639**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5Y610
			Subtotal:	\$108,833

**Stage 3 Costs to address Potential Low Voltages**

Light Load is Controlling Case

12 more transformers will be impacted.

Number of Transformers at or below 120 volts 161  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 218  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 3050  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.37  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 17

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
8	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$12,480
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$15,600

Total estimated cost to resolve low voltage concerns: \$49,504

**Stage 3 Modification Total = \$158,337**

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$281,975**

**Clinton 5Y610**

Changes for Stage 1	Node	Line	Load	Losses	Swap Phases	Staff	hours	rate	total	Work Description	
						Engineer		4	\$130	\$520	Engineering and Analysis
						Svc Line Worker		0	\$130	\$0	Install /Remove metering
<b>S01b</b>	FP278203_479410700	5Y610_479410265			A->B	Notifier		2	\$100	\$200	Notify customers of outage
						SVC Crew (3 person + 2 flaggers)		3	\$520	\$1,560	Make phase changes
						<b>Total</b>		<b>9</b>		<b>\$2,280</b>	
<b>Metering</b>											
						Substation				\$8,130	
						End of Line				\$9,540	
										<b>\$17,670</b>	

**Stage 1 Costs to address Potential Low Voltages**  
*Light Load is Controlling Case*

Number of Transformers at or below 120 volts	16
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	277
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2707
Heavy Load =	9250
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	7

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,400

Total estimated cost to resolve low voltage concerns: \$33,488

**Total Stage 1 = \$53,438**

Changes for Stage 2	Node	Load	Labor	Material	AFUDC	Total	
<b>S02b</b>	Add Sw Cap	FP278510_460481740	+ 600 kVAR	\$6,575	\$12,136	\$2,339	\$21,049
							\$2,105 Engineering = 10% of Total
							\$23,154
<b>S02c</b>	1 from	<b>Node</b>	<b>Conductor</b>	<b>Length (ft)</b>	\$	44.24	\$ 45.33
	to	FP279560_460480611	1083 [12.5 4/0AAC3PMn 8xa]	576.0	\$	11.20	\$101 Per foot cost - Urban Average
		FP279609_460480657	1055 [12.5 4/77AAC3PLn 8xa]				\$58,041 Labor, Material, AFUDC, Total
							\$5,804 Engineering = 10% of total
							\$63,845 Total

**Stage 2 Costs to address Potential Low Voltages**  
*Light Load is Controlling Case.*

5 less transformers will be impacted.

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	95
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2707
Heavy Load =	9250
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	2

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-2	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$9,152)
-3	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$4,680)
-1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$1,560)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$7,020)

Total estimated cost to resolve low voltage concerns: (\$22,412)

**Stage 2 Modification Total = \$64,587**

**Stage 1 + Stage 2 Modification Total = \$118,025**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5Y608
Subtotal:			\$108,833	

**Stage 3 Costs to address Potential Low Voltages**

Light Load is Controlling Case.

8 more transformers will be impacted.

Number of Transformers at or below 120 volts 95  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 198  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2707  
 Heavy Load = 9250  
 Light Load / Heavy Load = 0.29  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 10

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
5	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$7,800
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,660

Total estimated cost to resolve low voltage concerns: \$33,748

**Stage 3 Modification Total = \$142,581**

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$260,606**

**Orchard 5Y456**

Changes for Stage 1	Node	Line	Load	Losses	Swap Phases	Staff	hours	rate	total	Work Description	
<b>S01a</b>	FP168004_306160613	5Y456_306160060			C->B	2 - Single Phase moves					
						Engineer	7.2	\$130	\$936	Engineering and Analysis	
	FP213700_738390496	5Y456_738390191			A->B	Svc Line Worker	0	\$130	\$0	Install /Remove metering	
						Notifier	4	\$100	\$400	Notify customers of outage	
	FP163200_306160581	5Y456_306160113			CBA->CAB	SVC Crew (3 person + 2 flaggers)	6	\$520	\$3,120	Make phase changes	
						Total	17.2		\$4,456		
							Three Phase swap				
							Engineer	4	\$130	\$520	Engineering and Analysis
							Svc Line Worker	0	\$130	\$0	Install /Remove metering
							Notifier	4	\$100	\$400	Notify customers of outage
SVC Crew (4 person + 2 flaggers)							6	\$650	\$3,900	Make phase changes	
Total	14		\$4,820								
						Metering					
						Substation			\$8,130		
						End of Line			\$9,540		
									\$17,670		

**Stage 1 Costs to address Potential Low Voltages**  
*HL Case is subset of LL Case w/ same number of potential transformers*

Assumed Solution:

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	215
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	1837
Heavy Load =	7300
Light Load / Heavy Load =	0.25
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	4

Qty. (ea)	Work Description	Assumptions	Total
2	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$9,152
2	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$3,120
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$6,760

Total estimated cost to resolve low voltage concerns: \$22,152

**Total Stage 1 = \$49,098**

Changes for Stage 2	Node	Load	Labor	Material	AFUDC	Total	
<b>S02b</b>	Add Sw Cap	FP215411					
		+ 600 kVAR	\$6,575	\$12,136	\$2,339	\$21,049	
						\$2,105	Engineering = 10% of Total
						\$23,154	
<b>S02c</b>							
	Node	Conductor	Length (ft)				
	1 from 7000_306160615	1256 [12.5 #6 CU 3]	812.0	\$21	\$21	\$5	\$47
	to 7101_306161294	1243 [12.5 #2AAC3PSn 8xa]		Used 4/0 Easy cost			\$47,773
							\$4,777
							\$52,550
	2 from 7101_306161294	943 [12.5 #4ACS 3f]	211.0				
	to 7102_306160572	1243 [12.5 #2AAC3PSn 8xa]					
		Total reconductor=	1023.0				

**Stage 2 Costs to address Potential Low Voltages**  
 The number of impacted transformers is less in stage 2 than in stage 1. No additional costs

**Stage 2 Modification Total = \$75,704**

**Stage 1 + Stage 2 Modification Total = \$124,802**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	
Subtotal:			\$108,833	

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is controlling case.

7 more transformers will be impacted.

Number of Transformers at or below 120 volts 46  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 34  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 11

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,400

Total estimated cost to resolve low voltage concerns: \$33,488

Stage 3 Modification Total = \$142,321

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$267,123**

**Orchard 5Y498**

**Changes for Stage 1**                      **Node**                      **Line**                      **Load**                      **Losses**                      **Swap Phases**                      **Staff**                      **hours**                      **rate**                      **total**                      **Work Description**

No System Improvements necessary for Stage 1

**Stage 1 Costs to address Potential Low Voltages**

HL Case is subset of LL Case

Assumed Solution:

Number of Transformers at or below 120 volts                      0  
 Estimated percent with secondary Vd > 4 volts                      26.8%  
 Number of Transformers from 120 to 121 volts                      322  
 Estimated percent with secondary Vd > 5 volts                      10.6%  
 Light Load =                      1446  
 Heavy Load =                      6280  
 Light Load / Heavy Load =                      0.23  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance =                      6

Qty. (ea)	Work Description	Assumptions	Total
2	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$9,152
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$8,320

Total estimated cost to resolve low voltage concerns:                      \$26,832

<b>Metering</b>	
Substation	\$8,130
End of Line	\$9,540
	<u>\$17,670</u>

**Total Stage 1 = \$44,502**

<b>Changes for Stage 2</b>	<b>Node</b>	<b>Load</b>	<b>Labor</b>	<b>Material</b>	<b>AFUDC</b>	<b>Total</b>	
			\$6,575	\$10,393	\$2,121	\$19,088	
<b>S02b</b>	Add Sw Cap	FP225240				<u>\$1,909</u>	Engineering = 10% of Total
		+ 900 kVAR				\$20,997	

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is the same as in stage 1. No additional costs

**Stage 2 Modification Total = \$20,997**

**Stage 1 + Stage 2 Modification Total = \$65,499**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	
Subtotal:			\$108,833	

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is controlling case

13 more transformers will be impacted.

Number of Transformers at or below 120 volts	63
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	96
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	19

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
9	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$14,040
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$17,420

Total estimated cost to resolve low voltage concerns: \$56,004

**Stage 3 Modification Total = \$164,837**

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$230,336**



**Wiley 5Y434**

Changes for Stage 1	Node	Line	Load	Losses	Swap Phases	Labor	Material	AFUDC	Total		
<b>No phase changes</b>											
					None						
Add Cap	FP301903_506870503		600 kVar			\$3,071	\$2,818	\$736	\$6,624	Engineering = 10% of Total	
									\$662		
									\$7,287		
Add Cap	FP254905_47582199		300 kVar			\$3,071	\$5,209	\$1,076	\$9,356	Engineering = 10% of Total	
									\$936		
									\$10,292		
									<b>Metering</b>		
									Substation	\$8,130	
									End of Line	\$9,540	
										\$17,670	

**Stage 1 Costs to address Potential Low Voltages**

Heavy Load is controlling case

Assumed Solution:

Number of Transformers at or below 120 volts	53
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	69
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	15

Qty. (ea)	Work Description	Assumptions	Total
5	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$22,880
10	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$15,600
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$20,280

Total estimated cost to resolve low voltage concerns: \$65,000

**Total Stage 1 = \$100,248**

Changes for Stage 2	Node	Line	Load	Labor	Material	AFUDC	Total	
S02b Add Sw Cap	FP365800		+ 600 kVAR	\$6,575	\$12,136	\$2,339	\$21,049	Engineering = 10% of Total
							\$2,105	
							\$23,154	Total

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is only slightly less than in stage 1. No additional costs

**Stage 2 Modification Total= \$23,154**

**Stage 1 + Stage 2 Modification Total = \$123,402**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	
Subtotal:			\$214,114	

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is controlling case.

15 more transformers will be impacted.

Number of Transformers at or below 120 volts	150
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	17
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	30

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
5	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$22,880
10	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$15,600
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$20,280

Total estimated cost to resolve low voltage concerns: \$65,000

Stage 3 Modification Total = \$279,114

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$402,516**

**Nob Hill 5Y197**

**Changes for Stage 1**                      **Node**                      **Line**                      **Load**                      **Losses**                      **Swap Phases**

**S01a**                      No Phase changes for Stage 1

**Stage 1 Costs to address Potential Low Voltages**

Heavy Load is controlling case

Number of Transformers at or below 120 volts                      0  
 Estimated percent with secondary Vd > 4 volts                      26.8%  
 Number of Transformers from 120 to 121 volts                      0  
 Estimated percent with secondary Vd > 5 volts                      10.6%  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance =                      0

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
0	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$0
0	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$0
3	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$4,680
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$1,560

Total estimated cost to resolve low voltage concerns:                      \$6,240

**Metering**  
 Substation                      \$8,130  
 End of Line                      \$9,540  
 \$17,670

**Total Stage 1 = \$23,910**

**Changes for Stage 2**                      **Node**                      **Load**

**S02b**                      Add Sw Cap                      FP365800                      + 900 kVAR

Labor    Material    AFUDC    Total  
 \$6,575    \$12,136    \$2,339    \$21,049  
 \$2,105    Engineering = 10% of Total  
 \$23,154    Total

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is less than in stage 1. No additional costs

**Stage 2 Modification Total= \$23,154**

**Stage 1 + Stage 2 Modification Total = \$47,064**

**Changes for Stage 3**

All changes in Stage three are to address potential low voltage.

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.33	\$210,563	\$70,188	Shared cost with 5Y194 & 5Y273
			Subtotal:	\$73,739

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is controlling case

7 more transformers will be impacted.

Number of Transformers at or below 120 volts 0  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 96  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 7

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,400

Total estimated cost to resolve low voltage concerns: \$33,488

Stage 3 Modification Total = \$107,227

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$154,291**

**Nob Hill 5Y194**

Changes for Stage 1		Node	Line	Load	Losses	Swap Phases	Labor	Material	AFUDC	Total	
<b>S01b</b>	Add Fixed Cap	FP2433005_991160290		+1200 kVAr			\$3,071	\$3,611	\$835	\$7,517	
										\$752	Engineering = 10% of Total
										\$8,269	Total
	Add Fixed Cap	FP242209_991162198		+300 kVAr			\$3,071	\$5,209	\$1,076	\$9,356	
										\$936	Engineering = 10% of Total
										\$10,292	Total
	Relocate Fixed Cap	FP242209_991162198		600 kVAr			\$6,141		\$798	\$6,940	
										\$694	Engineering = 10% of Total
										\$7,633	Total
No Phase changes for Stage 1											
<b>Metering</b>											
Substation											
\$8,130											
End of Line											
\$9,540											
<hr/>											
\$17,670											

**Stage 1 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset

Assumed Solution:

Number of Transformers at or below 120 volts	164
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	65
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2710
Heavy Load =	8200
Light Load / Heavy Load =	0.33
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	12

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
8	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$12,480
3	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$4,680
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$16,120

Total estimated cost to resolve low voltage concerns: \$51,584

**Total Stage 1 = \$95,448**

**Changes for Stage 2**

Changes for Stage 2		Node	Line	Load	Losses	Swap Phases	Labor	Material	AFUDC	Total	
<b>S02b</b>	Add Sw Cap	FP2433005_991160290		+ 1200 kVAr			\$19,725	\$36,406	\$4,678	\$60,809	Cost for all 3 units installed
	Add Sw Cap	FP242209_991162198		+ 600 kVAr						\$6,081	Engineering = 10% of Total
	Add Sw Cap	FP242209_991162198		+600 kVAr (only 300 kVAr needed)						\$66,889	Total
	Remove 600 kVAr fixed bank						\$3,071		\$399	\$3,470	
										\$347	Engineering = 10% of Total
										\$3,817	Total
Credit for Stage one fixed Capacitors at the same locations											
										(\$26,194)	
<b>S02c</b>	1 from	MP_931350832		<b>Conductor</b>		<b>Length (ft)</b>					
	to	FP999999_931350864		1050 [12.5 500 AL3PUGCond]		313.0	\$6,927	\$13,105	\$2,504	\$22,536	Urban Average Cost
				1049 [12.5 1000AL3PUGCond]						\$2,254	Engineering = 10% of Total
										\$24,790	Total
	2 from	FP999999_931350864		1097 [12.5 2/0ACS 3PSn 8xa]		119.0	\$5,265	\$5,394	\$1,332	\$11,991	Urban Medium Cost
	to	FP269312_931350900		1055 [12.5 477AAC3PLn 8xa]						\$1,199	Engineering = 10% of Total
										\$13,190	Total

**Stage 2 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.

12 less transformers will be impacted.

Number of Transformers at or below 120 volts 0  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 0  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2710  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.33  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 0

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$18,304)
-8	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$12,480)
-2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$3,120)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$15,600)

Total estimated cost to resolve low voltage concerns: (\$49,504)

Stage 2 Modification Total= \$32,988

Stage 1 + Stage 2 Modification Total = \$128,436

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.33	\$210,563	\$70,188	Shared cost with 5Y197 and 5Y273

Subtotal: \$73,739

**Stage 3 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.

24 more transformers will be impacted.

Number of Transformers at or below 120 volts 355  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 65  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2710  
 Heavy Load = 8200  
 Light Load / Heavy Load = 0.33  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 24

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
8	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$36,608
16	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$24,960
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$30,160

Total estimated cost to resolve low voltage concerns: \$94,848

Stage 3 Modification Total = \$168,587

Stage 1 + Stage 2 + Stage 3 Modification Total = \$297,023

**Nob Hill 5Y273**

Changes for Stage 1	Node	Line	Load	Losses	Swap Phases	Staff	hours	rate	total	Work Description
S01a FP264901_656800698	5Y273_656800259				C->A	Engineer	4	130	520	Engineering and Analysis
						Svc Line Worker	0	130	0	Install /Remove metering
						Notifier	2	100	200	Notify customers of outage
						SVC Crew (3 person + 2 flaggers)	3	520	1560	Make phase changes
						Total	9		\$2,280	
S01b Remove Cap	FP239106_556790602				- 600 kVar	Engineer	4	130	520	Engineering & Admin
						SVC Crew (3 person + 2 flaggers)	4	520	2080	Remove Cap Bank
									2600	
									<b>Metering</b>	
									Substation	\$8,130
									End of Line	\$9,540
										\$17,670

**Stage 1 Costs to address Potential Low Voltages**  
LL Case is controlling case with HL as subset

Number of Transformers at or below 120 volts	463
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	0
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2324
Heavy Load =	8080
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	25

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
8	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$36,608
17	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$26,520
6	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$9,360
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$33,020

Total estimated cost to resolve low voltage concerns: \$105,508

**Total Stage 1 = \$128,058**

**Changes for Stage-2**

Node	Load	Labor	Material	AFUDC	Total	
502b Add Sw Cap FP239106_556790602	+ 600 kVAR	\$13,149	\$24,271	\$4,678	\$42,098	Cost are for both units installed
Add Sw Cap FP268700	+ 600 kVAR				\$4,210	Engineering = 10% of Total
					\$46,308	Total

**Stage 2 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.  
 16 less transformers will be impacted.

Number of Transformers at or below 120 volts	0
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	420
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2324
Heavy Load =	8080
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	9

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-5	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$22,880)
-11	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$17,160)
-4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$6,240)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$21,060)
Total estimated cost to resolve low voltage concerns:			(\$67,340)

Stage 2 Modification Total = (\$21,032)

Stage 1 + Stage 2 Modification Total = \$107,026

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.33	\$210,563	\$70,188	Shared cost w/ 5Y194 and 5Y197
Subtotal:			\$73,739	

**Stage 3 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.  
 15 more transformers will be impacted.

Number of Transformers at or below 120 volts	420
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	43
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	2324
Heavy Load =	8080
Light Load / Heavy Load =	0.29
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	24

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
5	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$22,880
10	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$15,600
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$19,240
Total estimated cost to resolve low voltage concerns:			\$60,840

Stage 3 Modification Total = \$134,579

Stage 1 + Stage 2 + Stage 3 Modification Total = \$241,604



**North Park 5Y356**

**Changes for Stage 1**

Node	Line	Load	Losses	Swap Phases					
<b>S01a</b>	No Line/Phase swaping needed				Engineer	4	130	520	Engineering & Admin
					SVC Crew (3 person + 2 flaggers)	4	520	2080	Remove Cap Bank
<b>S01b</b>	Remove Cap	FP219900_826650557	-900 kVar					2600	
								<b>Metering</b>	
								Substation	\$8,130
								End of Line	\$9,540
									\$17,670

**Stage 1 Costs to address Potential Low Voltages**

Heavy Load is controlling case

Assumed Solution:

Number of Transformers at or below 120 volts	158
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	73
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	35

Qty. (ea)	Work Description	Assumptions	Total
11	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$50,336
24	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$37,440
8	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$12,480
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$45,760

Total estimated cost to resolve low voltage concerns: \$146,016

**Total Stage 1 = \$166,286**

**Changes for Stage 2**

Node	Line	Load	Labor	Material	AFUDC	Total			
<b>S02b</b>	Add Sw Cap	FP219900_826650557	+900 kVar	\$6,575	\$10,393	\$2,121	\$19,088		
						\$1,909	Engineering = 10% of Total		
						\$20,997			
<b>S02c</b>	1 from to	<b>Node</b> FP178002_640300540 FPUNK_640300538	<b>Conductor</b> 1083 [12.5 4/0AAC3PMn 8xa] 1055 [12.5 477AAC3PLn 8xa]	<b>Length (ft)</b> 607.0	\$26,854	\$27,515	\$6,796	\$61,165 Urban Average Cost	
						\$6,117	Engineering = 10% of Total		
						\$67,282	Total		
<b>S02e</b>	Line Regulator	FP160001_274180881	5Y356_274180328-SP1	[ld = 602] 328 A 3Ph 16 step 3x180 kVA	\$11,110	\$47,553	\$7,333	\$65,995 Per Block Estimate	
						\$6,599	Engineering = 10% of total		
						\$72,594			
								<b>Metering</b>	
								Regulator	\$16,000
								End of Line	\$9,540
									25540

**Stage 2 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.

29 less transformers will be impacted.

Number of Transformers at or below 120 volts 0  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 232  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2496  
 Heavy Load = 6800  
 Light Load / Heavy Load = 0.37  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 6

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
-9	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	(\$41,184)
-20	transformer tap changes	(4 hrs x 3 person crew) per tap change	(\$31,200)
-7	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	(\$10,920)
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	(\$37,960)

Total estimated cost to resolve low voltage concerns: (\$121,264)

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is approximately the same as stage 1. No additional costs

Stage 2 Modification Total = \$65,149

Stage 1 + Stage 2 Modification Total = \$231,435

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	
Subtotal:			\$221,029	

**Stage 3 Costs to address Potential Low Voltages**

LL Case is controlling case with HL as subset.

17 more transformers will be impacted.

Number of Transformers at or below 120 volts 232  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 244  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2496  
 Heavy Load = 6800  
 Light Load / Heavy Load = 0.37  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 23

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
6	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$27,456
11	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$17,160
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$22,100

Total estimated cost to resolve low voltage concerns: \$69,836

Stage 3 Modification Total = \$290,865

Stage 1 + Stage 2 + Stage 3 Modification Total = \$522,300

**River Road 5Y444**

**Changes for Stage 1**

Node	Line	Load	Losses	Swap Phases	Three - 1 Phase swap				
<b>S01a</b>	FP150014_154241218	5Y444_154240243		A -> C	Engineer	12	\$130	\$1,560	Engineering and Analysis
	FP157000_154241204	5Y444_154240477		A -> C	Svc Line Worker	0	\$130	\$0	Install /Remove metering
					Notifier	6	\$100	\$600	Notify customers of outage
	FP156080_154241134	5Y444_154240377		A -> C	SVC Crew (4 person + 2 flaggers)	9	\$520	\$4,680	Make phase changes
				<b>Total</b>	<b>27</b>		<b>\$6,840</b>		

<b>S01b</b>	Reduce Cap	FP237905_419030342	1200 kVAr -> 600 kVAr		Labor	Material	AFUDC	Total	
					\$8,000	\$500	\$0	\$8,500	
								\$850	Engineering = 10% of Total
								\$9,350	

<b>Metering</b>		
Substation		\$8,130
End of Line		\$9,540
		<b>\$17,670</b>

**Stage 1 Costs to address Potential Low Voltages**

For Stage 1 LL Case is controlling case with HL as subset

Number of Transformers at or below 120 volts	43
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	406
Estimated percent with secondary Vd > 5 volts	10.6%
Light Load =	3314
Heavy Load =	10600
Light Load / Heavy Load =	0.31
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	12

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
4	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$18,304
8	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$12,480
3	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$4,680
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$16,120

Total estimated cost to resolve low voltage concerns: \$51,584

**Total Stage 1 = \$85,444**

**Changes for Stage 2**

		Node	Load	Labor	Material	AFUDC	Total		
<b>S02b</b>	Add Sw Cap	FP232945	+ 600 kVAr						
	Add Sw Cap	FP147243	+ 600 kVAr	\$13,149	\$24,271	\$4,678	\$42,098	Cost are for both units installed	
							\$4,210	Engineering = 10% of Total	
							\$46,308	Total	
		Node	Conductor	Length (ft)					
<b>S02c</b>	1 from	FP158001_80630559	1256 [12.5 #6 CU 3PSn 8xa]	106.0	\$21	\$21	\$5	\$47	Per foot cost - Urban Average
	to	FP158002_154241123	17 [12.5 1/0ACS3PSn 8xa]		Used 4/0 Easy cost			\$31,195	Labor, Material, AFUDC, Total
							\$3,119	Engineering = 10% of total	
							\$34,314	Total	
<b>S02e</b>	2 from	FP158002_154241123	938 [12.5 #2 ACS 3PSn 8xa]	562.0					
	to	FP158104_154241172	17 [12.5 1/0ACS3PSn 8xa]						
				Total Reconductor =	668.0				
<b>S02e</b>	Add Regulator	FP141001_33500763	5Y444_1031038802-SP1 [ld = 602] 328 A 3Ph 16 step 3x180 kVA	\$11,110	\$47,553	\$7,333	\$65,995	Per Block Estimate	
								\$6,599	Engineering = 10% of total
							\$72,594		
								<b>Metering</b>	
								Regulator	
								\$16,000	
								End of Line	
								\$9,540	
								\$25,540	

**Stage 2 Costs to address Potential Low Voltages**

The number of impacted transformers is the same as stage 1. No additional costs

**Stage 2 Modification Total=** \$178,757

**Stage 1 + Stage 2 Modification Total =** \$264,201

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	
			Subtotal:	\$221,029

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is controlling case for Stage 3.

16 more transformers will be impacted.

Number of Transformers at or below 120 volts	57
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	251
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	28

**Assumed Solution:**

Qty. (ea)	Work Description	Assumptions	Total
5	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$22,880
11	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$17,160
4	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$6,240
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$21,060

Total estimated cost to resolve low voltage concerns: \$67,340

**Stage 3 Modification Total =** \$288,369

**Stage 1 + Stage 2 + Stage 3 Modification Total =** \$552,570



Changes for Stage 3

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5Y317
Subtotal:			\$108,833	

Stage 3 Costs to address Potential Low Voltages

Light Load is Controlling Case.  
8 more transformers will be impacted.

Number of Transformers at or below 120 volts 209  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 18  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 1583  
 Heavy Load = 4500  
 Light Load / Heavy Load = 0.35  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 15

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
5	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$7,800
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,660

Total estimated cost to resolve low voltage concerns: \$33,748

Stage 3 Modification Total= \$142,581

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$240,890**

**Sunnyside 5Y317**

**Changes for Stage 1**

5Y317 S01a

**Node**

FP257504\_823200895

**Line**

5Y317\_823200406  
5Y317\_823200313

**Load**

TR\_257501\_823200453

**Swap Phases**

B-->A  
ABC-->ACB  
A-->B

Two 1-phase changes (tap and transformer)

Staff	hours	rate	total	Work Description
Engineer	6	\$130	\$780	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	3	\$100	\$300	Notify customers of outage
SVC Crew (3 person + 2 flaggers)	6	\$520	\$3,120	Make phase changes
<b>Total</b>	<b>15</b>		<b>\$4,200</b>	

**One - Three Phase swap**

Engineer	4	\$130	\$520	Engineering and Analysis
Svc Line Worker	0	\$130	\$0	Install /Remove metering
Notifier	4	\$100	\$400	Notify customers of outage
SVC Crew (4 person + 2 flaggers)	6	\$650	\$3,900	Make phase changes
<b>Total</b>	<b>14</b>		<b>\$4,820</b>	

**Metering**

Substation	\$8,130
<b>End of Line</b>	<b>\$9,540</b>
	<b>\$17,670</b> total metering

**Stage 1 Costs to address Potential Low Voltages**

The number of transformers with potentially low secondary voltage = 0

**Total Stage 1 = \$26,690**

**Changes for Stage 2**

S02b

New Switched FP256511\_937580500

**Line**

**Load**

+SW 600 kVAr

**Labor**

\$6,575

**Material**

\$12,136

**AFUDC**

\$2,339

**Total**

\$21,049

\$2,105 Engineering = 10% of Total

\$23,154

**Stage 2 Costs to address Potential Low Voltages**

The number of transformers with potentially low secondary voltage = 0

Stage 2 Modification Total= \$23,154

**Stage 1 + Stage 2 Modification Total = \$49,844**

Changes for Stage 3

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	2	\$3,551	\$7,102	
Line regulator: wireless 'radio' link to the substation	1	\$3,364	\$3,364	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	0.5	\$210,563	\$105,282	Shared cost with 5Y313
Subtotal:			\$115,748	

Stage 3 Costs to address Potential Low Voltages

Light Load is Controlling Case.  
 9 more transformers will be impacted.

Number of Transformers at or below 120 volts 135  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 19  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 1279  
 Heavy Load = 4000  
 Light Load / Heavy Load = 0.32  
 Estimated total number of transformers that may have customers with low voltage at Service Entrance = 9

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
6	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$9,360
2	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$3,120
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$11,960

Total estimated cost to resolve low voltage concerns: \$38,168

Stage 3 Modification Total= \$153,916

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$203,759**



**Grandview 5Y351**

Changes for Stage 1		Node	Line	Load	Losses	Swap Phases					
5Y351	S01a	FP274501_564110792	5Y351_564110009			BAC --> ABC	<b>One - Three Phase swap</b>				
							Engineer	4	\$130	\$520	Engineering and Analysis
							Svc Line Worker	0	\$130	\$0	Install /Remove metering
							Notifier	4	\$100	\$400	Notify customers of outage
							SVC Crew (4 person + 2 flaggers)	6	\$650	\$3,900	Make phase changes
							<b>Total</b>	<b>14</b>		<b>\$4,820</b>	
5Y351	S01b	Reduce Cap	FP227502_728880503	Fixed	600 kVAr --> 300 kVAr		<b>Labor</b>	<b>Material</b>	<b>AFUDC</b>	<b>Total</b>	
							\$8,000	\$500	\$0	\$8,500	
										\$850	Engineering = 10% of Total
										\$9,350	

<b>Metering</b>	
Substation	\$8,130
<b>End of Line</b>	\$9,540
	\$17,670 total metering

**Stage 1 Costs to address Potential Low Voltages**  
Heavy Load is Controlling Case.

Number of Transformers at or below 120 volts	19
Estimated percent with secondary Vd > 4 volts	26.8%
Number of Transformers from 120 to 121 volts	20
Estimated percent with secondary Vd > 5 volts	10.6%
Estimated total number of transformers that may have customers with low voltage at Service Entrance =	5

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
2	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$9,152
3	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$4,680
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$7,020

Total estimated cost to resolve low voltage concerns: \$22,412

**Total Stage 1 = \$54,252**

Changes for Stage 2		Node	Line	Load	Losses	Swap Phases	Costs to install both capacitor banks				
5Y351	S02b	Add Sw Cap	FP229907_1040375491	Switched	600 kVAr		<b>Labor</b>	<b>Material</b>	<b>AFUDC</b>	<b>Total</b>	
		Add Sw Cap	FP226502_728882270	Switched	600 kVAr		\$13,149	\$24,271	\$4,678	\$42,098	
							<b>\$0.13</b>			\$4,210	Engineering = 10% of Total
										\$46,308	
		Add Regulator	FP226205_728880766				\$11,110	\$40,480	\$6,449	\$58,038	
		[Id = 63] 219 A 3Ph 16 step 3x180 kVA	5Y351_728880260-SP1	Flow (kVA) =	855.1					\$5,804	Engineering = 10% of Total
										\$63,842	
							<b>Metering</b>				
							Regulator			\$16,000	
							End of Line			\$9,540	
										\$25,540	

**Stage 2 Costs to address Potential Low Voltages**

Light Load is Controlling Case.

7 more transformers will be impacted.

Number of Transformers at or below 120 volts 155  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 174  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Light Load = 2171  
 Heavy Load = 7700  
 Light Load / Heavy Load = 0.28  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 12

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
4	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$6,240
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$9,880

Total estimated cost to resolve low voltage concerns: \$31,408

Stage 2 Modification Total = \$167,097

**Stage 1 + Stage 2 Modification Total = \$221,349**

**Changes for Stage 3**

Work Description	No. of locations	Cost per location	Total	Notes
End of 1ph voltage control zone: wireless 'radio' link to substation	1	\$3,551	\$3,551	
Line regulator: wireless 'radio' link to the substation	0	\$3,364	\$0	
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	1	\$210,563	\$210,563	

Subtotal: \$214,114

**Stage 3 Costs to address Potential Low Voltages**

Heavy Load is Controlling Case.

8 more transformers will be impacted.

Number of Transformers at or below 120 volts 63  
 Estimated percent with secondary Vd > 4 volts 26.8%  
 Number of Transformers from 120 to 121 volts 111  
 Estimated percent with secondary Vd > 5 volts 10.6%  
 Estimated total number of transformers that  
 may have customers with low voltage at Service Entrance = 20

Assumed Solution:

Qty. (ea)	Work Description	Assumptions	Total
3	transformer change out	(8 hrs x 4 person crew) + 10% of labor for material - per unit	\$13,728
5	transformer tap changes	(4 hrs x 3 person crew) per tap change	\$7,800
1	service change out	(4 hrs x 2 person crew) + 50% of labor for material - per unit	\$1,560
	Planning and Engineering	(Estimated to be 50% of Crew Labor)	\$10,660

Total estimated cost to resolve low voltage concerns: \$33,748

Stage 3 Modification Total = \$247,862

**Stage 1 + Stage 2 + Stage 3 Modification Total = \$469,211**

**Appendix 11: High and Low Voltage Reports**

**John P. White**

---

**From:** Pierce, Wyatt [Wyatt.Pierce@PacifiCorp.com]  
**Sent:** Wednesday, April 06, 2011 3:16 PM  
**To:** John P. White  
**Subject:** Revised OPQ list  
**Attachments:** Voltage OPQ List for Tier 1 Circuits version 2.xlsx

John,

As promised, here is a new version of the OPQ sheet, which I think looks better. It's the same data except for one row. Doug informed me that the third OPQ on the old list was not an issue, so I removed it.

Thanks,

Wyatt W. Pierce, PE

**Pacific Power**

**NID Support & Special Projects**

**Desk:** 541•633•2481

**Cell:** 541•848•7970

Feeder	Request Date	OPQ Number	Voltage	Request Description	Xfmr ID	Comments
4W22	10/20/2005	2737162	Maybe	PLEASE INVESTIGATE, CUST IS EXPERIENCING LOW VOLTAGE DUE TOSOME UPGRADES IN HIS AREA BECAUSE OF CONSTRUCTION AROUND HIM, HE FEELS HIS SERVICE HAS BEE	TR_126582_726180197	CONCLUSION UNKNOWN.
4W22	11/16/2005	2751051	Yes	PLEASE INVESTIGATE, CUST IS EXPERIENCING LOW VOLTAGE DUE TOSOME UPGRADES IN HIS AREA BECAUSE OF CONSTRUCTION. SINCE UPGRADE, HAS HAD LOW VOLTAGE. NOT	TR_126582_726180197	A SECTIONALIZER WAS ADDED TO REDUCE THE SECONDARY LENGTH.
5W116	2/25/2009	5288343	Yes	PLEASE INVESTIGATE. LIGHT BULBS HAVE BEEN BURNING OUT TOO FAST. THEIR ELECTRICIAN THINKS TOO MUCH VOLTAGE IS COMING IN AND 312 N DIVISION AND 314 N DI	TR_212704_122450256	POSSIBLY LIGHTLY LOADED PHASE, CLOSE TO SUB.
5W116	6/21/2010	5444889	Yes	FLICKERING LIGHTS - CUSTOMER HAS INSTALLED A HEAT PUMP WITHOUT INFORMING US. SET RVM PER REQUEST OF DOUG G/ENGINEER.	TR_161001_755430222	CUSTOMER INTRODUCED NEW 9% FLICKER.
5W127	11/22/2010	5496672	Yes	PLEASE INVESTIGATE CUST GETTING DIMMING LIGHTS WHEN RUNNINGA SAW IN THE GARRAGE. AN ELECTRICTION STATED THAT SHE THOUGHT THAT OUR LINE FROM THE POLE T	TR_281801_544870376	STEADY STATE 113V UNDER LOAD, 7% FLICKER.
5W154	8/17/2004	2508998	Maybe	PLEASE INVESTIGATE. CUSTOMER IS EXPERIENCING POWER FLUCTUATIONS. SOMETIMES JUST MINUTES APART, SOMETIMES HOURS APART. THE VOLTAGE SEEMS TO DECREASE	TR_358607_369970338	FAR FROM SUB; CONCLUSION UNKNOWN.
5W342	2/26/2007	2984768	Yes	CUSTOMER'S LIGHTS DIM WHEN HEAT PUMP STARTS UP. PLEASESET MR-4	TR_355402_463490102	NEW HEAT PUMP, NEW 5.4% DIP.
5Y317	12/10/2008	5266498	Yes	PLEASE INVESTIGATE. STATES THAT THEY HAVE A LOT OF LIGHT BULBS BURN OUT. NO ISSUES WITH BREAKERS GOING OFF A LOT THOUGH. LAND LORD TOLD THEM THAT 130V	TR_255603_823200514	POSSIBLY LIGHTLY LOADED PHASE, CLOSE TO SUB.
5Y351	1/3/2011	5507484	Yes	FROM DMS# 674204: CUST STATES VOLTAGE AT SITE IS 515, SVCMANWAS ALREADY AT THIS SITE, ASKED US TO CREATE A REQUEST	TR_230801_858280420	WE MEASURED 515V ON 480V SYSTEM. WE LOWERED THE VOLTAGE.
5Y356	7/22/2003	2303616	Maybe	DMS ORDER HAS BEEN SENT. PLEASE INVESTIGATE VOLT ISSUES THAT ARE CAUSING CUSTOMER TO LOSE POWER AND, IN SEVERAL CASES, LOSE APPLIANCES. CUSTOMER HAS	TR_157583_1031037258	FAR FROM SUB; CONCLUSION UNKNOWN.
5Y456	7/30/2010	5458766	Yes	KEN MARTIN EXPERIENCES BROWN OUTS EVERYTIME TURNS ON AC. LIGHTING DIMS CANNOT RECEIVE ANY POWER. HAS HAD ELECTRICIAN TOSITE STATES NOT INTERNAL. HAPPE	TR_164180_306160252	CUST ADDED A/C.
5Y498	1/30/2009	5280544	Yes	PLEASE INVESTIGATE WHEN FURNACE COMES ON ELECTRICIAN TOLD HIM THERE IS NOT ENOUGH VOLTAGE COMING TO THE HOME PLS CHECK THIS HAPPENS DAILY THANKS CUSTO	TR_229202_185300510	CUSTOMER WAS ALREADY NEAR LIMIT AND THEN ADDED LOAD.

**Appendix 12: Summary of Study Data**



Circuit No.	5W150	5W154	5W22	5W116	5W127	5W342	5Y608	5Y610	5Y194	5Y197	5Y273	5Y356	5Y456	5Y498	5Y434	5Y444	5Y351	5Y313	5Y317
Substation	BOWMAN	BOWMAN	DODD RD	MILL CREEK	MILL CREEK	POMEROY	CLINTON	CLINTON	NOB HILL	NOB HILL	NOB HILL	NORTH PARK	ORCHARD	ORCHARD	WILEY	RIVER ROAD	GRANDVIEW	SUNNYSIDE	SUNNYSIDE
Circuit Name	PINE STREET	GARDEN	WINDWARD	GREEN PARK	WILBUR	POMEROY	IKE	BOULEVARD	16TH AVE	TWELFTH AVE.	18TH AVE	FREEWAY	COWICHE	PEACH	DAZET	WRIGHT	EUCLID	CARNATION	EDISON

Stage 3 Case	One Exist Reg																		
<b>Feeder VCZ</b>	Add 1 Reg		Add 2 Reg	Add 1 Reg		Add 2 Reg						Add 1 Reg				Add 1 Reg	Add 1 Reg		
C Max VD% (peak Load)		2.0		2.4	2.8		3.7	3.3	4.2	1.8	3.5	2.8	3.6	3.3	4.1	2.7	2.8	3.5	2.3
C V-Rise (Peak Load)	Add one	2.3	Add two	0.0	5.9	Add two	5.4	5.4	2.3+2.7	2.3+2.7	2.9+1.3	4.5	4.6	5.2	4.7	4.3	4.5	4.7	4.7
C V-Set (No Load)	series	121	paralell	124	120	paralell	120	120	121	121	121	121	121	121	121	121	121	121	121.0
C kW Demand (Fdr)	reg	8198.8	regs	8097.3	6218.4	regs	8197.7	9247.6	8366.3	5899.4	7984.8	6790.0	7297.7	6277.7	6992.1	10595.0	7699.4	4999.0	3,999.8
C kW Demand (Reg 1)		0.0		3304.0	0.0		0.0	0.0	0.0	0.0	0.0	6650.0	0.0	0.0	0.0	6189.0	851.7	0.0	0.0
Post-VO Max VD% (peak Load)		0.8		2.0	2.7		3.2	3.0	3.2	1.8	3.2	2.6	3.6	2.7	3.8	1.7	2.5	3.0	1.8
Post-VO V-Rise (Peak Load)		2.9		2.9	2.9		4.0	4.0	3.5	3.5	4.3	4.5	4.6	3.8	4.7	2.6	2.9	2.9	2.9
Post-VO V-Set (No Load)		119.0		119.0	119.0		119.0	119.0	119.0	119.0	119.0	118.0	119.0	119.0	119.0	119.0	119.0	119.0	119.0
<b>Regulator VCZ</b>																			
C Max VD% (peak Load)				2.1								2.7				1.7	1.7		
C V-Rise (Peak Load)				-0.5								3.4				3.1	2.0		
C V-Set (No Load)				124.0								121.0				121.0	121.0		
C kW Demand (Reg 1)				3,304.0								6,650.0				6,189.0	851.7		
C kW Demand (Reg 2)				0.0								0.0				0.0	0.0		
Post-VO Max VD% (peak Load)				2.5								2.7				2.4	2.0		
Post-VO V-Rise (Peak Load)				3.3								3.4				2.8	2.7		
Post-VO V-Set (No Load)				119.0								119.0				119.0	119.0		
<b>kW Line Loss</b>	302.3	106.1	247.4	114.6	59.3	164.9	95.2	116.2	146.8	43.5	151.6	229.5	100.8	93.6	130.1	186.9	82.9	58.4	35.3
<b>Improvement Costs \$</b>	\$345,514	\$272,600	\$583,960	\$318,157	\$256,139	\$622,153	\$281,975	\$260,606	\$297,023	\$154,291	\$241,604	\$522,300	\$267,123	\$230,336	\$402,516	\$552,570	\$469,211	\$240,890	\$203,759



**Appendix 13: Metering and Communication Costs**

## Commonwealth Developed Metering – Cost Estimate

Each feeder in each substation will need to be individually monitored and metered. Similarly, the end of the line will need to be metered. However, only voltage quantity will be monitored. The load side of a three-phase line regulator will need to be metered with a full complement of quantities monitored.

Several choices for multi-function meters are available that could be used to meter the distribution circuits. For this estimate, an SEL 751A Feeder Protection Relay was selected for use in the substation. A single phase GE kV2 Multifunction Electricity Meter was chosen for the end of the line application. And, a three phase GE kV2 Multifunction Electricity Meter was selected to be used at a line regulator

### Metering Within the Substation

Metering is present in each substation for each power transformer load. That means that there are voltage transformers available to be used for the feeder metering. The substation feeders are being protected with circuit breakers. The circuit breakers have current transformers which can be used for feeder metering. A control enclosure is available in which to mount the meter.

The installation of the meters in the substation should be straightforward. The process for the substation installation will be to remove the existing overcurrent and reclosing relays and replace them with the SEL 751A relay. The relay will be mounted on the panel in place of the existing relays. A test switch will be mounted adjacent (below) the relay. The appropriate voltage quantities will be routed from the existing metering voltage transformer circuits, probably already in the control enclosure. The voltages will be wired to the test switch and relay. Current quantities will be wired to the test switch and relay from the feeder breaker current transformers. The relaying and metering settings will be installed in the relay and a functional check of the relay will be performed.

The estimated cost per circuit to install the metering in a substation is itemized as follows:

	ITEM	QTY	EA	Total
1	SEL 751A Feeder Protection Relay	1	2,500.00	2,500.00
2	Modifications to the relay panel	1	300.00	300.00
	Labor (assume 2 relay/metermen 8 hours per instl.)	8	258.10	2,064.80
3	Test Switch	1	175.00	175.00
4	4 conductor control cable (ft)	150	1.25	187.50
5	Labor (assume 6 hours per installation)	6	258.10	1,548.60
	( 2 man crew = \$258.10 per hour)			
			TOTAL	6,775.90

### Metering at the End of the Line

At the end of the line, there will only be a need to measure the voltage quantities. The installation at the end of the line will be different than the substation installation. One voltage transformers will be provided and mounted on a convenient pole. The transformer will be mounted on a cluster rack at the top of the pole and connected to the line using a fuse cutout and hot clamps. The meter will be mounted to the pole near the base and connected to the voltage transformers using control cable. Since the meter will be exposed to public access, the control cable will be installed in conduit, up the pole, until the cable reaches 10 feet above the ground. After the wiring is complete, the meter will be installed in the meter base and the installation energized and verified. This installation will require a line crew to install the instrument transformers at the top of the pole and a meter man (men) to install and verify the meter.

The estimated cost per circuit to install the metering at the end of the circuit is itemized as follows:

	ITEM	QTY	EA	TOTAL
1	GE kV2 1-Ph. Multifunction Meter	1	\$1,200.00	\$1,200.00
2	Meter base with space for test switch.	1	\$200.00	\$200.00
3	Test Switch	1	\$125.00	\$125.00
4	Fuse cutouts and hot clamps	1	\$550.00	\$550.00
5	Instrument transformer rack	1	\$250.00	\$250.00
6	Voltage transformer	1	\$1,200.00	\$1,200.00
7	4 conductor control cable (ft)	75	\$1.25	\$93.75
8	Ground rods and ground wire (lot)	1	\$200.00	\$200.00
9	Labor (assume 8 hours per installation)	8	\$516.20	\$4,129.60
	(4 man crew, linemen and metermen = \$516.2 per hour)			
			TOTAL	\$7,948.35

### Metering at a Three Phase Line Regulator

The metering set for use at a three-phase line regulator will be installed on a pole, as close to the load side of the regulators as practical. Three current transformers and three voltage transformers will be mounted on an instrument transformer cluster rack near the top of the pole. The voltage transformers will be connected to the line conductors through cutouts and hot clamps. The current transformers will be connected to the line across insulators added to the line, or at a deadend structure. The meter will be mounted to the pole near the base and connected to the voltage transformers using control cable. Since the meter will be exposed to public access, the control cable will be installed in conduit, up the pole, until the cable reaches 10 feet above the ground. After the wiring is complete, the meter will be installed in the meter base and the installation energized and verified. This installation will require a line

crew to install the instrument transformers at the top of the pole and a meter man (men) to install and verify the meter.

The estimated cost per circuit to install the metering at a three phase voltage regulator is itemized as follows:


	ITEM	QTY	EA	TOTAL
1	GE kV2 3-Ph. Multifunction Meter	1	\$1,750.00	\$1,750.00
2	Meter base with space for test switch.	1	\$275.00	\$275.00
3	Test Switch	1	\$175.00	\$175.00
4	Fuse cutouts and hot clamps	3	\$550.00	\$1,650.00
5	Instrument transformer rack	1	\$500.00	\$500.00
6	Voltage transformer	3	\$1,200.00	\$3,600.00
7	Current transformers	3	\$1,200.00	\$3,600.00
8	12 conductor control cable (ft)	75	\$1.55	\$116.25
9	Ground rods and ground wire (lot)	1	\$200.00	\$200.00
10	Labor (assume 8 hours per installation)	8	\$516.20	\$4,129.60
	(4 man crew, linemen and metermen = \$516.2 per hour)			
			TOTAL	\$15,995.85

Costs and Spreadsheet provided by PacifiCorp, Applied by Commonwealth for Washington Distribution Efficiency Study  
**Metering and Communications Cost Estimate for Stage 3 Implementation**


Work Description (Feeder Improvements)	Cost Per Location	Walla Walla 5W150	Walla Walla 5W154	Walla Walla 4W22	Walla Walla 5W116	Walla Walla 5W127	Walla Walla 5W342	Yakima 5Y608	Yakima 5Y610	Yakima 5Y194	Yakima 5Y197	Yakima 5Y273	Yakima 5Y356	Yakima 5Y456	Yakima 5Y498	Yakima 5Y434	Yakima 5Y444	Sunnyside 5Y351	Sunnyside 5Y313	Sunnyside 5Y317	
Three phase voltage control points			1	1		1	2											1			
Single phase voltage control points		1	2	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
End of voltage control zone: 3ph primary metering on new pole	\$ 11,500	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
End of voltage control zone: 1ph primary metering on new pole	\$ 6,700	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
End of any voltage control zone: revenue meter, socket, test switch, miscellaneous wiring	\$ 8,000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
End of 1ph voltage control zone: wireless 'radio' link to substation	\$ 3,551	1	2	2	1	2	3	1	1	1	1	1	2	1	1	1	2	1	1	2	
Line regulator: wireless 'radio' link to substation	\$ 3,364	0	1	1	0	1	2	0	0	0	0	0	1	0	0	0	1	0	0	1	
<b>Total Circuit Cost</b>		<b>\$3,551</b>	<b>\$10,466</b>	<b>\$10,466</b>	<b>\$3,551</b>	<b>\$10,466</b>	<b>\$17,381</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$10,466</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$10,466</b>	<b>\$3,551</b>	<b>\$3,551</b>	<b>\$10,466</b>
<b>Total, Tier 1 Circuits</b>																					
	\$ 122,789																				
<b>Average Circuit Cost</b>	\$ 6,463																				
Work Description (Substation Improvements)	Cost Per Substation	All Districts	Walla Walla Substations	Yakima Substations	Sunnyside Substations																
Substation: communications gear, links, central equipment, software to support CVR, IVVO, FDIR, AMI, DR, other smart grid services. Secure, real-time, always on.	\$ 210,563		4	6	2																
<b>Total, Tier 1 Subs</b>	\$ 2,526,756		\$ 842,252	\$ 1,263,378	\$ 421,126																
Work Description (All Improvements)		All Districts	Walla Walla Substations	Yakima Substations	Sunnyside Substations																
<b>Total All Circuits and Subs</b>		\$ 2,649,545	\$ 898,133	\$ 1,312,718	\$ 438,694																
<b>Average Circuit Cost</b>	\$ 139,450		\$ 149,689	\$ 131,272	\$ 146,231																

**Appendix 14: VAR Profiles**

### Bowman 5W150 Reactive Profile




### Bowman 5W154 Reactive Profile







### Clinton 5Y608 Reactive Profile




### Clinton 5Y610 Reactive Profile




### Dodd Road 4W22 Reactive Profile




Grandview 5Y351 Reactive Profile




### Mill Creek 5W116 Reactive Profile




### Mill Creek 5W127 Reactive Profile



### Nob Hill 5Y194 Reactive Profile




### Nob Hill 5Y197 Reactive Profile







### Nob Hill 5Y273 Reactive Profile




### North Park 5Y356 Reactive Profile




### Orchard 5Y456 Reactive Profile




### Orchard 5Y498 Reactive Profile




### Pomeroy 5W342 EOL1 Reactive Profile




### Pomeroy 5W342 EOL2 Reactive Profile



### River Road 5Y444 Reactive Profile




### Sunnyside 5Y313 Reactive Profile






### Sunnyside 5Y317 Reactive Profile




### Wiley 5Y434 Reactive Profile




# Appendix 15: Power Factor Profiles


### Bowman 5W150 Power Factor Profile




### Bowman 5W154 Power Factor Profile




Clinton 5Y608 Power Factor Profile



### Clinton 5Y610 Power Factor Profile




### Dodd Road 4W22 Power Factor Profile







Grandview 5Y351 Power Factor Profile




Mill Creek 5W116 Power Factor Profile




### Mill Creek 5W127 Power Factor Profile




### Nob Hill 5Y194 Power Factor Profile




### Nob Hill 5Y197 Power Factor Profile




### Nob Hill 5Y273 Power Factor Profile



### North Park 5Y356 Power Factor Profile




### Orchard 5Y456 Power Factor Profile







### Orchard 5Y498 Power Factor Profile




### Pomeroy 5W342 EOL1 Power Factor Profile




Pomeroy 5W342 EOL2 Power Factor Profile




### River Road 5Y444 Power Factor Profile




### Sunnyside 5Y313 Power Factor Profile



### Sunnyside 5Y317 Power Factor Profile



### Wiley 5Y434 Power Factor Profile



**Appendix 16: Comparison of Distribution System Efficiency Potential**



## Comparison of Distribution System Efficiency Potential

R.H. Fletcher, PhD, P.E.

Utility Planning Solutions, PLLC

April 22, 2011 (v1)

Electric utilities vary in distribution system design and operation practices. However, Northwest utilities have primary and secondary systems that are radial-designed except for specific service areas (downtown areas, business districts, and some military and hospital installations) where reliability considerations are far more important than cost and economic considerations. The primary voltage class among utilities varies from 4kV to 34.5 kV. Most are either 12.5kV or 24.9 kV systems. Allowable maximum conductor loading, percent phase unbalance, maximum voltage drops, and minimum power factor practices also differ among utilities.

The following table provides a comparison of utility practices and potential energy savings that is available based on typical financial constraints. Typical NW utility and High Performance utility attributes are based on experience performing distribution system feasibility studies in the Northwest.

	PacifiCorp 19 feeder Attributes	Typical NW Utility Attributes	High Performance Utility Attributes
Feeder Metering	kW, kvar and Amp demand Manual Data Collection	kW, kvar and Amp demand Manual Data Collection	Hourly kW, kvar, and Amp Manual Data Collection
Maximum conductor loading % of emergency	60%	80%	<50%
Maximum allowed phase unbalance	20%	30%	<15%
Minimum hourly <i>PF</i>	95%	93%	>96%
Average Annual hourly <i>PF</i>	97%	96%	>98%
Maximum Allowed Primary voltage drop(V)	5	5	<3
Maximum allowed Secondary voltage drop(V)	6	3.5	<3
Source REG Voltage Control Method	LDC	Fixed	LDC
Source REG Voltage Settings	121	124	119
Exist Pri Volts	122.0	123.0	119.6
Potential for Avg Pri Volts	120.6	119.6	119.6
Potential average voltage change	1.17 %	2.83%	0%
Potential VO Energy Savings(%)	0.61%	1.48%	0%

## Notes

1. Potential for energy savings assumes an end-use VO factor of 0.6 and system loss savings 15% of total savings.
2. The Potential Average Primary voltage is determined by the utility's financial constraints. For PacifiCorp, the average voltage potential is higher than other utilities due to PacifiCorp requirement to have continuous voltage monitoring because of high secondary voltage drops and the potential for voltages below 114V at the end-use service entrance.

The Pacific energy savings potential from its distribution systems is lower than other northwest utilities primarily due to its existing operating practices with line drop compensation (LDC) and having a relatively low source regulator voltage setting of 121V. However, PacifiCorp does have the potential to increase its energy saving by removing the costly continuous voltage monitor requirement as part of the lowering of voltage initiative to 119V. Other PacifiCorp design and operation attributes are similar to those of the typical northwest utility and exhibit potential for distribution efficiency loss reduction.

#####