

AMENDATORY SECTION (Amending Docket No. UE-990473, General Order No. R-482, filed 5/3/01, effective 6/3/01)

WAC 480-100-163 Service entrance facilities. (1) An electric utility may require customers to:

(a) Provide service entrance facilities at the easiest access point to the utility's distribution system; and

(b) Comply with reasonable requirements to keep those facilities free from tampering or interference.

(2) In order to permit the required clearances, utilities may require their customers to provide a structurally sound point of attachment for the utility's service conductors pursuant to the National (~~Electric~~) Electrical Code. Information about the National (~~Electric~~) Electrical Code regarding the version adopted and where to obtain it is set out in WAC 480-100-999 Adoption by reference.