

Form Name: Incident Notification
 Submission Time: May 17, 2017 9:37 pm
 Browser: Mobile Safari 10.0 / iOS
 IP Address: 24.18.98.252
 Unique ID: 327498356
 Location: 46.977798461914, -122.87159729004

Inspector (Your Name)	Derek Norwood
Email	dnorwood@utc.wa.gov
Company	Cascade Natural Gas
Company Contact Name	Chris Grissom
Street Address of Damage	Humorist Rd & Edith Rd
City	Burbank
County	Walla Walla County
Date & Time of Call	May 17, 2017 17:48
Date & Time of Incident	May 17, 2017 00:00
Operator On Site - Date & Time	May 17, 2017 00:00
Evacuation	No
Reporting Reason	Courtesy Call (Pressure Reduction)
Reportable?	Non-Reportable
Damage Done / Line Size, etc.	8
How Damage Was Done	Third Party
Notes	Chris Grissom from CNG called to inform us that they will be reducing the pressure of their 8" Attalia line by 20%. They were doing in-situ excavation as part of their MAOP validation. At this site they found what appeared to be third party damage significant enough to warrant a 20% pressure reduction and a repair. They are mobilizing equipment tonight and will begin the repair tomorrow morning. MAOP of this line is 300 psig, operating pressure was 282 psig and will be 225 psig after the reduction.