



***PUGET SOUND ENERGY***



**Eastside Needs Assessment Report  
Transmission System  
King County**

*Redacted Draft*

**October 2013**

**Puget Sound Energy**

Report prepared by:  
Thomas J. Gentile, P.E. – Quanta Technology  
Donald J. Morrow, P.E. – Quanta Technology  
Zach Gill Sanford – Puget Sound Energy  
Carol O. Jaeger, P.E. – Puget Sound Energy



#### 4.1.7 Load Power Factor Assumptions

The power factor at each substation was based on the MW and MVAR loadings at the time of the January 18, 2012 system peak. As the load levels changed based on the load forecast, the power factor at each substation did not change.

#### 4.1.8 Transfer Levels

The NI (Northern Intertie) flows were assumed based on season and historic flows; Winter Peak NI-1500 MW S-N and Summer Peak NI-2850 MW N-S.

#### 4.1.9 Generation Dispatch Scenarios

For the winter peak load cases, no PSE and SCL generation west of the Cascades were run. Tacoma Power generation was left on, due certain internal system constraints. The generators off-line in the Eastside Needs Assessment are listed in Table 4-4.

A low-generation case was simulated as a sensitivity. The Puget Sound area generation run during that case is indicated in Table 4-4.

Table 4-4: List of Puget Sound Area Generators Adjusted in the 2013 Eastside Needs Assessment

Generation Plant	Winter MW Rating	Expected MW Output during Winter Peak for Low-Generation Sensitivity Case	Type	Owner	Transmission Delivery Area
Enserch	184.8	125	Natural Gas, Combined Cycle	PSE	Whatcom County
Sumas	139.8	0	Natural Gas, Combined Cycle	PSE	Whatcom County
Ferndale	282.1	0	Natural Gas, Combined Cycle	PSE	Whatcom County
Whitehorn	162.2	0	Natural Gas, Simple Cycle	PSE	Whatcom County
Fredonia	341	0	Natural Gas, Simple Cycle	PSE	Skagit County
Sawmill	31	22	Biomass	Private Owner	Skagit County
Upper Baker	106	80	Hydro Dam	PSE	Skagit County
Lower Baker	78	54	Hydro Dam	PSE	Skagit County
Komo Kulshan	14	0	Hydro Run-of-River	Private Owner	Skagit County
March Point	151.6	134	Natural Gas, Combined Cycle	Shell	Skagit County
Ross	450	295	Hydro Dam	SCL	Snohomish County
Gorge	190.7	157	Hydro Dam	SCL	Snohomish County
Diablo	166	160	Hydro Dam	SCL	Snohomish County
South Tolt River	16.8	0	Hydro Run-of-River	SCL	Northeast King County
Snoqualmie	37.8	0	Hydro Run-of-River	PSE	East King County
Twin Falls	24.6	0	Hydro Run-of-River	Private Owner	East King County
Cedar Falls	30	0	Hydro Run-of-River	SCL	East King County
Freddy 1	270	0	Natural Gas, Combined Cycle	Atlantic Power/PSE	Pierce County
Electron	20	4	Hydro Run-of-River	PSE	Pierce County
Frederickson	162.2	0	Natural Gas, Simple Cycle	PSE	Pierce County

Expected MW output during Winter peak is based off of actual 2011-2012 Winter peak output except for SCL hydro, which is based off of modeled generation levels in WECC winter peak case.