

From: Bezovics, Jozsef (DOH)
Sent: Tuesday, July 01, 2008 3:02 PM
To: MyWaterCompany@aol.com
Cc: Halvorson, Clark R (DOH); Waybright, Bonnie (DOH); Klocke, Karen (DOH); Weisman, Kitty (DOH); Brooks, Brad (DOH)
Subject: Re: Petition Opposing Rate Increase

Hi Greg,

I received a copy of your subject Memorandum dated June 20, 2008. It appears that;

- Item 2 (d) (3) - (Install transfer switch for portable generator at well site) - is not included in the 2007 Project Scope. Please clarify the location of the transfer switch, whether it will be installed at Well #1 or Well #2 (or both?).

- Item 2 (d) (5) - (If funds remain...) is not included in the 2007 Project Scope. Decommissioning of a well can be costly. What is your cost estimate for decommissioning of the "old well"? If costs are significant, submittal and approval of project scope change will likely be required by the loan office.

Is the "old well" separated from the distribution system and how? Please clarify it.

Please clarify Item 2 (d) (5) regarding sequencing of the needed work. It appears that decommissioning of the "old well" is to be completed first, then installation of the reservoir.

The "old well" is not listed in DOH files. It appears that Diamond Point has three wells and not two. Please submit an updated Water Facility Inventory (WFI) form and well log to our office.

Jozsef Bezovics, PE
Washington State Department of Health
Office of Drinking Water
Southwest Drinking Water Regional Operations
PO Box 47823
Olympia, Washington 98504-7823
Physical Address:
243 Israel Road Southeast
Tumwater, WA 98501
Phone: 360-236-3034
email address: jozsef.bezovics@doh.wa.gov
Website: www.doh.wa.gov/ehp/dw/