

STEAM PLANT ADDITIONS:

Jim Bridger CCR Jim Bridger FGD Pond 3 (In-Service Date 09/30/2023) (Reference page 10.6.2)

Development and construction of a mixed-use impoundment for the management of coal combustion residuals (CCR) specifically flue gas desulfurization (FGD) and wastewater effluent. Due to a recent court decision (U.S. Court of Appeals for the District of Columbia) the existing FGD Pond 2 must be closed because it is an unlined impoundment. Under the current CCR rules for the alternative closure, a new FGD Pond must be placed in-service by October 2023 because FGD Pond 2 will no longer be allowed to accept CCR waste. A new CCR compliant mixed use FGD and effluent impoundment will provide Jim Bridger with a CCR-compliant disposal and effluent site for continued, uninterrupted operation.