



8113 W. GRANDRIDGE BLVD., KENNEWICK, WASHINGTON 99336-7166  
TELEPHONE 509-734-4500 FACSIMILE 509-737-9803  
www.cngc.com

Date: December 9, 2021

Subject: Leak Survey Notification

Sender: Ryan Privratsky, Director, System Integrity  
Cascade Natural Gas Corporation

Mailing Address: 8113 W. Grandridge Blvd., Kennewick WA 99336-7166

Phone Number: (509) 734-4599

Email Address: [ryan.privratsky@mdu.com](mailto:ryan.privratsky@mdu.com)

Identification of Proceeding: PG-150120

Identification of Documents: 150120-CNG-LEAKSURV-LTR-12-9-21



8113 W. GRANDRIDGE BLVD., KENNEWICK, WASHINGTON 99336-7166  
TELEPHONE 509-734-4500 FACSIMILE 509-737-9803  
www.cngc.com

December 9, 2021

Sean C. Mayo – Pipeline Safety Director, Pipeline Safety Program  
State of Washington Utilities and Transportation Commission  
P.O. Box 47250  
Olympia, WA 98504-7250

Subject: Docket PG-150120, V.B.3. Leak Surveys

Dear Mr. Mayo,

This letter serves as Cascade Natural Gas Corporation’s (CNGC) notification as required per Settlement Agreement, Docket PG-150120 Section V.B.3., between the Staff of the Washington Utilities and Transportation Commission (WUTC) and CNGC.

Section V.B.3. requires CNGC to notify the WUTC when a pipeline segment returns to code-based survey intervals based from information available to substantiate SMYS below 20% or to validate the MAOP of a pipeline segment. Pipeline segment length that will be returning to leak survey intervals prescribed by code include the following:

District	Work Order #	Segment Length (ft)
Mount Vernon	32166	41
Mount Vernon	GG002457	204
Mount Vernon	MTVL1-1	81,574

If you have any questions or would like to review any of the documentation pertaining to any of these segments, please do not hesitate to contact me directly.

Respectfully Submitted,

Ryan Privratsky  
Director, System Integrity  
Cascade Natural Gas Corporation  
8113 W. Grandridge Blvd.  
Kennewick, WA 99336-7166  
ryan.privratsky@cngc.com