



Oregon

John A. Kitzhaber, MD, Governor

Department of Energy

625 Marion St NE
Salem, OR 97301-3737
Phone: 503-378-4040
Toll Free: 1-800-221-8035
FAX: 503-373-7806
www.oregon.gov/energy

April 4, 2014

Teri Ikeda
PacifiCorp
825 NE Multnomah St.
Portland, OR 97232



RE: Updated Certification for Efficiency Upgrades at Eleven Hydropower Generating Units

Dear Ms. Ikeda:

The Oregon Department of Energy has approved Pacific Power's request for an updated incremental hydropower efficiency percentage for the following eleven generating units. As part of the update, Pacific Power provided the department with hourly generation data for the time period 2007 through 2012.

Generating Unit	WREGIS Number	Approval Number	New Incremental Percentage
Prospect 2	W140	12alt002or	1.68%
Yale 1 & 2	W141	12alt003wa	1.35%
Copco 1	W142	12alt004ca	0.52%
Cutler	W151	12alt005ut	3.10%
Lemolo 1	W157	12alt006or	10.16%
Lemolo 2	W158	12alt007or	0.78%
Oneida	W160	12alt008id	7.87%
Pioneer	W162	12alt009ut	6.74%
Prospect 3	W164	12alt010or	10.71%
Big Fork	W179	12alt011mt	4.22%
JC Boyle	W180	12alt012or	1.33%

The Department notified WREGIS of this change on April 4, 2014 and generation sourced from the following units will continue to be marked as "alternate use" fuel in WREGIS. If any changes are made to these facility that could affect their eligibility for the Oregon RPS, the Department must be notified.

Please contact me with any questions about this letter or approval.

Best,

Julie Peacock
WREGIS Program Administrator-Oregon
Oregon Department of Energy
503.373.2125
Julie.peacock@state.or.us

