

**BEFORE THE  
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION**

**WASHINGTON UTILITIES AND  
TRANSPORTATION COMMISSION,**

**Complainant,**

**v.**

**CASCADIA WATER, LLC,**

**Respondent.**

**DOCKET UW-240151**

**WATER CONSUMER ADVOCATES OF WASHINGTON, INTERVENOR**

November 20, 2024

**Direct Exhibit of Blaine C. Gilles**

**Letter from Lightg{ 'Vcuqhtto Washington DOH**

**Exh. BCG-14**



February 1, 2022

Jocelyne Gray  
State of Washington Department of Health  
Southwest Drinking Water Operations  
PO Box 47823  
Olympia, WA 98504-3029

Re: Sanitary Survey – Estates Inc. Water System ID# 081669

Dear Ms. Gray,

As the engineering firm supporting Cascadia Water, Davido Consulting Group, Inc. was provided a copy of the Sanitary Survey Report dated January 12, 2022. This report identified a significant finding in regard to the system's underground storage reservoir. We agree that underground reservoirs are a potential problem due to the fact that surface or ground water could leak into the reservoir as opposed to an above ground reservoir where water inside of the reservoir would leak out. Although there is no indication that the leakage is a current concern based upon routine coliform monitoring, the company plans on installing a new above ground reservoir and discontinuing use of the existing below ground reservoirs.

A sizing report and construction plan for the new reservoir and associated site piping will be submitted to your office once those items are completed. Attached is a preliminary schedule with major deliverables to properly size, approve, and construct a suitable reservoir. Please let us know if you have any questions on the schedule or feel that we have omitted a significant step.

We thank you for inspecting the Estates Inc. Water System and supporting Cascadia Water in providing safe drinking water.

Sincerely,

Davido Consulting Group, Inc.

Digitally signed by  
Jeffrey M. Tasoff, PE  
Date: 2022.02.01  
12:18:04 -08'00'

Jeffrey M. Tasoff, PE  
Principal-Civil Engineer

CC: Dale Metzger  
Culley Lehman

Seattle	Mount Vernon	Freeland	Federal Way	Spokane
9706 4th Ave NE, Ste 300 Seattle, WA 98115 Tel 206.523.0024	2210 Riverside Dr, Ste 110 Mount Vernon, WA 98273 Tel 360.899.1110	1796 E Main St, Ste 105 Freeland, WA 98249 Tel 360.331.4131	31620 23rd Ave S, Ste 307 Federal Way, WA 98003 Tel 253.237.7770	601 Main Ave, Ste 617 Spokane, WA 99201 Tel 509.606.3600