

**BEFORE THE
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION**

**WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION,**

Complainant,

v.

CASCADIA WATER, LLC,

Respondent.

DOCKET UW-240151

WATER CONSUMER ADVOCATES OF WASHINGTON, INTERVENOR

November 20, 2024

Direct Exhibit of Blaine C. Gilles

Cascadia Responses to WUTC IR 42

Exh. BCG-23



Rates & Regulatory Affairs

UW-240151

Cascadia Water LLC Proposed General Rate Case

Data Request Response

Request No.: UW-240151 WUTC IR 42

If the company's has the information, please tell Staff how many times since the last rate case has a boiled notice been required, and how many times did a boiled water notice actually go out. Please provide for each system.

Response:

We do not have these records easily available prior to 2023. There were eight boil notices issued in 2023: two for the CAL Waterworks system (due to new system components being installed), one for the TEL 3 system (due to a leak repair), one for the WB Waterworks system (due to new system components being installed), one for the Silver Lake system (due to a leak repair), one at Bacus Road for a scheduled power outage by PSE, one for the Estates system (due to a leak repair) and one at Diamond Point for water quality.

There have been three so far in 2024: one on the Skagit River Colony system (system components froze in January), one for the WB Waterworks system (due to an issue when new system components were installed), and one on the Diamond Point system (due to a contractor hitting the line).