


2004-2013 AVA SAIDI Performance in Different Measurements
(Average number of outage minutes per customer per year)

As of December 31, 2013

Table 1: 2004-2013 AVA SAIDI Performance by Measurement by Year

Year	Calendar Year	Annual IEEE SAIDI Excluding Daily Results over T _{MED}	Annual Total SAIDI Results: All Minutes w/o Exclusion	Annual Total SAIDI Results Excluding 2006	Total SAIDI 5-Year Rolling Annual Average Excluding 2006	
1	2004	126	172	172	172	
2	2005	108	176	176	174	Baseline
3	2006	143	374			
4	2007	132	209	209	186	
5	2008	159	227	227	196	
6	2009	193	193	193	195	
7	2010	146	236	236	208	
8	2011	118	118	118	197	
9	2012	138	163	163	187	
10	2013	138	199	199	182	
		167				Target

Chart 1: 2004-2013 AVA SAIDI Performance in Different Measurements by Year



2004 - 2013 AVA SAIFI Performance in Different Measurements (Average number of interruptions per year per customer)

As of December 31, 2013

Table 1: 2004 - 2013 AVA SAIFI Performance by Measurement by Year

Year	Calendar Year	Annual IEEE SAIFI Excluding Daily Results over TMED	Annual Total SAIFI Results: All Minutes w/o Exclusion	Annual Total SAIFI Results Excluding 2006	Total SAIFI 5-Year Rolling Annual Average Excluding 2006	
1	2004	1.01	1.13	1.13	1.13	
2	2005	0.97	1.17	1.17	1.15	Baseline
3	2006	1.29	1.91			
4	2007	1.14	1.40	1.40	1.23	
5	2008	1.40	1.60	1.60	1.33	
6	2009	1.52	1.52	1.52	1.36	
7	2010	1.23	1.49	1.49	1.44	
8	2011	1.08	1.08	1.08	1.42	
9	2012	1.14	1.25	1.25	1.39	
10	2013	1.05	1.21	1.21	1.31	
		1.34				Target

Chart 1: 2004-2013 AVA SAIFI Performance in Different Measurements by Year

