

wsdlsafetycommittee@gmail.com

From: sendmail@washington-ucc.org
Sent: Monday, November 25, 2019 8:49 AM
To: wsdlsafetycommittee@gmail.com
Subject: Complaint Form

Complaint Form Request

Requester Information

Name: Lisa Williams
Company: Rainier Valley Construction
Company Phone: (360)446-2549
Company Email: lisa@rainiervalleyinc.com
Company Address: PO Box 550, Rainier, 98576
Ticket Requested: yes
Ticket Number: 19490445
Ticket Date: 11/06/19

Violation Information

Violation RCW: RCW 19.122.030
Violation Section: 3b, 4bi, 4bii
Violation Description: Utility owner marked water main on shoulder of road. Utility owner marked two triangles with question marks in driveways indicating unlocatable service laterals. Crew safely excavated safely around water main mark, then proceeded to start bore under road and hit water main approximately 8' to 10' in road. After notifying water company to report damage, we were told the triangles was indicating a unlocatable main and that we were suppose to call water company on site. We had no prior calls before work to indicate main was unlocatable.
Violation Address: PO Box 550
Violation Date: 11/12/19

Alleged Violator

Violator Name: Lake Limerick
Violator Phone Number: (360)426-9581
Violator Email: cam@lakelimerick.com

Water Department: (360) 426-4563

Water Department Manager, Joe Castellucio,

Violator Address: 790 E. Saint Andrews Dr, Shelton, 98584

Violator Employess On Site: Brendin Harman, Nick Buckingham and Alejandro Gutierrez

Case 19-098

Other Information

Other Information: