

Fir Meadows 4 Iron & Manganese Treatment Results

Title	Date and Time	Site	Iron MG/L		Iron Test Method	Manganese		Manganese Test Method	GPM	Cl2 residual	Test Taken By
			Before Treatment	Iron MG/L After Treatment		Before Treatment	Manganese After Treatment				
	3/16/2018 10:45	Fir Meadows 4	0.02	0.03	Colorimeter	0.13	0.00	Colorimeter	315	0.58	Candi Shelton
	3/1/2018 13:05	Fir Meadows 4	0.04	0.00	Colorimeter	0.13	0.00	Colorimeter	325	0.42	Candi Shelton
	2/16/2018 8:10	Fir Meadows 4	0.00	0.00	Colorimeter	0.13	0.00	Colorimeter	315	0.50	Candi Shelton
	2/8/2018 14:15	Fir Meadows 4	0.00	0.00	Colorimeter	0.12	0.01	Colorimeter	297	0.44	Paul Tatum
	1/11/2018 14:20	Fir Meadows 4	0.02	0.00	Colorimeter	0.13	0.00	Colorimeter	295	0.59	Candi Shelton
	12/14/2017 8:05	Fir Meadows 4	0.02	0.00	Colorimeter	0.14	0.01	Colorimeter	305	0.75	Candi Shelton
	11/28/2017 12:35	Fir Meadows 4	0.01	0.01	Colorimeter	0.13	0.00	Colorimeter	305	0.63	Candi Shelton
	11/3/2017 13:05	Fir Meadows 4	0.02	0.00	Colorimeter	0.12	0.01	Colorimeter	305	0.79	Candi Shelton
	10/23/2017 11:35	Fir Meadows 4	0.00	0.01	Colorimeter	0.14	0.01	Colorimeter	295	0.75	Candi Shelton
	10/5/2017 10:15	Fir Meadows 4	0.02	0.02	Colorimeter	0.13	0.01	Colorimeter	305	0.73	Candi Shelton
	9/21/2017 13:55	Fir Meadows 4	0.03	0.01	Colorimeter	0.13	0.01	Colorimeter	300	0.44	Candi Shelton
	9/7/2017 14:50	Fir Meadows 4	0.04	0.01	Colorimeter	0.14	0.01	Colorimeter	315	0.54	Candi Shelton
	8/30/2017 9:35	Fir Meadows 4	0.04	0.06	Colorimeter	0.14	0.02	Colorimeter	320	0.55	Candi Shelton
	8/17/2017 8:25	Fir Meadows 4	0.03	0.00	Colorimeter	0.14	0.01	Colorimeter	325	0.49	Candi Shelton
	7/26/2017 8:05	Fir Meadows 4	0.05	0.02	Colorimeter	0.12	0.01	Colorimeter	345	0.65	Candi Shelton
	7/6/2017 15:00	Fir Meadows 4	0.02	0.02	Colorimeter	0.11	0.00	Colorimeter	360	0.64	Candi Shelton