

Operator Information Needed for IOCS Database

Date of Inspection: Start Date 10/20/2008 End Date 10/23/2008

Number of Inspection Days: 4 **Name of Inspector(s):** Scott Rukke

Activity Type: I01 Unit Inspection

Activity Types: I01 Unit Inspection, I02 Construction Inspection, I03 Failure Investigation, I04 Public Complaint Investigation, I05 Specialized Inspection (See Guidance Attached).

Operator ID: 13845 **Operator Name:** Williams Gas Pipeline -West

Unit ID: 1155 **Unit Name:** Plymouth Liquefied Natural Gas Plant

Unit Address: 42612 East Christy Road, PO Box 330

City: Plymouth **State:** WA **Zip Code:** 99346

Line Segment(s) Inspected:

The portion of the unit inspected included two LNG storage tanks, two liquefaction processors, four vaporizers, aboveground fuel and refrigerant storage containers, auxiliary power supply, aboveground piping, foam generators, personnel fire protection clothing, signs, and cathodic protection rectifiers. Field emphasis was placed on LNG 2.

Contact Name: Von Studer

Contact Title: General Manager

Contact Phone: (509) 466-6650 **Contact Fax:** (509) 467-7964

Comments:

There was one probable violation of ¹⁵³2619(c)(2) found during this inspection. Fire detector maintenance and testing exceeded the 6 month frequency.

Probable Violations: YES X NO __

If Probable Violations were found provide the following information regarding the compliance correspondence to be sent:

Name of Company Executive: Randy Barnard

Executive Title: VP Operations

Executive Address: 295 Chipeta Way

City: Houston **State:** TX **Zip Code:** 77056

Executive Phone: (713) 215-2375 **Executive Fax:** (713) 215-4269