


Please Print Plainly
 USE HEAVY PEN
 DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
 Tacoma, WA 98404
 (253) 531-3121

82.2

INORGANIC CHEMICALS (IOCS) REPORT


System ID No: N/A	System Name: Southwood	
Lab/Sample No: 08903858	Date Collected: 01-31-19	DOH Source No: 527
Multiple Source Nos: N/A	Sample Type: Post	Sample Purpose: I
Date Received: 01-31-19	Date Reported: 02-04-19	Supervisor: OMS
County: PIERCE	Date Digested: NA	Group: <input checked="" type="radio"/> A <input type="radio"/> B <input type="radio"/> Other
Sample Location: Wellhouse - outside tap (BJN452)		
Send Results & Bill To: Rainier View Water Co. PO Box 44427 Tacoma, WA 98448		Remarks: AR182R

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS	Method/Analyst
EPA REGULATED							Trigger?	MCL?
4	Arsenic	NA	mg/L	0.001	0.01	0.01		200.8
5	Barium		mg/L	0.1	2	2		200.8
6	Cadmium		mg/L	0.001	0.005	0.005		200.8
7	Chromium		mg/L	0.007	0.1	0.1		200.8
11	Mercury		mg/L	0.0002	0.002	0.002		200.8
12	Selenium		mg/L	0.002	0.05	0.05		200.8
110	Beryllium		mg/L	0.0003	0.004	0.004		200.8
112	Antimony		mg/L	0.003	0.006	0.006		200.8
113	Thallium		mg/L	0.001	0.002	0.002		200.8
116	Cyanide		mg/L	0.01	0.2	0.2		4500-CNF
19	Fluoride		mg/L	0.2	2	4		300.0
114	Nitrite - N		mg/L	0.1	0.5	1		300.0
20	Nitrate - N		mg/L	0.2	5	10		300.0
161	Total Nitrate/Nitrite		mg/L	0.5	5	10		300.0
EPA REGULATED (Secondary)								
8	Iron	NA	mg/L	0.1		0.3		3111B
10	Manganese	<0.01	mg/L	0.01		0.05	NO	200.8 OMS
13	Silver	NA	mg/L	0.1		0.1		200.8
21	Chloride		mg/L	20		250		300.0
22	Sulfate		mg/L	50		250		300.0
24	Zinc		mg/L	0.2		5		200.8
STATE REGULATED								
14	Sodium	NA	mg/L	5				200.8
15	Hardness		mg/L	10				2340C
16	Conductivity		unhos/cm	70		700		2510B
17	Turbidity		NTU	0.1				2130B
18	Color		color units	15		15		2120B
26	Total Dissolved Solids		mg/L	100		500		2540C
111	Nickel		mg/L	0.005				200.8
STATE UNREGULATED								
9	Lead	NA	mg/L	0.001				200.8
23	Copper		mg/L	0.02				200.8

COMMENTS: Manganese

S27 = Fir Meadows Well #4

Please Print Plainly
 USE HEAVY PEN
 DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
 Tacoma, WA 98404
 (253) 531-3121

INORGANIC CHEMICALS (IOCS) REPORT


212

System ID No: NIA	System Name: Southwood	
Lab/Sample No: 08903859	Date Collected: 01-31-19	DOH Source No: 592
Multiple Source Nos: NIA	Sample Type: Post	Sample Purpose: I
Date Received: 01-31-19	Date Reported: 02-04-19	Supervisor: OMS
County: Pierce	Date Digested: NA	Group: (A) B Other
Sample Location: 7202 201st St E - sample station		
Send Results & Bill To: Rainier View Water Co.		Remarks:
PO Box 44427		AR182R
Tacoma WA 98448		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS	Method/Analyst
EPA REGULATED							Trigger?	MCL?
4	Arsenic	NA	mg/L	0.001	0.01	0.01		200.8
5	Barium		mg/L	0.1	2	2		200.8
6	Cadmium		mg/L	0.001	0.005	0.005		200.8
7	Chromium		mg/L	0.007	0.1	0.1		200.8
11	Mercury		mg/L	0.0002	0.002	0.002		200.8
12	Selenium		mg/L	0.002	0.05	0.05		200.8
110	Beryllium		mg/L	0.0003	0.004	0.004		200.8
112	Antimony		mg/L	0.003	0.006	0.006		200.8
113	Thallium		mg/L	0.001	0.002	0.002		200.8
116	Cyanide		mg/L	0.01	0.2	0.2		4500-CNF
19	Fluoride		mg/L	0.2	2	4		300.0
114	Nitrite - N		mg/L	0.1	0.5	1		300.0
20	Nitrate - N		mg/L	0.2	5	10		300.0
161	Total Nitrate/Nitrite		mg/L	0.5	5	10		300.0
EPA REGULATED (Secondary)								
8	Iron	NA	mg/L	0.1		0.3		3111B
10	Manganese	<0.01	mg/L	0.01		0.05	NO	200.8 OMS
13	Silver	NA	mg/L	0.1		0.1		200.8
21	Chloride		mg/L	20		250		300.0
22	Sulfate		mg/L	50		250		300.0
24	Zinc		mg/L	0.2		5		200.8
STATE REGULATED								
14	Sodium	NA	mg/L	5				200.8
15	Hardness		mg/L	10				2340C
16	Conductivity		umhos/cm	70		700		2510B
17	Turbidity		NTU	0.1				2130B
18	Color		color units	15		15		2120B
26	Total Dissolved Solids		mg/L	100		500		2540C
111	Nickel		mg/L	0.005				200.8
STATE UNREGULATED								
9	Lead	NA	mg/L	0.001				200.8
23	Copper		mg/L	0.02				200.8

COMMENTS: Manganese

Please Print Plainly
 USE HEAVY PEN
 DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
 Tacoma, WA 98404
 (253) 531-3121


INORGANIC CHEMICALS (IOCS) REPORT

System ID No: <u>N/A</u>	System Name: <u>Southwood</u>	
Lab/Sample No: <u>08904019</u>	Date Collected: <u>02-14-19</u>	DOH Source No: <u>N/A</u>
Multiple Source Nos: <u>N/A</u>	Sample Type: <u>POST</u>	Sample Purpose: <u>I</u>
Date Received: <u>02-14-19</u>	Date Reported: <u>02-21-19</u>	Supervisor: <u>DMS</u>
County: <u>Pierce</u>	Date Digested: <u>NA</u>	Group: A B <u>Other</u> <u>VT</u>
Sample Location: <u>Fir Meadows Well #4 - outside tap</u>		
Send Results & Bill To: <u>Rainier View Water Co.</u>		Remarks:
<u>Po Box 44427</u>		<u>AR182R</u>
<u>Tacoma WA 98448</u>		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS	Method/Analyst
EPA REGULATED							Trigger?	MCL?
4	Arsenic	<u>NA</u>	mg/L	0.001	0.01	0.01		200.8
5	Barium		mg/L	0.1	2	2		200.8
6	Cadmium		mg/L	0.001	0.005	0.005		200.8
7	Chromium		mg/L	0.007	0.1	0.1		200.8
11	Mercury		mg/L	0.0002	0.002	0.002		200.8
12	Selenium		mg/L	0.002	0.05	0.05		200.8
110	Beryllium		mg/L	0.0003	0.004	0.004		200.8
112	Antimony		mg/L	0.003	0.006	0.006		200.8
113	Thallium		mg/L	0.001	0.002	0.002		200.8
116	Cyanide		mg/L	0.01	0.2	0.2		4500-CNF
19	Fluoride		mg/L	0.2	2	4		300.0
114	Nitrite - N		mg/L	0.1	0.5	1		300.0
20	Nitrate - N		mg/L	0.2	5	10		300.0
161	Total Nitrate/Nitrite	<u>↓</u>	mg/L	0.5	5	10		300.0
EPA REGULATED (Secondary)								
8	Iron	<u><0.1</u>	mg/L	0.1		0.3	<u>NO</u>	3111B <u>DMS</u>
10	Manganese	<u><0.01</u>	mg/L	0.01		0.05	<u>NO</u>	200.8 <u>DMS</u>
13	Silver	<u>NA</u>	mg/L	0.1		0.1		200.8
21	Chloride		mg/L	20		250		300.0
22	Sulfate		mg/L	50		250		300.0
24	Zinc	<u>↓</u>	mg/L	0.2		5		200.8
STATE REGULATED								
14	Sodium	<u>NA</u>	mg/L	5				200.8
15	Hardness		mg/L	10				2340C
16	Conductivity		umhos/cm	70		700		2510B
17	Turbidity		NTU	0.1				2130B
18	Color		color units	15		15		2120B
26	Total Dissolved Solids		mg/L	100		500		2540C
111	Nickel	<u>↓</u>	mg/L	0.005				200.8
STATE UNREGULATED								
9	Lead	<u>NA</u>	mg/L	0.001				200.8
23	Copper	<u>↓</u>	mg/L	0.02				200.8

COMMENTS: Manganese, Iron

Please Print Plainly
 USE HEAVY PEN
 DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
 Tacoma, WA 98404
 (253) 531-3121

INORGANIC CHEMICALS (IOCS) REPORT

System ID No: <u>N/A</u>	System Name: <u>Southwood</u>	
Lab/Sample No: <u>08904020</u>	Date Collected: <u>02-14-19</u>	DOH Source No: <u>N/A</u>
Multiple Source Nos: <u>N/A</u>	Sample Type: <u>Post</u>	Sample Purpose: <u>I</u>
Date Received: <u>02-14-19</u>	Date Reported: <u>02-21-19</u>	Supervisor: <u>AMS</u>
County: <u>Pierce</u>	Date Digested: <u>NA</u>	Group: A B <u>Other</u> <u>PUT</u>
Sample Location: <u>7202 201st St E</u>		
Send Results & Bill To: <u>Rainier View Water Co.</u>		Remarks:
<u>PO Box 44427</u>		<u>AR182R</u>
<u>Tacoma WA 98448</u>		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS	Method/Analyst
EPA REGULATED							Trigger?	MCL?
4	Arsenic	<u>NA</u>	mg/L	0.001	0.01	0.01		200.8
5	Barium		mg/L	0.1	2	2		200.8
6	Cadmium		mg/L	0.001	0.005	0.005		200.8
7	Chromium		mg/L	0.007	0.1	0.1		200.8
11	Mercury		mg/L	0.0002	0.002	0.002		200.8
12	Selenium		mg/L	0.002	0.05	0.05		200.8
110	Beryllium		mg/L	0.0003	0.004	0.004		200.8
112	Antimony		mg/L	0.003	0.006	0.006		200.8
113	Thallium		mg/L	0.001	0.002	0.002		200.8
116	Cyanide		mg/L	0.01	0.2	0.2		4500-CNF
19	Fluoride		mg/L	0.2	2	4		300.0
114	Nitrite - N		mg/L	0.1	0.5	1		300.0
20	Nitrate - N		mg/L	0.2	5	10		300.0
161	Total Nitrate/Nitrite	<u>↓</u>	mg/L	0.5	5	10		300.0
EPA REGULATED (Secondary)								
8	Iron	<u><0.1</u>	mg/L	0.1		0.3	<u>NO</u>	3111B <u>AMS</u>
10	Manganese	<u><0.01</u>	mg/L	0.01		0.05	<u>NO</u>	200.8 <u>AMS</u>
13	Silver	<u>NA</u>	mg/L	0.1		0.1		200.8
21	Chloride	<u>↓</u>	mg/L	20		250		300.0
22	Sulfate		mg/L	50		250		300.0
24	Zinc	<u>↓</u>	mg/L	0.2		5		200.8
STATE REGULATED								
14	Sodium	<u>NA</u>	mg/L	5				200.8
15	Hardness		mg/L	10				2340C
16	Conductivity		umhos/cm	70		700		2510B
17	Turbidity		NTU	0.1				2130B
18	Color		color units	15		15		2120B
26	Total Dissolved Solids		mg/L	100		500		2540C
111	Nickel	<u>↓</u>	mg/L	0.005				200.8
STATE UNREGULATED								
9	Lead	<u>NA</u>	mg/L	0.001				200.8
23	Copper	<u>↓</u>	mg/L	0.02				200.8

COMMENTS: Manganese, Iron



1515 80th St E Tacoma, WA 98404 | (253) 531 - 3121 | customerservice@watermanagementlabs.com

Chain of Custody

Lab Use	Preserved? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	Seal? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Dept: Micro	Inorg <input checked="" type="checkbox"/> Org <input type="checkbox"/>	Intact? Yes <input type="checkbox"/> No <input type="checkbox"/>
Test(s) Requested		

Sample #	# of Bottles	Sample Type			Date Sampled	Time Sampled	Sampled By	Sample Identification	Manganese	Iron	Test(s) Requested									
		Water	Waste	Other																
1	1	X			2-14-19	9:10 am	WML - Chad Garrettson	Southwood Fir Meadows - Well #4, outside tap	X	X										
2	1	X			2-14-19	9:21 am	WML - Chad Garrettson	7202 201 st St E	X	X										
3																				
4																				
5																				
6																				
7																				
8																				
9																				
10																				


Company Name: Rainier View Water Co.
 Company Address: PO Box 44427
Tacoma, WA 98448

Report to: Jimmy Jensen
 Phone #: (253) 606-7169
 Email: _____

Remarks: # Investigative #

Printed Name	Signature	Company	Date / Time
Relinquished by:			
received by: <u>Alli Ihlen</u>	<u>Alli Ihlen</u> (2)	<u>WML</u>	<u>2-14-19 10:00 am</u>
Relinquished by:			
received by:			

Print Plainly
 USE HEAVY PEN
 DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
 Tacoma, WA 98404
 (253) 531-3121

INORGANIC CHEMICALS (IOCS) REPORT

2.2

System ID No: <u>N/A</u>	System Name: <u>Southwood</u>	
Lab/Sample No: <u>08904202</u>	Date Collected: <u>02-28-19</u>	DOH Source No: <u>N/A</u>
Multiple Source Nos: <u>N/A</u>	Sample Type: <u>Post</u>	Sample Purpose: <u>I</u>
Date Received: <u>02-28-19</u>	Date Reported: <u>03.06.19</u>	Supervisor: <u>MSB</u>
County: <u>Pierce</u>	Date Digested: <u>NA</u>	Group: A B <u>Other</u> <u>PVT</u>
Sample Location: <u>Fir Meadows, Well #4 - outside tap</u>		
Send Results & Bill To: <u>Rainier View Water Co.</u>		Remarks: <u>AR182R</u>
<u>PO Box 44427</u>		
<u>Tacoma, WA 98448</u>		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS		Method/Analyst
							Trigger?	MCL?	
EPA REGULATED									
4	Arsenic	<u>NA</u>	mg/L	0.001	0.01	0.01			200.8
5	Barium		mg/L	0.1	2	2			200.8
6	Cadmium		mg/L	0.001	0.005	0.005			200.8
7	Chromium		mg/L	0.007	0.1	0.1			200.8
11	Mercury		mg/L	0.0002	0.002	0.002			200.8
12	Selenium		mg/L	0.002	0.05	0.05			200.8
110	Beryllium		mg/L	0.0003	0.004	0.004			200.8
112	Antimony		mg/L	0.003	0.006	0.006			200.8
113	Thallium		mg/L	0.001	0.002	0.002			200.8
116	Cyanide		mg/L	0.01	0.2	0.2			4500-CNF
19	Fluoride		mg/L	0.2	2	4			300.0
114	Nitrite - N		mg/L	0.1	0.5	1			300.0
20	Nitrate - N		mg/L	0.2	5	10			300.0
161	Total Nitrate/Nitrite		mg/L	0.5	5	10			300.0
EPA REGULATED (Secondary)									
8	Iron	<u><0.1</u>	mg/L	0.1		0.3		<u>NO</u>	3111B <u>MSB</u>
10	Manganese	<u><0.01</u>	mg/L	0.01		0.05		<u>NO</u>	200.8 <u>MSB</u>
13	Silver	<u>NA</u>	mg/L	0.1		0.1			200.8
21	Chloride		mg/L	20		250			300.0
22	Sulfate		mg/L	50		250			300.0
24	Zinc		mg/L	0.2		5			200.8
STATE REGULATED									
14	Sodium	<u>NA</u>	mg/L	5					200.8
15	Hardness		mg/L	10					2340C
16	Conductivity		umhos/cm	70		700			2510B
17	Turbidity		NTU	0.1					2130B
18	Color		color units	15		15			2120B
26	Total Dissolved Solids		mg/L	100		500			2540C
11	Nickel		mg/L	0.005					200.8
STATE UNREGULATED									
9	Lead	<u>NA</u>	mg/L	0.001					200.8
23	Copper		mg/L	0.02					200.8

COMMENTS: Manganese, Iron

INORGANIC CHEMICALS (IOCS) REPORT

**2.2*

System ID No: <i>NIA</i>	System Name: <i>Southwood</i>	
Lab/Sample No: <i>08904203</i>	Date Collected: <i>02-28-19</i>	DOH Source No: <i>NIA</i>
Multiple Source Nos: <i>NIA</i>	Sample Type: <i>Post</i>	Sample Purpose: <i>I</i>
Date Received: <i>02-28-19</i>	Date Reported: <i>03-06-19</i>	Supervisor: <i>OMS</i>
County: <i>Pierce</i>	Date Digested: <i>NA</i>	Group: A B <u>Other</u> <i>PVT</i>
Sample Location: <i>7202 201st St E</i>		
Send Results & Bill To: <i>Rainier View Water Co.</i>		Remarks:
<i>PO Box 44427</i>		<i>AR182R</i>
<i>Tacoma, WA 98448</i>		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS		Method/Analyst	
							Trigger?	MCL?		
EPA REGULATED										
4	Arsenic	<i>NA</i>	mg/L	0.001	0.01	0.01			200.8	
5	Barium	↓	mg/L	0.1	2	2			200.8	
6	Cadmium		mg/L	0.001	0.005	0.005			200.8	
7	Chromium		mg/L	0.007	0.1	0.1			200.8	
11	Mercury		mg/L	0.0002	0.002	0.002			200.8	
12	Selenium		mg/L	0.002	0.05	0.05			200.8	
110	Beryllium		mg/L	0.0003	0.004	0.004			200.8	
112	Antimony		mg/L	0.003	0.006	0.006			200.8	
113	Thallium		mg/L	0.001	0.002	0.002			200.8	
116	Cyanide		mg/L	0.01	0.2	0.2			4500-CNF	
19	Fluoride		mg/L	0.2	2	4			300.0	
114	Nitrite - N		mg/L	0.1	0.5	1			300.0	
20	Nitrate - N		mg/L	0.2	5	10			300.0	
161	Total Nitrate/Nitrite		↓	mg/L	0.5	5	10			300.0
EPA REGULATED (Secondary)										
8	Iron		<i><0.1</i>	mg/L	0.1		0.3		<i>NO</i>	3111B <i>OMS</i>
10	Manganese		<i><0.01</i>	mg/L	0.01		0.05		<i>NO</i>	200.8 <i>OMS</i>
13	Silver	<i>NA</i>	mg/L	0.1		0.1			200.8	
21	Chloride	↓	mg/L	20		250			300.0	
22	Sulfate		mg/L	50		250			300.0	
24	Zinc		↓	mg/L	0.2		5			200.8
STATE REGULATED										
14	Sodium	<i>NA</i>	mg/L	5					200.8	
15	Hardness	↓	mg/L	10					2340C	
16	Conductivity		umhos/cm	70		700			2510B	
17	Turbidity		NTU	0.1					2130B	
18	Color		color units	15		15			2120B	
26	Total Dissolved Solids		mg/L	100		500			2540C	
111	Nickel		↓	mg/L	0.005					200.8
STATE UNREGULATED										
9	Lead	<i>NA</i>	mg/L	0.001					200.8	
23	Copper	↓	mg/L	0.02					200.8	

COMMENTS: *Manganese, Iron*

INORGANIC CHEMICALS (IOCS) REPORT

#2.2

System ID No: N/A System Name: Southwood

Lab/Sample No: 08904385 Date Collected: 03-14-19 DOH Source No: N/A

Multiple Source Nos: N/A Sample Type: Post Sample Purpose: I

Date Received: 03-14-19 Date Reported: 03-19-19 Supervisor:

County: Pierce Date Digested: NA Group: A B Other PVT

Sample Location: Fir Meadows - well #4 - outside tap

Send Results & Bill To: Rainier View Water Co. Remarks:


PO Box 44427 AR182R

Tacoma WA 98448

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS		Method/Analyst
							Trigger?	MCL?	
EPA REGULATED									
4	Arsenic	<u>NA</u>	mg/L	0.001	0.01	0.01			200.8
5	Barium		mg/L	0.1	2	2			200.8
6	Cadmium		mg/L	0.001	0.005	0.005			200.8
7	Chromium		mg/L	0.007	0.1	0.1			200.8
11	Mercury		mg/L	0.0002	0.002	0.002			200.8
12	Selenium		mg/L	0.002	0.05	0.05			200.8
110	Beryllium		mg/L	0.0003	0.004	0.004			200.8
112	Antimony		mg/L	0.003	0.006	0.006			200.8
113	Thallium		mg/L	0.001	0.002	0.002			200.8
116	Cyanide		mg/L	0.01	0.2	0.2			4500-CNF
19	Fluoride		mg/L	0.2	2	4			300.0
114	Nitrite - N		mg/L	0.1	0.5	1			300.0
20	Nitrate - N		mg/L	0.2	5	10			300.0
161	Total Nitrate/Nitrite	<u>↓</u>	mg/L	0.5	5	10			300.0
EPA REGULATED (Secondary)									
8	Iron	<u><0.1</u>	mg/L	0.1		0.3		<u>NO</u>	3111B <u>DMB</u>
10	Manganese	<u><0.01</u>	mg/L	0.01		0.05		<u>NO</u>	200.8 <u>DMB</u>
13	Silver	<u>NA</u>	mg/L	0.1		0.1			200.8
21	Chloride		mg/L	20		250			300.0
22	Sulfate		mg/L	50		250			300.0
24	Zinc	<u>↓</u>	mg/L	0.2		5			200.8
STATE REGULATED									
14	Sodium	<u>NA</u>	mg/L	5					200.8
15	Hardness		mg/L	10					2340C
16	Conductivity		umhos/cm	70		700			2510B
17	Turbidity		NTU	0.1					2130B
18	Color		color units	15		15			2120B
26	Total Dissolved Solids		mg/L	100		500			2540C
111	Nickel	<u>↓</u>	mg/L	0.005					200.8
STATE UNREGULATED									
9	Lead	<u>NA</u>	mg/L	0.001					200.8
23	Copper	<u>↓</u>	mg/L	0.02					200.8

COMMENTS: Manganese, Iron

USE HEAVY PEN
DO NOT WRITE IN SHADED AREAS



1515 80th St. E.
Tacoma, WA 98404
(253) 531-3121

INORGANIC CHEMICALS (IOCS) REPORT

**2.2*

System ID No: <i>N/A</i>	System Name: <i>Southwood</i>	
Lab/Sample No: <i>00904386</i>	Date Collected: <i>03-14-19</i>	DOH Source No: <i>N/A</i>
Multiple Source Nos: <i>N/A</i>	Sample Type: <i>Post</i>	Sample Purpose: <i>I</i>
Date Received: <i>03-14-19</i>	Date Reported: <i>03-19-19</i>	Supervisor:
County: <i>Pierce</i>	Date Digested: <i>NA</i>	Group: A B <u>Other</u> <i>PVT</i>
Sample Location: <i>7202 201st St E</i>		
Send Results & Bill To: <i>Rainier View Water Co.</i>		Remarks:
<i>PO Box 44427</i>		<i>AR182R</i>
<i>Tacoma WA 98448</i>		

DOH#	ANALYTES	RESULTS	UNITS	SRL	TRIGGER	MCL	EXCEEDS		Method/Analyst
							Trigger?	MCL?	
EPA REGULATED									
4	Arsenic	<i>NA</i>	mg/L	0.001	0.01	0.01			200.8
5	Barium		mg/L	0.1	2	2			200.8
6	Cadmium		mg/L	0.001	0.005	0.005			200.8
7	Chromium		mg/L	0.007	0.1	0.1			200.8
11	Mercury		mg/L	0.0002	0.002	0.002			200.8
12	Selenium		mg/L	0.002	0.05	0.05			200.8
110	Beryllium		mg/L	0.0003	0.004	0.004			200.8
112	Antimony		mg/L	0.003	0.006	0.006			200.8
113	Thallium		mg/L	0.001	0.002	0.002			200.8
116	Cyanide		mg/L	0.01	0.2	0.2			4500-CNF
19	Fluoride		mg/L	0.2	2	4			300.0
114	Nitrite - N		mg/L	0.1	0.5	1			300.0
20	Nitrate - N		mg/L	0.2	5	10			300.0
161	Total Nitrate/Nitrite	↓	mg/L	0.5	5	10			300.0
EPA REGULATED (Secondary)									
8	Iron	<i><0.1</i>	mg/L	0.1		0.3		<i>NO</i>	3111B <i>OND</i>
10	Manganese	<i><0.01</i>	mg/L	0.01		0.05		<i>NO</i>	200.8 <i>OND</i>
13	Silver	<i>NA</i>	mg/L	0.1		0.1			200.8
21	Chloride		mg/L	20		250			300.0
22	Sulfate		mg/L	50		250			300.0
24	Zinc	↓	mg/L	0.2		5			200.8
STATE REGULATED									
14	Sodium	<i>NA</i>	mg/L	5					200.8
15	Hardness		mg/L	10					2340C
16	Conductivity		umhos/cm	70		700			2510B
17	Turbidity		NTU	0.1					2130B
18	Color		color units	15		15			2120B
26	Total Dissolved Solids		mg/L	100		500			2540C
111	Nickel	↓	mg/L	0.005					200.8
STATE UNREGULATED									
9	Lead	<i>NA</i>	mg/L	0.001					200.8
23	Copper	↓	mg/L	0.02					200.8

COMMENTS: *Manganese, Iron*