

Docket UE _____
Exhibit ___(CAR-5)

WUTC		
DOCKET NO. <u>UE-991832</u>		
EXHIBIT # <u>255</u>		
ADMIT	W/D	REJECT
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

BEFORE THE
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

PACIFICORP

Exhibit Accompanying Testimony of Carole A. Rockney

General Rules and Regulations

November 1999

PACIFIC POWER & LIGHT COMPANY

FOR COMMISSION'S RECEIPT STAMP

GENERAL RULES AND REGULATIONS

RULE 2

TYPES OF SERVICE

(T)

(T)

- (a) Demand Pulse Access Service: Company will provide access to Company's metering pulses proportional to Customer's kilowatt-hour usage by means of Demand Pulse Relay equipment to be owned (C) and installed by the Company. The installation of Company owned (C) Demand Pulse Relay equipment shall be conditioned on the following:
- (1) Customer enters into an agreement with Company for not less than one year and pays Company an amount as specified in Schedule 300 for installation of Demand Pulse Relay (C) equipment. (C)
 - (2) Except for metering equipment normally furnished for Customer's load characteristics, any metering equipment or associated work that must be provided to make the Demand Pulse Relay operable, shall be by Company at Customer's expense.
 - (3) The Company's billing meter installation shall, in all instances, govern in establishing Customer's energy and demand record for billing purposes.
 - (4) The Company's meter used in determining the Customer's billing shall measure demand by rolling consecutive subintervals and shall not provide end of interval pulses to the Customer.
 - (5) Company reserves the right, after a minimum 24 hour notification to Customer, to interrupt the supply of pulse information to perform meter tests or maintenance procedures and assumes no responsibility for the effect on the Customer's operation or equipment.
 - (6) If, at any time, in Company's sole judgment, the supply of demand pulse information through the Demand Pulse Relay equipment becomes detrimental to reliable metering or to the Company's metering practices, the Company shall, after a minimum 24 hours notification to Customer, have the right to disconnect the Demand Pulse Relay equipment from its metering facilities without liability to Customer.

(Continued)

Issued November 24, 1999 Effective January 1, 2000

Issued by PACIFIC POWER & LIGHT COMPANY

By Anne E. Eakin Anne E. Eakin Title Vice President, Regulation

TF2 D.IPCF

Advice No. _____

PACIFIC POWER & LIGHT COMPANY

FOR COMMISSION'S RECEIPT STAMP

GENERAL RULES AND REGULATIONS

Rule 2
(Continued)

TYPES OF SERVICE

(T)
(T)

Residential Service: Service furnished to Customers using service for domestic purposes in single-family dwelling houses; mobile homes, apartments and flats when each dwelling unit is separately metered and billed; fraternity and sorority houses, and combined family dwelling houses and rooming houses where not more than four rooms are used as sleeping or living quarters by persons not members of the Customer's family but excluding recreational vehicles, and dwellings where the tenancy is typically less than 30 days, such as hotels, motels, camps, lodges and clubs. Residential Service also includes an "adult family home" which is a regular family abode in which a person (or persons) provides personal care, special care, room and board, to more than one but not more than six adults who are not related by blood or marriage to the person or persons providing the services. Residential rates will be applicable to residential buildings served through one meter but so constructed as to provide separate living units for more than one family only when the minimum charge, basic charge and the number of kilowatt-hours in each of the rate blocks is multiplied by the maximum number of families or single-family units which could be so served. For so long as service capacity is not increased, rewiring to multiple residential meters will not be required for multi-family structures which receive residential service through a single meter. (C)

Any residential space-heating or water-heating appliance having a total capacity greater than 11.5 kilowatts shall be so designed and controlled that not more than 11.5 kilowatts will be switched on or off at any one time.

Residential heat pumps supplemented by electric resistance heating elements shall be designed, installed and operated such that the resistance heat is not switched on at the same time the heat pump motor starts. The Customer shall contact Company before the installation of residential space heating units.

Where the major portion of the electric service or capacity provided for dwelling is used regularly for the conduct of business, or for any nonresidential purpose, the electricity consumed in the portion so used will be separately metered and billed under the appropriate schedule. If separate circuits are not provided by the Customer, the entire premises may be classified as nonresidential and billed accordingly.

Issued November 24, 1999 Effective January 1, 2000

Issued by PACIFIC POWER & LIGHT COMPANY

By Anne E. Eakin Anne E. Eakin Title Vice President, Regulation

TF2 D.3PCF

Advice No. _____

PACIFIC POWER & LIGHT COMPANY

FOR COMMISSION'S RECEIPT STAMP

GENERAL RULES AND REGULATIONS

RULE 14

LINE EXTENSIONS

(T)

(T)

I. Conditions and Definitions (Continued)

H. Restrictions

An Extension of the Company's facilities is subject to these rules and other rules and restrictions. These may include, but are not limited to: laws of the United States; State law; executive and administrative proclamations; Commission orders or regulations; or, any lawful requirement of a governmental body.

I. Routes, Easements and Rights-of-Way

The Company will select the route of an Extension in cooperation with the Applicant. The Applicant must pay all costs of complete unencumbered rights-of-way, easements, or licenses to use land, including ongoing fees, and for any preparation or clearing the Company may require. The Applicant may acquire and prepare these, or if requested by the Applicant, the Company will do so at the Applicant's expense. (C)

J. Rules Previously in Effect

Rule changes do not modify existing Extension contracts. If a Customer advanced funds for an Extension under a rule or a contract previously in effect, the Company will make refunds for additional Customers as specified in the previous rule or contract.

K. Service Conductors

The secondary-voltage conductors extending from the pole line, the underground secondary-voltage main, a secondary voltage transformer, or a secondary-voltage switch cabinet to the Point of Delivery.

II. Residential Extensions

A. Extension Allowances

The Extension Allowance for Residential applications is \$1050. The Extension Allowance for Residential applications in a Planned Development is \$250. Residential Service meters used by the Company for billing purposes are provided at no cost to the Applicant. The Applicant must advance the costs exceeding the Extension Allowance prior to the start of construction.

(Continued)

Issued _____

Effective _____

January 1, 2000

Issued by PACIFIC POWER & LIGHT COMPANY

By Anne E. Eakin Anne E. Eakin

Title Vice President, Regulation

TF2 P.3PCF

Advice No. _____

PACIFIC POWER & LIGHT COMPANY

FOR COMMISSION'S RECEIPT STAMP

GENERAL RULES AND REGULATIONS

RULE 14

(Continued)

LINE EXTENSIONS

(T)
I
(T)

VII. Contract Administration Credit

Customers may waive their right to receive refunds on an Extension (C) advance. Customers who waive this right will receive a Contract Administration Credit as specified in Schedule 300. The Customer's (C) choice to receive the Contract Administration Credit must be made at the time the Extension advance is paid.

Issued November 24, 1999 Effective January 1, 2000

Issued by PACIFIC POWER & LIGHT COMPANY

By Anne E. Eakin Anne E. Eakin Title Vice President, Regulation

TF2 P.13PCF

Advice No. _____