

Exh. RAV-1T

Docket UE-230172

Witness: Richard A. Vail

**BEFORE THE WASHINGTON
UTILITIES AND TRANSPORTATION COMMISSION**

WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION,

Complainant,

v.

PACIFICORP dba
PACIFIC POWER & LIGHT COMPANY

Respondent.

Docket UE-230172

PACIFICORP

DIRECT TESTIMONY OF RICHARD A. VAIL

March 2023 (REFILED April 19, 2023)

TABLE OF CONTENTS

I. QUALIFICATIONS..... 1

II. PURPOSE OF TESTIMONY..... 1

III. OVERVIEW OF PACIFICORP’S TRANSMISSION SYSTEM..... 2

IV. CUSTOMER BENEFITS OF PACIFICORP’S TRANSMISSION SYSTEM..... 9

V. OVERVIEW OF INVESTMENTS 12

 A. Gateway South and Gateway West Transmission Lines14

 B. EV2024 Network Upgrades.....21

 C. Ahtanum 115-12.5 kV Substation Projects.....25

 D. Flint 115-12.5 kV Substation Projects26

VI. CONCLUSION..... 27

1 **Q. Please state your name, business address, and current position with PacifiCorp**
2 **d/b/a Pacific Power & Light Company (PacifiCorp or Company).**

3 A. My name is Richard A. Vail. My business address is 825 NE Multnomah Street, Suite
4 1600, Portland, Oregon 97232. I am the Vice President of Transmission at
5 PacifiCorp. I am responsible for transmission system planning, customer generator
6 interconnection requests and transmission service requests, regional transmission
7 initiatives, capital budgeting for transmission, transmission and distribution project
8 delivery, and administration of the Open Access Transmission Tariff (OATT).

9 **I. QUALIFICATIONS**

10 **Q. Please describe your education and professional experience.**

11 A. I have a Bachelor of Science degree with Honors in Electrical Engineering with a
12 focus in electric power systems from Portland State University. I have been Vice
13 President of Transmission for PacifiCorp since December 2012. I was Director of
14 Asset Management from 2007 to 2012. Before that position, I had management
15 responsibility for a number of organizations in PacifiCorp's asset management group
16 including capital planning, maintenance policy, maintenance planning, and
17 investment planning since joining PacifiCorp in 2001.

18 **II. PURPOSE OF TESTIMONY**

19 **Q. What is the purpose of your direct testimony in this case?**

20 A. The purpose of my testimony is to describe PacifiCorp's transmission system and the
21 benefits it provides to Washington customers, and specifically describe PacifiCorp's
22 major capital investment projects for new distribution and transmission systems
23 included in this rate case. These investments include transmission projects associated

1 with Energy Vision 2024 (Gateway South and Gateway West Segment D.1), various
2 generation interconnection network upgrades, and two new 115–12.5 kilovolt (kV)
3 substations and related projects.

4 My testimony demonstrates that the Company’s decisions are prudent, and
5 that these investments result in an immediate benefit to PacifiCorp’s Washington
6 customers. I recommend that the Washington Utilities and Transportation
7 Commission (Commission) find these investments prudent.

8 **III. OVERVIEW OF PACIFICORP’S TRANSMISSION SYSTEM**

9 **Q. What is the purpose of this section of your testimony?**


10 A. I provide an overview of PacifiCorp’s transmission system, transmission reliability
11 requirements, and standards and compliance mechanisms.

12 **Q. Please provide a brief overview of the purpose of PacifiCorp’s transmission
13 system.**

14 A. PacifiCorp’s transmission system is designed to reliably transfer affordable electric
15 energy from a broad array of generation resources to loads both within the
16 Company’s balancing authority areas (BAAs) and beyond, including other BAAs that
17 PacifiCorp interconnects with, and participants in the California Independent System
18 Operation’s (CAISO) Western Energy Imbalance Market (EIM).

19 **Q. Please briefly describe PacifiCorp’s transmission system.**

20 A. As seen in the image below PacifiCorp owns and operates approximately
21 17,770 miles of transmission lines ranging from 46 kV to 500 kV across multiple
22 western states. PacifiCorp serves nearly two million customers with approximately
23 140,000 customers located in Washington.




1 **Q. What are Balancing Authorities and BAAs?**

2 A. A Balancing Authority is the entity responsible for maintaining balance of load,
 3 generation, and interchange in a specific BAA, and supports interconnection
 4 frequency in real time. BAAs include all of the generation, transmission, and loads
 5 within a specific metered region.

6 PacifiCorp is a Balancing Authority and manages two BAAs: PacifiCorp East
 7 (PACE) BAA and PacifiCorp West (PACW) BAA. The PACW BAA includes
 8 interconnections with the Bonneville Power Administration (BPA), northern points of
 9 CAISO, and other utilities in California, Oregon, and Washington. The PACE BAA
 10 interconnects with utilities in the intermountain west and southwest, and also provides

1 access to the southern portion of the CAISO. As a Balancing Authority, PacifiCorp
 2 manages the production and consumption of electricity in these areas, by ensuring
 3 that there are adequate available generation resources or electricity transfers from
 4 other BAAs to meet load. As seen in the figure below, there are 38 BAAs in the
 5 Western Interconnection.¹



6 **Q. How does PacifiCorp operate the two BAAs?**

7 A. PacifiCorp separately balances each BAA for energy and load. To optimize dispatch
 8 for the benefit of customers, PacifiCorp dispatches generation across both BAAs to
 9 serve load across the entire system. Deliveries of energy over PacifiCorp's

¹ Available at <https://www.wecc.org/Administrative/06-Balancing%20Authority%20Overview.pdf>.

1 transmission system are managed and scheduled in accordance with the Federal
2 Energy Regulatory Commission's (FERC) requirements. The flexibility of
3 PacifiCorp's integrated transmission system provides options for optimizing dispatch
4 to serve load and designating units for holding reserves, and provides for additional
5 reliability during planned or unplanned generation outages. PacifiCorp also provides
6 transmission service across both BAAs, meaning that a transmission customer can
7 purchase transmission service from any point in one BAA to the other BAA for a
8 single tariff rate.

9 **Q. Please describe PacifiCorp's responsibility for maintaining open access to its**
10 **transmission system and creating stakeholder transmission planning processes.**

11 A. In 1996, the FERC required transmission system owners like PacifiCorp to provide
12 non-discriminatory access to their transmission systems for all transmission
13 customers.² FERC expanded this open-access policy in 2011 by requiring
14 transmission system owners to create regional, inter-regional, and local transmission
15 planning processes.³

16 Under these authorities, the Company is required to provide non-
17 discriminatory and reliable transmission and interconnection service according to the
18 rates, terms, and conditions of PacifiCorp's OATT, and must engage in participant-
19 driven planning processes covering its six-state transmission footprint.⁴ These
20 planning processes incorporate economics, reliability, and public policy inputs and

² See, *In re Open Access Transmission Services*, Order No. 888, 75 FERC ¶ 61,080 (May 10, 1996).

³ See, *In re Transmission Planning and Cost Allocation*, Order No. 1000, 136 FERC ¶ 61,051 (Jul. 21, 2011).

⁴ See, PacifiCorp's Open Access Transmission Tariff Volume No. 11, Attachment K (updated Aug. 31, 2022) (available [Microsoft Word - PAC OATT 2.1.2022 PRINT \(oati.com\)](#)).

1 requirements to develop comprehensive transmission development strategies.⁵

2 Where a request for transmission service cannot be reliably provided on the
3 existing system, the Company's OATT and FERC policies require the Company to
4 construct and expand its system to provide FERC-jurisdictional transmission and
5 interconnection service.⁶ This obligation to construct transmission facilities in
6 response to transmission or interconnection service requests applies to both newly
7 identified facilities and planned system expansions or upgrades.⁷

8 **Q. Please describe PacifiCorp's responsibility for maintaining reliability on its**
9 **transmission system.**

10 A. In 2005, Congress directed the FERC to establish reliability standards to ensure the
11 safe and reliable operation of the Nation's Bulk Electric System.⁸ The following year,
12 the FERC adopted rules to implement the statute,⁹ and delegated these responsibilities
13 to the North American Electric Reliability Corporation (NERC).¹⁰

⁵ See, e.g., PacifiCorp's Local Transmission System Plan (2020-2021 Biennial Cycle) (Dec. 30, 2021) (available [Attachement K Transmission System Plan Draft Report \(oati.com\)](#)).

⁶ PacifiCorp's OATT, §§ 28.2 and 15.4 (reflecting FERC's pro forma tariff and requiring PacifiCorp to construct facilities as necessary to reliably provide requested transmission service); *In re Standardized Generator Interconnection Agreements and Procedures*, Order No. 2003, 104 FERC ¶ 61,103 at 767 (2003) (explaining that FERC's pro forma interconnection services "provide for the construction of Network Upgrades that would allow the Interconnection Customer to flow the output of its Generating Facility onto the Transmission Provider's Transmission System in a safe and reliable manner."); *In re Preventing Undue Discrimination and Preference in Transmission Service*, Order No. 890, 118 FERC ¶ 61,119 at 814 (2007) (explaining that despite certain policy reforms, transmission providers "will continue to be obligated to construct new facilities to satisfy a request for service if that request cannot be satisfied using existing capacity").

⁷ See, *In re CAISO Tariff Revision*, 133 FERC ¶ 61,224 (2010) (OATT construction obligations attach to planned facilities identified as necessary to grant interconnection requests, stating that "[t]he fact that CAISO has voluntarily chosen to evaluate a network upgrade in its transmission planning process should not affect the obligation to build these facilities.").

⁸ 16 USC § 824o.

⁹ *In re Electric Reliability Standards Rulemaking*, 71 FR 8662-01, Docket No. RM05-30-000; Order No. 672 (Feb. 17, 2006).

¹⁰ *In re NERC Certification*, 116 FERC ¶ 61,062 (Jul. 20, 2006), *aff'd Alcoa Inc. v. FERC*, 564 F.3d 1342 (D.C. Cir. 2009).

1 NERC proceeded to establish various reliability standards, including
2 transmission system planning performance requirements (TPL Standards). NERC’s
3 TPL Standards establish, among other things, “Transmission system planning
4 performance requirements within the planning horizon to develop a Bulk Electric
5 System (BES) that will operate reliably over a broad spectrum of System conditions
6 and following a wide range of probable Contingencies.”¹¹ These TPL Standards,
7 along with regional (*i.e.*, established by the Western Electricity Coordinating Council
8 (WECC)) and utility-specific planning criteria, define the minimum transmission
9 system requirements to safely and reliably serve customers.

10 **Q. How does PacifiCorp ensure compliance with NERC TPL Standards?**

11 A. The Company plans, designs, and operates its transmission system to meet or exceed
12 NERC Standards for BES and WECC Regional standards and criteria. To ensure
13 compliance with applicable TPL Standards, PacifiCorp conducts an annual system
14 assessment to evaluate the performance of the Company’s transmission system and to
15 identify system deficiencies. The annual system assessment is comprised of steady-
16 state, stability, and short circuit analyses to evaluate peak and off-peak load seasons
17 in the near-term (one-, two-, and five-year) and long-term (10-year) planning
18 horizons.¹² The assessment is performed using power flow base cases maintained by
19 WECC and developed in coordination among all transmission planning entities in the

¹¹ See Standard TPL-001-4 — Transmission System Planning Performance Requirements, at A(3) (available [RSCompleteSet.pdf \(nerc.com\)](#)) (last accessed Winter 2023).

¹² Analyses consist of taking a normal system (N-0) and applying events (N-1, N-1-1, N-2, etc.) within each category (P0, P1, P2, P3, etc.) listed within the TPL Standards to identify system deficiencies. For example: An N-1-1 event describes two transmission system elements out of service at the same time, but due to independent causes. An example of an N-1-1 event would be a planned outage of one 230 kilovolt transmission line followed by an unplanned outage of any additional element in the system being used to continue service with the initial element out.

1 Western Interconnection. These base cases include load and resource forecasts along
2 with planned transmission system changes for each of the future year cases and are
3 intended to identify future system deficiencies to be mitigated.

4 As part of the annual system assessment, corrective action plans are developed
5 to mitigate identified deficiencies, and may prescribe construction of transmission
6 system reinforcement projects or, as applicable, adoption of new operating
7 procedures. In certain instances, operating procedures prescribing action to change
8 the configuration of the transmission system can prevent deficiencies from occurring
9 when there are two back-to-back (N-1-1) (or concurrent) transmission system events
10 with allowed system adjustments between two events in form of an operating
11 procedure. However, the use of operating procedure actions have limitations. In
12 particular, actions taken in connection with operating procedures that are designed to
13 protect the integrity of the larger integrated transmission system in the Western
14 Interconnection of the United States can lead to large numbers of customers being at
15 risk of an outage upon the occurrence of the second of two back-to-back (N-1-1)
16 events. An effective corrective action plan is critical to ensuring system reliability so
17 that large numbers of customers are not subjected to avoidable outage risk.

18 **Q. Is compliance with the reliability standards optional?**

19 A. No. The reliability standards are a federal requirement, subject to oversight and
20 enforcement by WECC, NERC, and FERC. PacifiCorp is subject to compliance
21 audits every three years, and may be required to prove compliance during NERC or
22 WECC reliability initiatives or investigations. Failure to comply with the reliability
23 standards could expose the Company to penalties of up to \$1.29 million per day, per

1 violation. Accordingly, compliance with reliability standards is a major driver for the
2 new capital investments in PacifiCorp's system transmission assets identified in and
3 supported by my testimony.

4 **Q. Are there additional concerns that influence PacifiCorp's distribution and**
5 **transmission system investment decisions?**

6 A. Yes. Depending on the project, there are several factors that inform whether
7 PacifiCorp will build new distribution and transmission facilities, including increased
8 demand for transmission capacity, requests for transmission service, increased
9 demand for distribution capacity, and the age and condition of existing distribution
10 and transmission facilities. The specific concerns for the projects addressed in my
11 testimony are described in more detail below.

12 **IV. CUSTOMER BENEFITS OF PACIFICORP'S TRANSMISSION SYSTEM**

13 **Q. Please describe how the PacifiCorp transmission system benefits Washington**
14 **customers.**

15 A. PacifiCorp's transmission system is designed to reliably transport electricity from a
16 broad array of generation resources to load across both BAAs, and the Company
17 operates a geographically diverse and expansive transmission system serving retail
18 customers in six western states. This unique geographic footprint, including over
19 17,770 miles of transmission lines, allows the Company to take advantage of
20 efficiencies and economies from both a planning and operational perspective due to,
21 among other things, retail load characteristics, and variable resource diversity.
22 PacifiCorp's transmission system provides over 200 interconnections with adjacent
23 transmission provider BAAs as well as access to regional energy market hubs in

1 Washington, the California-Oregon Border, Utah, the Four Corners area, and
2 Arizona.

3 PacifiCorp's geographic diversity, access to adjacent transmission providers
4 and BAAs, and access to regional energy market hubs allows PacifiCorp to
5 economically dispatch units across its system and transfer energy from other systems
6 as facilitated by the Company's participation in the EIM. This expansive footprint
7 ensures PacifiCorp is uniquely situated to access some of the nation's best wind and
8 most cost-effective solar resources to serve load through PacifiCorp's service
9 territory.

10 PacifiCorp also takes advantage of its transmission system to minimize
11 operation costs related to generation reserve requirements and blackstart capability.
12 The Company is required to carry reserves to ensure system reliability in the event of
13 changes in load or system events. Instead of being required to carry reserves and
14 blackstart capability in each individual BAA, PacifiCorp is able to operate its
15 transmission as a collective system and use resources that are geographically remote
16 to meet the system requirements in all areas that PacifiCorp serves. This allows the
17 Company to engage in the most economic dispatch to lower costs for its customers.

18 **Q. Does PacifiCorp currently carry reserves in each BAA sufficient to meet that**
19 **BAA's requirements?**

20 A. Not always. PacifiCorp often meets its reserve requirements in PACW with resources
21 located in PACE. While meeting reliability standard reserve requirements is not a
22 transmission function, PacifiCorp's transmission system provides flexibility for
23 PacifiCorp to meet its reserve requirements.

1 **Q. Are investments across the system necessary to maintain PacifiCorp's**
2 **transmission system?**

3 A. Yes. The ability to flexibly use a diverse set of energy resources depends significantly
4 on the strength and reliability of PacifiCorp's transmission system connecting those
5 resources to the PacifiCorp retail customers in all six states. Transmission system
6 outages and other real-time operation constraints place additional burden on the
7 remainder of the transmission system as corrective actions plans are implemented to
8 maintain compliance with NERC and WECC standards and guidelines and ensure the
9 reliability of service to all PacifiCorp customers. Increasing PacifiCorp's transmission
10 system capacity enhances reliability and allows more generation to interconnect to
11 serve customer load, as well as allows PacifiCorp flexibility in designating generation
12 resources for reserve capacity to comply with mandatory reliability standards.

13 **Q. Can the benefits of a reliable system be easily quantified?**

14 A. No. Reliability is, essentially, the absence of system disruptions. It is very difficult to
15 quantify the benefit of reliability investments. That said, the access to different
16 regions and redundancy in operations provides reliable service under a variety of
17 conditions that benefits all PacifiCorp's customers.

18 **Q. How does PacifiCorp propose to allocate the costs and benefits from the**
19 **transmission assets in this case?**

20 A. Consistent with the Washington Inter-Jurisdictional Allocation Methodology
21 (WIJAM) approved by the Commission in the Company's last general rate case,
22 docket UE-191024, PacifiCorp proposes to allocate the costs and benefits of the

1 entirety of PacifiCorp's transmission system to Washington. This includes all
2 transmission assets in both PACW and PACE.

3 **V. OVERVIEW OF INVESTMENTS**

4 **Q. What specific distribution and transmission system investments are you**
5 **addressing in your testimony?**

6 A. My testimony addresses PacifiCorp's major planned distribution and transmission
7 system projects that will go in-service during the test period for this rate case. Each of
8 these investments will increase PacifiCorp's load serving capability, enhance
9 reliability, conform with NERC Reliability Standards, improve transfer capability
10 within the existing system, relieve existing congestion, and interconnect and integrate
11 new wind resources into PacifiCorp's transmission system. These projects include:

- 12 • The Gateway South Segment F Aeolus to Mona/Clover 500 kV (Gateway South)
13 and Gateway West Segment D.1 Windstar to Aeolus 230 kV (Gateway West)
14 Transmission Lines;
- 15 • GWS Supporting Projects;
- 16 • Ahtanum 115-12.5 kV Substation Projects; and
- 17 • Flint 115 kV to 12.5 kV Substation Projects.

18 **Q. What are the projected investment costs and their anticipated in-service dates?**

19 A. Please see the table below for the total-Company costs and in-service dates for each
20 project. These amounts include costs for engineering, project management, materials
21 and equipment, construction, right-of-way, and an allowance for funds used during
22 construction. These costs are detailed in the testimony and exhibits of Company

1 witness Sherona L. Cheung. The in-service dates are based on our current best
2 available information at the time of preparing this case.

TABLE 1

Project	Total-Company Cost	Washington-Allocated Cost	In-Service Date
Gateway South	\$2,046.0 million	\$163.2 million	Oct-24
Gateway West	\$285.8 million	\$22.8 million	Dec-24
EV2024 Network upgrades	\$36.3 million	\$2.9 million	Dec-24
Ahtanum 115-12.5 kV Substation Projects	\$11.1 million	\$8.3 million	May-25
Flint 115-12.5 kV Substation Projects	\$15.1 million	\$7.9 million	Dec-22

3 **Q. Will PacifiCorp’s OATT transmission customers pay their proportional share of**
4 **these assets?**

5 A. Yes. Transmission customers pay for transmission and ancillary services through the
6 Company’s transmission formula rate included in PacifiCorp’s OATT.¹³ Formula
7 rates are updated by the Company’s annual transmission revenue requirement
8 (ATRR) filing that includes the total cost of providing firm transmission service over
9 the test year.¹⁴ This includes all transmission system investments made by the
10 Company, a return on rate base, income taxes, expenses, and certain revenue credits,
11 among other specific elements and adjustments.¹⁵ Transmission assets, including the
12 capital expenditures described in this rate case, will be included in the Company’s
13 annual ATRR filing when each asset is placed in service, weighted by months in
14 service as necessary. This annual filing results in a wholesale customer rate by

¹³ *In re PacifiCorp’s Application for Formula Rates*, 143 FERC ¶ 61,162 (May 23, 2013) (letter order approving settlement agreement establishing formula rate).

¹⁴ *See, e.g.*, PacifiCorp’s OATT Volume No. 11, Attachment H: ATRR for Network Integration Transmission Service, at 326–365 (available [Microsoft Word - PAC OATT 2.1.2022 PRINT \(oati.com\)](#)).

¹⁵ *Id.* at Attachment H-2: Formula Rate Implementation Protocols, at 366–386 (available [Microsoft Word - PAC OATT 2.1.2022 PRINT \(oati.com\)](#)); *See, e.g.*, *In re PacifiCorp’s 2022 Transmission Formula Annual Update*, Docket No. ER11-3643 (May 13, 2022) (available [2022 Annual update-Formula rate filing.pdf \(oati.com\)](#)).

1 dividing the total ATRR by firm transmission demand. This rate is then assessed
2 against PacifiCorp's transmission customers.¹⁶

3 **Q. Do PacifiCorp's Washington retail customers receive an offsetting revenue**
4 **credit for a portion of the transmission revenue received under PacifiCorp's**
5 **OATT?**

6 A. Yes. A portion of PacifiCorp's transmission revenues are credited to the Company's
7 state retail customers. Under this approach, the Company allocates 100 percent of its
8 transmission costs to both state retail and FERC-jurisdictional customers. The FERC,
9 through the Company's ATRR filings, determines the appropriate amount to be
10 recovered from PacifiCorp's wholesale customers. This same amount is then credited
11 to PacifiCorp's retail customers. This ensures that PacifiCorp recovers its
12 transmission expenditures, and both wholesale and retail customers only pay their
13 proportional share of the Company's transmission system.

14 **A. Gateway South and Gateway West Transmission Lines**

15 **Q. Please describe the Energy Gateway Transmission Expansion.**

16 A. In 2007, PacifiCorp launched the Energy Gateway Transmission Expansion, a multi-
17 year strategy to add approximately 2,000 miles of new transmission lines across the
18 west. To date, three major segments of Energy Gateway are complete and in
19 service.¹⁷ After over a decade of planning, the Company now proposes to move
20 forward with constructing the Gateway South and a portion of Gateway West lines

¹⁶ See *PacifiCorp's Transmission and Ancillary Services Rates* (effective Jun. 1, 2022) (available [Rate Table 20220601.xlsx \(oati.com\)](#)).

¹⁷ See generally [Energy Gateway \(pacificorp.com\)](#).

1 (D.1).¹⁸ The following graphic provides an overview of the Energy Gateway
2 Transmission Expansion generally, and the Gateway South and Gateway West lines
3 specifically:



4 **Q. Please describe the Gateway South Transmission Project.**

5 **A.** The Gateway South project includes the following elements:

¹⁸ See, e.g., PacifiCorp 2021 Integrated Resource Plan, Vol. 1, Ch. 4 – Transmission, at 83–102 (available [2021 IRP Volume I \(pacificorp.com\)](#)).

- 1 • A 416-mile, high voltage 500 kV transmission line from the Aeolus substation,
2 near Medicine Bow, Wyoming to the Clover substation near Mona, Utah.
- 3 • Rebuilding certain 345 kV transmission facilities in and around the Mona and
4 Clover substations in Utah.
- 5 • Two new series compensation stations.
- 6 • Expansion of the Aeolus, Anticline, and Clover substations along with
7 modifications to the Mona substation.
- 8 • Additional shunt capacitors at Bonanza (Utah), Riverton and Mustang
9 (Wyoming) substations.
- 10 • Additions and modifications to various remedial actions schemes, voltage
11 controllers and control schemes necessary to ensure protection and control of the
12 grid after integration of Gateway South.

13 **Q. Please describe the Gateway West Segment D.1 Transmission Project.**

14 A. Gateway West Segment D.1 includes the following elements:

- 15 • A new 59-mile high-voltage, 230 kV transmission line from the Shirley Basin
16 substation in southeastern Wyoming to the Windstar substation near Glenrock
17 Wyoming.
- 18 • Rebuild of the existing Dave Johnston – Amasa – Difficulty – Shirley Basin
19 230 kV transmission line, which runs approximately 57 miles from the Shirley
20 Basin substation in southeastern Wyoming to the Dave Johnston substation near
21 Glenrock, Wyoming.
- 22 • A new 230 kV Heward substation adjacent to the Difficulty substation.

1 • Construction of four miles of high voltage 230 kV transmission line from the
2 Aeolus substation to the Freezeout substation near Medicine Bow, Wyoming.

3 • Additions to the Shirley Basin, Dave Johnston, and Windstar substations.

4 **Q. Please explain why the Gateway South and Gateway West Transmission Projects**
5 **(collectively, the Transmission Projects) are needed.**

6 A. The Transmission Projects are an important component of the Company's Energy
7 Gateway Transmission Expansion, and Gateway South has long been recognized as a
8 key transmission segment in the region's long-term transmission planning. These
9 lines will provide substantial customer benefits.

10 For example, the Company needs additional resources to serve load by 2024,
11 and the Transmission Projects enable new, cost-effective Wyoming generation
12 resources to fill this need, and these Transmission Projects allow the Company to
13 interconnect up to approximately 2,030 megawatts (MW) of new resources. These
14 projects also improve reliability of the transmission system by providing capacity
15 between Gateway West and Gateway Central, and relieve transmission congestion on
16 the existing Wyoming transmission system. The Gateway South line allows transfers
17 of up to 1,700 MW from eastern Wyoming to central Utah.

18 **Q. Is the increased capacity provided by the Transmission Projects consistent with**
19 **the Company's obligation to provide transmission service under its OATT?**

20 A. Yes. PacifiCorp adhered to OATT processes when identifying the need for these
21 transmission projects in response to nearly 2,500 MW of transmission and
22 interconnection service requests, and the Transmission Projects have been included in
23 multiple FERC-jurisdictional executed contracts. For example, PacifiCorp has

1 executed 13 contracts with third-party customers that require constructing one or both
2 of the Transmission Projects, including a transmission service agreement that requires
3 construction of Gateway South to reliably provide 500 MW firm point-to-point (PTP)
4 transmission service beginning by the contract start date of January 1, 2024. The
5 Transmission Projects are lynchpins in PacifiCorp's ability to meet its obligation to
6 grant generator interconnection service and transmission service under the OATT.

7 The Transmission Projects will also enhance the Company's ability to comply
8 with mandated NERC and WECC reliability and performance standards. Congestion
9 on the current transmission system in eastern Wyoming limits the ability to deliver
10 energy from eastern Wyoming to PacifiCorp load centers in Wyoming, Idaho, Utah,
11 and the Pacific Northwest.

12 **Q. Do the Transmission Projects increase the amount of generation that can be**
13 **interconnected and delivered across the Company's transmission system?**

14 A. Yes. The Transmission Projects will allow the Company to interconnect an additional
15 2,030 MW of generation resources in eastern Wyoming and increase the system
16 transfer capability by approximately 875 MW from the Windstar/Dave Johnston area
17 south to Shirley Basin/Aeolus, which will create approximately 1,700 MW of
18 incremental transfer capability from eastern Wyoming (Aeolus) to the central Utah
19 energy hub (Mona/Clover).

20 **Q. Did the Company consider alternatives to Transmission Projects?**

21 A. Yes. PacifiCorp and Northern Tier Transmission Group evaluated an alternative.

22 The Company analyzed one 345 kV line with bundled conductor from Aeolus
23 to Anticline (138 miles), and two 345 kV lines with bundled conductors from

1 Anticline to Populus (approximately 198 miles each), along with other supporting
2 mitigation such as transformers and shunt capacitors at different substations. These
3 analyses indicated that the amount of renewable resources that could be
4 interconnected to eastern Wyoming is reduced by approximately 1,100 MW. The
5 high-level estimated cost of this alternative is \$2.023 billion in 2020 dollars. This
6 alternative also showed additional reliability issues on the transmission system
7 between Rock Springs and Monument, as well as between Populus and Terminal that
8 would have to be mitigated, resulting in additional cost burdens. Like the Aeolus to
9 Mona line, this alternative does not provide an adequately diverse path for
10 PacifiCorp's network loads.

11 **Q. If the Company did not construct the Transmission Projects would you be able**
12 **to provide the roughly 2,500 MW of interconnection and transmission service**
13 **without constructing additional facilities?**

14 A. No. To grant only the 500 MW transmission service request, the Company would be
15 required to construct a 230 kV line at a cost of approximately \$1 billion. To grant the
16 transmission and interconnection service requests, consistent with the Company's
17 OATT, would require construction of the functional equivalent of the Transmission
18 Projects.

19 **Q. Has the Company obtained all necessary permits and rights-of-way (ROW) for**
20 **the Transmission Projects?**

21 A. All permits and ROW for the Gateway West Segment D.1 have been obtained. All
22 permits and ROW have been obtained for the Gateway South Project, with the
23 exception of property rights from the Utah Department of Natural Resources (DNR)

1 lands. The ROW from the Utah DNR are expected to be procured no later than
2 April 15, 2023, and no delays are expected to the current project schedule while the
3 Company secures these rights.

4 **Q. When did PacifiCorp begin construction of the Transmission Projects?**

5 A. The Company began construction of the Gateway South project in June 2022 once all
6 permits and rights-of-way required within Wyoming were obtained. Once the
7 Company received the permits and rights-of-way for Gateway West Segment D.1,
8 construction began in late September 2022. Regular construction status updates are
9 being filed with the Commission as required.

10 **Q. Is the Company confident that the Transmission Projects will be in service by**
11 **2024?**

12 A. Yes. To manage construction schedule risk, the Company has structured and managed
13 the projects on firm, date-certain, fixed-price, turnkey contracts. Construction
14 contractors and equipment suppliers will be held to key construction and delivery
15 milestones, guarantees, and development of compressed schedule mitigation plans, if
16 required. The construction remains on-track and on schedule.

17 **Q. Are the Transmission Projects currently on budget?**

18 A. Yes. The project budgets consist of firm, date-certain, fixed price, turnkey contracts
19 that include fixed cash flows assessed monthly against confirmed construction
20 progress, in addition to identification and mitigation of projects risks that could stall
21 or delay completion. To date, the projects are on budget.

1 **Q. What are the remaining major milestones for the Transmission Projects?**

2 A. Key milestones remaining before the October 2024 in service date for these two
3 projects include:

- 4 • Complete construction of the 230 kV Windstar to Shirley Basin line by December
5 2023.
- 6 • Complete all wound core device deliveries by May 2024.
- 7 • Complete construction of the 500 kV transmission line and reconstruction of the
8 230 kV transmission line by October 2024.
- 9 • Complete all communications network additions and upgrades by October 2024.
- 10 • Complete commissioning and placed in-service in fourth quarter of 2024.

11 The Transmission Projects are on track to achieve each milestone.

12 **B. EV2024 Network Upgrades**

13 **Q. What are network upgrades?**

14 A. Network upgrades are the modifications or additions to transmission-related facilities
15 that are integrated with and support PacifiCorp's overall Transmission System for the
16 general benefit of system users.¹⁹

17 **Q. Please explain how network upgrade cost allocation works under the OATT.**

18 A. When PacifiCorp receives a request for generation interconnection or transmission
19 service, the Company completes various studies to determine what new facilities or
20 upgrades to existing facilities are required to accommodate the request.²⁰ The studies
21 classify any required additions to support the requested service into two categories:

¹⁹ See, e.g., PacifiCorp's OATT Volume No. 11, § 1.27 (available [Microsoft Word - PAC OATT 2.1.2022 PRINT \(oati.com\)](#)).

²⁰ *Id.* §§ 38–43.

1 direct assigned or network upgrade. Direct-assigned assets are those assets that only
2 benefit, or are used solely by, the customer requesting generator interconnection or
3 transmission service. Those costs are directly assigned and paid for by that customer
4 and will not be included in either the Company's ATRR or retail rates. Network
5 upgrades, on the other hand, are assets that benefit all customers that use the
6 transmission system. Network upgrade costs can be included in PacifiCorp's ATRR,
7 and ATRR revenues, are then credited to PacifiCorp's retail customers in each state.²¹

8 **Q. Is the Company requesting recovery of any Generation Interconnection Network**
9 **Upgrades?**

10 A. Yes. There are six generation interconnection projects that were selected from a
11 recent request for proposal to interconnect 1,640 MW of new wind generation to the
12 Company's transmission system in eastern Wyoming. The request for proposal
13 process and the resulting resources selected are described in the testimony of
14 Company witness Rick T. Link. A separate generation interconnection agreement was
15 negotiated and signed for all six projects, and each will require generation
16 interconnection network upgrades to interconnect and integrate with PacifiCorp's
17 system. These projects include:

- 18 • Q0409 Boswell Springs Wind. This project is a 320 MW wind facility that will
19 interconnect to the existing Freezeout 230 kV substation near Aeolus, and is
20 planned to be in service by December 31, 2024. This project includes a new
21 breaker at the Freezeout substation, and a new remedial action scheme and
22 communications equipment at Aeolus substation.

²¹ *Id.* 47.

- 1 • Q0713 Cedar Springs IV Wind. This project is a 350 MW wind facility that will
2 interconnect to the existing Yellowcake 230 kV substation near Windstar, and is
3 planned to be in service on January 15, 2025. This project includes construction
4 of a new line position at the Yellowcake substation, including the installation of
5 three new 230 kV circuit breakers, and requires a new microwave system and
6 approximately 18 miles of fiber optic cable between Yellowcake and Windstar
7 substations.
- 8 • Q0719 Two Rivers Wind. This project is a 280 MW wind facility that will
9 interconnect to the existing Freezeout 230 kV substation near Aeolus, and is
10 planned to be in service on December 31, 2024. This project includes expansion
11 and conversion of the Freezeout substation with three new breakers, bus work,
12 and other protection and control equipment with updates to the remedial action
13 scheme.
- 14 • Q0785 Anticline Wind. This project is a 100 MW wind facility that will
15 interconnect to a new substation on PacifiCorp’s Casper – Claim Jumper 230 kV
16 line, and is planned to be in service on December 31, 2024. This project includes
17 a new three breaker ring bus substation on the Casper – Claim Jumper 230 kV
18 line, substation loop in on transmission line, communications upgrade at Casper
19 substation, and Main Grid operations center updates.
- 20 • Q0835 Rock Creek Wind. This project is a 190 MW wind facility that will
21 interconnect to PacifiCorp’s existing Foote Creek 230 kV substation and is
22 planned to be placed in service on December 15, 2024. This project includes
23 expansion of substation, bus, and line position at Foote Creek substation,

1 expansion for new breaker and line positions at Freezeout and Aeolus substations,
2 construction of new approximately 3.5 miles long 230 kV transmission line
3 between Aeolus and Freezeout substations.

- 4 • Q0836 Rock Creek Wind 2. This project is a 400 MW wind facility that will
5 interconnect to PacifiCorp's existing Aeolus 230 kV substation and is planned to
6 be placed in service on December 15, 2024. This project includes a new bay for a
7 230 kV line terminal at Aeolus substation.

8 **Q. Why are these projects classified as network upgrades, and not directly assigned**
9 **assets?**

10 A. The interconnection study for each project indicated that these upgrades would
11 provide system-wide benefits. Under PacifiCorp's OATT, this requires the Company
12 to include these costs in the Company's ATRR, as opposed to directly assigning these
13 costs to each project. Accordingly, the network upgrade costs for each of these
14 projects are reflected in their respective Large Generator Interconnection Agreements.

15 **Q. Is the Company confident that it can manage any construction schedule risk and**
16 **deliver the network upgrades for the new wind facilities by the planned in-**
17 **service dates?**

18 A. Yes. To manage construction scheduling risk, the Company structured each network
19 upgrade contract on a firm, date-certain, turnkey contract basis. Construction
20 contractors and equipment suppliers are being held to key construction and delivery
21 milestones and development of compressed schedule mitigation plans, if required.

22 The Company also established construction contract completion dates and

1 backstopped them with guarantees. To date, the remaining network upgrades remain
2 on track for planned in-service dates.

3 **C. Ahtanum 115-12.5 kV Substation Projects**

4 **Q. Please describe the proposed Ahtanum 115-12.5 kV Substation Projects.**

5 A. This project will construct a new 115-12.5 kV substation for the Company's urban
6 service area in south Yakima, Washington, and a new 115 kV transmission line from
7 Union Gap to the new substation. The transmission component of this project will be
8 in service by March 2025, and the distribution components will be in service by May
9 2025.

10 **Q. Please explain why these projects are needed and beneficial.**

11 A. The area surrounding the new substation is expected to experience load growth over
12 the next 5 to 10 years that will outpace existing capacity at the Clinton, Nob Hill,
13 Voelker, and Union Gap substations without significant improvements to each
14 substation. This new Ahtanum substation will immediately provide capacity relief to
15 these existing substations, improve system reliability and operability, and solve
16 outage concerns during peak loading periods due to the limited load transfer capacity
17 between current substations. The new 115 kV lines will also relocate an existing
18 115 kV off Yakama Nation land.

19 **Q. Did PacifiCorp consider alternatives to investing in the Ahtanum 115-12.5 kV
20 Substation projects?**

21 A. Yes, however the only reasonable alternative is to delay these projects until the area
22 reaches maximum loading capability (expected to occur sometime in the next
23 ten-year period). This delay would result in more substantial investments, because in

1 addition to the Ahtanum 115-12.5 kV Substation projects, the Company would need
2 to replace three transformers and construct two 25 MVA distribution transformers, as
3 well as upgrade the transmission and distribution equipment at each of the affected
4 four substations.

5 There are also reliability concerns with delaying these projects. By waiting
6 until each substation transformer reaches its maximum loading capability over the
7 next ten years, the substation and distribution systems will remain limited and
8 exposed to poor reliability for that same duration, as opposed to providing immediate
9 capacity relief to all four substations which shortens feeder lengths and improves
10 system operability. The Ahtanum 115-12.5 kV Substation projects result in more
11 incremental investments and greater reliability.

12 **D. Flint 115-12.5 kV Substation Projects**

13 **Q. Please describe the Flint 115-12.5 kV Substation Projects.**

14 A. This project constructs a new substation in the Flint, Washington area north of the
15 Yakima River, and extends a new 115 kV transmission line approximately 9.3 miles
16 from Punkin Center substation to supply the new substation. The majority of this
17 project was placed in-service in December 2022.

18 **Q. Please explain why these projects are needed and beneficial.**

19 A. These projects help resolve capacity restrictions at the existing Wapato and
20 Toppenish Substations that are located on the Yakama Indian Reservation in the
21 lower Yakima valley area of Washington.

1 **Q. Did PacifiCorp consider alternatives to investing in the Flint 115-12.5 kV?**

2 A. Yes. The Yakama Tribe recently enacted restrictions that prevent the upgrade of
3 distribution system facilities that supply areas off the tribal lands. To respect this
4 requirement, the Company considered constructing a 115 kV from the BPA Moxee
5 substation to the Donald area, rebuild the Union Gap to Hopland 115 kV transmission
6 line to higher capacity conductor, and then construct a small distribution substation in
7 the Donald area to off load Wapato substation. However, this alternative offers far
8 less additional capacity for the initial investment cost, and the new Flint substation
9 would still be needed in future years to address the distribution capacity problems out
10 of Toppenish and Punkin Center substations.

11 **VI. CONCLUSION**

12 **Q. Please summarize your testimony.**

13 A. I recommend that the Commission conclude that the projects described above are
14 prudent.

15 **Q. Does this conclude your direct testimony?**

16 A. Yes.