

UE-230172 / PacifiCorp  
November 28, 2023  
WUTC Data Request 168

### **WUTC Data Request 168**

**Jim Bridger Units 1 and 2** - Please provide all documentation regarding any and all alternatives the Company considered in lieu of the thicker pipe and an onsite heating station and resulting cost increase of the Jim Bridger Units 1 and 2 conversion project.

### **Response to WUTC Data Request 168**

The characteristics of the gas supplied by the pipeline are fixed, and the conditioning of the gas for injection into the boiler are required for safety and to meet permitted emission levels of carbon monoxide (CO) and nitrogen oxides (NOx); no alternatives are possible.

PREPARER: Gavin Mangelson

SPONSOR: Brad Richards