

**OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS**

NOTES-FIELD INSPECTION

Company:     **Puget Sound Energy**    

Date(s):     **March/April 2007**    

Unit:     **Snohomish County**    

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S on	P/S off	Volts	Amps	Set	Actual	
Monroe Meter# 881808			-1.730						Galvanic System
Gold Bar Town Border Station			-1.455				62	61.5	Galvanic System
Startup Gate Station			-1.288				32	31.87	Solar Impressed Current System.
Sultan Gate Station at Basin			-1.457				62	61.95	Galvanic System
Sultan Gate Station at 1 <sup>st</sup> & High St.			-1.240				55	54.39	Galvanic System
Monroe at Chain Link Rd.			-1.201				56	55.2	Vault < 200 cf.
Monroe Gate Station			-1.665				55	54.2	
Machias Reg. Station			-1.705				55	54.8	

**OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS**

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S on	P/S off	Volts	Amps	Set	Actual	
Sopher Hill DR			-1.397				57	55.1	
Everett Delta Gate Sta.			-1.583				465	464.6	
Lake Stevens RS			-1.138				56	55.19	
Marysville RS 132 St NE & 51 Ave NE			-1.011				55	54.8	
Marysville RS 1 <sup>st</sup> & Columbia Ave			-1.109				56	55.19	
Everett Delta Limit Station			-1.310				240	240	
Everett 25 <sup>th</sup> St & Harrison Ave			-1.269				7.5	7.5	Low Pressure District
N. Seattle RS			-1.228				239	239	