

Salishan Uprate 2012
Job Number: 887024719
Design Pressure Calculations

Salishan Supply

Facility ID	Worksheets
020.A-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.A-4	Design Pressure Worksheet
020.A-5	Design Pressure Worksheet
020.A-1.B	Design Pressure Worksheet
020.A-1.C	Design Pressure Worksheet
	Branch Calculation Worksheet
020.A-1.D	Design Pressure Worksheet
020.A-1.E	Design Pressure Worksheet
020.A-1.F	Design Pressure Worksheet
	Branch Calculation Worksheet
020.B-1	Design Pressure Worksheet
020.C-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.U-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.U-2	Design Pressure Worksheet
	Branch Calculation Worksheet
020.U-3	Design Pressure Worksheet
020.U-4	Design Pressure Worksheet
	Branch Calculation Worksheet
020.AR-1	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-0266 (RETIRED)	Design Pressure Worksheet
RS-0983 (RETIRED)	Design Pressure Worksheet
RS-1031 (RETIRED)	Design Pressure Worksheet
RS-1220 (RETIRED)	Design Pressure Worksheet
RS-1306 (RETIRED)	Design Pressure Worksheet
RS-1327 (RETIRED)	Design Pressure Worksheet
RS-1371 (RETIRED)	Design Pressure Worksheet
RS-1404 (RETIRED)	Design Pressure Worksheet
RS-1418 (RETIRED)	Design Pressure Worksheet
RS-1472 (RETIRED)	Design Pressure Worksheet
RS-1480 (RETIRED)	Design Pressure Worksheet
RS-1538 (RETIRED)	Design Pressure Worksheet

RS-1868 (RETIRED)	Design Pressure Worksheet
RS-1877 (RETIRED)	Design Pressure Worksheet
RS-1973 (RETIRED)	Design Pressure Worksheet
RS-2123 (RETIRED)	Design Pressure Worksheet
RS-2311	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-2695	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-2696	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-2697	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-2968	Design Pressure Worksheet
	Branch Calculation Worksheet
RS-2723	Design Pressure Worksheet
	Branch Calculation Worksheet

Pierce Transit Supply

Facility ID	Worksheets
020.X-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.X-2	Design Pressure Worksheet
	Branch Calculation Worksheet
020.Y-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.Y-1.A	Design Pressure Worksheet
020.Y-1.B	Design Pressure Worksheet
020.Z-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.Z-1.A	Design Pressure Worksheet
020.Z-1.B	Design Pressure Worksheet
020.Z-1.C	Design Pressure Worksheet
020.Z-1.D	Design Pressure Worksheet
020.Z-1.E	Design Pressure Worksheet
020.Z-1.F	Design Pressure Worksheet
020.Z-1.G	Design Pressure Worksheet
020.AA-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.AA-1.A	Design Pressure Worksheet
	Branch Calculation Worksheet
020.AB-1	Design Pressure Worksheet

	Branch Calculation Worksheet
020.AC-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.AC-1.A	Design Pressure Worksheet
020.AC-1.B	Design Pressure Worksheet
020.AS-1	Design Pressure Worksheet
020.AT-1	Design Pressure Worksheet
020.AU-1	Design Pressure Worksheet
020.AV-1	Design Pressure Worksheet
	Branch Calculation Worksheet
020.AW-1	Design Pressure Worksheet
RS-2558	Design Pressure Worksheet
	Branch Calculation Worksheet
HPS-0001 – HPS-0021	Design Pressure Worksheet
HPS-0022	Design Pressure Worksheet
	Branch Calculation Worksheet
HPS-0023 – HPS-0052	Design Pressure Worksheet

020_A.1
HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT1142011)
DIP PIPE SEGMENT

Descriptions of the Facility

Facility ID
Facility Type

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Reviewed By	Review Completion Date	Reviewed By	Review Completion Date
1	00517759	Relocation 020.A.1.C - Address Filtration	3D05-321	10/25/1680	B. Williams	6/10/2011		6/10/2011
2	175-274	RS-1418 Tie-In	710-365	6/22/1971	C. Koo	6/21/2011		6/21/2011
3	10923558	RS-2698 Tie-In	3D11-500	1/5/2006	C. Koo	6/21/2011		6/21/2011
4	728-800	RS-1433 Tie-In	728-800	9/19/1972	C. Koo	6/21/2011		6/21/2011
5	728-800	RS-1433 Tie-In	728-800	9/19/1972	C. Koo	6/21/2011		6/21/2011
6	678-355	RS-1031 Tie-In	678-355	6/11/1967	C. Koo	6/21/2011		6/21/2011
7	665-1019	RS-0943 Tie-In	665-1019	1/7/1967	C. Koo	6/21/2011		6/21/2011
8	10902352	RS-2695 Tie-In	3D11-539	12/22/2005	C. Koo	6/21/2011		6/21/2011
9	10902352	Relocation 020.A.1.C - Address Filtration	3D7-400	6/11/2001	C. Koo	6/21/2011		6/21/2011
10	10902352	Relocation 020.A.1.C - Address Filtration	3D7-400	6/11/2001	C. Koo	6/21/2011		6/21/2011
11	89228747	Install Gauge Point	3D5-321	TBD	D. Filiz	6/21/2012		6/21/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

531	0.4	(Class 4 Location)
610.3		
610.0		
610.0		
531.5		
150.0		
9.8%		
260.0		
18.4%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	Not Noted	6" PIPE X 0.188 WALL Gr-B	ACTIVE	6"	0.188	Gr-B	610	9.83%	16.38%	Historical Spec
11	2	8927607	3/4" PIPE X 0.154 WALL Gr-B	ACTIVE	3/4"	0.154	Gr-B	4197	1.46%	2.44%	

THE LOWEST DESIGN PRESSURE: 610 9.8% 16.4%

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Filling Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	8	Not Noted	6" Weld EX X 0.188 WALL Gr-B	ACTIVE	6"	0.188	OD 2	Th 2	Gr	Weld El	610	8.83%	16.38%	Thickness & grade - Historical Spec.
1	9	Not Noted	6" Weld Cap X 0.188 WALL Gr-B	ACTIVE	6"	0.188			Gr-B	Weld Cap	610	8.83%	16.38%	Thickness & grade - Historical Spec.
1	12	Not Noted	6" Weld Tee X 0.188 WALL Gr-B	ACTIVE	6"	0.188			Gr-B	Weld Tee	610	8.83%	16.38%	Thickness & grade - Historical Spec.
2	23	5200738	6" Weld Cap X 0.322 WALL X-42	ACTIVE	6"	0.322			X-42	Weld Cap	1284	4.78%	7.97%	Add-on Filling from 020.A.1.F
10	5	5200740	6" Weld Cap X 0.188 WALL X-42	ACTIVE	6"	0.188			X-42	Weld Cap	732	8.18%	13.65%	Add-on Filling from 020.A.1.F
3	N/A	N/A	2" Flaremouth X 0.154 WALL Gr-B	ACTIVE	2"	0.154			Gr-A23	Flaremouth	778	4.63%	7.71%	In-Filling for RS-1418 (retired)
11	7	8887804	3/4" Flaremouth X 0.154 WALL Gr-B	ACTIVE	3/4"	0.154	TH 3/4"		Gr-B	Nipple	3346	1.79%	2.99%	
11	7	8887805	3/4" Elbow X 0.154 WALL Gr-B	ACTIVE	3/4"	0.154			Gr-B	Elbow	4197	1.46%	2.44%	

THE LOWEST DESIGN PRESSURE: 610 9.8% 16.4%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	25	Not Noted	6" Valve Nonreturn, Flg 424E-1/4	ACTIVE	6"	CLASS 300	Save-A-Valve	Nonreturn, Flg 424E-1/4	720	Branch to RS-2698
2	26	450022621	2" X 8" Weld-Off WOP 720PSIG	ACTIVE	2"	CLASS 300	Save-A-Valve	Weld-Off WOP 720PSIG	1440	Branch to RS-1418
2	24	8985337	1" Save-A-Valve Mueller H-17491 WOP 1440PSIG	ACTIVE	1"	CLASS 300	Save-A-Valve	Mueller H-17491	1440	Branch to RS-1418
2	21	7800798	6" BIO Linestopper Mueller H-17281 CLASS 300 WOP 720PSIG	ACTIVE	6"	CLASS 300	BIO Linestopper	Mueller H-17281	720	Branch to 020.A.1.F
4	N/A	7800798	3/4" Flare Tee Mueller H-17281 CLASS 300 WOP 720PSIG	ACTIVE	3/4"	CLASS 300	Flare Tee	Mueller H-17281	720	Branch to RS-2698
6	N/A	N/A	1" Valve Tee H-17658 WOP 1200PSIG	ACTIVE	1"	CLASS 300	Valve Tee	H-17658	1200	Branch to RS-1418
7	N/A	N/A	3/4" Flare Tee Mueller H-18102 WOP 1200PSIG	ACTIVE	3/4"	CLASS 300	Flare Tee	Mueller H-18102	1200	Branch to RS-1418
8	N/A	N/A	3/4" Flare Tee Mueller H-18102 WOP 1200PSIG	ACTIVE	3/4"	CLASS 300	Flare Tee	Mueller H-18102	1200	Branch to RS-1418
9	1	7600786	6" BIO Stopper Mueller H-17281 CLASS 300 WOP 720PSIG	ACTIVE	6"	CLASS 300	BIO Stopper	Mueller H-17281	720	Branch to RS-2695
10	1	7600786	6" BIO Stopper Mueller H-17281 CLASS 300 WOP 720PSIG	ACTIVE	6"	CLASS 300	BIO Stopper	Mueller H-17281	720	Branch to 020.A.1.C
10	7	8985337	1" Save-A-Valve Mueller H-17491 WOP 1440PSIG	ACTIVE	1"	CLASS 300	Save-A-Valve	Mueller H-17491	1440	Branch to RS-1418
10	9	8985337	2" Save-A-Valve Mueller H-17491 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Save-A-Valve	Mueller H-17491	1440	Branch to RS-1418
11	5	2200074	3/4" Plug 6000 WOP 6000PSIG	ACTIVE	3/4"	6000	3/4" Plug	6000	6000	Branch to RS-1418
11	4	8985141	3/4" Ball Valve 2000 WOP 2000PSIG	ACTIVE	3/4"	2000	3/4" Ball Valve	2000	2000	Branch to RS-1418
11	1	7600912	3/4" Service Tee H-17501 WOP 1440PSIG	ACTIVE	3/4"	CLASS 300	Service Tee	H-17501	1440	Branch to RS-1418

THE LOWEST PRESSURE RATING: 610

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions										
Job Key of the Header Pipe	1	1	1	1	1	1	1	1	1	1
Header OD (inch)	8.625	8.625	8.625	8.625	8.625	8.625	8.625	8.625	8.625	8.625
Header Wall Thickness (inch)	0.188	0.188	0.188	0.188	0.188	0.188	0.188	0.188	0.188	0.188
Header Yield Strength	35000	35000	35000	35000	35000	35000	35000	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1	1	1	1	1	1	1	1
Job Key of the Branch	2	3	4	5	6	7	8	10	10	11
Branch Fitting Description	1" Save-A-Valve	2" Pipe	2" Tee H-17650	3/4" Tee H-18101	1" Tee H-17656	3/4" Tee H-18102	3/4" Tee H-18102	1" Save-a-Valve	2" Save-a-Valve	1" H-17501
Branch OD (inch)	1.125	2.375	2.410	1.180	1.430	1.180	1.180	1.125	2.218	1.430
Branch Wall Thickness (inch)	0.178	0.154	0.27	0.181	0.18	0.181	0.181	0.178	0.234	0.18
Branch Yield Strength (psi)	36000	25000	36000	36000	36000	36000	36000	36000	36000	36000
Branch Longitudinal Joint Factor	1	0.6	1	1	1	1	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1	1	1	1	1	1	1
Tap Size (Maximum) (inch)	0.769	2.067	1.87	0.818	1.07	0.818	0.818	0.769	1.75	1.07
Tap Size (inch)	0.769	2.067	1.87	0.818	1.07	0.818	0.818	0.769	1.75	1.07
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement										
Max 'Usable' Length (OD) of additional Reinforcement	1.538	4.134	3.74	1.636	2.14	1.636	1.636	1.538	3.5	2.14
OD of Additional Reinforcement (inch)	0	3.375	0	0	0	0	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0.188	0	0	0	0	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	35000	0	0	0	0	0	0	0	0
Effective A3 Provided by Weldments										
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0.25	0	0	0	0	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0.25	0	0	0	0	0	0	0	0
Conclusion and Calculation Summary										
Design Pressure (psig)	715.009231	572.4185821	542.6609133	701.6387322	604.7303862	701.6387322	701.6387322	715.009231	531.4649319	604.7304
L (inch)	0.445	0.47	0.47	0.4525	0.45	0.4525	0.4525	0.445	0.47	0.45
d – OD/2 (Max Reinforcement Width)	0.2065	0.8795	0.665	0.228	0.355	0.228	0.228	0.2065	0.641	0.355
t (inch)	0.220248379	0.176325367	0.167158942	0.216129788	0.186278556	0.216129788	0.216129788	0.220248379	0.16371018	0.186279
tb (inch)	0.027930048	0.113291178	0.045410167	0.028747698	0.030026543	0.028747698	0.028747698	0.027930048	0.040930181	0.030027
Ar (sq in)	0.169371004	0.364464533	0.312587222	0.176794167	0.199318055	0.176794167	0.176794167	0.169371004	0.286492815	0.199318
A1 (sq in)	0	0.024131467	0.038972778	0	0.001841945	0	0	0	0.042507185	0.001842
A2 (sq in)	0.133562257	0.038266293	0.211114443	0.137788333	0.134976111	0.137788333	0.137788333	0.133562257	0.18148563	0.134976
A2' (sq in)	0.133562257	0.027333066	0.211114443	0.137788333	0.134976111	0.137788333	0.137788333	0.133562257	0.18148563	0.134976
A3 (Fitting Weld Material)	0.06060775	0	0.0625	0.062016	0.0625	0.062016	0.062016	0.06060775	0.0625	0.0625
A3 Reinforcement (sq in)	0	0.188	0	0	0	0	0	0	0	0
A3 Weldment (sq in)	0	0.125	0	0	0	0	0	0	0	0
A3 (sq in)	0.06060775	0.313	0.0625	0.062016	0.0625	0.062016	0.062016	0.06060775	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active	Active	Active	Active	Active	Active	Active
Design Pressure Evaluation	715.009231	572.4185821	542.6609133	701.6387322	604.7303862	701.6387322	701.6387322	715.009231	531.4649319	604.7304

Branch Connection with Weld-o-let

Table 4A - Basic Input

Job Key of the Header Pipe (Table 1)	1	1
Header OD (inch)	8.625	8.625
Header Wall Thickness (inch)	0.188	0.188
Header Yield Strength	35000	35000
Job Key of the Branch (Table 1/2/3)	2	3
Branch Fitting Description	2" Salve-A-Valve	4" Fig 2245-1/2 Valve

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID:
 Facility Type:

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Reviewed By	Review Completion Date
1	095-335	Sulphur HP Supply	3005-321	10/25/1990	R Nakano	7/18/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	812 (Class 4 Location)
Design Factor	0.4
Pipe Design Pressure	811.6
Non-Rated Fitting Design Pressure	N/A
Rated Fitting Rated Pressure	N/A
Branch Connection Design Pressure	N/A
Current System MAOP	150.0
The Highest % SMYS of the Facility at the Current System MAOP	7.4%
Proposed system MAOP	250.0
The Highest % SMYS of the Facility at the Proposed System MAOP	12.3%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	9		8" PIPE X 0.26 WALL GR.B	8"	0.26	Gr.B	812	7.39%	12.32%	HL Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP
Select Data from the drop down menu!													

THE LOWEST DESIGN PRESSURE: 7.4%

THE LOWEST DESIGN PRESSURE: 12.3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down menu!										

THE LOWEST PRESSURE RATING:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 020_A53
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Description	Issuing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	605-323	Sullivan HP Supply	3006-321	10/25/1800	R Nakano	3/30/2011	C Kuo	3/30/2011
2	667083747	Install Gasline Pumps	3006-321	TBD	D Filiza	6/21/2012	D Filiza	6/21/2012

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

549	0.4	(Class 4 Location)
549.0		
549.0		
720.0		
604.7		
160.0		
10.8%		
250.0		
18.2%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	1	Not Noted	12" X 12" Weld Tee 0.25 X 0.25 WALL Gr.B	ACTIVE	12"	0.25	Gr.B	649	10.83%	18.21%	Historic pipe spec.
2	2	8997507	3/4" PIPE X 0.154 WALL Gr.B	ACTIVE	3/4"	0.154	Gr.B	1122	1.46%	2.44%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	11	Not Noted	12" X 12" Weld Tee 0.25 X 0.25 WALL Gr.B	ACTIVE	12"	0.25	12"	0.25	Gr.B	Weld Tee	649	10.83%	18.21%	Historic pipe spec.
2	3	8994224	3/4" X 1/4" NIPER 0.154 X 0.11653 WALL Gr.B	ACTIVE	3/4"	0.154	1H 3/4"	0.11653	Gr.B	Weld Reducer	649	1.78%	2.89%	
2	7	8997505	3/4" Elbow X 0.154 WALL Gr.B	ACTIVE	3/4"	0.154	3/4"	0.154	Gr.B	Elbow	1122	1.46%	2.44%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	14	Not Noted	12" Flange, WN, RF, Unknown CLASS 300 WOP 720PSIG	ACTIVE	12"	CLASS 300	Flange, WN, RF	Unknown	720	
2	6	8994224	3/4" Flange, WN, RF, 2000 WOP 200PSIG	ACTIVE	3/4"	2000	Flange, WN, RF	Unknown	6000	
2	1	7800812	3/4" Service Tee H-17501 WOP 1400PSIG	ACTIVE	3/4"	2000	Service Tee	H-17501	1440	

THE LOWEST DESIGN PRESSURE: 549

10.9%

18.2%

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP
 Proposed MAOP

Dimensions	
Job Key of the Header Pipe	1
Header OD (inch)	8.625
Header Wall Thickness (inch)	0.188
Header Yield Strength	35000
Header Longitudinal Joint Factor	1
Job Key of the Branch	11
Branch Fitting Description	1" H-17501
Branch OD (inch)	1.430
Branch Wall Thickness (inch)	0.18
Branch Yield Strength (psi)	36000
Branch Longitudinal Joint Factor	1
Temperature Derating Factor (from Header)	1
Tap Size (Maximum) (inch)	1.07
Tap Size (inch)	1.07
Recommended Fitting Weld Leg (in)	0.25
Fitting Weld Length (in)	0.25
Effective A3 Provided by Additional Reinforcement	
Max 'Usable' Length (OD) of additional Reinforcement	2.14
OD of Additional Reinforcement (inch)	0
Thickness of Additional Reinforcement M (inch)	0
Yield Strength of Additional Reinforcement (psi)	0
Effective A3 Provided by Weldments	
Max Header Weld Leg Length for A3 (inch)	0.25
Header Weld Leg Length for A3 (inch)	0
Max Branch Weld Leg Length for A3 (inch)	0.25
Branch Weld Leg Length for A3 (inch)	0
Conclusion and Calculation Summary	
Design Pressure (psig)	604.7303862
L (inch)	0.45
d – OD/2 (Max Reinforcement Width)	0.355
t (inch)	0.186278556
tb (inch)	0.030026543
Ar (sq in)	0.199318055
A1 (sq in)	0.001841945
A2 (sq in)	0.134976111
A2' (sq in)	0.134976111
A3 (Fitting Weld Material)	0.0625
A3 Reinforcement (sq in)	0
A3 Weldment (sq in)	0
A3 (sq in)	0.0625
Status (Branch Status from Calculation Worksheet)	Active
Design Pressure Evaluation	604.7303862

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Facility ID
Facility Type

020-A-1-B
HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	618-139	Initial P. STW HP	618-139	7/20/1983	618-139	3/29/2011	618-139	3/29/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % BMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % BMYS of the Facility at the Proposed System MAOP

610	614 (Class 4 Location)
610.3	
MA	
MA	
MA	
15.0%	
15.0%	
20.0%	
20.0%	
15.4%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Gr	Th	Gr	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
			6" PIPE X 0.188 WALL G. B			0.188	Gr. B		6.83%	16.83%	

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Filling Type	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
THE LOWEST DESIGN PRESSURE: 610													

Table 3 - Rated Filling Rated Pressure

Job Key	ITEM #	MID	Description	Status	Site	Class Rating	Filling Type	Manufacturer and Stock Number	Rated Pressure	Comments
THE LOWEST PRESSURE RATING:										

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT101142011)

Descriptions of the Facility

Facility ID: 020-A-1-0
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	10900726	Sullivan HP Branch Riser, 30XX E.M. 61, Tucson	307-400	8/17/2007	R. Valero	8/21/2011	C. Koo	8/21/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
720	
0.4	
1264.4	
1264.0	
720.0	
982.1	
160.0	
4.8%	
260.0	
8.0%	

Table 1 - Pipe Design Pressures

Job Key	ITEM #	MID	Description	OD	Th	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Design Pressure	Comments
1	2	7000821	8" PIPE X 0.322 WALL X 42	8"	0.322	X-42	4.78%	7.87%	1264	

THE LOWEST DESIGN PRESSURE: 1264

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP
1	4	6000811	8" 90 degree EI X 0.322 WALL X 42	8"	0.322			X-42	45 degree EI	1264	4.78%	7.87%

THE LOWEST DESIGN PRESSURE: 1264

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	6	6600788	8" BQ Stopcock Mueller, H-17241, WOP Z0P5IG	8"		8000	720		
1	9	6600841	2" Saw-A-Valve Mueller, H-17481, WOP 144P5IG	2"		8000	1440		Branch Fitting

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	8.625	
Header Wall Thickness (inch)	0.322	
Header Yield Strength	42000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	2" Save-a-Valve	
Branch OD (inch)	2.218	
Branch Wall Thickness (inch)	0.234	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	
Temperature Derating Factor (from Header)	1	
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	882.1295225	
L (inch)	0.585	0
d - OD/2 (Max Reinforcement Width)	0.641	0
t (inch)	0.226439498	#DIV/0!
tb (inch)	0.067936225	#DIV/0!
Ar (sq in)	0.396269121	#DIV/0!
A1 (sq in)	0.167230879	#DIV/0!
A2 (sq in)	0.194294617	#DIV/0!
A2' (sq in)	0.166538243	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	882.1295225	

020 A-10
HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Descriptions of the Facility

Facility ID
 Facility Type

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	639-100	Initial 8" STW, IP	639-100	01/11/03	R. Nataro	03/02/01	C. Kao	03/02/01

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

610
 0.4 (Class 4 Location)

610.0
N/A
N/A
140.0
9.8%
260.0
16.4%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	None	8" PIPE X 0.188 WALL GRB	8"	0.188	Gr	610	9.83%	16.38%	Historic pipe spec.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	None	8" WELD EIT X 0.188 WALL WFB	8"	0.188				Weld Eit	610	9.83%	16.38%	Historic pipe spec.

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Site	Class Rating	Fitting Type	Manufacturer and Access Number	Rated Pressure	Comments
1	1	None	8" WELD EIT X 0.188 WALL WFB					610	Historic pipe spec.

THE LOWEST PRESSURE RATING:

10%

10%

610

THE LOWEST DESIGN PRESSURE:

610

THE LOWEST DESIGN PRESSURE:

610

10%

10%

610

10%

10%

610

10%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 020_A31E
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	838-100	Install of CIV HP	838-100	8/17/99	R. Nelson	3/30/2011	C. Kop	3/30/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

810	(Class 4 Location)
0.4	
810.3	
810.0	
N/A	
N/A	
150.0	
9.8%	
250.0	
16.4%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	None	6" WELD ER X 0.188 WALL GR.B	6"	0.188	Gr.B	8.83%	16.35%	

THE LOWEST DESIGN PRESSURE: 810

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	None	6" WELD ER X 0.188 WALL WFB	6"	0.188			WFB	Weld Filt.	810	8.83%	16.35%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Site	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	1	None	6" WELD ER X 0.188 WALL WFB	ACTIVE						

THE LOWEST PRESSURE RATING: 810

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: Main ID 027X.A-1.F
 Facility Type: HP PIPE SEGMENT

Job No.	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
	10001778	8" STW HP Main Relocation - Balaban HP Supply	908-941	4/28/2009	R. Hagan	3/22/2011	C. Rao	3/30/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rel Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

927	0.4	(Class 1 Location)
1254.1		
1045.0		
827.0		
724.0		
600.0		
574		
280.0		
9.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Enter MIDX, PCX or "FC" in this field		Description	Status	Select Data from the drop down menu		Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			OD	Th			OD	Th					
	20	7000821	8"	0.322	8" PIPE X 0.322 WALL X-42	ACTIVE	8"	0.322	X-42	1254	4.78%	7.97%	

Table 2 - Non-Rel Fitting Design Pressure

Job Key	ITEM #	MID	Enter MIDX, PCX or "FC" in this field		Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			OD	Th												
	22	6000314	8"	0.322	8" 60 degree EL X 0.322 WALL Y-42	ACTIVE	8"	0.322			Y-42	80 degree EL	1254	4.78%	7.97%	
	23	6000739	8"	0.322	8" Cap X 0.322 WALL Y-42	ACTIVE	8"	0.322			Y-42	Cap	1254	4.78%	7.97%	
	27	6000818	8"	0.322	8" 45 degree EL X 0.322 WALL WFB	ACTIVE	8"	0.322			WFB	45 degree EL	1045	6.72%	9.97%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Enter MIDX, PCX or "FC" in this field		Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Media Number	Rated Pressure	Comments
			OD	Th								
	21	7000760	8"		8" 60 degree Mueller, H-1781 CLASS 300 WOP 720PSIG	ACTIVE	8"	CLASS 300	80 degree	Mueller, H-1781	1440	
	24	6000837	1"		1" Sw-a-Valve Nipple Mueller, H-17481 CLASS 300 WOP 1440	ACTIVE	1"	CLASS 300	Sw-a-Valve Nipple	Mueller, H-17481	1440	
	25	6000841	2"		2" Sw-a-Valve Nipple Mueller, H-17481 CLASS 300 WOP 1440	ACTIVE	2"	CLASS 300	Sw-a-Valve Nipple	Mueller, H-17481	1440	Branch Fitting w/ Weld-on-let
	28	FO	2"		2" x 8" Weld-on-let WOP 927PSIG	ACTIVE	2"		8" Weld-on-let		927	Branch Fitting

THE LOWEST DESIGN PRESSURE: 1045 8% 10%

THE LOWEST PRESSURE RATING: 927

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	8.625	
Header Wall Thickness (inch)	0.188	
Header Yield Strength	35000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	1" Save-A-Valve	
Branch OD (inch)	1.125	
Branch Wall Thickness (inch)	0.203125	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	
Temperature Derating Factor (from Header)	1	
Tap Size (Maximum) (inch)	0.71875	0
Tap Size (inch)	0.71875	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	1.4375	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	791.9865006	
L (inch)	0.47	0
d - OD/2 (Max Reinforcement Width)	0.15625	0
t (inch)	0.243960127	#DIV/0!
tb (inch)	0.030936973	#DIV/0!
Ar (sq in)	0.175346342	#DIV/0!
A1 (sq in)	0	#DIV/0!
A2 (sq in)	0.161856746	#DIV/0!
A2' (sq in)	0.161856746	#DIV/0!
A3 (Fitting Weld Material)	0.053710938	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.053710938	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	791.9865006	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01/14/2011)

Descriptions of the Facility

020. B-1
HP PIPE SEGMENT

Facility ID

Facility Type

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	#120	Install 8" STM HP Main	62-300	1/7/1993	R. Nakano	3/30/2011	C. Kao	3/30/2011

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP

The Highest % SMYS of the Facility at the Current System MAOP
Proposed system MAOP
The Highest % SMYS of the Facility at the Proposed System MAOP

610	0.4	(Class 4 Location)
610.3		
720.0		
N/A		
150.0		
9.8%		
250.0		
16.4%		

Table 1 - Pipe Design Pressure

Enter MID#, POK, or "PO" in this field

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	NKNSRG	8" PIPE X 0.188 WALL Gr.B	ACTIVE	8"	0.188	Gr.B	610	9.83%	16.35%	Hetrole Pipe Spec

THE LOWEST DESIGN PRESSURE: 610 10% 16%

Table 2 - Non-Rated Fitting Design Pressure

Enter MID#, POK, or "PO" in this field

Job Key	ITEM #	MID	Description	Status	OD 1	TH 1	OD 2	TH 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	4	Not Noted	8" X 00 Degree Weld EI X 0.188 WALL WPB	ACTIVE	8"	0.188	OD 2	TH 2	WPB	Reduce Tee	610	9.83%	16.35%	Specify & Thickness Assumed
1	NA	Not Noted	8" X 4" Reducer Tee 0.188 X 0.237 WALL WPB	ACTIVE	8"	0.188	4"	0.237	WPB	Reduce Tee	610	9.83%	16.35%	Reducer Tee to 4" 020-AR-01

THE LOWEST DESIGN PRESSURE: 610 10% 16%

Table 3 - Rated Fittings Rated Pressure

Enter MID#, POK, or "PO" in this field

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	2	Not Noted	8" Valve, Plug Noratrom Fig 4248-1/2 CLASS 300 WOP ZUPBIG	ACTIVE	8"	CLASS 300	Valve, Plug	Noratrom Fig 4248-1/2	720	

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

623.114
 HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	6055008	6" SMYS HP	605-5008	7/18/1971	R. Hinkley	7/18/1971	C. Kopp	4/21/2011
2	6055019	8" SMYS HP	605-5019	7/30/2007	C. Kopp	7/30/2007	C. Kopp	4/21/2011
3	6055019	8" SMYS HP	605-5019	7/30/2007	C. Kopp	7/30/2007	C. Kopp	4/21/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
604	
9.4	
732.4	
1045.0	
720.0	
604.2	
150.0	
8.2%	
250.0	
13.7%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1 & 50	Z00610	8" PIPE X 0.188 WALL X 42	ACTIVE	8"	0.188		X 42		X 90 Degree Elbow, Weld	731	8.18%	13.66%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	Gr	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	PO	8" X 90 Degree Elbow, Weld X 0.322 WALL WPB	ACTIVE	8"	0.322				X 90 Degree Elbow, Weld	1045	6.74%	9.67%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	2	6005933	8" Valve, Plug Nordstrom, Fig. 4246-1/2 CLASS 300 WOP 74	ACTIVE	8"	CLASS 300	Valve, Plug	Nordstrom, Fig. 4246-1/2	740	
1	11 & 65	6006041	2" Nipple, Sev-A-Valve Mueller, H-17491 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Nipple, Sev-A-Valve Mueller, H-17491	1440	Branch fitting	
1	16	PO	8" Coupling, Insulated Kerolast, WOP 720PSIG	ACTIVE	8"	CLASS 300	Coupling, Insulated Kerolast	720	Branch fitting for	
2	1	7600786	8" Bottom Out Mueller, H-17281 CLASS 300 WOP 720PSIG	ACTIVE	8"	CLASS 300	Bottom Out Mueller, H-17281	720	Branch fitting for	

THE LOWEST DESIGN PRESSURE: 1045

6%

10%

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	8.625	
Header Wall Thickness (inch)	0.188	
Header Yield Strength	42000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	2" Save-A-Valve	
Branch OD (inch)	2.219	
Branch Wall Thickness (inch)	0.234375	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	
Temperature Derating Factor (from Header)	1	
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	604.1993144	
L (inch)	0.47	0
d - OD/2 (Max Reinforcement Width)	0.640625	0
t (inch)	0.155095806	#DIV/0!
tb (inch)	0.046547473	#DIV/0!
Ar (sq in)	0.271417661	#DIV/0!
A1 (sq in)	0.057582339	#DIV/0!
A2 (sq in)	0.176557875	#DIV/0!
A2' (sq in)	0.151335322	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	604.1993144	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 10/14/2011)

Descriptions of the Facility

Facility ID: 020-102
 Facility Type: UP-PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	806504	6" STW/HP	3007-312	7/19/03	R. N. Nishida	4/7/2011	C. Koo	4/8/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

740	0.4	(Class 4 Location)
1045.3		
1045.0		
740.0		
770.8		
150.0		
5.7%		
250.0		
9.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	PO	6" PIPE X 0.322 WALL Gr.B		0.322	Gr.B	1045	5.74%	9.57%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	6	PO	6" X 90 Degree Elbow, Weld X 0.322 WALL WPB	6	0.322			Gr	1045	5.74%	6.74%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Class Rating	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	11	PO	2 Nipple, Sav-A-Valve Mueller, H-17491 WOP 440P8IG	2		2	Nipple, Sav-A-Valve Mueller, H-17491	1440 Branch Fitting	740	

THE LOWEST PRESSURE RATING: 740

THE LOWEST DESIGN PRESSURE: 1045

6%

8%

10%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	8.625	
Header Wall Thickness (inch)	0.322	
Header Yield Strength	35000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	2" Save-A-Valve	
Branch OD (inch)	2.219	
Branch Wall Thickness (inch)	0.234375	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	770.8434167	
L (inch)	0.5859375	0
d - OD/2 (Max Reinforcement Width)	0.640625	0
t (inch)	0.237447302	#DIV/0!
tb (inch)	0.059385723	#DIV/0!
Ar (sq in)	0.415532779	#DIV/0!
A1 (sq in)	0.147967221	#DIV/0!
A2 (sq in)	0.205065559	#DIV/0!
A2' (sq in)	0.205065559	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	770.8434167	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Description of the Facility

Facility ID	0101
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Reviewed By	Review Completion Date	Reviewed By	Review Completion Date
0101	0101-001	8" S.V.P.R. (1) in Pipe	3007-317	7/19/1991	R Nakano	4/16/2011	C Koo	4/21/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1045	(Class 4 Location)
0.4	
1045.3	
N/A	
N/A	
N/A	
150.0	
5.7%	
250.0	
9.8%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Or	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
0101	001	PO	8" PIPE X 0.322 WALL GR B	ACTIVE		0.322	0.322	1045	5.74%	9.57%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Or	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down manual										

THE LOWEST DESIGN PRESSURE: 1045

THE LOWEST DESIGN PRESSURE: 1045

THE LOWEST PRESSURE RATING: 1045

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	020_U14
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Reviewed By	Reviewed Date	Reviewer	Completion Date	Reviewed By	Reviewed Date	Reviewer	Completion Date
1	98-824	8" STV HP	3007-312	7/18/1991	R. Nakano	4/18/2011	C. Kao					4/21/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	771	Class 4 Location
	9.4	
	1045.3	
	1045.0	
	1440.0	
	770.8	
	150.0	
	5.7%	
	250.0	
	9.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Gr	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	38	PO	8" PIPE X 0.322 WALL GR-B	ACTIVE	8"	GR-B	0.322	GR-B	1045	5.74%	9.57%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	64	7800446	8" X 4" Tee, Radioling, Weld 0.322 X 0.237 WALL WFB	ACTIVE	8"	0.322	4"	0.237	WFB	Tee, Radioling, Weld	1045	6.74%	9.57%	Branch to RS-2311

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Site	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	11	6800441	2 Nipple, Sev-A-Valve Mueller, H-17461 WCP 1440PSIG	ACTIVE	2		Nipple, Sev-A-Valve Mueller, H-17461	1440	1440	Branch Fitting

THE LOWEST DESIGN PRESSURE: 1045

THE LOWEST DESIGN PRESSURE: 1045

THE LOWEST PRESSURE RATING: 1440

THE LOWEST PRESSURE RATING: 1440

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	8.625	
Header Wall Thickness (inch)	0.322	
Header Yield Strength	35000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	2" Save-A-Valve	
Branch OD (inch)	2.219	
Branch Wall Thickness (inch)	0.234375	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	770.8434167	
L (inch)	0.5859375	0
d - OD/2 (Max Reinforcement Width)	0.640625	0
t (inch)	0.237447302	#DIV/0!
tb (inch)	0.059385723	#DIV/0!
Ar (sq in)	0.415532779	#DIV/0!
A1 (sq in)	0.147967221	#DIV/0!
A2 (sq in)	0.205065559	#DIV/0!
A2' (sq in)	0.205065559	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	770.8434167	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

020-AR-1
 HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	EX992-200	Previously installed RS-0400, reinstalled in HP main	67D-109 or M652-3	7/7/653	R. Nishino	3/20/2011	C. Kop	3/20/2011
2	18928233	Relics RS-0400	3D11-659	7/7/653	R. Nishino	3/20/2011	C. Kop	3/20/2011
3	18928242	Change installed on main for RS-2605	3D11-659	12/19/2005	C. Kop	3/20/2011	C. Kop	3/20/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	510	(Class 4 Location)
	0.4	
	1474.7	
	610.0	
	740.0	
	1151.8	
	150.0	
	9.8%	
	250.0	
	16.4%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			4" PIPE X 0.237 WALL GR-B	4"	0.237	Gr-B	1475	4.07%	6.73%	RELOCATED

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	None	None	8" X 4" Tee, Weld 0.188 X 0.237 WALL WPB	ACTIVE	8"	0.188	4"	0.237	Gr	Tea Weld	610	9.63%	18.35%	Welded to existing 8" pipe
2	None	6200713	4" Cap. Weld X 0.237 WALL Y-42	ACTIVE	4"	0.237	4"	0.237	Y-42	Cap. Weld	1770	3.39%	6.65%	Could be Y-42
3	None	None	4" 15 Deg EI X 0.237 WALL WPB	ACTIVE	4"	0.237	4"	0.237	WPB	15 Deg EI	1475	4.07%	6.79%	Welders & Grade

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
3	9	260768	4" Valve, Plug Nordstrom, Fig 2x46-17z CLASS 600 WOP 14	ACTIVE	4"	CLASS 600	Valve, Plug	Nordstrom, Fig 2245-17z	1440	Branch Filling to RS 2895
3	5	68109-1	2" Swave-A-Valve H17481 WOP 1400PSIG	ACTIVE	2"	CLASS 300	Bottom Out	H17481 STD	1440	Branch Filling to RS 2895

THE LOWEST DESIGN PRESSURE: 610

THE LOWEST PRESSURE RATING: 740

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	.1	
Header OD (inch)	4.500	
Header Wall Thickness (inch)	0.237	
Header Yield Strength	35000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	3	
Branch Fitting Description	2" Save-A-Valve	
Branch OD (inch)	2.219	
Branch Wall Thickness (inch)	0.234375	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1151.853392	
L (inch)	0.5859375	0
d - OD/2 (Max Reinforcement Width)	0.640625	0
t (inch)	0.185119295	#DIV/0!
tb (inch)	0.088738705	#DIV/0!
Ar (sq in)	0.323958766	#DIV/0!
A1 (sq in)	0.090791234	#DIV/0!
A2 (sq in)	0.170667533	#DIV/0!
A2' (sq in)	0.170667533	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1151.853392	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT0142011)

Descriptions of the Facility

Facility ID: RS-0286 (Mid (Relined))
 Facility Type: REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Reviewed By	Review Completion Date
1	10412748	Supply	3005-321	10/26/1990	RUKAKAN	C. Ross	7/14/2011
2	10412748	Reline (Compatible/Remounted)	3002-304	10/17/1990	RUKAKAN	C. Ross	7/14/2011
3	10412748	Reline (In-Place)	3004-304	11/24/1988	RUKAKAN	C. Ross	7/14/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Non-Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	810 (Class 4 Location)
	0.4
	1198.8
	1170.0
	610.0
	N/A
	160.0
	5.1%
	290.0
	9.5%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments		
				Status	OD	Th						
1	15	MID	4" PIPE X 0.188 WALL GR.B	ACTIVE	4"	0.188	Gr	Gr.B	1170	5.19%	8.55%	High Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments		
				Status	OD 1	Th 1						
1	15	Not Noted	4" 90 Degree Weld El X 0.188 WALL W/PB	ACTIVE	4"	0.188	Gr	W/PB	1170	5.19%	8.55%	High Spec
2	2	220713	4" Weld Cap X 0.237 WALL W/PB	ACTIVE	4"	0.237	Gr	W/PB	1170	5.19%	8.55%	High Spec

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments	
				Status	Size	Class Rating					
1	5	Not Noted	4" Valve Regulator, Flr 2024-1/2 CLASS 300 WGP T20P510	ACTIVE	4"	CLASS 300	Gr	1170	5.19%	8.55%	High Spec
1	4	Not Noted	8" X 4" WELD-O-LET - WGP-510P510	ACTIVE	8"	8" X 4" WELD-O-LET	Gr	1170	5.19%	8.55%	High Spec

THE LOWEST PRESSURE RATING: 810

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

RS-0883 Intd - Retired
REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	685-10191	Install RS-0883	65-1019	1/1/967	R. Nakano	3/28/2011	C. Koo	3/28/2011
2	108326084	Retire RS-0883	65-1019	1/1/2009	R. Nakano	3/28/2011	C. Koo	3/28/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1281.4		
3013.0		
1200.0		
N/A		
150.0		
2.8%		
250.0		
4.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	Unknown	3/4" PIPE X 0.113 WALL GR.A25	3/4"	0.113	Gr.A25	1281	2.79%	4.65%	URGENT SPEC.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	5200559	3/4" WALL CAP X 0.113 WALL WFB	3/4"	0.113	OD 2	Th 2	Gr	WFB	3013	1.99%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	1	7800800	3/4" Auto-Perf Tee Mueller, H-18102	3/4"	WOP 1200PSIG	Auto-Perf Tee	Mueller, H-18102	1200	Confirmed 887095101

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST DESIGN PRESSURE: 1281

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RS-1031 Init. - Refined
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	675-355	Initial RS-1031	675-355	9/7/1987	R Nakano	3/28/2011	C Koo	3/28/2011
2	108522397	Refine RS-1031	RS-1031	1/29/2005	R Nakano	3/28/2011	C Koo	3/28/2011

Facility Evaluation Summary

Design Factor

- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1291.4		
3013.0		
1200.0		
N/A		
150.0		
2.8%		
250.0		
4.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1		Unknown	3/4" PIPE X 0.113 WALL GR A25	ACTIVE	3/4"	0.113	Gr A25	1291	2.73%	4.65%	REGULAR SPEC

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	35	620599	3/4" WROG Cap X 0.113 WALL WFB	ACTIVE	3/4"	0.113			WFB	Weld Cap	3013	1.99%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1		None	3/4" Auto-Perf Tee Mueller, H-18102 WOP-1200PSIG	ACTIVE	3/4"		Auto-Perf Tee	Mueller, H-18102	1200	Confirmed 88705762

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142014)

Descriptions of the Facility:

Facility ID	RE-1220 - Int. (Relief)
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	495-538	Inst. RE-1220	700-309	9/7/1970	R. Nakano	4/6/2011	C. Kop	4/6/2011
2	10852830	Relief RE-1220	700-308	3/14/2007	R. Nakano	4/6/2011	C. Kop	4/6/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % BMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % BMYS of the Facility at the Proposed System MAOP

400
9.4
N/A
N/A
400.0
N/A
160.0
0.8%
260.0
0.0%

(Class 4 Location)

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
					Select Data from the drop down manual						

THE LOWEST DESIGN PRESSURE: []

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
					Select Data from the drop down manual						

THE LOWEST DESIGN PRESSURE: []

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
					Select Data from the drop down manual					
	16	66770	4" Valve, Plug Nordatom, Fig. 306 WOP 400PSIG	ACTIVE	4"	CLASS 300	Valve, Plug	Nordatom, Fig. 306	400	
	17	64390	4" Flange, WN, FF, CLASS 300 WOP 720PSIG	ACTIVE	4"	CLASS 300	Flange, WN, FF		720	
	18	69920	8" X 4" Weld-On-L, WOP 610PSIG	ACTIVE	8"	CLASS 300	8" X 4" Weld-On-L		610	The In Filling
	21	6406228	4" Flange, Blind CLASS 300 WOP 740PSIG	ACTIVE	4"	CLASS 300	Flange, Blind		740	

THE LOWEST PRESSURE RATING: []

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RS-1306 Int. - Rellid
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	708-411	Intall RS-1306	708-411	02/07/07	R. Nakano	06/20/11	C. Koo	06/20/11
2	10062690	Rella RS-1306	708-411	02/28/07	R. Nakano	06/20/11	C. Koo	06/20/11

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % BNYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % BNYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1281.4		
3013.0		
1200.0		
N/A		
150.0		
2.8%		
260.0		
4.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% BNYS at Current System MAOP	% BNYS at Proposed System MAOP	Comments
			Select Data from the drop down manual							
	12	Not Noted	3/4" PIPE X 0.113 WALL GR.A26	3/4"	0.113	Gr.A26	1281	2.79%	4.65%	Historical Bar

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD #	Th #	Gr	Fitting Type	Design Pressure	% BNYS at Current System MAOP	% BNYS at Proposed System MAOP	Comments
			Select Data from the drop down manual								
	84	5200558	3/4" Gb. Weld X 0.113 WALL WFB	3/4"	0.113		WFB	3013	1.87%	3.22%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
			Select Data from the drop down manual						
	1	Not Noted	3/4" Tee, Autoparf Mueller, H-18101 WOP 1200PSIG	3/4"		Tee, Autoparf	Mueller, H-18101	1200	

THE LOWEST PRESSURE RATING: 1200

THE LOWEST DESIGN PRESSURE: 3013

2%

3%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RES-1327-1424
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	705-520	Instal RS-1327	795-576	9/25/1970	R Nakano	3/31/2011	C Kos	3/31/2011
2	109520099	Relife RS-1327	795-576	9/29/2005	R Nakano	3/31/2011	C Kos	3/31/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4 (Class 4 Location)
------	------------------------

1291.4	3013.0
1200.0	N/A
150.0	2.8%
250.0	4.6%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual											
1	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL Gr.A25	ACTIVE	3/4"	0.113	Gr.A25	1291	2.79%	4.65%	Historical Spec

THE LOWEST DESIGN PRESSURE: 1291 3% 5%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														
2	Not Noted	5200556	3/4" Cap. Weld X 0.113 WALL WPB	ACTIVE	3/4"	0.113			WPB	Cap. Weld	3013	1.99%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down manual										
1	Not Noted	Not noted	3/4" Tee, Service Mueller Autoperf WOP 1200PSIG	ACTIVE	3/4"		Tee, Service	Mueller Autoperf 1200 887025790		Confirmed

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RS-1371 - Inlet
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	705-803	Install RS-1371	705-803	11/29/1970	R Nakano	9/31/2011	C Kob	9/31/2011
2	108928118	Relife RS-1371	705-803	9/19/2008	R Nakano	9/31/2011	C Kob	9/31/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4 (Class 4 Location)
1291.4	
3013.0	
1200.0	
N/A	
150.0	
2.8%	
250.0	
4.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Present System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual											
1	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL Gr.A25	ACTIVE	3/4"		Gr.A25	1291	2.79%	4.65%	Historical Spec

THE LOWEST DESIGN PRESSURE: 1291 3% 5%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														
2	36	6200562	3/4" Cap. Weld, Prestressed X 0.113 WALL WPB	ACTIVE	3/4"	0.113				Cap Weld Prestressed	3013	1.89%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down manual										
1	Not Noted	Not Noted	3/4" Tee Mueller, Auto-Perf WOP 1200PSIG	ACTIVE	3/4"		Tee	Mueller, Auto-Perf	1200	Confirmed 881026105

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	719-071	Initial RS-1404	108522510	2/16/1971	C. Koo	6/10/2011	C. Koo	6/10/2011
2	108522510	Refile RS-1404		2/1/2005	C. Koo	6/10/2011	C. Koo	6/10/2011

Facility Evaluation Summary

- Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	(Class 4 Location)
------	--------------------

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" PIPE X 0.113 WALL Gr. A25	ACTIVE	3/4"	0.113	Gr. A25	1291	2.75%	4.65%	Historical Spec.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	1" CAP X 0.133 WALL WFB	ACTIVE	1"	0.133	OD 2		WFB	CAP	2832	2.12%	3.53%	

THE LOWEST DESIGN PRESSURE: 1291

2832

4%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	N/A	3/4" SERVICE TEE MEULLER 18101 WOP 1200PSIG	ACTIVE	3/4"		SERVICE TEE	MEULLER 18101	1200	68726989

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: REG-1318 (Refined)
 Facility Type: REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	10027274	Final 10027274	110-316	07/14/2011	08/08/11	07/14/2011	08/08/11	07/14/2011
2	10027282	Final 10027282	110-316	07/14/2011	08/08/11	07/14/2011	08/08/11	07/14/2011

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure

Current System MAOP: 400
 The Highest % SNGS of the Facility at the Current System MAOP: 9.4
 Proposed System MAOP: 400
 The Highest % SNGS of the Facility at the Proposed System MAOP: 9.4

400 (Class 4 Location)

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SNGS at Current System MAOP	% SNGS at Proposed System MAOP	Comments
1	6	7270	2" PIPE X 0.164 WALL GR.A25	2"	0.164	Gr.A25	779	4.83%	7.71%	

THE LOWEST DESIGN PRESSURE: 779 5% 779 6% 779 8%

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Filling Type	Design Pressure	% SNGS at Current System MAOP	% SNGS at Proposed System MAOP	Comments
1	6	7270	2" Filmmouth Tee X 0.164 WALL GR.A25	ACTIVE	2"	0.164			Gr.A25	Filmmouth Tee	779	4.83%	7.71%	Made filmmouth tee using a short section of 100.000.

THE LOWEST DESIGN PRESSURE: 779 5% 779 6% 779 8%

Table 3 - Rated Filling Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Filling Type	Manufacturer and Model Number	Rated Pressure	Comments
1	10	6690	2" Valve, Plug Nonreturn, Flg 306, WOP 400PSIG	ACTIVE	2"	CLASS 300	Valve, Plug	Nonreturn, Flg 306	400	
1	12	6185	2" Flange, Vln, RF, CLASS 300, WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, Vln, RF	Nonreturn, Flg 306	740	
2	63	640765	2" Flange, Blind, RF, CLASS 300, WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, Blind, RF	Nonreturn, Flg 306	740	
1	N/A	N/A	4" Weld X Valve, Vln, Non Return, Flg 2245-12, WOP 1480PSIG	ACTIVE	4"		Valve X Valve	Non Return, Flg 2245-12	1480	Bypass Valve
1	N/A	N/A	8" x 8" Weld-O-Let, WOP 610PSIG	ACTIVE	8"		Weld-O-Let		610	Bypass Valve Tie In

THE LOWEST PRESSURE RATING: 400

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RS-1472
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	718-487	Initial RS-1472	718-487	07/17/07	R. Nakano	4/6/2011	C. Kop	4/6/2011
2	10924908	Revised RS-1472	718-897	07/27/07	R. Nakano	4/6/2011	C. Kop	4/6/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1213.7		
2832.0		
1200.0		
150.0		
3.0%		
250.0		
4.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual								
	1	2000140	1" PIPE X 0.133 WALL GRADE	ACTIVE	1"	0.133	GR42E	1214	2.97%	4.84%	Biological Spoil

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual											
	2	5200808	1" Cmp. Wall X 0.133 WALL WFB	ACTIVE	1"	0.133			WFB	Cmp. Wall	2832	2.12%	3.63%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
			Select Data from the drop down manual							
	1	6000520	1" Tee Mueller, Auto-Perf. H-18101 WOP 1200PSIG	ACTIVE	1"		Tee	Mueller, Auto-Perf. H-18101	1200	

THE LOWEST DESIGN PRESSURE: 1214

THE LOWEST DESIGN PRESSURE: 2832

THE LOWEST PRESSURE RATINGS: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: RS-1538 Title: Reg. Station
 Facility Type: REGULATION STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	728-500	Instal RS-1538	728-500	8/18/1972	R. Nakano	3/28/2011	C. Koo	3/28/2011
2	10852000	Refine RS-1538	728-500	1/27/2009	R. Nakano	3/28/2011	C. Koo	3/28/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4, Location)
1291.4		
3013.0		
1200.0		
N/A		
450.0		
2.8%		
280.0		
4.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	NA	None	3/4" PIPE X 0.113 WALL GR-A25	ACTIVE	3/4"	0.113	Gr-A25	1291	2.79%	4.65%	Historical Spec

THE LOWEST DESIGN PRESSURE: 1291 3% 5%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	95	560556	3/4" WELD CAP. STD X 0.113 WALL W/PB	ACTIVE	3/4"	0.113	OD 2		W/PB	Weld Cap. Std	3013	1.95%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1		None	3/4" Auloperf Tee Mueller, H18101 WOP 1200PSIG	ACTIVE	3/4"		Auloperf Tee	Mueller, H18101	1200	827028100

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID: RS-188
 Facility Type: Inlet - Retired
REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	D-4 Card	Install RS-188	None	5/26/1992	R. Nakano	3/26/2011	C. Koo	3/26/2011
2	100426091	Retire RS-188	RS-188	1/20/2005	R. Nakano	3/26/2011	C. Koo	3/26/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1291	0.4	(Class 4 Location)
1291.4		
3013.0		
1440.0		
MA		
190.0		
2.8%		
290.0		
4.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	12	700740	SH PIPE X 0.113 WALL GR A2E	ACTIVE	3/4"	0.113	Gr A2E	1481	2.79%	4.65%	RECALCULATE

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	35	6509069	3/4" WFB GR X 0.113 WALL WFB	ACTIVE	3/4"	0.113			WFB	Weld Cap	3013	1.99%	3.32%	

THE LOWEST DESIGN PRESSURE: 1291 3% 5%

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	1	Not Noted	1" Valve Tee H-17656 WOP 1440PSIG	ACTIVE	1"		Valve Tee	H-17656	1440	1440 Confirmed per 95129753

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: RS-1877 (Site - Refined)
 Facility Type: REGULATORY STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	775-255	Instal RS-1877	775-255	3/31/10	R Nakano	4/4/2011	C Kob	4/4/2011
2	109528110	Refit RS-1877	775-255	3/14/2007	R Nakano	4/4/2011	C Kob	4/4/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4 (Class 4 Location)
1213.7	
2832.0	
1200.0	
N/A	
150.0	
3.0%	
2832.0	
4.3%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments	
				Select Data from the drop down manual								
(Station Piping)	1	7080140	1" PIPE X 0.133 WALL GR.A2E	ACTIVE	1"		Gr.A2E	1214	2.97%	4.84%	Historical Spec.	

THE LOWEST DESIGN PRESSURE: 1214

3%

5%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Select Data from the drop down manual										
(Station Piping)	2	5200605	1" Cap. Weld X 0.133 WALL WFB	ACTIVE	1"	0.133			WFB	Cap. Weld	2832	2.12%	3.53%	

2%

4%

THE LOWEST DESIGN PRESSURE: 2832

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				Select Data from the drop down manual						
(Station Piping)	1	6600620	3/4" X 1" Tee Mueller, Auto-Perf. H-18101 WOP 1200PEIG	ACTIVE	3/4"		X 1" Tee	Mueller, Auto-Perf. H-18101	1200	Confirmed 887028108

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT0142011)

Descriptions of the Facility

Facility ID	REG-1973-001-1-Regul
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	789-879	Initial RS-1973	789-879	11/2/1979	R. Nakano	3/30/2011	C. Kopp	3/30/2011
2	0082A009	Rel. RS-1973	789-879	10/4/2009	R. Nakano	3/30/2011	C. Kopp	3/30/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	(Class 4 Location)
0.4	
129.14	
3013.0	
1200.0	
N/A	
160.0	
2.8%	
260.0	
4.9%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th.	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual							
			3/4" PIPE X 0.113 WALL GR.A35	ACTIVE	3/4"	0.113	Gr.A35	2.79%	4.65%	Historical Spec.

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th.1	OD 2	Th.2	Gr	Filling Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual											
			3/4" Cap. Weld X 0.113 WALL WFB	ACTIVE	3/4"	0.113			WFB	Cap. Well	3013	1.99%	3.32%	

Table 3 - Rated Filling Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Filling Type	Manufacturer and Model Number	Rated Pressure	Comments
			Select Data from the drop down manual							
			3/4" Tee, Service Mueller H-18103 WOP 1200F-SIG	ACTIVE	3/4"		Tee, Service	Mueller H-18102	1200	

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	RES-212-1-104
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	845-287	Initial RES-212	845-287	7/19/1994	R. Nakano	3/31/2011	C. Koo	3/31/2011
2	108928114	REG. RES-212	845-282	09/16/2005	R. Nakano	3/31/2011	C. Koo	3/31/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

500	(Class 4 Location)
0.4	
1213.7	
2832.0	
5000.0	
N/A	
160.0	
3.0%	
2550.0	
4.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th.	Gr.	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual											
1	1	7009340	1" PIPE X 0.133 WALL GR. A2E	ACTIVE	1"	0.133	Gr. A2E	1214	2.97%	4.84%	Historical Spec

THE LOWEST DESIGN PRESSURE: 1214 3%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th. 1	OD 2	Th. 2	Gr.	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														
2	1	5200009	1" Cap. Weld X 0.133 WALL W.P.B.	ACTIVE		1"	0.133		W.P.B.	Cap. Weld	2832	2.12%	3.63%	

THE LOWEST DESIGN PRESSURE: 2832 2%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down manual										
1	1	0500430	1" Tee, Adcoast Mueller, H-18101, W.P.B. 7200PSIG	ACTIVE	1"	CLASS 300	Tee, Adcoast	Mueller, H-18101	1200	
1	2	0400049	1" Flange, W.N.L. FC, CLASS 300 W.P.B. 7200PSIG	ACTIVE	1"	CLASS 300	Flange, W.N.L. FC	Flange, W.N.L. FC	740	
1	3	0400050	1" Flange, W.N.L. FC, CLASS 300 W.P.B. 7200PSIG	ACTIVE	1"	CLASS 300	Flange, W.N.L. FC	Flange, W.N.L. FC	740	
2	1	0400050	1" Flange, W.N.L. FC, CLASS 300 W.P.B. 7200PSIG	ACTIVE	1"	CLASS 300	Flange, W.N.L. FC	Flange, W.N.L. FC	740	

THE LOWEST PRESSURE RATING: 500

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	000000	REGULATOR STATION	000000	01/01/2011	01/01/2011	01/01/2011	01/01/2011	01/01/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

400	0.4	(Class 4 Location)
1213.7		
1770.0		
400.0		
173.5		
160.0		
4.3%		
290.0		
7.1%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	TH	GR	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down menu!											
1	31	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	32	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	33	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	34	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	35	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	36	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	37	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	38	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	39	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	40	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	41	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	42	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	43	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	44	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	45	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	46	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	47	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	48	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	49	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	50	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	51	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	52	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	53	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	54	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	55	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	56	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	57	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	58	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	59	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	60	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	61	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	62	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	63	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	64	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	65	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	66	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	67	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	68	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	69	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	70	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	71	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	72	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	73	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	74	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	75	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	76	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	77	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	78	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	79	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	80	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	81	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	82	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	83	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	84	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	85	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	86	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	87	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	88	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	89	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	90	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	91	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	92	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	93	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	94	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	95	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	96	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	97	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	98	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	99	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	
1	100	7000440	4" PIPE X 0.161 WALL X 42	ACTIVE		0.161	X 42	1400	4.27%	7.12%	

THE LOWEST DESIGN PRESSURE: 1211 4% 7%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD.1	TH.1	OD.2	TH.2	GR	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down menu!														
1	31	7000440	4" X 2" Tee Weld 0.237 X 0.161 WALL WPR	ACTIVE	4"	0.161	2"	0.161	WPR	Tee Weld	1939	3.10%	5.16%	
1	32	7000440	4" Cap. Weld X 0.237 WALL WPR	ACTIVE	4"	0.237			WPR	Cap. Weld	1939	3.05%	5.16%	
1	33	7000440	4" X 80 Degree Elbow Weld X 0.237 WALL WPR	ACTIVE	4"	0.237			WPR	Elbow Weld	1939	3.10%	5.16%	
1	34	7000440	2" X 80 Degree Elbow Weld X 0.113 WALL G.245	ACTIVE	2"	0.113			WPR	X 80 Degree Elbow Weld	1818	3.30%	5.61%	
1	35	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	36	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	37	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	38	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	39	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	40	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	41	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	42	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	43	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	44	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153			WPR	Threaded Nipple	2618	2.28%	3.92%	Branch Fitting
1	45	7000440	TH. 1/2" Threaded Nipple X 0.07153 WALL WPR	ACTIVE	TH. 1/2"	0.07153								

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	4.500	2.375
Header Wall Thickness (inch)	0.188	0.154
Header Yield Strength	42000	35000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	1
Branch Fitting Description	3/4" Service Tee	1/2" Nipple
Branch OD (inch)	1.180	0.840
Branch Wall Thickness (inch)	0.18	0.109
Branch Yield Strength (psi)	36000	35000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	0.82	0.622
Tap Size (inch)	0.82	0.622
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	1.64	1.244
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1413.401564	1273.453096
L (inch)	0.45	0.2725
d - OD/2 (Max Reinforcement Width)	0.23	0.202
t (inch)	0.189294852	0.108016111
tb (inch)	0.057910203	0.038203593
Ar (sq in)	0.155221779	0.067186021
A1 (sq in)	0	0.028601979
A2 (sq in)	0.109880817	0.038584042
A2' (sq in)	0.094183558	0.038584042
A3 (Fitting Weld Material)	0.0621	0
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0621	0
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1413.401564	1273.453096

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01/14/2011)

Descriptions of the Facility

Facility ID: REG-2002-Inst
 Facility Type: REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
	00023882	Initial RS-2006	3011-339	12/22/2006	R. Makrop	3/26/2011	C. Kop	3/26/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
1789.6	
1045.0	
720.0	
1184.8	
180.0	
250.0	
9.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual										
	5	898568	4" PIPE X 0.237 WALL X-42	4"	0.237	X-42	1170	3.39%	5.65%	
Select Data from the drop down manual										
	7	700270	2" PIPE X 0.164 WALL Gr.B	2"	0.164	Gr.B	1840	3.30%	5.51%	
	17	898124	4" PIPE X 0.237 WALL X-42	4"	0.237	X-42	1170	3.39%	5.65%	

THE LOWEST DESIGN PRESSURE: 1170 3% 6%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual												
	2	600814	6" X60 Weld El X 0.322 WALL WFB	6"	0.322			WFB	1045	5.74%	9.57%	
	3	700576	6" X 4" Weld El X 0.237 WALL WFB	6"	0.237	4"	0.237	WFB	1045	5.74%	9.57%	
	4	600972	4" X 46 Weld El X 0.237 WALL WFB	4"	0.237			WFB	1045	5.74%	9.57%	
	5	600987	4" X 60 Weld El X 0.237 WALL WFB	4"	0.237			WFB	1045	5.74%	9.57%	
Select Data from the drop down manual												
	21	600987	4" X 60 Weld El X 0.237 WALL WFB	4"	0.237			WFB	1045	5.74%	9.57%	
	4	700576	6" X 4" Weld El X 0.164 WALL WFB	6"	0.164	2"	0.164	WFB	1045	5.74%	9.57%	
	5	600980	4" X 60 Weld El X 0.164 WALL WFB	4"	0.164			WFB	1045	5.74%	9.57%	
	8	700576	4" X 46 Weld El X 0.237 WALL WFB	4"	0.237			WFB	1045	5.74%	9.57%	
	15	600370	1 1/2" Nipple, Threaded X 0.07653 WALL Gr.B	1 1/2"	0.07653			Gr.B	2100	2.77%	4.61%	Sch 40 - Branch Fitting

THE LOWEST DESIGN PRESSURE: 1045 6% 10%

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop down manual									
	1	760786	6" BIO Stopper Mueller H-17281 CLASS 300 WOP 720PSIG	6"	CLASS 300	BIO Stopper	Mueller H-17281	720	Th-in filling
	6	600764	4" Valve Nonreturn Flg 2046-1/2 CLASS 300 WOP 740PSIG	4"	CLASS 300	Valve	Nonreturn Flg 2046	740	Inlet Valve
	8	898241	2" Nipple, Sw-ss Valve Mueller H17491 WOP 1440PSIG	2"		Nipple, Sw-ss Valve	Mueller H17491	1440	Branch fitting
Select Data from the drop down manual									
	2	600716	2" Flange, WN, RF CLASS 300 WOP 740PSIG	2"	CLASS 300	Flange, WN, RF	Ball-Joint	740	
	3	600716	2" Valve, Ball-Joint, Class 300 WOP 740PSIG	2"	CLASS 300	Valve	Ball-Joint	740	
	7	600716	2" Valve, Ball-Joint, Class 300 WOP 740PSIG	2"	CLASS 300	Valve	Ball-Joint	740	
	10	740370	2" Regulator, Monney EG-30 CLASS 300 WOP 740PSIG	2"	CLASS 300	Regulator	Monney EG-30	740	
	11	7400748	1/4" Pilot American Meter, Z8C-100 WOP 1440PSIG	1/4"		Pilot	American Meter, Z8C-100	1440	
	12	898568	1/4" Pilot Regulator Fitting WOP 1600PSIG	1/4"		Pilot Regulator Fitting	Fitting	1600	
	13	898568	1/4" Pilot Regulator Fitting WOP 1600PSIG	1/4"		Pilot Regulator Fitting	Fitting	1600	
	16	898568	3/4" Valve Ball Joint 2400PSIG	3/4"		Valve	Ball Joint	2400	

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	4.500	2.375
Header Wall Thickness (inch)	0.237	0.154
Header Yield Strength	42000	35000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	1
Branch Fitting Description	2" Save-A-Valve	3/4" Nipple
Branch OD (inch)	2.219	1.050
Branch Wall Thickness (inch)	0.234375	0.113
Branch Yield Strength (psi)	36000	35000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0.824
Tap Size (inch)	1.75	0.824
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	1.648
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1190.498092	1184.923845
L (inch)	0.5859375	0.2825
d - OD/2 (Max Reinforcement Width)	0.640625	0.299
t (inch)	0.159441709	0.100506933
tb (inch)	0.09171589	0.044434644
Ar (sq in)	0.27902299	0.082817713
A1 (sq in)	0.13572701	0.044078287
A2 (sq in)	0.167178644	0.038739426
A2' (sq in)	0.143295981	0.038739426
A3 (Fitting Weld Material)	0	0
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0	0
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1190.498092	1184.923845

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions			
Job Key of the Header Pipe	1	1	1
Header OD (inch)	4.500	4.500	2.375
Header Wall Thickness (inch)	0.237	0.188	0.154
Header Yield Strength	42000	35000	35000
Header Longitudinal Joint Factor	1	1	1
Job Key of the Branch	1	1	1
Branch Fitting Description	2" Save-A-Valve	2" Save-A-Valve	3/4" Nipple
Branch OD (inch)	2.219	2.219	1.050
Branch Wall Thickness (inch)	0.23475	0.23475	0.113
Branch Yield Strength (psi)	36000	36000	35000
Branch Longitudinal Joint Factor	1	1	1
Temperature Derating Factor (from Header)	1	1	1
Tap Size (Maximum) (inch)	1.74925	1.74925	0.824
Tap Size (inch)	1.74925	1.74925	0.824
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement			
Max 'Usable' Length (OD) of additional Reinforcement	3.4985	3.4985	1.648
OD of Additional Reinforcement (inch)	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0
Effective A3 Provided by Weldments			
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0
Conclusion and Calculation Summary			
Design Pressure (psig)	1306.178302	964.3086445	1573.187198
L (inch)	0.586875	0.47	0.2825
d - OD/2 (Max Reinforcement Width)	0.639875	0.639875	0.299
t (inch)	0.174934594	0.154978175	0.133439986
tb (inch)	0.100627886	0.074290271	0.05899452
Ar (sq in)	0.306004339	0.271095573	0.109954548
A1 (sq in)	0.108567911	0.057763427	0.016941452
A2 (sq in)	0.157425832	0.150832145	0.030513096
A2' (sq in)	0.134936427	0.150832145	0.030513096
A3 (Fitting Weld Material)	0.0625	0.0625	0.0625
A3 Reinforcement (sq in)	0	0	0
A3 Weldment (sq in)	0	0	0
A3 (sq in)	0.0625	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active	Active
Design Pressure Evaluation	1306.178302	964.3086445	1573.187198

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: RB-2897 - HNS
 Facility Type: REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	1002043	Initial FG-287	901154	31/07/07	R. HANCOCK	4/9/2011	C. KOOP	4/9/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Relief Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed System MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	720	740	760	780	800	820	840	860	880	900	920	940	960	980	1000
(Class 4 Location)															

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down menu!								
			4" PIPE X 0.237 WALL X-42	ACTIVE	4"		X-42	1770	3.39%	5.65%	Base
			2" PIPE X 0.154 WALL G-8	ACTIVE	2"		G-8	1819	3.30%	5.61%	Base
			4" PIPE X 0.237 WALL X-42	ACTIVE	4"		X-42	1770	3.39%	5.65%	Base

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down menu!											
	23	600097	4" X 90 Degree Elbow, Weld X 0.237 WALL Y-42	ACTIVE	4"				Y-42	Y-42	1770	3.35%	5.65%	
			2" X 90 Degree Elbow, Weld X 0.154 WALL WPB	ACTIVE	2"				WPB	Y-42	1810	3.30%	5.61%	
			4" X 4" Tee, Weld 0.237 X 0.237 WALL Y-42	ACTIVE	4"		4"		Y-42	Y-42	1770	3.35%	5.65%	
			1/4" 3/4" Nipple, Weld X Thread, Sch 40 X 0.07853 WALL G-8	ACTIVE	1/4"	3/4"			G-8	Nipple, Weld X Thread, Sch 40	2100	2.77%	4.61%	Branch Filling
			4" X 2" X 90 Degree, Elbow, Reducing, Weld 0.237 X 0.154 WALL Y-42	ACTIVE	4"		2"		Y-42	X 90 Degree, Elbow, Reducing, Y-42	1770	3.35%	5.65%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
			Select Data from the drop down menu!							
	5	600784	4" Valve, Plug Nordstrom, Fig 2046-1Z CLASS 300 WOP 740PSIG	ACTIVE	4"	CLASS 300	Valve, Plug	Nordstrom, Fig 2046-1Z	740	Branch Filling, The In Filling
	94	7800785	2" Stem, Flanged Mueller, H-17608 CLASS 300 WOP 720PSIG	ACTIVE	2"	CLASS 300	Tee, Flanged	Mueller, H-17608	720	Branch Filling, The In Filling
	15	6800841	2" Gate Valve Mueller, H-17401 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Gate Valve	Mueller, H-17401	1440	Branch Filling
			2" Flange, WN, FF CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, WN, FF	Bellco-Mex	740	
			2" Valve, Ball, Flanged Mueller, H-17608 CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Valve, Ball, Flanged	Mueller, H-17608	740	
			2" Stem, Mueller, 12B-EG CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Stem	Mueller, 12B-EG	740	
			2" Regulator Mueller, EG-30 CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Regulator	Mueller, EG-30	740	
			1/4" Pilot American Meter, ZSC-100 WOP 1440PSIG	ACTIVE	1/4"	CLASS 300	Pilot	American Meter, ZSC-100	1440	
			1/4" Pilot Regulator Fisher, F-994 WOP 1402PSIG	ACTIVE	1/4"	CLASS 300	Pilot Regulator	Fisher, F-994	1400	
			3/4" Valve, Ball, WOP 2000PSIG	ACTIVE	3/4"	CLASS 300	Valve, Ball		2000	

THE LOWEST PRESSURE RATING: 720

THE LOWEST DESIGN PRESSURE: 1770

3% 3% 6%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	4.500	2.375
Header Wall Thickness (inch)	0.237	0.154
Header Yield Strength	42000	35000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	1
Branch Fitting Description	2" Save-A-Valve	3/4" Nipple
Branch OD (inch)	2.219	1.050
Branch Wall Thickness (inch)	0.234375	0.113
Branch Yield Strength (psi)	36000	35000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0.824
Tap Size (inch)	1.75	0.824
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0.25
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	1.648
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1304.9389	1573.187198
L (inch)	0.5859375	0.2825
d - OD/2 (Max Reinforcement Width)	0.640625	0.299
t (inch)	0.174768603	0.133439986
tb (inch)	0.100532402	0.05899452
Ar (sq in)	0.305845055	0.109954548
A1 (sq in)	0.108904945	0.016941452
A2 (sq in)	0.156846794	0.030513096
A2' (sq in)	0.134440109	0.030513096
A3 (Fitting Weld Material)	0.0625	0.0625
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1304.9389	1573.187198

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: RS-2698
Facility Type: REGULATOR STATION

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	70003389	Install RS-2698	3D11-560	7/9/2006	R. Nakano	3/29/2011	C. Koo	3/29/2011
2	88709024	Upgrade the Inlet Tie-in Filling	3D11-560	TBD	D. Fiese	8/21/2012	D. Fiese	8/21/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Ret'd Fitting Design Pressure
- Ret'd Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

492	0.4	(Class 4 Location)
1815.6	1815.6	
740.0	740.0	
481.9	481.9	
150.0	150.0	
3.3%	3.3%	
250.0	250.0	
5.5%	5.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down manual											
(Station Piping)											
1	2	7000370	2" PIPE X 0.154 WALL Gr.B	ACTIVE	2"	2"	Gr.B	1816	3.30%	3.30%	5.51% STW
3	7	7000282	2" PIPE X 0.154 WALL Gr.B	ACTIVE	2"	2"	Gr.B	1816	3.30%	3.30%	5.51%
(First Stage Piping)											
1	1	7000270	2" PIPE X 0.154 WALL Gr.B	ACTIVE	2"	2"	Gr.B	1816	3.30%	3.30%	5.51% Bare

THE LOWEST DESIGN PRESSURE: 1816 3% 6%

Table 2 - Non-Ret'd Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down manual														
(Station Piping)														
1	26	6000500	2" 90 Degree Weld Ell X 0.154 WALL WFB	ACTIVE		2"	0.154			WFB	1816	3.30%	3.30%	5.51%
(First Stage Piping)														
1	2	7800340	2" X 2" Weld Tee, 0.154 X 0.154 WALL WFB	ACTIVE	2"	2"	0.154	2"		WFB	1816	3.30%	3.30%	5.51%
3	5	6000500	2" 90 Degree Weld Ell X 0.154 WALL WFB	ACTIVE	2"	2"	0.154			WFB	1816	3.30%	3.30%	5.51%
1	15	6800370	TH 3/4" X 6" Threaded Nipple, SCH 40 X 0.07653 WALL Gr.B	ACTIVE	TH 3/4"	0.07653				Gr.B	2168	2.77%	2.77%	4.61% Branch Filling

THE LOWEST DESIGN PRESSURE: 1816 3% 6%

Table 3 - Ret'd Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the drop-down manual										
(Station Piping)										
1	1	7600775	2" Valve Tee Mueller, H-17650 WOP 250PSIG	RETIRED	2"		Valve Tee	Mueller, H-17650	250	Tie-in Branch Filling
1	3	8600642	2" Valve Nordstrom Fig 2045 CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Valve	Nordstrom Fig 2045	740	
1	6	6400165	2" Flange, WN, FF, CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, WN, FF	Flange, WN, FF	740	
1	8	8800341	2" Save-A-Valve Mueller, H17491, WOP 1440PSIG	ACTIVE	2"		Save-A-Valve	Mueller, H17491	1440	Branch Filling
2	TBD	N/A	2" Valve Tee Mueller H-17650 (Upgraded) WOP 1440PSIG	ACTIVE	2"		Valve Tee	Mueller H-17650	1440	Upgraded to 1440 PSIG
(First Stage Piping)										
1	2	6400165	2" Flange, WN, FF, CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, WN, FF	Flange, WN, FF	740	
1	6	8850910	2" Valve, Ball, Ball-to-Max CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Valve, Ball	Ball-to-Max	740	
1	7	8850940	2" Strainer Mueller, 1361CS CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Strainer	Mueller, 1361CS	740	
1	10	7400372	1/4" Pilot Regulator, Series 20, WOP 1800PSIG	ACTIVE	1/4"	CLASS 300	Pilot Regulator	Mueller, FS-30	740	
1	12	6880338	1/4" Pilot Regulator, Fisher, 112, WOP 1800PSIG	ACTIVE	1/4"		Pilot Regulator	Fisher, Series 20	1500	
1	13	6200376	1/4" Pilot Filler, Fisher, P584-1, WOP 1400PSIG	ACTIVE	1/4"		Pilot Filler	Fisher, 112	1500	
1	16	8980141	3/4" Valve Ball, WOP 2000PSIG	ACTIVE	3/4"		Valve Ball	Fisher, P584-1	1400	

THE LOWEST PRESSURE RATING: 740

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions			
Job Key of the Header Pipe	1	1	1
Header OD (inch)	8.625	2.375	2.375
Header Wall Thickness (inch)	0.188	0.154	0.154
Header Yield Strength	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1
Job Key of the Branch	1	1	1
Branch Fitting Description	2"x2" H-17650 Tee	2" Save-A-Valve	3/4" Nipple
Branch OD (inch)	2.410	2.219	1.050
Branch Wall Thickness (inch)	0.27	0.234375	0.113
Branch Yield Strength (psi)	36000	36000	35000
Branch Longitudinal Joint Factor	1	1	1
Temperature Derating Factor (from Header)	1	1	1
Tap Size (Maximum) (inch)	1.87	1.75	0.824
Tap Size (inch)	1.87	1.75	0.824
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25
Fitting Weld Length (in)	0	0	0
Effective A3 Provided by Additional Reinforcement			
Max 'Usable' Length (OD) of additional Reinforcement	3.74	3.5	1.648
OD of Additional Reinforcement (inch)	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0
Effective A3 Provided by Weldments			
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0
Conclusion and Calculation Summary			
Design Pressure (psig)	491.8773553	1263.262558	1184.923845
L (inch)	0.47	0.385	0.2825
d - OD/2 (Max Reinforcement Width)	0.665	0.640625	0.299
t (inch)	0.151515792	0.107151735	0.100506933
tb (inch)	0.04116057	0.09732166	0.044434644
Ar (sq in)	0.283334532	0.187515536	0.082817713
A1 (sq in)	0.068225468	0.081984464	0.044078287
A2 (sq in)	0.215109064	0.105531072	0.038739426
A2' (sq in)	0.215109064	0.105531072	0.038739426
A3 (Fitting Weld Material)	0	0	0
A3 Reinforcement (sq in)	0	0	0
A3 Weldment (sq in)	0	0	0
A3 (sq in)	0	0	0
Status (Branch Status from Calculation Worksheet)	Active	Active	Active
Design Pressure Evaluation	491.8773553	1263.262558	1184.923845

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01/14/2011)

Descriptions of the Facility

Facility ID	RS-2723 Inlet
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	100031159	Inlet RS-2723	3011-589	7/20/2007	Row N	4/2/2011	C. Lee	4/1/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Clear of Location)
1758.8	
807.0	
720.0	
1355.0	
8.6%	
255.0	
11.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual										
	1	8985868	4" PIPE X 0.237 WALL X-42	ACTIVE	4"	0.237	X-42	3.39%	3.39%	5.65%
	1	8985724	4" PIPE X 0.237 WALL X-42	ACTIVE	4"	0.237	X-42	3.39%	3.39%	5.65%
	2	7600512	3/4" PIPE X 0.113 WALL GR-B	ACTIVE	3/4"	0.113	GR-B	1.89%	1.89%	3.32%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th.1	OD 2	Th.2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														
	2	6000782	6" X 90 Degree, Elbow, Weld X 0.168 WALL Y-62	ACTIVE	6"	0.168				Y-62	907	6.62%	6.62%	11.03%
	3	8985793	6" X 45 Degree, Elbow, Weld X 0.168 WALL Y-52	ACTIVE	6"	0.168				Y-52	907	6.62%	6.62%	11.03%
	6	6000779	4" X 90 Degree, Elbow, Weld X 0.237 WALL Y-62	ACTIVE	4"	0.237				Y-62	2191	2.74%	2.74%	4.66%
First Stage Piping														
	2	6000997	4" X 90 Degree, Elbow, Weld X 0.237 WALL WFB	ACTIVE	4"	0.237				WFB	1475	4.07%	4.07%	6.76%
	3	7600412	4" X Tee, Weld X 0.237 WALL WFB	ACTIVE	4"	0.237				WFB	1475	4.07%	4.07%	6.76%
	10	6000824	1/2" 3/4" Nipple, Weld X 0.1163 WALL GR-B	ACTIVE	1/2"	0.1163				GR-B	3348	1.79%	1.79%	2.90%
	13	7200502	4" X Tee, Reducer, Weld X 0.164 WALL WFB	ACTIVE	4"	0.237		2"		WFB	1935	3.10%	3.10%	5.16%
(RTU Piping)														
	3	6000105	3/4" X 90 Degree, Elbow, Weld X 0.113 WALL GR-B	ACTIVE	3/4"	0.113				GR-B	3013	1.89%	1.89%	3.32%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Incon Number	Rated Pressure	Comments
Select Data from the drop down manual										
	1	7600795	6" Stopper, B/C, TW Mueller, H-17281 CLASS 300 WOP ZAPBISG	ACTIVE	6"	CLASS 300	Stopper, B/C, TW Mueller, H-17281	720		
	5	6000941	2" Nipple, Sav-A-Valve Mueller, H-17461 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Nipple, Sav-A-Valve Mueller, H-17461	1440 Branch Filling		
	7	6000785	4" Valve, Plug Nordstrom, Fig. 2045-1/4 CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Valve, Plug Nordstrom, Fig. 2045-1/4	740		
	9	8980844	4" Flange, WN, RE CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Flange, WN, RE Class 300 WOP ZAPBISG	2000		
	11	6000411	3/4" Valve, Ball, WOP 2000PSIG	ACTIVE	3/4"	CLASS 300	Valve, Ball, WOP 2000PSIG			
First Stage Piping										
	4	6000944	4" Flange, WN, RE CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Flange, WN, RE Class 300 WOP ZAPBISG	740		
	6	6000911	4" Valve, Ball, Ball, O-Max CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Valve, Ball, O-Max	740		
	7	6000360	4" Flange, WN, FF CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Flange, WN, FF Class 300 WOP ZAPBISG	740		
	9	8985835	4" Branch, Mueller, Fig. 188 CLASS 300 WOP ZAPBISG	ACTIVE	4"	CLASS 300	Branch, Mueller, Fig. 188	740		
	11	7200370	2" Flange, WN, FF CLASS 300 WOP ZAPBISG	ACTIVE	2"	CLASS 300	Flange, WN, FF Class 300 WOP ZAPBISG	740		
	14	7200370	2" Flange, WN, FF CLASS 300 WOP ZAPBISG	ACTIVE	2"	CLASS 300	Flange, WN, FF Class 300 WOP ZAPBISG	740		
	17	7400146	1/4" Pilot American Meter, ZSC-100 WOP 1440PSIG	ACTIVE	1/4"		Pilot American Meter, ZSC-100	1440		
	18	7200372	1/4" Reducer, Mueller, Type 248 WOP 1500PSIG	ACTIVE	1/4"		Reducer, Mueller, Type 248	1500		
	19	6000379	1/4" Pilot Filter Filtar P894-1 WOP 1440PSIG	ACTIVE	1/4"		Pilot Filter Filtar P894-1	1440		
(RTU Piping)										
	1	7600512	3/4" Tee, Service Mueller, H-17501 WOP 1440PSIG	ACTIVE	3/4"		Tee, Service Mueller, H-17501	1440 Branch Filling		
	4	8985411	3/4" Valve, Ball, WOP 2000PSIG	ACTIVE	3/4"		Valve, Ball, WOP 2000PSIG	2000		

THE LOWEST DESIGN PRESSURE: 807

7%

11%

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	4.500	4.500
Header Wall Thickness (inch)	0.237	0.237
Header Yield Strength	42000	42000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	1
Branch Fitting Description	2" Save-A-Valve	3/4" H17501 Tee
Branch OD (inch)	2.219	1.430
Branch Wall Thickness (inch)	0.234375	0.18
Branch Yield Strength (psi)	36000	35000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	1.07
Tap Size (inch)	1.75	1.07
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0.25
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	2.14
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1304.9389	1388.350646
L (inch)	0.5859375	0.45
d - OD/2 (Max Reinforcement Width)	0.640625	0.355
t (inch)	0.174768603	0.185939819
tb (inch)	0.100532402	0.070905051
Ar (sq in)	0.305845055	0.198955606
A1 (sq in)	0.108904945	0.054634394
A2 (sq in)	0.156846794	0.098185454
A2' (sq in)	0.134440109	0.081821212
A3 (Fitting Weld Material)	0.0625	0.0625
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1304.9389	1388.350646

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

020.X4
 Facility ID
 Facility Type
 HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	9708121	6" Pierce Transit HP Supply - 6" Tie-in between 6"x6" reducer and the BO US of DR 2311	9705121	5/19/1998 R Nakano	C.Kop	4/26/2011		6/28/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720
0.4 (Class 4 Location)
953.5
1420.0
720.0
874.6
150.0
6.3%
250.0
10.5%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	49	5200730	6" PIPE X 0.188 WALL X-42	6"	0.188	X-42	953	6.29%	10.49%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	49	600752	6" X 90 Degree, Elbow, Weld X 0.28 WALL Y-42	6"	0.28	OD 2		Y-42	1420	4.23%	7.04%	
1	51	520730	6" 90° WELDED X 0.28 WALL WSP	6"	0.28	6"		WSP	1555	3.85%	6.43%	
1	57	780082	6" X 6" Tee, WSP X 0.28 WALL Y-42	6"	0.28	6"		Y-42	1420	4.23%	7.04%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fittings Type	Manufacturer and Model	Rated Pressure	Comments
1	Not Noted	7800641	6" Stopper, B/D Mueller, H-17261 CLASS 300 WOP 720PSIG	6"	Class 300	Stopper, B/D	Mueller, H-17261	720	Tie-In Fitting Confirmed
1	Not Noted	7800641	1" Service Tee Mueller Class 600 WOP 1440PSIG	1"	Class 600	Service Tee	Mueller	1440	887025759

THE LOWEST DESIGN PRESSURE: 1420 4% 7%

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	6.625	
Header Wall Thickness (inch)	0.188	
Header Yield Strength	42000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	1" Service Tee	
Branch OD (inch)	1.430	
Branch Wall Thickness (inch)	0.18	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	
Temperature Derating Factor (from Header)	1	
Tap Size (Maximum) (inch)	1.07	0
Tap Size (inch)	1.07	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	2.14	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	874.5563064	
L (inch)	0.45	0
d - OD/2 (Max Reinforcement Width)	0.355	0
t (inch)	0.172438557	#DIV/0!
tb (inch)	0.04342415	#DIV/0!
Ar (sq in)	0.184509256	#DIV/0!
A1 (sq in)	0.016650744	#DIV/0!
A2 (sq in)	0.122918265	#DIV/0!
A2' (sq in)	0.105358513	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	874.5563064	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 050_X-2
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	8705171	6" Pierce Trane HP Supply - Between VA-1949 and 6" supply (including the reducer)	9705121	5/19/1998	R Niekamp	4/26/2011	C Kob	4/26/2011
2	867028747	Install Chicago Points	TBD		D Frieze	6/21/2012	D Frieze	6/21/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

604	0.4 (Class 4 Location)
732.4	
1254.0	
1440.0	
804.2	
150.0	
8.2%	
250.0	
13.7%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not noted	Not noted	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	732	8.19%	13.65%	13.65% Municipal Purchase
2	2	8997607	3/4" PIPE X 0.154 WALL Gr.B	ACTIVE	3/4"	0.154	Gr.B	841	1.45%	2.44%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	Fitting Type	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	65	7200570	6" X 6" Reducer, Reducing, Weld 0.322 X 0.28 WALL Y-42	ACTIVE	6"	0.322	6"	0.28	Y-42	1254	Reducer, Reducing, Weld	4.78%	7.87%	
2	3	8995424	3/4" X 1/2" 3/4" Nipple 0.154 X 0.11653 WALL Gr.B	ACTIVE	3/4"	0.154	1/2"	0.11653	Gr.B	336	Nipple	1.75%	2.60%	
2	7	8987865	3/4" Elbow X 0.154 WALL Gr.B	ACTIVE	3/4"	0.154			Gr.B	487	Elbow	1.48%	2.44%	

THE LOWEST DESIGN PRESSURE: 732

5%

8%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not noted	Not Noted	2" X 3" Nipple, Sav-A-Valve Mueller, H-17481 WOP 1440PSI	ACTIVE	2"		X 3" Nipple, Sav-A-Valve	Mueller, H-17481	1440	Branch Fitting
2	5	7200024	3/4" Plug 6000 WOP 6000PSIG	ACTIVE	3/4"		6000 Plug		6000	
2	4	8998141	3/4" Ball Valve 2000 WOP 2000PSIG	ACTIVE	3/4"		2000 Ball Valve		2000	
2	1	7600512	3/4" Service Tee H-17501 WOP 1440PSIG	ACTIVE	3/4"		Service Tee	H-17501	1440	

THE LOWEST PRESSURE RATING: 1440

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	8.625	8.625
Header Wall Thickness (inch)	0.188	0.188
Header Yield Strength	42000	35000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	11
Branch Fitting Description	2" Save-A-Valve	1" H-17501
Branch OD (inch)	2.219	1.430
Branch Wall Thickness (inch)	0.234375	0.18
Branch Yield Strength (psi)	36000	36000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	1.07
Tap Size (inch)	1.75	1.07
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0.25
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	2.14
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	604.1993144	604.7303862
L (inch)	0.47	0.45
d - OD/2 (Max Reinforcement Width)	0.640625	0.355
t (inch)	0.155095806	0.186278556
tb (inch)	0.046547473	0.030026543
Ar (sq in)	0.271417661	0.199318055
A1 (sq in)	0.057582339	0.001841945
A2 (sq in)	0.176557875	0.134976111
A2' (sq in)	0.151335322	0.134976111
A3 (Fitting Weld Material)	0.0625	0.0625
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	604.1993144	604.7303862

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	020-X-1
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	005-504B	6" Piece Transit HP Supply - Original & operated at IP then upgraded to HP	905-504B	7/12/1991 R Nakano		4/27/2011	C. Koo	4/27/2011
2	0700121	6" Upgrade - New fittings installed	815-878	11/21/1999 C. Koo		4/27/2011	C. Koo	4/27/2011
3	915-878	6" Upgrade - New fittings installed	D-4	11/21/1999 C. Koo		6/29/2011	C. Koo	6/29/2011
4	1-1/4" Service	1-1/4" Service		11/21/1999 C. Koo		6/29/2011	C. Koo	6/29/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
953.5	
1420.0	
720.0	
771.5	
150.0	
6.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	7000521	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	Gr	853	6.28%	10.45%	

Table 2 - Non-Rated Fittings Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	5	6000742	6" x 45 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Gr	X-45 Degree, Elbow, Weld	1420	4.23%	7.04%	

THE LOWEST DESIGN PRESSURE: 853

THE LOWEST DESIGN PRESSURE: 1420

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	2	6400440	6" Valve, Plug Nordstrom, Fig 143	RETIRED	6"	CLASS 150	Valve, Plug	Nordstrom, Fig 143	N/A	Retired 9/05/21 Rated for 200 psig
1	3	6000840	6" Flange, FN, RF CLASS 150 WOP NAPSIG	RETIRED	6"	CLASS 150	Flange, FN, RF		N/A	Retired 9/05/21 - Rated for 215 psig
1	6	7600778	6" Stopper, B/O Mueller, H-17260 CLASS 150 WOP NAPSIG	RETIRED	6"	CLASS 150	Stopper, B/O	Mueller, H-17260	N/A	Retired 9/05/21 - Rated for 215 psig
2	4B	7600779	6" Stopper, B/O Mueller, H-17261 WOP ZPSISIG	ACTIVE	6"	Class 600	Stopper, B/O	Mueller, H-17261	20	Confirmed
1	Not Noted	7800841	1" Service Tee Mueller Class 600 WOP 1440PSIG	ACTIVE	1"	Class 600	Service Tee	Mueller	1440	89/02/59
2	Not Note	Not Note	2" Service Tee Mueller Class 600 WOP 1440PSIG	ACTIVE	2"	Class 600	Service Tee	Mueller	1440	Branch fitting (For serv line replacement)
3	Not Note	Not Note	2" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	2"	Class 600	Service Tee	Mueller H17501	1440	Branch to 020, AS-1
4	Not Note	Not Note	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"	Class 600	Service Tee	Mueller H17501	1440	Branch to HPS-007

THE LOWEST PRESSURE RATING: 720

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions				
Job Key of the Header Pipe	1	1	1	1
Header OD (inch)	6.625	6.625	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188	0.188	0.188
Header Yield Strength	42000	42000	42000	42000
Header Longitudinal Joint Factor	1	1	1	1
Job Key of the Branch	2	2	3	4
Branch Fitting Description	2" Save-A-Valve	1" Service Tee	2" Service Tee H-17501	1-1/4" Service Tee H17501
Branch OD (inch)	2.219	1.430	2.410	1.810
Branch Wall Thickness (inch)	0.234375	0.18	0.27	0.22
Branch Yield Strength (psi)	36000	36000	36000	36000
Branch Longitudinal Joint Factor	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1
Tap Size (Maximum) (inch)	1.75	1.07	1.87	1.37
Tap Size (inch)	1.75	1.07	1.87	1.37
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement				
Max 'Usable' Length (OD) of additional Reinforcement	3.5	2.14	3.74	2.74
OD of Additional Reinforcement (inch)	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0	0
Effective A3 Provided by Weldments				
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0	0
Conclusion and Calculation Summary				
Design Pressure (psig)	771.5468507	874.5563064	784.7477896	841.6409874
L (inch)	0.47	0.45	0.47	0.47
d - OD/2 (Max Reinforcement Width)	0.640625	0.355	0.665	0.465
t (inch)	0.152127913	0.172438557	0.154730777	0.165948558
tb (inch)	0.059439916	0.04342415	0.065668131	0.052894798
Ar (sq in)	0.266223848	0.184509256	0.289346553	0.227349524
A1 (sq in)	0.062776152	0.016650744	0.062213447	0.030210476
A2 (sq in)	0.164438979	0.122918265	0.192071957	0.15707889
A2' (sq in)	0.140947696	0.105358513	0.164633106	0.134639048
A3 (Fitting Weld Material)	0.0625	0.0625	0.0625	0.0625
A3 Reinforcement (sq in)	0	0	0	0
A3 Weldment (sq in)	0	0	0	0
A3 (sq in)	0.0625	0.0625	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active
Design Pressure Evaluation	771.5468507	874.5563064	784.7477896	841.6409874

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 720
 Facility Type: HP PIPE SEGMENT

Rev. No.: 1
 Date: 01/11/2011

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	70512	6" Pipe Repair/Update @ HP Offset at East Island	70512	01/11/2011	R. W. Howard	01/11/2011		01/11/2011
2	70512	6" Pipe Repair/Update @ HP Offset at East Island	70512	01/11/2011	R. W. Howard	01/11/2011		01/11/2011

Facility Evolution Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	Class 4 Location
0.4	
855.5	
1420.0	
740.0	
N/A	
100.0	
9.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressures

Job Key	ITEM #	MID	Description	OD	TH	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	1	700821	6" PIPE X 0.188 WALL X 42	6"	0.188	X-42	853	8.28%	10.49%	

Table 2 - Non-Rated Fittings Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	TH 1	OD 2	TH 2	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	1	600752	6" X 90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	0.28		Y-42	1420	4.23%	7.04%	
	5	500730	6" Cap, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	1420	4.23%	7.04%	BOM notes 01/11/2011

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	1	700779	6" Separator, BIC, Bid Mueller, H17261 CLASS 300 WOP ZOP	ACTIVE	6"	300	Class 300	Class 300 Mueller, H17261	720	Per Manufacturer Literature
	1	Not Noted	6" Coupling, Insulator Kenestek WOP ZOP SIG	ACTIVE	6"		Coupling Insuloid Kenestek	720	720	

THE LOWEST PRESSURE RATING: 720

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

720-YA-B
 HP PIPE GEOMETRY

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	9705121	Final HP Main - 10" in piping at Park & 69th	9705121	8/17/2011	R. Nakrop	7/26/2011	S. Karp	7/26/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SNYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SNYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
963.5	
1420.0	
720.0	
N/A	
150.0	
6.3%	
250.0	
10.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SNYS at Current System MAOP	Design Pressure	% SNYS at Proposed System MAOP	Comments
	52	700521	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	8.29%	953	10.49%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
	48	60076	6" X 90 Degree Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			V-42	X 90 Degree Elbow, Weld	1420	4.23%	7.04%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	48	760076	6" Stopper, BIO Mueller, H-17261 CLASS 300 WOP 720PSIG ACTIVE	ACTIVE	6"	CLASS 300	Stopper, BIO	Mueller, H-17261	720	

THE LOWEST DESIGN PRESSURE: 953

THE LOWEST PRESSURE RATING: 720

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 020-2-1
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	EX884-004	Install 6" IP Gas Main	EX884-008	11/21/1994	R Nakano	6/30/2011	C Koo	6/30/2011
2	8708121	Install 6" HP	9399077	4/21/1994	C Koo	6/30/2011	C Koo	6/30/2011
3	8399077	Install 2" Main		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
4	N/A	Install HPS-0034		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
5	N/A	Install HPS-0035		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
6	N/A	Install HPS-0036		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
7	N/A	Install HPS-0037		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
8	N/A	Install HPS-0038		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
9	N/A	Install HPS-0039		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
10	N/A	Install HPS-0040		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
11	N/A	Install HPS-0041		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
12	N/A	Install HPS-0042		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
13	N/A	Install HPS-0043		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
14	N/A	Install HPS-0044		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
15	N/A	Install HPS-0045		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
16	N/A	Install HPS-0046		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
17	N/A	Install HPS-0047		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
18	N/A	Install HPS-0048		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
19	N/A	Install HPS-0049		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
20	N/A	Install HPS-0050		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
21	N/A	Install HPS-0051		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
22	N/A	Install HPS-0052		7/15/2011	C Koo	7/15/2011	C Koo	7/15/2011
23	87294782	Plumb and install fittings		4/16/2012	D Filosa	6/6/2012	D Filosa	6/6/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Location)
1183.4		
1183.4		
230.8		
300.5		
150.3		
31.9		
250		
8.5%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	DESCRIPTION	STATUS	OD	TH	GR	DESIGN PRESSURE	% SMYS AT SYSTEM MAOP	DESIGN PRESSURE	% SMYS AT PROPOSED SYSTEM MAOP	COMMENTS
1	1	6" WALL G.B	ACTIVE	6"	0.28	G-B	1183	5.0%	1183	8.45%	High Spec.
2	2	6" WALL X 0.28 WALL G.B	ACTIVE	6"	0.28	X-B	1038	3.10%	1038	5.16%	
3	3	6" WALL X 0.28 WALL G.B	ACTIVE	6"	0.28	G-B	1183	5.0%	1183	8.45%	High Spec.
4	4	2" PIPE X 0.154 WALL G.B	ACTIVE	2"	0.154	G-B	1816	3.35%	1816	5.51%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	DESCRIPTION	STATUS	OD 1	TH 1	OD 2	TH 2	GR	FILLING TYPE	DESIGN PRESSURE	% SMYS AT SYSTEM MAOP	DESIGN PRESSURE	% SMYS AT PROPOSED SYSTEM MAOP	COMMENTS
1	1	6" Stopper BO Mueller H17261 WOP 720PSIG	ACTIVE	6"	0.28	6"	0.28	WPS	Y-45 Elbow	1183	5.07%	1183	8.45%	High Spec.
2	2	2" Save-A-Valve Mueller H17491 WOP 1440PSIG	ACTIVE	2"	0.28	2"	0.28	Y-42	Void Cap	1440	4.23%	1440	7.04%	
3	3	2" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	2"	0.28	2"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
4	4	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
5	5	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
6	6	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
7	7	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
8	8	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
9	9	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
10	10	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
11	11	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"	0.28	1-1/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
12	12	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"	0.28	1-1/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
13	13	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
14	14	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
15	15	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
16	16	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
17	17	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
18	18	1-1/4" Service Tee Mueller H17501 WOP 250PSIG	ACTIVE	1-1/4"	0.28	1-1/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
19	19	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
20	20	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
21	21	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
22	22	1-1/4" Service Tee Mueller H17501 WOP 250PSIG	ACTIVE	1-1/4"	0.28	1-1/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
23	23	4" Service Tee Mueller H17491 WOP 1440PSIG	ACTIVE	4"	0.28	4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.
24	24	3/4" Service Tee Mueller H17491 WOP 1440PSIG	ACTIVE	3/4"	0.28	3/4"	0.28	WPS	Y-42	1183	5.07%	1183	8.45%	High Spec.

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	DESCRIPTION	STATUS	SIZE	CLASS RATING	FILLING TYPE	MANUFACTURER AND MODEL NUMBER	RATED PRESSURE	COMMENTS
2	48	6" Stopper BO Mueller H17261 WOP 720PSIG	ACTIVE	6"		Stopper BO	Mueller H17261	720	Branch to 020-Z-1B, 020-Z-1C, 020-Z-1D and 020-Z-1G
2	Not Noted	2" Save-A-Valve Mueller H17491 WOP 1440PSIG	ACTIVE	2"		Save-A-Valve	Mueller H17491	1440	Branch Fitting, Rated HPS-0001, HPS-0012, HPS-0014, HPS-0015, HPS-0024, HPS-0025, HPS-0042, HPS-0043
3	Not Noted	2" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	2"		Service Tee	Mueller H17501	1440	Branch to 020-AT-1 1440" Interim Store Ticket
4	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0034
5	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0035
6	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0036
7	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0037
8	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0038
9	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0039
10	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0040
11	N/A	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17501	1440	Branch to HPS-0041
12	N/A	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17501	1440	Branch to HPS-0042
13	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0043
14	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0044
15	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0045
16	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0046
17	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0047
18	N/A	1-1/4" Service Tee Mueller H17501 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17501	250	Branch to HPS-0048
19	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0049
20	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0050
21	N/A	3/4" Service Tee Mueller H18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H18101	1200	Branch to HPS-0051
22	N/A	1-1/4" Service Tee Mueller H17501 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17501	250	Branch to HPS-0052
23	N/A	4" Service Tee Mueller H17491 WOP 1440PSIG	ACTIVE	4"	CLASS 300	Save-A-Valve	Mueller H17491	1440	
24	N/A	3/4" Service Tee Mueller H17491 WOP 1440PSIG	ACTIVE	3/4"	CLASS 300	Save-A-Valve	Mueller H17491	1440	

THE LOWEST PRESSURE RATING: 250

THE LOWEST DESIGN PRESSURE: 1183

5%

8%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions						
Job Key of the Header Pipe	1	1	1	1	1	1
Header OD (inch)	6.625	6.625	6.625	6.625	6.625	6.625
Header Wall Thickness (inch)	0.28	0.28	0.28	0.28	0.28	0.28
Header Yield Strength	35000	35000	35000	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1	1	1	1
Job Key of the Branch	2	3	4, 5, 6, 7, 8, 9, 10, 12, 13, 14, 15, 16, 17, 19, 21	11	18, 22	20
Branch Fitting Description	2" Save-A-Valve	2" Tee H-17501	3/4" Tee H-18101	1-1/4" Tee H-17501	1-1/4" Tee H-17500	3/4" Tee H-17500
Branch OD (inch)	2.219	2.410	1.180	1.810	1.810	1.180
Branch Wall Thickness (inch)	0.2343	0.27	0.18	0.22	0.22	0.18
Branch Yield Strength (psi)	36000	36000	36000	36000	36000	36000
Branch Longitudinal Joint Factor	1	1	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1	1	1
Tap Size (Maximum) (inch)	1.7501	1.87	0.82	1.37	1.37	0.82
Tap Size (inch)	1.7501	1.87	0.82	1.37	1.37	0.82
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement						
Max 'Usable' Length (OD) of additional Reinforcement	3.5002	3.74	1.64	2.74	2.74	1.64
OD of Additional Reinforcement (inch)	0	0	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0	0	0	0
Effective A3 Provided by Weldments						
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0	0	0	0
Conclusion and Calculation Summary						
Design Pressure (psig)	900.4683469	952.6200649	1067.75373	959.1105887	959.1105887	1067.75373
L (inch)	0.58575	0.675	0.45	0.55	0.55	0.45
d - OD/2 (Max Reinforcement Width)	0.64075	0.665	0.23	0.465	0.465	0.23
t (inch)	0.213057243	0.225396712	0.252638159	0.226932416	0.226932416	0.252638159
tb (inch)	0.069370456	0.079715776	0.043748243	0.060277436	0.060277436	0.043748243
Ar (sq in)	0.372871481	0.421491851	0.207163291	0.31089741	0.31089741	0.207163291
A1 (sq in)	0.117156519	0.102108149	0.022436709	0.07270259	0.07270259	0.022436709
A2 (sq in)	0.193214961	0.256883702	0.122626581	0.17569482	0.17569482	0.122626581
A2' (sq in)	0.193214961	0.256883702	0.122626581	0.17569482	0.17569482	0.122626581
A3 (Fitting Weld Material)	0.0625	0.0625	0.0621	0.0625	0.0625	0.0621
A3 Reinforcement (sq in)	0	0	0	0	0	0
A3 Weldment (sq in)	0	0	0	0	0	0
A3 (sq in)	0.0625	0.0625	0.0621	0.0625	0.0625	0.0621
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active	Active	Active
Design Pressure Evaluation	900.4683469	952.6200649	1067.75373	959.1105887	959.1105887	1067.75373

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 029_Z-L-A
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	87E-464	Initial HP gas main	Main Card	7/22/1987	R Nakano	7/25/2011	C Koo	7/25/2011
2	87G5121	Relieve portion of HP gas main	9705121	5/17/1998	R Nakano	7/25/2011	C Koo	7/25/2011
3	87J26782	Initial save-a-valves	9705121	4/16/2002	D Friesz	4/28/2012	D Friesz	4/28/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

275
0.4 (Class 4 Location)
784.6
795.0
275.0
535.2
160.0
7.6%
269.0
12.9%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	6" PIPE X 0.188 WALL Gr.B	ACTIVE	6"	0.188	Gr.B	785	7.65%	12.99%	Historic pipe specs

THE LOWEST DESIGN PRESSURE: 785

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	6" X90 Degree, Elbow, Weld X 0.188 WALL WFB	ACTIVE	6"	0.188			Gr	WFB	785	7.65%	7.65%	
2	61	5600730	6" Cmp. Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	Cap. Weld	1420	4.23%	7.05%	

THE LOWEST DESIGN PRESSURE: 785

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	6" Stopper B/O	ACTIVE	6"		Stopper B/O	Muller, H-17260	275	
2	Not Noted	Not Noted	2" Save-a-valve Muller, H-17481	ACTIVE	2"		Save-a-valve	Muller, H-17481	140	
3	Not Noted	Not Noted	4" Save-a-valve Muller, H-17489	ACTIVE	4"		Save-a-valve	Muller, H-17489	720	

THE LOWEST PRESSURE RATING: 275

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188
Header Yield Strength	35,000	35,000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	3	3
Branch Fitting Description	2" Save-a-valve	4" Save-a-valve
Branch OD (inch)	2.218	4.625
Branch Wall Thickness (inch)	0.234	0.299
Branch Yield Strength (psi)	36000	36000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	4.027
Tap Size (inch)	1.75	4.027
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0.25
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	8.054
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	679.0091506	535.1755322
% SMYS at the Current System MAOP	0.088364052	0.112112749
% SMYS at the Proposed System MAOP	0.14727342	0.186854581
L (inch)	0.47	0.47
d – OD/2 (Max Reinforcement Width)	0.641	1.7145
t (inch)	0.160658415	0.126626354
tb (inch)	0.052293135	0.085943987
Ar (sq in)	0.281152226	0.509924326
A1 (sq in)	0.047847774	0.247151674
A2 (sq in)	0.170804453	0.200272652
A2' (sq in)	0.170804453	0.200272652
A3 (Fitting Weld Material)	0.0625	0.0625
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	679.0091506	535.1755322

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Descriptions of the Facility

Job No.	720
Facility ID	04
Facility Type	PIPE RESUMPT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Date
	9708231	04-11-2011-04-11-2011	9708231	11/21/1999	R. M. M. M.	5/19/2011	C. K. O.	5/19/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
953.5	
1420.0	
720.0	
N/A	
150.0	
5.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	700621	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	953	0.28%	10.46%	X-42 and 0.28" wall fittings were called for this job, but the fittings are not to be used on this job. Build at this location.

Table 2 - Non-Rated Fittings Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	600752	6" X10 Degree, Elbow, Weld X 0.28 WALL X-42	ACTIVE	6"	0.28			Gr	X10 Degree Elbow, Weld X-42	1420	4.23%	7.04%	7/42 and 0.28" wall fittings were called for this job, but the fittings are not to be used on this job. Build at this location.

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	Not Noted	Not Noted	6" Stopper, B/O Mueller, H-17281 300 WOP 720PSIG	ACTIVE	6"	300 Stopper, B/O	300 Stopper, B/O	Mueller, H-17281	720	Part # is not noted on the location in the AA bill. H-17281 is based on which was checked to the Field Work Order Form.

THE LOWEST DESIGN PRESSURE: 953

1420

4%

7%

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	720
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	970614	Initial HP gas main	970614	5/17/1998	R Makano	5/19/2011	C Ksp	5/19/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	0.4 (Class 4 Location)
963.5	
1420.0	
720.0	
N/A	
150.0	
6.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
	Not Noted	700052	8" PIPE X 0.186 WALL X-42	ACTIVE	8"	0.186	X-42	6.23%	963	10.49%	Grade and Elevation information not available from the Field Work Order. Please refer to the Field Work Order.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	6000793	8" X90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	8"	0.28	8"	0.28	Y-42	90 Degree Elbow, Weld X 0.28 WALL Y-42	1420	4.23%	7.04%	Y-42 and 0.28" wall 90 degree elbow. The design pressure is based on the MAOP of 1420. The design pressure is not noted on the A-1000 drawing as it is not built at this location.

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	Not Noted	760073	8" Stopper, B/O Mueller, H-177281 300 WCP 720P8IG	ACTIVE	8"	800	Stopper, B/O	Mueller, H-177281	720	Part # not noted on the A-1000 drawing. Design pressure is based on the MAOP of 1420. Materials List attached to the Field Work Order.

THE LOWEST DESIGN PRESSURE: 963

6%

10%

4%

7%

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	050-741-E
Facility Type	PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	0705721	Install LP gas main	9/27/09	R. Nikken	5/18/2011	S. Kopp	7/1/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
953.5	
1420.0	
720.0	
N/A	
150.0	
6.3%	
200.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
	Not Noted	7000921	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	6.26%	853	10.48%	Pipe Grade is 10.48% which matches the notational area.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	8000763	6" X90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	X90 Degree, Elbow, Weld	1420	4.23%	7.04%	Y42 and 0.28" thicknss ELLs were called for the number was not listed on the As-Built at this location
	Not Noted	Not Noted	6" X46 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	X46 Degree, Elbow, Weld	1420	4.23%	7.04%	Y42 and 0.28" thicknss ELLs were called for the number was not listed on the As-Built at this location

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	7007947	6" Stopper, BJO Mueller H-7281 300 WCP 720PSIG	ACTIVE	6"	300	Stopper, BJO	Mueller H-7281	720	Part # not listed on the DWG, H-7281 is based on the Material List in the Field Work Order.

THE LOWEST DESIGN PRESSURE: 1420

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: MANHATTAN 2-1-F
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
	970623	UPHILL HP MAIN	970623	7/27/1998	R. Urbano	7/29/2011	O. Koss	5/19/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
953.6	
1420.0	
720.0	
N/A	
160.0	
6.3%	
260.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Or	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	67	7000521	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	953	6.29%	10.49%	Comments: This is a Y42 pipe. The MAOP specification which matches with the historical specification.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Or	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	49	6000762	6" X 90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	OD 2	Th 2	Or	Y-42 Degree, Elbow, Weld	1420	4.23%	7.04%	Comments: Y42 and 0.28" wall. This was called for this job, but the item # was not listed at this location.

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	46	6000367	6" Stopper, BIC Mueller, H-17261 CLASS 300 WOP 720PSIG	ACTIVE	6"	CLASS 300	Stopper 60	Mueller H-17261	720	Comments: Item # is for stock on link location on the AS-built. The H-17261 is based on the Material List which was attached to the Work Order Sheet Form.

THE LOWEST DESIGN PRESSURE: 1420 4% 7%

THE LOWEST PRESSURE RATING: 720

070.251G
 HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	070.251G
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
	970813	Initial H&E, 44" main	6706131	12/1/89	R. Makino	6/18/2011	C. Koo	6/18/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

720	(Class 4 Location)
0.4	
953.5	
1420.0	
720.0	
N/A	
150.0	
6.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	7000221	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	953	6.29%	10.46%	Pipe Grade is 10.46% which matches with the historical specification

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	6000752	6" X90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	Y-42	1420	4.23%	7.04%	Y-42 and 0.28" wall 90 deg. elbow, but the item # was not noted on the ASME build at this location
	Not Noted	Not Noted	6" X45 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	Y-42	1420	4.23%	7.04%	Y-42 and 0.28" wall 45 deg. elbow, but the item # was not noted on the ASME build at this location

THE LOWEST DESIGN PRESSURE: 953

6%

10%

7%

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	Not Noted	7600779	6" Stopper, BIO Mueller, H-17261 300 WOP 720PSIG	ACTIVE	6"	300	Stopper, BIO	Mueller, H-17261	720	Part # is not noted on this location on the ASME build as this Material List which was attached to the Field Work Order Form

THE LOWEST PRESSURE RATING: 720

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

020-AA-1
HF PIPE SEGMENT

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID
Facility Type

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	695-515	Install IP Main	695-515	7/15/1999	R Nakano	5/2/2011	C Koo	7/1/2011
2	795-373	Relocate portion of main & update to HF	795-373	9/9/1979	R Nakano	5/2/2001	C Koo	7/1/2011
3	795-371	Relocate portion of main & update to HF	D-4	9/4/1982	C Koo	7/1/2011	C Koo	7/1/2011
4	N/A	Service Installation HPS-0046	795-373	6/13/2012	D Fizez	6/13/2012	D Fizez	6/13/2012
5	100088555	Bottom-out Relocation						

Facility Evaluation Summary

Facility Design Pressure
Design Factor
Pipe Design Pressure
Non-Rated Fitting Design Pressure
Rated Fitting Rated Pressure
Branch Connection Design Pressure
Current System MAOP
The Highest % SMYS of the Facility at the Current System MAOP
Proposed system MAOP
The Highest % SMYS of the Facility at the Proposed System MAOP

275
0.4 (Class 4 Location)

794.6
1420.0
275.0
584.2
150.0
7.5%
250.0
12.5%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	4	70520	6" PIPE X 0.188 WALL Gr.B	ACTIVE	6"	0.188	Gr	795	7.55%	12.55%	Hydro-Tested

Select Data from the drop down manual

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
3	N/A	6" Weld Cap X 0.28 WALL Y-42	ACTIVE	6"	0.28	Y-42		Gr	Weld Cap	1420	4.23%	7.04%	
3	25	6" Weld Cap X 0.28 WALL Y-42	ACTIVE	6"	0.28	Y-42		Gr	Weld Cap	1420	4.23%	7.04%	
3	19	3/4" X 1/4" 304 Stainless 0.1875 X 0.11653 WALL Gr.B	ACTIVE	3/4"	0.184	TH 3/4"	0.11653	Gr.B	Nipple	3956	1.77%	2.87%	

Select Data from the drop down manual

THE LOWEST DESIGN PRESSURE: 795 8% 13%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	6	6" Short Stop or Line Stopper CLASS 150 WOP N/APSIG	RETIRED	6"	CLASS 150	Short Stop or Line Stopper		N/A	Retired on 8/05/12
2	2	6" Bottom Out Stopper-suelter, H-17280 TM WOP 275PSIG	ACTIVE	6"		Bottom Out Stopper	Suelter, H-17280 TM	275 1A	Branch to 020-AA-1A
2	7	6" Weld Plug WOP N/APSIG	RETIRED	6"		Weld Plug			Rated only for 125 psig. Field Confirmation is required. If the fitting will be retired 867025764
3	N/A	6" Bottom-Out Mueller H-17281 WOP 720PSIG	ACTIVE	6"		Bottom-Out	Mueller H-17281	720	Branch to 020-Z-1G
4	N/A	1-1/4" Service Tee Mueller H17501 WOP 1440PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17501	1440	Branch to HPS-0046 Mode number is based on Standards research
5	11	3/4" Auto-jet Tee Mueller H-18102 WOP 1200PSIG	ACTIVE	3/4"		Auto-jet Tee	Mueller H-18102	1200	
5	14	3/4" Socket Cap CLASS 3000 WOP 3000PSIG	ACTIVE	3/4"	CLASS 3000	Socket Cap		3000	
5	15	3" Save-a-valve Mueller H-17491 WOP 1440PSIG	ACTIVE	3"		Save-a-valve	Mueller H-17491	1440	

Select Data from the drop down manual

THE LOWEST PRESSURE RATING: 275

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions			
Job Key of the Header Pipe	1	1	1
Header OD (inch)	6.625	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188	0.188
Header Yield Strength	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1
Job Key of the Branch	4	5	5
Branch Fitting Description	1-1/4" Service Tee H-17501	3" Save-a- valve	3/4" Nipple
Branch OD (inch)	1.810	3.500	1.050
Branch Wall Thickness (inch)	0.22	0.281	0.154
Branch Yield Strength (psi)	36000	36000	35000
Branch Longitudinal Joint Factor	1	1	1
Temperature Derating Factor (from Header)	1	1	1
Tap Size (Maximum) (inch)	1.37	2.938	0.742
Tap Size (inch)	1.37	2.938	0.742
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement			
Max 'Usable' Length (OD) of additional Reinforcement	2.74	5.876	1.484
OD of Additional Reinforcement (inch)	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0
Effective A3 Provided by Weldments			
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0
Conclusion and Calculation Summary			
Design Pressure (psig)	744.8048143	584.2212	840.7553
L (inch)	0.47	0.47	0.385
d – OD/2 (Max Reinforcement Width)	0.465	1.188	0.217
t (inch)	0.176226139	0.138231	0.198929
tb (inch)	0.046808914	0.070999	0.031528
Ar (sq in)	0.241429811	0.406122	0.147605
A1 (sq in)	0.016130189	0.146222	0
A2 (sq in)	0.162799621	0.197401	0.094303
A2' (sq in)	0.162799621	0.197401	0.094303
A3 (Fitting Weld Material)	0.0625	0.0625	0.061411
A3 Reinforcement (sq in)	0	0	0
A3 Weldment (sq in)	0	0	0
A3 (sq in)	0.0625	0.0625	0.061411
Status (Branch Status from Calculation Worksheet)	Active	Active	Active
Design Pressure Evaluation	744.8048143	584.2212	840.7553

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	Main ID 020-AA-LA
Facility Type	HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	795-373	Install IP main	795-373	6/9/1979	R Nakano	5/3/2011	C Koo	5/25/2011
2	9705121	Upgrade to HP	9705121	11/21/1999	R Nakano	5/3/2011	C Koo	5/25/2011
3	D-4	Install Service HPS-0016	D-4	7/19/1995	C Koo	7/1/2011	C Koo	7/1/2011
4	D-4	Install Service HPS-0017	D-4	6/28/1999	C Koo	7/1/2011	C Koo	7/1/2011
5	10908555	Bottomsout/Relocation	795-373	199	D Fitea	6/13/2012	D Fitea	6/13/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Location)
784.6		
1420.0		
250.0		
584.2		
150.0		
7.6%		
290.0		
12.6%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Proposed System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	700920	6" PIPE X 0.188 WALL Gr.B	ACTIVE	6"	0.188	Gr.B	795	7.55%	12.65%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	3	600752	6" X 90 Degree Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	X 90 Degree, Elbow, Weld	1420	4.23%	7.04%	
2	25	590730	6" MSH Gr.B X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	Weld Cap	1420	4.23%	7.04%	
3	15	PC	3/4" X 1/4" 3/4" NIBBS 9.154 X 0.11653 WALL Gr.B	ACTIVE	3/4"	0.154	TH 3/4"	0.11653	Gr.B	Nibbs	3348	1.76%	2.85%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	2	76786	6" Stopper, B/C, T/W Mueller, H-17280 CLASS 150 WOP 275PSIG	ACTIVE	6"	CLASS 150	Stopper, B/C, T/W	Mueller, H-17280	275	Confirmed
3	N/A	N/A	3/4" Service Tee Mueller H-18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H-18101	1200	86705942
4	N/A	N/A	1-1/4" Service Tee Mueller H17500 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H17500	250	Branch to HPS-
5	11	760930	3/4" Auto-seal Tee Mueller H-18102 WOP 1300PSIG	ACTIVE	3/4"		Auto-seal Tee	Mueller H-18102	1300	0017
6	14	990730	3/4" Socket Cap CLASS 3000 WOP 3000PSIG	ACTIVE	3/4"	CLASS 3000	Socket Cap		3000	
5	15	680041	3" Save-a-valve Mueller H-17481 WOP 1440PSIG	ACTIVE	3"		Save-a-valve	Mueller H-17481	1440	

THE LOWEST PRESSURE RATING: 250

THE LOWEST DESIGN PRESSURE: 795

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions				
Job Key of the Header Pipe	1	1	1	1
Header OD (inch)	6.625	6.625	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188	0.188	0.188
Header Yield Strength	35000	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1	1
Job Key of the Branch	3	4	5	5
Branch Fitting Description	3/4" Service Tee H18101	1-1/4" Service Tee H17500	3" Save-a-valve	3/4" Nipple
Branch OD (inch)	1.180	1.810	3.500	1.050
Branch Wall Thickness (inch)	0.18	0.22	0.281	0.154
Branch Yield Strength (psi)	36000	36000	36000	35000
Branch Longitudinal Joint Factor	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1
Tap Size (Maximum) (inch)	0.82	1.37	2.938	0.742
Tap Size (inch)	0.82	1.37	2.938	0.742
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement				
Max 'Usable' Length (OD) of additional Reinforcement	1.64	2.74	5.876	1.484
OD of Additional Reinforcement (inch)	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0	0
Effective A3 Provided by Weldments				
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0	0
Conclusion and Calculation Summary				
Design Pressure (psig)	890.2105484	744.8048143	584.2212	840.7553
L (inch)	0.45	0.47	0.47	0.385
d - OD/2 (Max Reinforcement Width)	0.23	0.465	1.188	0.217
t (inch)	0.210630174	0.176226139	0.138231	0.198929
tb (inch)	0.036473904	0.046808914	0.070999	0.031528
Ar (sq in)	0.172716743	0.241429811	0.406122	0.147605
A1 (sq in)	0	0.016130189	0.146222	0
A2 (sq in)	0.129173486	0.162799621	0.197401	0.094303
A2' (sq in)	0.129173486	0.162799621	0.197401	0.094303
A3 (Fitting Weld Material)	0.0621	0.0625	0.0625	0.061411
A3 Reinforcement (sq in)	0	0	0	0
A3 Weldment (sq in)	0	0	0	0
A3 (sq in)	0.0621	0.0625	0.0625	0.061411
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active
Design Pressure Evaluation	890.2105484	744.8048143	584.2212	840.7553

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	Main ID: 020 AB-1
Facility Type	PIP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	745-221	Install 6" IP Gas Main	745-221	7/10/1974	Rev N	5/13/2011	C Koo	5/20/2011
2	970721	HFS-018 - Original Service Installation (Relief)	970721	6/30/1979	Rev N	5/13/2011	C Koo	5/20/2011
3	N/A	HFS-018 - Original Service Installation (Relief)	D-4	7/10/1974	C Koo	5/20/2011	C Koo	5/20/2011
4	N/A	HFS-018 - Original Service Installation (Relief)	D-4	7/10/1974	C Koo	5/20/2011	C Koo	5/20/2011
5	N/A	HFS-020 - Original Service Installation (Relief)	Main Card	6/27/1980	C Koo	5/20/2011	C Koo	5/20/2011
6	N/A	2" Service Tee to 2" Main (Relief)	615-178	12/31/1990	C Koo	5/20/2011	C Koo	5/20/2011
7	N/A	6" Relocation	785-373	6/9/1979	C Koo	7/1/2011	C Koo	7/1/2011
8	10000955	Bottom-out Rehabilitation	785-373	1BD	D Frieze	6/13/2012	D Frieze	6/13/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4 (Class 4 Location)
794.8	
1420.0	
250.0	
584.2	
150.0	
7.6%	
250.0	
12.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	4	70520	6" PIPE X 0.188 WALL Gr.B	ACTIVE	6"		Gr.B	795	7.55%	12.55%	Hestic pipe spec.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
5	25	5200730	6" Cap X 0.28 WALL Y-42	ACTIVE	6"	0.28			Gr	Y-42 Cap	1420	4.23%	7.04%	
5	13	PO	3/4" X 3/4" Nipple 0.154 X 0.11653 WALL Gr.B	ACTIVE	3/4"	0.154	TH 3/4"	0.11653	Gr.B	Nipple	3346	1.79%	2.89%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
3	N/A	N/A	1-1/4" Service Tee H17500 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	H17500	250	Branch of HFS-0020
4	N/A	N/A	1-1/4" Service Tee H17500 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	H17500	250	Branch of HFS-0019
5	N/A	N/A	1/2" Service Tee H17500 WOP 250PSIG	ACTIVE	1/2"		Service Tee	H17500	250	Branch of HFS-0019
6	N/A	N/A	2" Service Tee H17500 WOP 250PSIG	ACTIVE	2"		Service Tee	H17500	250	Branch of 020 AU-1
6	2	75786	6" Bottom Out Mueller H17280 WOP 276PSIG	ACTIVE	6"		Bottom Out	Mueller H17280	276	Branch to 020 AA-01A
1	N/A	N/A	3/4" Service Tee Mueller H-18101 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H-18101	1200	BIO Purge Filling Confirmed 687095761
8	11	7809000	3/4" Auto-vent Tee Mueller H-18102 WOP 1200PSIG	ACTIVE	3/4"		Auto-vent Tee	Mueller H-18102	1200	
9	14	6917199	3/4" Socket Cap CLASS 3000 WOP 3000PSIG	ACTIVE	3/4"	CLASS 3000	Socket Cap	Mueller H-17481	3000	
9	15	6800641	3" Service Valve Mueller H-17481 WOP 1440PSIG	ACTIVE	3"		Service Valve	Mueller H-17481	1440	

THE LOWEST PRESSURE RATING: 250

THE LOWEST DESIGN PRESSURE: 795

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions					
Job Key of the Header Pipe	1	1	1	1	1
Header OD (inch)	6.625	6.625	6.625	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188	0.188	0.188	0.188
Header Yield Strength	35000	35000	35000	35000	35000
Header Longitudinal Joint Factor	1	1	1	1	1
Job Key of the Branch	3,4,5	6,7	1	9	9
Branch Fitting Description	1-1/4" Service Tee H17500	2" Service Tee H17500	3/4" Service Tee H-18101	3" Save-a- valve	3/4" Nipple
Branch OD (inch)	1.810	2.375	1.180	3.500	1.050
Branch Wall Thickness (inch)	0.22	0.25	0.18	0.281	0.154
Branch Yield Strength (psi)	36000	36000	36000	36000	35000
Branch Longitudinal Joint Factor	1	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1	1
Tap Size (Maximum) (inch)	1.37	1.875	0.82	2.938	0.742
Tap Size (inch)	1.37	1.875	0.82	2.938	0.742
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement					
Max 'Usable' Length (OD) of additional Reinforcement	2.74	3.75	1.64	5.876	1.484
OD of Additional Reinforcement (inch)	0	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0	0	0
Effective A3 Provided by Weldments					
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0	0	0
Conclusion and Calculation Summary					
Design Pressure (psig)	744.8048143	673.7188468	890.2105484	584.2212	840.7553
L (inch)	0.47	0.47	0.45	0.47	0.385
d – OD/2 (Max Reinforcement Width)	0.465	0.6875	0.23	1.188	0.217
t (inch)	0.176226139	0.159406691	0.210630174	0.138231	0.198929
tb (inch)	0.046808914	0.055558412	0.036473904	0.070999	0.031528
Ar (sq in)	0.241429811	0.298887546	0.172716743	0.406122	0.147605
A1 (sq in)	0.016130189	0.053612454	0	0.146222	0
A2 (sq in)	0.162799621	0.182775093	0.129173486	0.197401	0.094303
A2' (sq in)	0.162799621	0.182775093	0.129173486	0.197401	0.094303
A3 (Fitting Weld Material)	0.0625	0.0625	0.0621	0.0625	0.061411
A3 Reinforcement (sq in)	0	0	0	0	0
A3 Weldment (sq in)	0	0	0	0	0
A3 (sq in)	0.0625	0.0625	0.0621	0.0625	0.061411
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active	Active
Design Pressure Evaluation	744.8048143	673.7188468	890.2105484	584.2212	840.7553

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	020-AC-1
Facility Type	HP PIPE REQUIREMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	808-3048	Final P. 10.000	808-3048	09/27/89	R. Nakano	5/19/2011	S. Koo	7/15/21
2	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
3	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
4	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
5	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
6	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
7	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
8	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
9	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21
10	7141	Final P. 10.000	7141	07/17/89	R. Nakano	5/19/2011	S. Koo	7/15/21

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SNIYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SNIYS of the Facility at the Proposed System MAOP

250	(Class 4 Location)
353.3	
1420.0	
290.0	
771.3	
690.0	
6.3%	
290.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SNIYS at Current System MAOP	% SNIYS at Proposed System MAOP	Comments
1	1	7000921	6" PIPE X 0.188 WALL X 42	ACTIVE	6"	0.188	X-42	953	6.29%	10.49%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SNIYS at Current System MAOP	% SNIYS at Proposed System MAOP	Comments
1	3	600782	6" X 45 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	0.28		Y-42	1420	4.23%	7.04%	
1	4	620730	6" Cap, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	1420	4.23%	7.04%	
1	11	600742	6" X 45 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28	0.28		Y-42	1420	4.23%	7.04%	
1	15	700432	6" X 6" Tee, Weld 0.28 X 0.28 WALL Y-42	ACTIVE	6"	0.28	0.28		Y-42	1420	4.23%	7.04%	
1	16	700419	6" X 6" Tee, Weld, Reducing 0.28 X 0.287 WALL Y-42	ACTIVE	6"	0.28	0.287		Y-42	1420	4.23%	7.04%	
2	51	600730	6" Cap, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	1420	4.23%	7.04%	
1	Not Noted	Not Noted	2" Transition Fitting, Steel Portion X 0.164 WALL W/PB	ACTIVE	2"	0.164			W/PB	1818	3.30%	6.61%	See Min ID 020-AC-1A
3	41	620076	2" Cap, Weld X 0.164 WALL W/PB	ACTIVE	2"	0.164			W/PB	1818	3.30%	6.61%	

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	2" Tee, Service Mueller, H-17600 WOP 260PSIG	ACTIVE	2"		Tee, Service	Mueller, H17600	260	Retired to H-17600
1	Not Noted	Not Noted	2" Tee, Service Mueller, H17601 WOP 1440PSIG	ACTIVE	2"		Tee, Service	Mueller, H17601	1440	Retired to H-17601
2	Not Noted	600841	2" Service Valve Mueller H17491 WOP 1440PSIG	ACTIVE	2"		Service Valve	Mueller H17491	1440	Retired to H-17491
2	48	700779	6" Bottom Out Mueller 17261 WOP 720PSIG	ACTIVE	6"		Bottom Out	Mueller 17261	720	Branch to 020-AC-1A and 020-AC-1B
3	Not Noted	Not Noted	1-1/4" Tee, Service Mueller, H17601 WOP 1440PSIG	ACTIVE	1-1/4"		Tee, Service	Mueller, H17601	1440	Branch to FPS

THE LOWEST PRESSURE RATING: 250

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions				
Job Key of the Header Pipe	1	1	1	1
Header OD (inch)	6.625	6.625	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188	0.188	0.188
Header Yield Strength	42000	42000	42000	42000
Header Longitudinal Joint Factor	1	1	1	1
Job Key of the Branch	1	1	2	3
Branch Fitting Description	2" Tee H-17500	2" Tee H-17501	2" Save-A-Valve	1-1/4" Tee H-17501
Branch OD (inch)	2.410	2.410	2.249	1.810
Branch Wall Thickness (inch)	0.27	0.27	0.2343	0.22
Branch Yield Strength (psi)	36000	36000	36000	36000
Branch Longitudinal Joint Factor	1	1	1	1
Temperature Derating Factor (from Header)	1	1	1	1
Tap Size (Maximum) (inch)	1.87	1.87	1.7501	1.37
Tap Size (inch)	1.87	1.87	1.7501	1.37
Recommended Fitting Weld Leg (in)	0.25	0.25	0.25	0.25
Fitting Weld Length (in)	0.25	0.25	0.25	0.25
Effective A3 Provided by Additional Reinforcement				
Max 'Usable' Length (OD) of additional Reinforcement	3.74	3.74	3.5002	2.74
OD of Additional Reinforcement (inch)	0	0	0	0
Thickness of Additional Reinforcement M (inch)	0	0	0	0
Yield Strength of Additional Reinforcement (psi)	0	0	0	0
Effective A3 Provided by Weldments				
Max Header Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0	0	0
Conclusion and Calculation Summary				
Design Pressure (psig)	784.7477896	784.7477896	771.452496	841.6409874
L (inch)	0.47	0.47	0.47	0.47
d - OD/2 (Max Reinforcement Width)	0.665	0.665	0.64075	0.465
t (inch)	0.154730777	0.154730777	0.152109309	0.165948558
tb (inch)	0.065668131	0.065668131	0.059431307	0.052894798
Ar (sq in)	0.289346553	0.289346553	0.266206502	0.227349524
A1 (sq in)	0.062213447	0.062213447	0.062812298	0.030210476
A2 (sq in)	0.192071957	0.192071957	0.164376571	0.15707889
A2' (sq in)	0.164633106	0.164633106	0.140894204	0.134639048
A3 (Fitting Weld Material)	0.0625	0.0625	0.0625	0.0625
A3 Reinforcement (sq in)	0	0	0	0
A3 Weldment (sq in)	0	0	0	0
A3 (sq in)	0.0625	0.0625	0.0625	0.0625
Status (Branch Status from Calculation Worksheet)	Active	Active	Active	Active
Design Pressure Evaluation	784.7477896	784.7477896	771.452496	841.6409874

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT0142011)

Descriptions of the Facility

Facility ID: 021AC1A
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Reviewed By	Review Completion Date	Reviewed By	Review Completion Date
1	9705121	Initial HP P&ID	8/15/121	8/15/121	R. Niams	8/16/2011	R. Niams	8/16/2011

Facility Evaluation Summary

Facility Design Pressure
 Design Factor
 Pipe Design Pressure
 Non-Rated Fitting Design Pressure
 Rated Fitting Rated Pressure
 Branch Connection Design Pressure
 Current System MAOP
 The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

720	0.4 (Class 4 Location)
953.5	
1420.0	
720.0	
N/A	
150.0	
5.3%	
260.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS of Current System MAOP	% SMYS of Proposed System MAOP	Comments
1	52	700621	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	953	6.23%	10.43%	FEE Cont'd

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS of Current System MAOP	% SMYS of Proposed System MAOP	Comments
1	49	600762	6" X90 Degree, Elbow, Weld X 0.28 WALL Y-42	ACTIVE	6"	0.28			Y-42	X90 Degree, Elbow, Weld	1420	4.23%	7.04%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	48	760779	6" Stopper, B/O Nuts, H-17251	ACTIVE	6"	CLASS 300	Stopper, B/O	Nuts, H-17251	720	
1	50	616662	6" Valve, Plug Nordstrom, Fig. 2046-1/4 CLASS 300 WOP 7402816	ACTIVE	6"	CLASS 300	Valve, Plug	Nordstrom, Fig. 2046-1/4	740	

THE LOWEST DESIGN PRESSURE: 720

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01/14/2011)

Descriptions of the Facility
 Facility ID
 Facility Type

Main ID: 000-AC-1-B
 HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	706181	Install G. HP. 800 in.	706181	7/20/2009	R. Nakano	7/22/2011	G. Kao	7/22/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	(Class 4 Location)
720	
0.4	
953.5	
1420.0	
720.0	
N/A	
150.0	
6.3%	
250.0	
10.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	02	706092	6" PIPE X 0.188 WALL X 42	6"	0.188	X-42	953	6.28%	10.49%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	46	600762	6" X 60 Degree Weld Elbow X 0.28 WALL Y-42	6"	0.28			Y-42	X-80 Degree Weld Elbow	1420	4.23%	7.04%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	48	760079	6" Stopper, BIO Mueller, H-17261 CLASS 300 WOP	6"	CLASS 300	Stopper, BIO Mueller	H-17261	720	

THE LOWEST DESIGN PRESSURE: 953

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

THE LOWEST PRESSURE RATING: 720

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT0142011)

Descriptions of the Facility

Facility ID: 020AS-1
 Facility Type: HP PIPE SEGMENT

Job No.	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	9705141	Install 2" IP Gas main	616.478	1/21/99	B. N. Nims	8/26/01	C. Koo	9/26/01
2	9705141	Relief 2" IP Gas Main	9705141	6/11/87	B. N. Nims	8/26/01	C. Koo	8/26/01
3	9705141	Upgrade to HP	N/A	1/21/99	C. Koo	8/26/01	C. Koo	8/26/01

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Relief Filling Design Pressure
- Relief Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4 (Class 4 Location)
N/A	
1818.0	
1450.0	
N/A	
160.0	
3.3%	
250.0	
5.5%	

Table 1 - Pipe Design Pressure

Job No.	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Design Pressure	Comments
					Select Data from the drop down manual						

Table 2 - Non-Relief Filling Design Pressure

Job No.	ITEM #	MID	Description	Status	OD 1	Th 1	Gr	OD 2	Th 2	Gr	Filling Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
					Select Data from the drop down manual										
1	6	780080	2" Transition Filling, HOPE to 8T X 0.164 WALL GRB	ACTIVE	2"	0.164	GRB				Transition Filling, HOPE to 8T	1818	3.30%	6.67%	Only about section of the 8T portion of the transition filling
2	41	820075	2" Cap. Wall X 0.164 WALL WFB	ACTIVE	2"	0.164	WFB				Cap. Wall	1818	3.30%	6.67%	

Table 3 - Relief Filling Rated Pressure

Job No.	ITEM #	MID	Description	Status	Size	Class Rating	Filling Type	Manufacturer and Model Number	Rated Pressure	Comments
					Select Data from the drop down manual					
1	19	780071	2" Service Line Valve, H-57601 WOP-1406910	ACTIVE	2"			H-57601	1400	

THE LOWEST DESIGN PRESSURE: 1818 3% 6%

THE LOWEST PRESSURE RATING: 1440

022A14
HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID: _____
 Facility Type: _____

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	990977	1st Main 2" IP Gas Main	990977	4/21/1993	R. Nakano	5/20/2011	C. Kiser	5/20/2011
2	970521	Relief 2" IP Gas Main A. 15" into 10" IP	970521	5/11/1997	R. Nakano	5/20/2011	C. Kiser	5/20/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SNYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SNYS of the Facility at the Proposed System MAOP

1440	0.4	(Class 4 Location)
N/A	N/A	
1816.0		
1440.0		
N/A		
160.0		
3.3%		
250.0		
5.5%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
1	0	7600800	2" Transition Fitting, HDPE to ST X 0.164 WALL Gr.B	ACTIVE	2"	0.164	2"		Gr.B	Transition Fitting, HDPE to ST	1816	3.30%	5.61%	Only short section of the ST portion of the transition fitting.
2	11	6200676	2" Cap, W/0.164 WALL WPB	ACTIVE	2"	0.164			WPB	Cap, W/0.164 WALL	1816	3.30%	5.51%	

THE LOWEST DESIGN PRESSURE: 1816 3% 0%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 020-AY-1
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	109089555	Bottom-out Relocation	795-373	TBD	D Fizez	6/13/2012	D Fizez	6/13/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SNYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SNYS of the Facility at the Proposed System MAOP

740	0.4 (Class 4 Location)
-----	------------------------

1420.1	1758.0	740.0	1026.6	160.0	4.0%	260.0	7.0%
--------	--------	-------	--------	-------	------	-------	------

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Or	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
1	12	7008510	6" PIPE X 0.28 WALL X-42	ACTIVE	6"	0.28	X-42	1420.07	4.00%	7.00%	

THE LOWEST DESIGN PRESSURE: 1420.07 4.00% 7.00%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Or	Fitting Type	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
1	17	9986780	6" Elbow X 0.28 WALL Y-52	ACTIVE	6"	0.28			Y-52	Elbow	1758	3.41%	5.69%	

THE LOWEST DESIGN PRESSURE: 1758 3% 6%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	15	6909841	2" Save-A-Valve Mueller H-17481 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Save-A-Valve	Mueller H-17481	1440	Branch Fitting
1	16	760267	6" Bottom-Out Mueller H-17261 CLASS 300 WOP 740PSIG	ACTIVE	6"	CLASS 300	Bottom-Out	Mueller H-17261	740	740

THE LOWEST PRESSURE RATING: 740

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	
Header OD (inch)	6.625	
Header Wall Thickness (inch)	0.28	
Header Yield Strength	42000	
Header Longitudinal Joint Factor	1	
Job Key of the Branch	1	
Branch Fitting Description	2" Save-A-Valve	
Branch OD (inch)	2.219	
Branch Wall Thickness (inch)	0.234375	
Branch Yield Strength (psi)	36000	
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0
Tap Size (inch)	1.75	0
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	0
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1026.623596	
L (inch)	0.5859375	0
d - OD/2 (Max Reinforcement Width)	0.640625	0
t (inch)	0.202422063	#DIV/0!
tb (inch)	0.079091011	#DIV/0!
Ar (sq in)	0.354238611	#DIV/0!
A1 (sq in)	0.135761389	#DIV/0!
A2 (sq in)	0.181973425	#DIV/0!
A2' (sq in)	0.155977222	#DIV/0!
A3 (Fitting Weld Material)	0.0625	0
A3 Reinforcement (sq in)	0	#DIV/0!
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	#DIV/0!
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1026.623596	

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 0200AW41
 Facility Type: HP PIPE SEGMENT

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Reviewed By	Review Completion Date
1	870844	2" Cap. Weld X 0.164 WALL WFB	815178	12/08/11	R. Nichols	7/7/2011
2	870844	2" Transition Fitting X 0.164 WALL GR.B	815178	12/08/11	R. Nichols	7/7/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
260	
0.4	
N/A	
1815.0	
260.0	
N/A	
150.0	
3.3%	
260.0	
5.6%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	TH	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Select Data from the drop down manual

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	TH 1	OD 2	TH 2	Gr	WFB	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	2600676		2" Cap. Weld X 0.164 WALL WFB	ACTIVE	2	0.164					Cap. Weld	1815	1815	3.32%	
2	600800		2" Transition Fitting X 0.164 WALL GR.B	ACTIVE	2	0.164				Gr.B	Transition Fitting	1815	1815	3.30%	5.81% FIE section of the fitting was cut away.

Select Data from the drop down manual

THE LOWEST DESIGN PRESSURE: 1815 3% 0%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	26010		2" Banjo Tee Mueller, H-17500, WOP 260PSIG	ACTIVE	2"	260	Banjo Tee	Mueller, H-17500	260	Branch of the B

Select Data from the drop down manual

THE LOWEST PRESSURE RATING: 260

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT0142011)

Descriptions of the Facility

Facility ID	RS-2659 - Inlet
Facility Type	REGULATOR STATION

Job Key	Job Number	Job Description	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	9705131	Inlet, RS-2659	8/24/1998	R. Ninkano	8/11/2011	C. Igo	8/11/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

500	0.4	(Class 4 Location)
1403.7		
1420.0		
500.0		
1304.9		
150.0		
4.3%		
250.0		
7.1%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Gr	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	31	7000440	4" PIPE X 1/8" WALL X 42	4"	Y-42	0.188	Y-42	1424	4.23%	7.12%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	70	6000760	6" X 4" X 90 Degree, Elbow, Reducing, Weld 0.28 X 0.237 WALL Y-42	ACTIVE	6"	0.28	4"	0.237	Y-42	Y-42	1420	4.23%	7.04%	
1	65	6000997	4" X 80 Degree, Elbow, Weld X 0.237 WALL Y-42	ACTIVE	4"	0.237	Y-42	Y-42	Y-42	X 90 Degree, Elbow, Weld	1770	3.99%	6.65%	
1	64	6000412	4" Tee, Weld X 0.237 WALL Y-42	ACTIVE	4"	0.237	Y-42	Y-42	Y-42	Tee, Weld	1770	3.99%	6.65%	
1	33	7200500	4" X 2" Tee, Weld X 0.237 WALL Y-42	ACTIVE	4"	0.237	Y-42	Y-42	Y-42	Tee, Weld	1770	3.99%	6.65%	
1	22	6000236	1 1/2" X 2" Nipple (Cul. In Mail), 866.20 X 0.07163 WALL	ACTIVE	1 1/2"	0.07163	Gr. A	Gr. A	Gr. A	X of Nipple (Cul. In Mail), 866.20	2444	2.67%	4.46%	Branch on the 4"
1	67	6000572	4" X 45 Degree Elbow X 0.237 WALL Y-42	ACTIVE	4"	0.237	Y-42	Y-42	Y-42	X 45 Degree Elbow	1770	3.99%	6.65%	

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	02	7600787	6" Stopper, B/O, T/W Nordform, Fig 2045-12 CLASS 300 WOP 720PSIG	ACTIVE	6"	CLASS 300	Stopper, B/O, T/W	Muller, H-17241	720	
1	61	6000744	4" Valve, Plug Nordform, Fig 2045-12 CLASS 300 WOP 720PSIG	ACTIVE	4"	CLASS 300	Valve, Plug	Nordform, Fig 2045-12	740	
1	55	7400370	2" Flange, WN, CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, WN	Boomer, FG-30	740	
1	23	6400166	2" Flange, WN, CLASS 300 WOP 740PSIG	ACTIVE	2"	CLASS 300	Flange, WN	Boomer, FG-30	740	
1	17	6000276	4" Valve, Plug Nordform, Fig 625 WOP 500PSIG	ACTIVE	4"	CLASS 300	Valve, Plug	Boomer, DZ-500	720	
1	14	6000242	1/2" Valve, Ball Legend, Fig 113-103 WOP 1000PSIG	ACTIVE	1/2"	CLASS 300	Valve, Ball	Nordform, Fig 113-103	1000	
1	12	9000941	2" Ball Valve H-17491 WOP 1440PSIG	ACTIVE	2"	CLASS 300	Ball Valve	Legend, Fig 113-103	1440	Branch on the 2"
1	33	7200510	1/4" Plug Valve - WOP 1000PSIG	ACTIVE	1/4"	CLASS 300	Plug Valve	Muller, H-17461	1000	

THE LOWEST PRESSURE RATINGS: 500

THE LOWEST DESIGN PRESSURE: 1420

4%

7%

7%

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	4.500	4.500
Header Wall Thickness (inch)	0.237	0.237
Header Yield Strength	42000	42000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	1
Branch Fitting Description	2" Save-A-Valve	1/2" Nipple
Branch OD (inch)	2.219	0.840
Branch Wall Thickness (inch)	0.234375	0.109
Branch Yield Strength (psi)	36000	30000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	1.75	0.622
Tap Size (inch)	1.75	0.622
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0.25	0.25
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	3.5	1.244
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	1304.9389	1387.333796
L (inch)	0.5859375	0.2725
d - OD/2 (Max Reinforcement Width)	0.640625	0.202
t (inch)	0.174768603	0.185803633
tb (inch)	0.100532402	0.048556683
Ar (sq in)	0.305845055	0.11556986
A1 (sq in)	0.108904945	0.03184414
A2 (sq in)	0.156846794	0.032941608
A2' (sq in)	0.134440109	0.02352972
A3 (Fitting Weld Material)	0.0625	0.060196
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0.0625	0.060196
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	1304.9389	1387.333796

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HP-SERVICE
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completed	Reviewed By	Review Completion Date
2	816621	HP SERVICE	None	6/23/98	R. Nando	4/27/2011	C. Kop	6/28/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP

The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP

1440	(Class 4 Location)
0.4	
N/A	
N/A	
1440.0	
N/A	
160.0	
0.0%	
260.0	
0.0%	

Table 1 - Pipe Design Pressure

Enter MID, FOD, or "FC" in this field

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments

Table 2 - Non-Rated Fitting Design Pressure

Enter MID, FOD, or "FC" in this field

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Table 3 - Rated Fittings Rated Pressure

Enter MID, FOD, or "FC" in this field

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	Not Noted	Not Noted	2" nipple, 800-A-Valve Mueller, H-17401 WOP 1440PSIG	ACTIVE	2"		nipple, 800-A-Valve Mueller, H-17401	1440	See valve was installed after the initial design file.	

THE LOWEST DESIGN PRESSURE: 1440

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	HPF0002-1410 B DR 61 Terms
Facility Type	HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completed Date
1	Not Noted	Install HP Service	2-4	01/11/09	R. Nakano	02/27/2011	C. Koo	02/26/2011
2	970511	Build HP Service for Upgrading the line to HP	970511	02/23/09	R. Nakano	02/27/2011	C. Koo	02/26/2011

Facility Evaluation Summary

Facility Design Pressure
 Design Factor
 Pipe Design Pressure
 Non-Rated Fitting Design Pressure
 Rated Fitting Rated Pressure
 Branch Connection Design Pressure
 Current System MAOP
 The Highest % BNYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % BNYS of the Facility at the Proposed System MAOP

1200	0.4 (Class 4 Location)
1291.4	
3013.0	
1200.0	
N/A	
190.0	
2.8%	
260.0	
4.8%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% BNYS at Current System MAOP	% BNYS at Proposed System MAOP	Design Pressure	Comments
1	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL GR-A25	ACTIVE	3/4"	0.113	GR-A25	2.79%	4.85%	3013	Pipe grade & thickness are based on Flat Pipe

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% BNYS at Current System MAOP	% BNYS at Proposed System MAOP	Comments
2	Not Noted	Not Noted	3/4" Cap, Weld X 0.113 WALL WFB	ACTIVE	3/4"	0.113			WFB	Cap, Weld	3013	1.89%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	3/4" Tee, Service Mueller H101 WCP 1200PSIG	ACTIVE	3/4"		Tee, Service	Mueller H10101	1200	Model number is based on standards research

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: RES-0103-1415 S. Pt. St. Thomas
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	Not Filled	Initial IP Service	D-4	6/11/97	R. Nakano	4/27/01	S. Kopp	6/25/01
2	Not Filled	Initial IP Service for Changing the Tech to HP	7/08/21	6/27/98	R. Nakano	4/27/01	S. Kopp	6/25/01

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200
0.4 (Class 4 Location)

1657.1
2013.0
1200.0
N/A
150.0
2.3%
250.0
3.9%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual								
	Not Noted	Not Noted	1/2" PIPE X 0.108 WALL GR-A2B	ACTIVE		0.108	GR-A2B	1657	2.31%	3.85%	Pipe grade & thickness are based on Hist Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Select Data from the drop down manual											
	Not Noted	Not Noted	3/4" Cap. Wall X 0.113 WALL WPB	ACTIVE	.84"	0.113			Gr	Cap/Weld	3013	1.99%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments	
			Select Data from the drop down manual								
	Not Noted	Not Noted	3/4" Tee, Service Mueller H-18101 WCP 120PSIG	ACTIVE	3/4"		Teel Service	Mueller H-18101	1200	Model number H based on Specified pressure.	

THE LOWEST DESIGN PRESSURE: 1657

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HE-SERVICE
 Facility Type: HE-SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	1001	Design P. Service	P-1	02/29/1999	R. Nkomo	02/29/1999	C. Koo	02/29/1999
2	1002	Design P. Service	P-2	02/24/1998	R. Nkomo	02/24/1998	C. Koo	02/24/1998
3	1003	Design P. Service	P-3	07/05/21	R. Nkomo	07/05/21	C. Koo	07/05/21

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1557.1		
3013.0		
1200.0		
N/A		
150.0		
2.3%		
250.0		
3.8%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	Not Noted	1/2" PIPE X 0.100 WALL GR.A2B	ACTIVE	1/2"	0.100	Gr A2B	1657	2.31%	3.86%	Pipe grade & thickness are based on Hit. Specs

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	1	Not Noted	3/4" Tee, Service Mueller H-18101 WCP 1200PSIG	ACTIVE	3/4"	0.415	OD 2	Th 2	Gr	Cap. Weld	3013	1.08%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	1	Not Noted	3/4" Tee, Service Mueller H-18101 WCP 1200PSIG	ACTIVE	3/4"		Tee, Service	Mueller H-18101	3013	Model Number is based on Standard

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Description of the Facility

Facility ID:
 Facility Type:

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	8008334	Initial LP Service	None	1/10/1998	R. N. Adams	4/7/2011	C. K. K.	6/9/2011
2	8008334	Initial LP Service	None	1/10/1998	R. N. Adams	4/7/2011	C. K. K.	6/9/2011

Facility Evaluation Summary

Facility Design Pressure

Design Factor

Pipe Design Pressure

Non-Rated Fitting Design Pressure

Rated Fitting Rated Pressure

Branch Connection Design Pressure

Current System MAOP

The Highest % SMYS of the Facility at the Current System MAOP

Proposed system MAOP

The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4	(Class 4 Location)
N/A	N/A	
N/A	N/A	
1440.0	N/A	
N/A	N/A	
150.0	0.0%	
250.0	0.0%	
250.0	0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				ACTIVE	2"		nipple, Sav-A-Valve	Mueller H-17461	1440	Sav-A-Valve was installed over the rated pressure.

THE LOWEST DESIGN PRESSURE:

THE LOWEST PRESSURE-RATING:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: MSL0001433
 Facility Type: 6 SP. ST. TEGOMA HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Initial HP Service	D-4 and	8/17/2011	R. Nakano	7/20/2011	C. Kuo	6/26/2011
2	Not Noted	UPGRADE HP & RALFA HP SERVICE	2705121	8/17/2011	R. Nakano	7/20/2011	C. Kuo	6/26/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1557.1		
3013.0		
1200.0		
N/A		
150.0		
2.3%		
250.0		
3.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Sheet Data from the drop down manual								
	Not Noted	Not Noted	1/2" PIPE X 0.108 WALL GR. A28	ACTIVE	1/2"	0.108	GR. A28	1557	2.31%	3.86%	Pipe Grade & Thickness are based on Hist Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			Sheet Data from the drop down manual											
	Not Noted	Not Noted	3/4" Cap. Weld X 0.113 WALL W/PB	ACTIVE	3/4"	0.113			W/PB	Cap. Weld	3013	1.89%	3.32%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Flange Number	Rated Pressure	Comments
			Sheet Data from the drop down manual							
	Not Noted	Not Noted	3/4" Tee-Service Mueller H-10101 WCP 1200PSIG	ACTIVE	3/4"		Tee-Service	Mueller H-10101	1200	Model number is based on Standards research

THE LOWEST DESIGN PRESSURE: 1557 2% 4%

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-0007
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Installation Date	Reviewed By	Completion Date	Reviewed	Completion Date
1	2008121	IS Service for LWR	1/2/1992	R. Nunez	8/17/2011	C.Koo	8/25/2011
2	2008121	Relief Services for LWR	8/25/2011	R. Nunez	8/17/2011	C.Koo	8/25/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Current Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1012	(Class 4 Location)
0.4	
1012.0	
3104.0	
1440.0	
N/A	
150.0	
3.8%	
280.0	
5.9%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	1-1/4" PIPE X 0.14 WALL GRADES	ACTIVE	1-1/4"	0.14	Gr. A36	1012	3.89%	5.99%	Pipe grade & thickness are based on pipe spec.

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	Not Noted	Not Noted	1-1/4" Cap. Weld X 0.14 WALL WPR	ACTIVE	1-1/4"	0.14			WPR	Cap. Weld	3104	1.83%	3.22%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	1-1/4" Tee, Service Number, H-47801 WCP 1440PSIG	ACTIVE	1-1/4"		The Service	Manufacturer Number, H-47801	1440	Model Number is 1440 based on equivalent pressure.

THE LOWEST DESIGN PRESSURE: 3104

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-0008-1442 S 85 St. Tacoma
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Initial HP Service	D-4	11/21/1980	R Nakano	4/28/2011	C Koo	6/17/2011
2	8705121	Rebate HP Service & Update tie-in to HP	8705121	8/24/1998	R Nakano	4/28/2011	C Koo	6/17/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	(Class 4 Location)
0.4	
1291.4	
3013.0	
1200.0	
N/A	
150.0	
2.8%	
250.0	
4.5%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL Gr.A35	ACTIVE	3/4"	0.113	Gr.A35	1291	2.78%	4.65%	

THE LOWEST DESIGN PRESSURE: 1291

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	Not Noted	Not Noted	3/4" Cap. Weld X 0.113 WALL WPB	ACTIVE	3/4"	0.113			WPB	Cap. Weld	3013	1.69%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	3/4" Tee, Service H-1801 WOP 1200PSIG	ACTIVE	3/4"		Tee, Service	H-1801	1200	88725840

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

HP SERVICE
 HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	1011944	Initial HP Service	D-4	3/19/1994	R. Niskand	4/28/2011	G. Kos	5/25/2011
2	1439141	Re-HP Service at Location in the HP	9/05/21	9/28/1998	R. Niskand	4/28/2011	G. Kos	5/25/2011

Facility Evaluation Summary

Facility Design Pressure
 Design Factor
 Pipe Design Pressure
 Non-Rated Fitting Design Pressure
 Rated Fitting Rated Pressure
 Branch Connection Design Pressure
 Current System MAOP
 The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Location)
1291.4		
3013.0		
250.0		
N/A		
150.0		
2.5%		
200.0		
4.5%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Proposed System MAOP	Design Pressure	% SMYS at Current System MAOP	Comments
1	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL Gr A35	ACTIVE	0.4"	0.113	Gr A35	2.79%	1291	4.65%	Pipe grade & thickness are based on HP Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Proposed System MAOP	% SMYS at Current System MAOP	Comments
2	Not Noted	Not Noted	3/4" Cap, Weld X 0.113 WALL WPB	ACTIVE	0.4"	0.113			WPB	Cap, Weld	3013	1.99%	3.32%	

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
3	Not Noted	Not Noted	3/4" Tee, Service Number H-17600 WOP 250PSIG	ACTIVE	3/4"		Flange	Manufacturer H-17600 Model Number 250	250	Model number is based on research

THE LOWEST DESIGN PRESSURE: 1291

THE LOWEST DESIGN PRESSURE: 3013

THE LOWEST PRESSURE RATING: 250

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	HP.S.0011.1639.S.66.St. Tucson
Facility Type	HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Install IP Service	D-4	12/21/99	R Nakano	4/28/2011	C Kob	6/17/2011
2	9705121	Repair HP Service & Update 16-in to 1P	9705121	9/29/99	R Nakano	4/28/2011	C Kob	6/17/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200
0.4 (Class 4 Location)

1291.4
3013.0
1200.0
N/A
150.0
2.8%
250.0
4.5%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	1	Not Noted	3/4" PIPE X 0.113 WALL Gr.A25	ACTIVE	3/4"	0.113	Gr.A25	1291	2.79%	4.65%	Historical Spec

THE LOWEST DESIGN PRESSURE: 1291

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	1	Not Noted	3/4" Cap, Weld X 0.113 WALL WPB	ACTIVE	3/4"	0.113	OD 2		WPB	Cap, Weld	3013	1.95%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	1	Not Noted	3/4" Tee, Service Mueller H-18101 WOP 1200PSIG	ACTIVE	3/4"		Tee, Service	Mueller H-18101	1200	887028841

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	HPS-0512 1708 \$100 SI Tacoma
Facility Type	HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Initial IP service	None	11/20/1974	R Nakano	4/29/2011	C Koo	
2	9705121	Relief service	9705121	07/27/1993	R Nakano	4/29/2011	C Koo	

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4 (Class 4 Location)
N/A	
N/A	
1440.0	
N/A	
160.0	
0.0%	
250.0	
0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Select Data from the drop down menu!

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Select Data from the drop down menu!

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Class Rating	Size	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	Not Noted	Not Noted	2" nipple, Sav-A-Valve Mueller, H-17491 WOP 1440PSIG	ACTIVE		2"	nipple, Sav-A-Valve Mueller, H-17491	1440	1440	Sav-A-Valve over service life

THE LOWEST DESIGN PRESSURE: 1440

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-01142011
 Facility Type: HPS SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Date
1	Not Noted	Initial IP Service	6-4	11/19/1994	R. Ninkano	4/26/2011	G. Koo	5/25/2011
2	9705121	Revised IP Service for Upgrading the 16-in. to HP	9705121	6/29/1998	R. Ninkano	4/29/2011	G. Koo	5/25/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250
 0.4 (Class 4 Location)

1291.4
3013.0
250.0
N/A
150.0
2.8%
250.0
4.6%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	Not Noted	3/4" PIPE X 0.113 WALL GRA25	ACTIVE	3/4"	0.113	Gr. A25	125	2.76%	4.65%	Pipe grade & thickness are listed on this spec.

THE LOWEST DESIGN PRESSURE: 1231 3% 5%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	Not Noted	Not Noted	3/4" Cap. Weld X 0.113 WALL WPB	ACTIVE	3/4"	0.113			WPB	Cap. Weld	3013	1.99%	3.27%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	Not Noted	Not Noted	3/4" Tee, Service Muller H-17600 WCP 250PSIG	ACTIVE	3/4"		For Service	Manufacturer: H-17600	250	Model number is listed on this research.

THE LOWEST PRESSURE RATING: 250

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: **IPES00143761 S 00 SH Tecom**
 Facility Type: **IP SERVICE**

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	0010000	Initial IP Service	07/05/12	7/07/07	R. Nishiro	4/29/2011	C. Kob	5/1/2011
		Write the Service for Operation the Utility IP		7/13/09	T. Nakano		C. Kob	5/1/2011

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % BMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % BMYS of the Facility at the Proposed System MAOP

1440	0.4	(Class 4 Location)
N/A	N/A	
N/A	N/A	
1440.0	1440.0	
N/A	N/A	
160.0	160.0	
0.0%	0.0%	
280.0	280.0	
0.0%	0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MD	Description	Status	OD	Th	Gr	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
					Select Data from the drop down manual						

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MD	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% BMYS at Current System MAOP	% BMYS at Proposed System MAOP	Comments
					Select Data from the drop down manual									

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MD	Description	Status	Site	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
					Select Data from the drop down manual					
			2" nipple, Sav-A-Valve Mueller, H-17461 WCP 1440PSIG	ACTIVE			nipple, sav-A-Valve Mueller, H-17461	1440		Save-a-valve was installed over the initial design pressure

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 1440
 Facility Type: 1440

MS. 0015 7/26 8:09:51 AM
 HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Completion Date
1	01011	01011 P. Service	None	7/27/1988	R. Nakano	4/29/2011	C. Ko	5/11/2011
2	01011	01011 P. Service	None	7/27/1988	R. Nakano	4/29/2011	C. Ko	5/11/2011

Facility Evaluation Summary

Facility Design Pressure

1440	(Class 4 Location)
N/A	
N/A	
1440.0	
N/A	
0.0%	
250.0	
0.0%	

Design Factor
 Pipe Design Pressure
 Non-Rated Fitting Design Pressure
 Rated Fitting Design Pressure
 Branch Connection Design Pressure
 Current System MAOP
 The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Or	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the pipe data manual											

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Or	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the pipe data manual														

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
Select Data from the pipe data manual										

THE LOWEST DESIGN PRESSURE: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	1985-2015-2015 S 98 St, Tacoma
Facility Type	HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Install IP service	D-4	7/16/1985	R Nakano	5/3/2011	C Koo	6/17/2011
2	9705121	Relife IP service & update fit-in to HP	9705121	8/20/1998	R Nakano	5/3/2011	C Koo	6/17/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	(Class 4 Location)
0.4	
1213.7	
2632.0	
1200.0	
N/A	
150.0	
3.0%	
250.0	
4.3%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	1" PIPE X 0.133 WALL GR-A35	ACTIVE	1"	0.133	Gr-A35	1214	2.97%	4.94%	Historic pipe specs

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	Not Noted	Not Noted	1" Cap, Weld X 0.133 WALL WFB	ACTIVE	1"	0.133			WFB	Cap, Weld	2832	2.12%	3.53%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not noted	Not noted	1" Service Tee Mueller H-16101 WOP 1200PSIG	ACTIVE	1"		Service Tee	Mueller H-16101	1200	1200 887025942

THE LOWEST PRESSURE RATING: 1200

THE LOWEST DESIGN PRESSURE: 1214

5%

3%

THE LOWEST DESIGN PRESSURE: 2832

2%

4%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	URS 0017 2102 S 05 St. Tezoma
Facility Type	IP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	Not noted	Initial IP Service	D-4	6/25/1999	R Nakano	5/3/2011	C. Kep	5/26/2011
2	9705121	Retrofit IP Service for Upgrading the tie-in to HP	9705121	8/21/1998	R Nakano	5/3/2011	C. Kep	5/26/2011

Facility Evaluation Summary

Facility Design Pressure
 Design Factor
 Pipe Design Pressure
 Non-Rated Fitting Design Pressure
 Rated Fitting Rated Pressure
 Branch Connection Design Pressure
 Current System MAOP
 The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Location)
1012.0		
2361.0		
250.0		
MA		
150.0		
3.6%		
250.0		
5.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	1-1/4" PIPE X 0.14 WALL Gr.A25	ACTIVE	1-1/4"	0.14	Gr.A25	1612	3.56%	6.93%	Pipe grade & thickness are based on Hist Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	Not Noted	Not noted	1-1/4" Cap. Weld X 0.14 WALL WPB	ACTIVE	1-1/4"	0.14			WPB	Cap. Weld	2361	2.54%	4.23%	location is noted on the D-4. Based on D-4, Service retirement is concluded to be CBS

THE LOWEST DESIGN PRESSURE: 1012

3%

4%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not noted	1-1/4" Service Tee Mueller H-17500 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H-17500	250	Confirmed 887026544

THE LOWEST PRESSURE RATING: 250

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

HP-9-0018 - HP Review to B004.22.Ava 6
 HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Install HP Service	D-4 end	09/07/09	R Nakano	07/22/11	C. Kob	01/20/11
2	7205171	Relief HP Service for Unfilled the tank to HP	0705171	01/07/09	R Nakano	07/22/11	C. Kob	01/20/11

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Locallon)
1012.0		
2351.0		
250.0		
N/A		
150.0		
3.6%		
250.0		
5.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
	Not Noted	Not Noted	1-1/4" PIPE X 0.14 WALL GR-A25	1-1/4"	0.14	Gr-A25	3.65%	1012	5.93%	Pipe grade & thickness are based on Heat Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
30	6206835		1-1/4" CRD. WALL X 0.14 WALL W/PB	ACTIVE	1-1/4"	0.14	0.14		CRD. WALL				

THE LOWEST DESIGN PRESSURE: 1012

3%

4%

6%

8%

10%

12%

14%

16%

18%

20%

22%

24%

26%

28%

30%

32%

34%

36%

38%

40%

42%

44%

46%

48%

50%

52%

54%

56%

58%

60%

62%

64%

66%

68%

70%

72%

74%

76%

78%

80%

82%

84%

86%

88%

90%

92%

94%

96%

98%

100%

102%

104%

106%

108%

110%

112%

114%

116%

118%

120%

122%

124%

126%

128%

130%

132%

134%

136%

138%

140%

142%

144%

146%

148%

150%

152%

154%

156%

158%

160%

162%

164%

166%

168%

170%

172%

174%

176%

178%

180%

182%

184%

186%

188%

190%

192%

194%

196%

198%

200%

202%

204%

206%

208%

210%

212%

214%

216%

218%

220%

222%

224%

226%

228%

230%

232%

234%

236%

238%

240%

242%

244%

246%

248%

250%

252%

254%

256%

258%

260%

262%

264%

266%

268%

270%

272%

274%

276%

278%

280%

282%

284%

286%

288%

290%

292%

294%

296%

298%

300%

302%

304%

306%

308%

310%

312%

314%

316%

318%

320%

322%

324%

326%

328%

330%

332%

334%

336%

338%

340%

342%

344%

346%

348%

350%

352%

354%

356%

358%

360%

362%

364%

366%

368%

370%

372%

374%

376%

378%

380%

382%

384%

386%

388%

390%

392%

394%

396%

398%

400%

402%

404%

406%

408%

410%

412%

414%

416%

418%

420%

422%

424%

426%

428%

430%

432%

434%

436%

438%

440%

442%

444%

446%

448%

450%

452%

454%

456%

458%

460%

462%

464%

466%

468%

470%

472%

474%

476%

478%

480%

482%

484%

486%

488%

490%

492%

494%

496%

498%

500%

502%

504%

506%

508%

510%

512%

514%

516%

518%

520%

522%

524%

526%

528%

530%

532%

534%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Description of the Facility

Facility ID: 1012
 Facility Type: HT SERVICE

DESIGNER: URS
 PROJECT NO: 2426 S.W. 5th
 DATE: 6/7/2011

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	7705171	Initial IP Service	D-4 end	6/14/10	R. Nakano	6/17/2011	C. Kip	6/17/2011
2	7705171	Relief IP Service	8705171	8/17/09	R. Nakano	5/13/2011	C. Kip	5/13/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Related Fitting Design Pressure
- Related Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

230	0.4 (Class 4 Location)
1012.0	
2351.0	
260.0	
N/A	
150.0	
3.6%	
250.0	
5.9%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
					Steel Data from the drop down manual						
				ACTIVE	1-1/4"	0.14	Gr A285	3.69%	1012	6.63%	Pipe grade & thickness are based on flat Spec

Table 2 - Non-Related Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	Gr	OD 2	Th 2	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
					Steel Data from the drop down manual									
	30	620055	1-1/2" Cap. Weld X 0.14 WALL WFB	ACTIVE	1-1/2"	0.14	Gr WFB			WFB	2351	2.61%	4.23%	

Table 3 - Related Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
					Steel Data from the drop down manual					
				ACTIVE	1-1/4"	250PSIG	Service Tee	Mueller H17600	250	based on Standards research

THE LOWEST DESIGN PRESSURE: 2351

THE LOWEST PRESSURE RATING: 260

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	URS 020 - HP service to 2425 S 95 St, Tacoma
Facility Type	HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	Not Noted	Initial IP Service	D-4 card	7/10/1974	R Nakano	5/13/2011	C. Kop	6/17/2011
2	9705121	Final IP service, update tie-in to HP	9705121		R Nakano	5/13/2011	C. Kop	6/17/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	0.4	(Class 4 Location)
1012.0		
2361.0		
2500.0		
N/A		
1500.0		
3.6%		
2500.0		
5.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	Not Noted	Not Noted	1-1/4" PIPE X 0.14 WALL Gr-A25	ACTIVE	1-1/4"	0.14	Gr-A25	1012	3.69%	5.93%	Historic Pipe Specs

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
2	30	5200635	1-1/4" Cap, Weld X 0.14 WALL WPB	ACTIVE	1-1/4"	0.14			WPB	Cap, Weld	2361	2.54%	4.23%	Confirmed 06729543

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	Not Noted	Not Noted	1-1/4" Service Tee Mueller H-17500 WOP 250PSIG	ACTIVE	1-1/4"		Service Tee	Mueller H-17500	250	Model number per standard's research

THE LOWEST PRESSURE RATING: 250

THE LOWEST DESIGN PRESSURE: 1012

4%

6%

THE LOWEST DESIGN PRESSURE: 2361

3%

4%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-0021-3119 E 36 St. Lakewood
 Facility Type: HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	949108	Install IP service	D4	2/15/1934	R Nakano	5/17/2011	O. Koo	9/16/2011
2	9705121	Repair IP service & upgrade W/J to HP	8705121	8/19/1998	R Nakano	5/17/2011	O. Koo	9/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1012	(Class 4 Location)
0.4	
N/A	
1012.0	
1440.0	
N/A	
150.0	
3.6%	
280.0	
5.8%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Filling Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

THE LOWEST DESIGN PRESSURE: 1012 4% 8%

Table 3 - Rated Filling Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Filling Type	Manufacturer and Model Number	Rated Pressure	Comments

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-0022 (Initial Pressure Terminal)
 Facility Type: HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Reviewed By	Review Completion Date
1	07-007682	Initial 8" Trench (H/E/P) Piping Terminal	AD28-371	11/27/1999	Shi Pseudofalk	3/20/11

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
400	
0.4	
953.6	
1420.0	
400.0	
607.6	
160.0	
0.1	
260.0	
0.0	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current system MAOP	% SMYS at Proposed System MAOP	Comments
	10	76-00621	6" PIPE X 0.188 WALL X-42	ACTIVE	6"	0.188	X-42	953	6.25%	10.45%	
	11	76-00742	6" 45 elbow X 0.28 WALL X-42	ACTIVE	6"	0.28	X-42	953	6.25%	10.45%	
	12	76-00419	6" X 4" weld (see 0.28 X 0.23 WALL X-42	ACTIVE	6"	0.28	X-42	953	6.25%	10.45%	
	13	76-00620	6" X 2" reducer 0.28 X 0.194 WALL X-42	ACTIVE	6"	0.28	X-42	953	6.25%	10.45%	
	14	76-00698	4" X 2" reducer 0.237 X 0.154 WALL X-42	ACTIVE	4"	0.237	X-42	1404	4.27%	7.12%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current system MAOP	% SMYS at Proposed System MAOP
	5-17	66-00752	6" 90 elbow X 0.28 WALL X-42	ACTIVE	6"	0.28	6"	X-42	X-42	90 elbow	1420	4.23%	7.04%
	10	60-00742	6" 45 elbow X 0.28 WALL X-42	ACTIVE	6"	0.28	6"	X-42	X-42	45 elbow	1420	4.23%	7.04%
	11	76-00419	6" X 4" weld (see 0.28 X 0.23 WALL X-42	ACTIVE	6"	0.28	4"	0.237	X-42	weld (see 0.28 X 0.23)	1420	4.23%	7.04%
	13	76-00620	6" X 2" reducer 0.28 X 0.194 WALL X-42	ACTIVE	6"	0.28	2"	0.184	X-42	reducer	1420	4.23%	7.04%
	14	76-00698	4" X 2" reducer 0.237 X 0.154 WALL X-42	ACTIVE	4"	0.237	2"	0.184	X-42	reducer	1770	3.39%	5.65%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	50	76-00796	6" Bellon Gull HT281 CLASS 300 WOP 740 PSIG	ACTIVE	6"	CLASS 300	Ballon Gull Plug Valve	Northstrom Flg 4249	740	This Item is 8" B.O
	51	66-00683	6" Plus Valve Nordstrom Flg 4245 CLASS 300 WOP 740 PSIG	ACTIVE	6"	CLASS 300	Plus Valve	Northstrom Flg 4245	740	
	55	64-00450	6" WN flange CLASS 300 WOP 740 PSIG	ACTIVE	6"	CLASS 300	WN flange	Northstrom Flg 4245	740	
	72	76-00417	6" Filler Klantline KL-6-720 CLASS 300 WOP 720 PSIG	ACTIVE	6"	CLASS 300	Filler	Klantline KL-6-720	720	
	83	64-00186	2" Regulator Aival Flow CLASS 300 WOP 740 PSIG	ACTIVE	2"	CLASS 300	Regulator	Aival Flow	740	
	9	64-00380	4" WN flange CLASS 300 WOP 740 PSIG	ACTIVE	4"	CLASS 300	WN flange	Northstrom Flg 308	740	
	21	66-00770	4" Plug Valve Nordstrom Flg 305 NA WOP 400 PSIG	ACTIVE	4"	NA	Plug Valve	Northstrom Flg 308	400	

THE LOWEST PRESSURE RATING: 400

THE LOWEST DESIGN PRESSURE: 1420

0.033905687 0.066509946

Design Pressure Calculation on a Branch

Design Factor (F) 0.4
 Current MAOP 150
 Proposed MAOP 250

Dimensions		
Job Key of the Header Pipe	1	1
Header OD (inch)	6.625	6.625
Header Wall Thickness (inch)	0.188	0.188
Header Yield Strength	42000	42000
Header Longitudinal Joint Factor	1	1
Job Key of the Branch	1	2
Branch Fitting Description	3/4" RTU Inlet	1/2" purge point
Branch OD (inch)	1.050	0.840
Branch Wall Thickness (inch)	0.113	0.109
Branch Yield Strength (psi)	35000	35000
Branch Longitudinal Joint Factor	1	1
Temperature Derating Factor (from Header)	1	1
Tap Size (Maximum) (inch)	0.824	0.622
Tap Size (inch)	0.824	0.622
Recommended Fitting Weld Leg (in)	0.25	0.25
Fitting Weld Length (in)	0	0
Effective A3 Provided by Additional Reinforcement		
Max 'Usable' Length (OD) of additional Reinforcement	1.648	1.244
OD of Additional Reinforcement (inch)	0	0
Thickness of Additional Reinforcement M (inch)	0	0
Yield Strength of Additional Reinforcement (psi)	0	0
Effective A3 Provided by Weldments		
Max Header Weld Leg Length for A3 (inch)	0.25	0.25
Header Weld Leg Length for A3 (inch)	0	0
Max Branch Weld Leg Length for A3 (inch)	0.25	0.25
Branch Weld Leg Length for A3 (inch)	0	0
Conclusion and Calculation Summary		
Design Pressure (psig)	607.4668867	642.8551263
% SMYS at the Current System MAOP	0.098770816	0.093333626
% SMYS at the Proposed System MAOP	0.164618026	0.155556044
L (inch)	0.2825	0.2725
d - OD/2 (Max Reinforcement Width)	0.299	0.202
t (inch)	0.119775837	0.126753429
tb (inch)	0.022780008	0.019285654
Ar (sq in)	0.09869529	0.078840633
A1 (sq in)	0.05621671	0.038095367
A2 (sq in)	0.050974295	0.048894319
A2' (sq in)	0.042478579	0.040745266
A3 (Fitting Weld Material)	0	0
A3 Reinforcement (sq in)	0	0
A3 Weldment (sq in)	0	0
A3 (sq in)	0	0
Status (Branch Status from Calculation Worksheet)	Active	Active
Design Pressure Evaluation	607.4668867	642.8551263

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Descriptions of the Facility

Facility ID: HPF-0023 (Relief)
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	HPF-0023 Installation	0-1	8/7/1993	C. Ken	7/18/2011	C. Ken	7/18/2011
2	9705141	HPF-0023 Relieffix	9705141	8/19/1998	C. Ken	7/18/2011	C. Ken	7/18/2011

Facility Evaluation Summary

- Facility Design Pressure: 1440 (Class 4 Location)
- Design Factor: N/A
- Pipe Design Pressure: N/A
- Non-Rated Fitting Design Pressure: 1440.0
- Rated Fitting Rated Pressure: N/A
- Branch Connection Design Pressure: N/A
- Current System MAOP: 150.0
- The Highest % SMYS of the Facility at the Current System MAOP: 0.0%
- Proposed system MAOP: 200.0
- The Highest % SMYS of the Facility at the Proposed System MAOP: 0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	Gr	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual															

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	N/A	6000841	2" Save-A-Valve Mueller WOP 1440PSIG	ACTIVE	2"		Save-A-Valve	Mueller	1440	The Fitting was installed over the relief service tee.

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID: [REDACTED]
 Facility Type: [REDACTED]

DESIGN (Redline)
 THE SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	0-4	7/19/1999	G. Koss	7/19/2011	C. Koop	7/19/2011
2	870821	Relinishment	870821	8/20/1999	G. Koss	7/19/2011	C. Koop	7/19/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4 (Class 4 Location)
N/A	
N/A	
1440.0	
N/A	
150.0	
0.0%	
250.0	
0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!											

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!														

THE LOWEST DESIGN PRESSURE: [REDACTED]

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	2	N/A	2" Save-A-Valve Mueller WOP 140PSIG	ACTIVE	2"		Save-A-Valve	Mueller	1440	The Fitting Was Installed over the rated service lead.

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID: _____
 Facility Type: _____

URS | 6028 (Railroad)
 RFE SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	8705121	7/18/1997	C Kop	7/18/2011	C Kop	7/18/2011
2	8705121	Relinquent	8705121	6/11/1998	C Kop	7/18/2011	C Kop	7/18/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4	(Class 4 Location)
N/A	N/A	
N/A	N/A	
1440.0		
N/A		
150.0		
0.0%		
250.0		
0.0%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD	Gr				

THE LOWEST DESIGN PRESSURE: _____

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu						Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD 1	TH 1	OD 2	TH 2	Gr				

THE LOWEST DESIGN PRESSURE: _____

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu				Rated Pressure	Comments
				Status	Size	Class Rating	Fitting Type		

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Descriptions of the Facility

Facility ID:
 Facility Type:

UAS 007 (REV 03)
 HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
2	970531	Installation	04	01/17/99	C. Kos	7/18/2011	C. Kos	7/18/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4	(Class 4 Location)
N/A	N/A	
N/A	N/A	
1440.0	N/A	
N/A	N/A	
450.0	N/A	
0.0%	0.0%	
250.0	0.0%	
0.0%	0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down menu:											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down menu:													

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	N/A	980084	2" Save-A-Valve Mueller WOP 140PSIG	ACTIVE	2"		Save-A-Valve	Mueller	140	The Fitting Was Inspected over the rated service life

THE LOWEST PRESSURE RATING:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: Facility Type:

IPS: 0228 (Railroad) HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	1/23/1992	G. Koe	7/16/2011	C. Koe	7/16/2011
2	9706321	Relinquent	9706321	6/17/1998	C. Koe	7/16/2011	C. Koe	7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440
0.4 (Class 4 Location)

N/A
N/A
N/A
1440.0
N/A
150.0
0.0%
280.0
0.0%

Table 1 - Pipe Design Pressure

Enter MID#, POK, or PCP in this field

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Enter MID#, POK, or PCP in this field

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!														

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Enter MID#, POK, or PCP in this field

Job Key	ITEM #	MID	Description	Status	Site	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	N/A	860844	Z Service Valve Mueller WCP-1440PSIG	ACTIVE	Z		Save-A-Valve	Mueller	1440	Installed over the relief service line

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Facility ID:
 Facility Type:

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	4/7/1995	C. Kog	7/15/2011	C. Kog	7/15/2011
2	8708131	Reinforcement	8708131	8/19/1998	C. Kog	7/15/2011	C. Kog	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Brench Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4 (Class 4 Location)
N/A	
N/A	
1440.0	
N/A	
150.0	
0.0%	
250.0	
0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				ACTIVE	2"		Save-A-Valve	Mugler	1440	The Fitting was installed over the drilled section see

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HP-SERVICE
 Facility Type: HP-SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	12/24/1994	C. Koo	7/15/2011	C. Koo	7/15/2011
2	1440	Replacement	970521	8/18/1998	C. Koo	7/15/2011	C. Koo	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	(Class 4 Location)
0.4	
N/A	
N/A	
1440.0	
N/A	
150.0	
0.0%	
250.0	
0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD	Th	Gr			

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD 1	Th 1	Gr				

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				Status	Size	OD 2	Gr					
1440	2	N/A	2" Bay-A-Valve Mueller WOP 1440PSIG	ACTIVE	2"			Bay-A-Valve	Mueller	1440	The Fitting was installed over the rated service life.	

THE LOWEST PRESSURE RATING:

1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: **RES-001 (REIN)**
 Facility Type: **HP SERVICE**

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Date
1	N/A	Installation	9/15/12	07/17/1988	C. Koo	7/15/2011	C. Koo	7/15/2011
2	9/15/12	System	9/15/12	07/17/1988	C. Koo	7/15/2011	C. Koo	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	0.4 (Class 4 Location)
N/A	
N/A	
1440.0	
N/A	
160.0	
0.0%	
280.0	
0.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fittings Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down menu!														

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
2	N/A	600984	2" Save-A-Valve Mueller WOP 1440PSIG	ACTIVE	2"		Save-A-Valve	Mueller	1440	The Fitting was installed over the rated service.

THE LOWEST PRESSURE RATINGS: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

HPS-0037 (Retired)
 HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	09/19/00	C. Kop	7/16/2011	C. Kop	7/16/2011
2	8795121	Retirement	8795121	8/14/1998	C. Kop	7/16/2011	C. Kop	7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440
 0.4
 N/A
 N/A
 1440.0
 N/A
 150.0
 0.0%
 250.0
 0.0%
 (Class 4 Location)

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments	
												Select Data from the drop down menu!

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments				
											Select Data from the drop down menu!			

THE LOWEST DESIGN PRESSURE: 1440

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 101142011)

Descriptions of the Facility

Facility ID: Facility Type:

FRS:0633 (Revised) PIP SERVICE

Job Key	Job Number	Job Descriptions	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	870871	Installation	2/18/98	C. Kos	7/18/2011	C. Kos	7/18/2011
2	870872	Installation	7/14/98	C. Kos	7/18/2011	C. Kos	7/18/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440	(Class 4 Location)
0.4	
N/A	
N/A	
1440.0	
N/A	
150.0	
9.0%	
250.0	
9.0%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			% SMYS at Proposed System MAOP	Design Pressure	% SMYS at Current System MAOP	Comments
				Status	OD	Gr				

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual				Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD 1	Th 1	OD 2					

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Manufacturer and Model Number	Rated Pressure	Comments
				Status	Size	Class Rating			

THE LOWEST PRESSURE RATING:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	HFS-0034 (Realized)
Facility Type	HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	2/27/98	C. Koo	7/19/2011	C. Koo	7/19/2011
2	8705121	Retirement	8705121	8/17/99	C. Koo	7/19/2011		7/19/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1291.4		
2583.0		
1200.0		
N/A		
150.0		
2.6%		
250.0		
4.5%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" PIPE X 0.113 WALL Gr.A25	3/4"	0.113	Gr.A25	1291	2.75%	4.65%	

THE LOWEST DESIGN PRESSURE: 1291

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" Transition Fitting X 0.113 WALL Gr.A	3/4"	0.113			Gr.A	Transition Fitting	2663	2.32%	3.87%	1/4 portion is citted
2	N/A	N/A	3/4" Weld Cap X 0.113 WALL WPB	3/4"	0.113			WPB	Weld Cap	3013	1.69%	3.32%	Confirmed 88702659

THE LOWEST DESIGN PRESSURE: 2563

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	N/A	3/4" Service Tee Mueller H-18101 WCP 1200PSIG	3/4"		Service Tee	Mueller H-18101	1200	Confirmed 887026259

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID	HP-0034 (Refined)
Facility Type	HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	870431	Installation	0-4	7/16/1997	C. Koo	7/16/2011	C. Koo	7/16/2011
2	870431	Recommissioning	9-10-21	9/10/1998	C. Koo	7/16/2011	C. Koo	7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1657.1		
3013.0		
1200.0		
N/A		
150.0		
2.3%		
250.0		
3.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	Select Data from the drop down menu			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
					OD	Th	Gr				
1	1	N/A	1/2" PIPE X 0.108 WALL Gr. A26	ACTIVE	1/2"	0.108	Gr. A26	1657	2.31%	3.86%	

THE LOWEST DESIGN PRESSURE: 1657 2% 4%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	Select Data from the drop down menu			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
					OD 1	Th 1	OD 2				
1	2	N/A	3/4" WALL Cap X 0.113 WALL Gr. B	ACTIVE	3/4"	0.113	Gr. B	3013	1.89%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Select Data from the drop down menu			Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
					Size	Class Rating	Splice Type					
1	1	N/A	1/2" Service Tee Mueller H-18101 WOP-1200PSIG	ACTIVE	1/2"				Manufacturer and Model Number H-18101	1200		

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPSE0038 (Revised)
 Facility Type: HP SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
2	070611	Re-Installation	270912	07/07/09	0.135	07/15/2011	C. King	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure: 1200 (Class 4 Location)
- Non-Rated Fitting Design Pressure: 1557.1
- Rated Fitting Rated Pressure: 3533.0
- Branch Connection Design Pressure: 1200.0
- Current system MAOP: N/A
- Proposed system MAOP: 150.0
- The Highest % SMYS of the Facility at the Current System MAOP: 2.3%
- The Highest % SMYS of the Facility at the Proposed System MAOP: 250.0
- 3.9%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Proposed System MAOP	% SMYS at Current System MAOP	Design Pressure	Fitting Type	% SMYS at Proposed System MAOP	% SMYS at Current System MAOP	Comments
	1	N/A	1/2" PIPE X 0.108 WALL GR. B	ACTIVE	1/2"	0.108	Gr. A2B	1557	2.31%	3.65%	1557	Weld Cap	3.65%	3.65%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	Fitting Type	% SMYS at Proposed System MAOP	% SMYS at Current System MAOP	Comments
	1	N/A	1/2" X 0.108 GR. B	ACTIVE	1/2"	0.108	0.108	0.108	Gr. B	3533	Weld Cap	1.85%	2.75%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	1	N/A	1/2" Service Tee Mueller H-18101 WOP 1200PSIG	ACTIVE	1/2"	1200	Service Tee	Mueller H-18101	1200	Per Standard Research

THE LOWEST DESIGN PRESSURE: 1557

THE LOWEST DESIGN PRESSURE: 3533

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01142011)

Descriptions of the Facility

Facility ID: HP-SERVICE

Facility Type: HP-SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	970521	Rebuild	970521	11/17/09	C. Kop	7/19/2011	C. Kop	7/19/2011
2	970521	Rebuild	970521	7/19/09	C. Kop	7/19/2011	C. Kop	7/19/2011

Facility Evolution Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Red Fitting Design Pressure
- Red Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
1200	
0.4	
1291.4	
3013.0	
1200.0	
N/A	
150.0	
2.8%	
200.0	
4.8%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	TH	OR	Gr. A2E	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" PIPE X 0.113 WALL GR. A2E	ACTIVE	3/4"	0.113	OR	Gr. A2E	1481	2.78%	4.65%	Full S.M.P.

THE LOWEST DESIGN PRESSURE: 1291 3% 5%

Table 2 - Non-Red Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	TH 1	OD 2	TH 2	Or	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" WALL COP X 0.113 WALL WFB	ACTIVE	3/4"	0.113	OD 2	TH 2	WFB	WFB Cop	3013	1.85%	3.32%	

THE LOWEST DESIGN PRESSURE: 3013 2% 3%

Table 3 - Red Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	N/A	3/4" Service Tee Mueller H-16101 WCP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H-16101		Per Standard Research

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: HPS-003 (Revised)
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	0705141	Installation	0-4	27/11/07	G. Koo	7/15/2011	G. Koo	7/15/2011
2	0705141	Reliability	0-4	27/11/07	G. Koo	7/15/2011	G. Koo	7/15/2011
3	0705141	Rating	0-4	27/11/07	G. Koo	7/15/2011	G. Koo	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure: 1200 (Class 4 Location)
- Pipe Design Pressure: 9.4
- Non-Rated Fitting Design Pressure: 1597.1
- Rated Fitting Rated Pressure: 3933.0
- Branch Connection Design Pressure: 1200.0
- Current System MAOP: N/A
- The Highest % SMYS of the Facility at the Current System MAOP: 7.3%
- Proposed system MAOP: 250.0
- The Highest % SMYS of the Facility at the Proposed System MAOP: 3.9%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Proposed System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
			1/2" PIPE X 0.109 WALL GR. A35	ACTIVE	1/2"	0.109	Gr. A35	2.31%	1597	3.95%	
Select Data from the drop down manual											

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			1/2" Weld Conn. X 0.109 WALL W.P.F.	ACTIVE	1/2"	0.109	OD 2	0.109	Gr. W.P.F.	Weld Conn.	3933	1.95%	2.70%	
Select Data from the drop down manual														

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
			3/4" Service Tee Mueller H-18101 WCP 1200PSIG	ACTIVE	3/4"	1200	Service Tee	Mueller H-18101	1200	RESEARCH
Select Data from the drop down manual										

THE LOWEST DESIGN PRESSURE: 1597

THE LOWEST DESIGN PRESSURE: 3933

THE LOWEST PRESSURE RATING: 1200

2%

4%

2%

3%

3%

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 1200
 Facility Type: HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Initial High Pressure	04	8/29/07	C/Kob	7/19/2011	G/Kob	7/19/2011
2	91012	Modification	08/05/12	8/22/08	C/Kob	7/19/2011	G/Kob	7/19/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

Value	(Class 4 Location)
1200	
0.4	
1557.1	
3633.0	
1200.0	
N/A	
150.0	
2.3%	
250.0	
3.9%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	1/2" PIPE X 0.109 WALL GR. A25	1/2"	0.109	Gr. A25	1657	2.31%	3.65%	Select Data from the drop down manual

THE LOWEST DESIGN PRESSURE: 1657

2%

4%

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	2	N/A	1/2" Weld Cap X 0.109 WALL WFB	1/2"	0.109	OD 2		WFB	Weld Cap	3633	1.65%	2.72%	Select Data from the drop down manual

3%

2%

3%

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	N/A	3/4" Service Tee Number H-18101 WOP 1200PSIG	3/4"		Service Tee		2000	Per Standard Rating

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

DESIGN (Required)
 SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Reviewed By	Review Completion Date
	N/A	Installation	C-4	9/1/1999	C.Koo	C.Koo	7/16/2011
	8705121	Replacement	8705121	7/14/1998	G.Koo	G.Koo	7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1200
 9.4
 1557.1
 3633.0
 1200.0
 N/A
 150.0
 2.3%
 250.0
 3.9%
 (Class 4 Location)

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	N/A	N/A	1/2" PIPE X 0.109 WALL GR.235	1/2"	0.109	Gr. 235	1557	2.31%	3.65%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	N/A	N/A	1/2" Weld Cap X 0.109 WALL WFB	1/2"	0.109			WFB	Weld Cap	3633	1.65%	2.75%	

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	N/A	N/A	3/4" Service Tee Mueller H-18101 WOP 1200PSIG	3/4"		Service Tee	Mueller H-18101	1200	Research

THE LOWEST DESIGN PRESSURE: 1557

THE LOWEST DESIGN PRESSURE: 3633

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

PHS-0041 (Rating)
 PH-SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	10/27/1995	C. Kob	7/16/2011	C. Kob	7/16/2011
2	970521	Retirement	970521	6/23/1998	C. Kob	7/16/2011	C. Kob	7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

	1012 (Class 4 Location)
Design Factor	0.4
Design Pressure	1012.0
Non-Rated Fitting Design Pressure	2024.0
Branch Connection Design Pressure	1440.0
Current System MAOP	N/A
Highest % SMYS of the Facility at the Current System MAOP	4.50%
Proposed system MAOP	250.0
Highest % SMYS of the Facility at the Proposed System MAOP	5.9%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			1-1/4" PIPE X 0.14 WALL GRADE	1-1/4"	0.14	Gr	1012	5.93%	5.93%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
			1-1/4" Void Cap X 0.14 WALL WFB	1-1/4"	0.14			WFB	Void Cap	2024	2.54%	4.23%	
			1-1/4" Transition Fitting X 0.14 WALL GRA	1-1/4"	0.14			GRA	Transition Fitting	2024	2.80%	4.84%	Fit Fulfill w/ out diff

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Size	Class Rating	Fitting Type	Manufacturer and Model No.	Rated Pressure	Comments
			1-1/4" Service Tee Mueller H-17601 WOP 140PSIG	1-1/4"		Service Tee	Mueller H-17601	1440	PH Standard Research

THE LOWEST DESIGN PRESSURE: 1012

THE LOWEST DESIGN PRESSURE: 2024

3%

5%

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT 01/14/2011)

Descriptions of the Facility

Facility ID:
 Facility Type:

HFSP042 (Required)
 HF SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-1	6/10/1998	C Kob	7/15/2011	C Kob	7/15/2011
2	9705141	Reclamation	9705141	6/29/1998	C Kob	7/15/2011	C Kob	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440
 0.4% (Class 4 Location)

N/A
 N/A
 1440.0
 N/A
 150.0
 0.0%
 250.0
 0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Sheet Data from the drop down manual											
Status											
OD											
Th											
Gr											
Design Pressure											
% SMYS at Current System MAOP											
% SMYS at Proposed System MAOP											
Comments											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Filling Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Filling Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Sheet Data from the drop down manual														
Status														
OD 1														
Th 1														
OD 2														
Th 2														
Gr														
Filling Type														
Design Pressure														
% SMYS at Current System MAOP														
% SMYS at Proposed System MAOP														
Comments														

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Filling Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Filling Type	Manufacturer and Model	Rated Pressure	Comments
Sheet Data from the drop down manual										
Status										
Size										
Class Rating										
Filling Type										
Manufacturer and Model										
Rated Pressure										
Comments										

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Facility ID
Facility Type

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Reviewed By	Review Completion Date
2	9709121	Installation	9705121	04/18/03	O. Kos	C. Kos	7/16/2011
		Relinquish		07/21/08	C. Kos		7/16/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

(Class 4 Location)

1440
0.4
N/A
N/A
1440.0
N/A
150.0
0.0%
250.0
0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Design Pressure	Comments
Select Data from the drop-down manual											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop-down manual														

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Description of the Facility
 Facility ID
 Facility Type

HPS 0044 (Refined)
 HR SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	04	10/20/1999	C. Koo	7/15/2011	C. Koo	7/15/2011
2	8785	Redesign	0705 P2	02/11/2008	C. Koo	7/15/2011	C. Koo	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP

The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

1200	0.4	(Class 4 Location)
1657.1		
3633.0		
1200.0		
N/A		
150.0		
2.3%		
260.0		
3.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Th 1	Or	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
				ACTIVE	12"	0.109	0.109	Gr. A25	2.31%	1657	3.65%	1657.1
			1/2" PIPE X 0.109 WALL GR. A25									

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Or	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				ACTIVE	12"	0.109				Weld Cap	3633	1.65%	2.75%	
			1/2" Weld Cap X 0.109 WALL W.P.B.											

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Wende Number	Rated Pressure	Comments
				ACTIVE	3/4"	1500	Weld Tee	3/4" Service Tee Mueller 14-18101	1200	Research
			3/4" Service Tee Mueller 14-18101							

THE LOWEST DESIGN PRESSURE: 1657

3633

2%

3%

THE LOWEST PRESSURE RATING: 1200

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Description of the Facility
 Facility ID
 Facility Type

DESIGN (Required)
 HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-1	6/4/1994	G Kob	7/16/2011	C Kob	7/16/2011
2	878974	Relocation	7207898	7/20/1998	C Kob	7/16/2011	C Kob	7/16/2011
3	970574							

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1012	0.4	(Class 4 Location)
1012.0		
2024.0		
1440.0		
N/A		
160.0		
3.6%		
260.0		
5.9%		

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				ACTIVE	1-1/4"	0.14	Gr. A3E	1012	3.65%	5.83%	1012
			1-1/4" PIPE X 0.14 WALL Gr. A3E								

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				ACTIVE	1-1/4"	0.14			WFB	Weld Cap	2024	2.61%	4.23%	2024
			1-1/4" Weld Cap X 0.14 WALL WFB											
				ACTIVE	1-1/4"	0.14			Gr. A	Transition Fitting	2024	2.06%	4.04%	2024
			1-1/4" Transition Fitting X 0.14 WALL Gr. A											PE Portion was cut off

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				ACTIVE	1-1/4"		Standard	Muller H-17501	1440	Per Muller Research
			1-1/4" Service Tee Muller H-17501 WOP 1440PSIG							

THE LOWEST DESIGN PRESSURE: 1012

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID:
 Facility Type:

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Compiled By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	3/1/1999 C.Kop	C.Kop	7/15/2011	C.Kop	7/15/2011
2	9798121	Reliefnet	9798121	8/18/1999 C.Kop	C.Kop	7/15/2011	C.Kop	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure
- Pipe Design Pressure
- Non-Rated Filling Design Pressure
- Rated Filling Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440 (Class 4 Location)

1440	0.4
N/A	N/A
1440.0	N/A
N/A	N/A
150.0	0.0%
250.0	0.0%
0.0%	0.0%

Table 1 - Pipe Design Pressures

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Sheet Data from the drop down manual											

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Sheet Data from the drop down manual														

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
256	N/A	6609541	2 Save-A-Valve Mueller WCP 1440PSIG	ACTIVE	2"		Save-A-Valve	Mueller	1440	Comments: Fitting is installed at the relief net

THE LOWEST PRESSURE RATING: 1440

THE LOWEST DESIGN PRESSURE:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID:
 Facility Type:

DATE ONLY (Required)
 W.P. SERVICE

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	0-1	9/29/09	C.Kop	7/15/2011	C.Kop	7/15/2011
2	9705121	Relief	9705121	8/19/09	C.Kop	7/15/2011	C.Kop	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % BNYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % BNYS of the Facility at the Proposed System MAOP

1440 (Class 4 Location)

1440	0.4
N/A	N/A
N/A	N/A
1440.0	N/A
N/A	N/A
150.0	0.0%
250.0	0.0%
0.0%	0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% BNYS at Current System MAOP	Design Pressure	% BNYS at Proposed System MAOP	Comments
Select Data from the drop down manual.											

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% BNYS at Current System MAOP	% BNYS at Proposed System MAOP	Comments
Select Data from the drop down manual.													

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	6610941	2" Gate-A-Valve Mueller WOP 1440PSIG	ACTIVE	2"		Gate-A-Valve Mueller	1440	1440	The Fitting was installed over the relief valve leg.

THE LOWEST PRESSURE RATING:

1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: Facility Type:

HP SERVICE:

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
2	870871	Installation	870871	9/23/1990	G Kob	7/15/2011	G Kob	7/15/2011
			870872	8/19/1999	G Kob	7/15/2011	G Kob	7/15/2011

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

1440
0.4 (Class 4 Location)

Design Factor	N/A
Pipe Design Pressure	1440.0
Non-Rated Fitting Design Pressure	N/A
Branch Connection Design Pressure	N/A
Current System MAOP	250.0
The Highest % SMYS of the Facility at the Current System MAOP	0.0%
Proposed system MAOP	250.0
The Highest % SMYS of the Facility at the Proposed System MAOP	0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD	Th	Gr				

THE LOWEST DESIGN PRESSURE:

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD 1	Th 1	OD 2				

THE LOWEST DESIGN PRESSURE:

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down menu:				Manufacturer and Model	Related Pressure	Comments
				Status	Size	Class Rating	Fitting Type			

THE LOWEST PRESSURE RATING:

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

HERS ORG (Redlined)	1001142011
HP SERVICE	1001142011

Facility ID
Facility Type

Job Key	Job Number	Job Descriptions	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	0-4	8/28/1993	S Kob	7/15/2011	C Kob	7/15/2011
2	278914	Relinquent	970412	9/19/1998	D Kob	7/15/2011	C Kob	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

Pipe Design Pressure

Non-Rated Fitting Design Pressure

Rated Fitting Rated Pressure

Branch Connection Design Pressure

Current System MAOP

The Highest % SNYS of the Facility at the Current System MAOP

Proposed system MAOP

The Highest % SNYS of the Facility at the Proposed System MAOP

1440 (Class 4 Location)

0.4

N/A

N/A

1440.0

N/A

150.0

0.0%

200.0

0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Enter MW, PCW or PC in this field			Status	OD	Th	Gr	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
				MW	PCW	PC								
Select Data from the drop down manual.														

THE LOWEST DESIGN PRESSURE:

1440

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Enter MW, PCW or PC in this field			Status	OD 1	Th 1	OD 2	Th 2	Gr	Design Pressure	% SNYS at Current System MAOP	% SNYS at Proposed System MAOP	Comments
				MW	PCW	PC										
Select Data from the drop down manual.																

THE LOWEST DESIGN PRESSURE:

1440

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Enter MW, PCW or PC in this field			Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				MW	PCW	PC							

THE LOWEST PRESSURE RATING:

1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility
 Facility ID
 Facility Type

HP-SERVICE (RE-ENGINEERING)
 HP-SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	07/27/94	07/27/94	C Koop	7/15/2011	C Koop	7/15/2011
2	70912	Relocation	9/08/12	9/08/12	C Koop	7/15/2011	C Koop	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP

The Highest % SMYS of the Facility at the Current System MAOP
 Proposed system MAOP
 The Highest % SMYS of the Facility at the Proposed System MAOP

1440
 0.4 (Class 4 Location)

1440
0.4 (Class 4 Location)
N/A
N/A
1440.0
N/A
150.0
0.0%
250.0
0.0%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD	Gr				

THE LOWEST DESIGN PRESSURE: []

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
				Status	OD 1	Th 1				

THE LOWEST DESIGN PRESSURE: []

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Select Data from the drop down manual			Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
				Status	Size	Gr					

THE LOWEST PRESSURE RATING: 1440

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: _____
 Facility Type: _____

HES-0051 (Required)
 HP SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	N/A	Installation	D-4	7/7/1999	C Koo	7/15/2011	C Koo	7/19/2011
2	9705121	Relinements	9705121	11/27/1999	G Koo	7/15/2011	C Koo	7/19/2011
3	89799986	Modified Refinement Method	N/A	9/19/2011	D Frieze	9/16/2011	D Frieze	4/26/2012

Facility Evaluation Summary

- Facility Design Pressure
- Design Factor
- Pipe Design Pressure
- Non-Rated Fitting Design Pressure
- Rated Fitting Rated Pressure
- Branch Connection Design Pressure
- Current System MAOP
- The Highest % SMYS of the Facility at the Current System MAOP
- Proposed system MAOP
- The Highest % SMYS of the Facility at the Proposed System MAOP

250	(Class 4 Location)
0.4	
1291.4	
N/A	
250.0	
N/A	
150.0	
2.8%	
250.0	
4.9%	

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
1	N/A	N/A	3/4" PRE-X.0.113 WALL Gr. A25	ACTIVE	3/4"	0.113	Gr. A25	1291	2.79%	4.95%	100% OK Spec

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
Select Data from the drop down manual														
THE LOWEST DESIGN PRESSURE: 1291														
3%														
5%														

Table 3 - Rated Fittings Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
1	N/A	N/A	3/4" Service Tee Mueller H-17500 WOP 250PSIG	ACTIVE	3/4"		Socket Cap	Mueller H-17500	250	Per Standard Research
3	N/A	N/A	3/4" Socket Cap WOP 3000PSIG	ACTIVE	3/4"		Socket Cap		3000	

THE LOWEST PRESSURE RATING: 250

HIGH PRESSURE FACILITY DESIGN PRESSURE CALCULATION (DRAFT01142011)

Descriptions of the Facility

Facility ID: 1231
 Facility Type: WATER SERVICE

Job Key	Job Number	Job Description	Drawing Number	Installation Date	Completed By	Completion Date	Reviewed By	Review Completion Date
1	61043	WATER SERVICE	D-1	8/29/1998	C. Koo	7/15/2011	C. Koo	7/15/2011

Facility Evaluation Summary

Facility Design Pressure

Design Factor	Class 4 (Location)
Pipe Design Pressure	1200
Non-Rated Fitting Design Pressure	0.4
Rated Fitting Rated Pressure	1281.4
Branch Connected Design Pressure	2993.0
Current System MAOP	1200.0
The Highest % SMYS of the Facility at the Current System MAOP	N/A
Proposed system MAOP	150.0
The Highest % SMYS of the Facility at the Proposed System MAOP	2.8%
	250.0
	4.8%

Table 1 - Pipe Design Pressure

Job Key	ITEM #	MID	Description	Status	OD	Th	Gr	% SMYS at Current System MAOP	Design Pressure	% SMYS at Proposed System MAOP	Comments
	1	N/A	3/4" PIPE X 0.113 WALL GR A2E	ACTIVE	3/4"	0.113	Gr A2E	2.78%	1281	4.82%	

Table 2 - Non-Rated Fitting Design Pressure

Job Key	ITEM #	MID	Description	Status	OD 1	Th 1	OD 2	Th 2	Gr	Fitting Type	Design Pressure	% SMYS at Current System MAOP	% SMYS at Proposed System MAOP	Comments
	1	N/A	3/4" Weld Cap X 0.113 WALL WPB	ACTIVE	3/4"	0.113			WPB	Weld Cap	2683	1.88%	3.32%	
	2	N/A	3/4" Transition Fitting X 0.113 WALL GR A	ACTIVE	3/4"	0.113			Gr A	Transition Fitting	2683	2.32%	3.87%	Only was portion of the fitting installed.

Table 3 - Rated Fitting Rated Pressure

Job Key	ITEM #	MID	Description	Status	Size	Class Rating	Fitting Type	Manufacturer and Model Number	Rated Pressure	Comments
	1	N/A	3/4" Service Tee Mueller H-6100 WOP 1200PSIG	ACTIVE	3/4"		Service Tee	Mueller H-6100	1200	Per Skidblad Research

THE LOWEST DESIGN PRESSURE: 1281

THE LOWEST DESIGN PRESSURE: 2683

THE LOWEST DESIGN PRESSURE: 1200