

24-062
M&L Construction

The gas line is abandoned the power is not. Power was not marked, but we stopped to wait for the hydrovac to expose the lines in the exit pit and found an extra electric line.... Once marked we found this.

