

**OPTIONAL FIELD DATA COLLECTION FORM FOR INTERSTATE OPERATORS**

**NOTES-FIELD INSPECTION**

**Company:** Puget Sound Energy

**Date(s):** August 4, 2011

**Unit:** Sumas Gas Pipeline

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
Sumas PV-126 Run #1 Run #2								456.5 454.0	PSE #4700.1600 Pressure Valve operation is tested by stroking the valve.
Sumas Valve #7932 Pipe to Soil Reads			-1.493 V						PSE #4515.1210 Exercised valve an eighth of a turn.
Test Site #TS-066842 Sumas at Rock Road			-1.485 V						
Check Odorant Levels in pipeline at OT-0204									Gas in Air 0.337%