

# Exhibit SLM-3

Testimony of  
Qwest Communications Corporation  
Witness Victoria Hunnicutt-Bishara  
In ICC Docket No. 05-0675

ILLINOIS  
COMMERCE COMMISSION

BEFORE THE ILLINOIS COMMERCE COMMISSION  
2006 FEB 12 52

Docket No. 05-0675 CHIEF CLERK'S OFFICE

**RESPONSE TESTIMONY OF  
VICTORIA HUNNICUTT-BISHARA  
FOR  
QWEST COMMUNICATIONS CORPORATION**

**QCC Exhibit 1.0**

**PUBLIC VERSION**

**FEBRUARY 2, 2006**

**TABLE OF CONTENTS**

**I. INTRODUCTION..... 1**

**II. THE SBC PER AMP PROPOSAL WILL NOT BE COST OR REVENUE  
NEUTRAL ..... 3**

**III. A BASIC UNDERSTANDING OF POWER REQUIREMENTS EXPLAINS  
WHY SBC’S PROPOSAL IS NOT REVENUE OR COST NEUTRAL..... 8**

**IV. CONCLUSION ..... 17**

1 **I. INTRODUCTION**  
2

3 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

4 A. My name is Victoria S. Hunnicutt-Bishara. My business address is 1801 California St.  
5 #4760, Denver, Colorado.  
6

7 **Q. PLEASE STATE YOUR EMPLOYER AND POSITION.**

8 A. I am employed by Qwest Services Corporation as a senior technical analyst in the Public  
9 Policy department.  
10

11 **Q. PLEASE DESCRIBE YOUR EDUCATION BACKGROUND AND  
12 TELECOMMUNICATIONS EMPLOYMENT EXPERIENCE**

13 A. I have a Bachelor of Science in Electrical Engineering from the University of Virginia. I  
14 have taken numerous telecommunications seminars and classes including graduate  
15 courses in Telecommunications Management. I have been employed by Qwest (formerly,  
16 US West) since 1998. My original position was with the transport modeling team in the  
17 Pricing and Regulatory Matters department as a Cost Analyst. In 1999, I assumed  
18 responsibility for the Collocation Cost Model, programming the model and producing the  
19 cost studies for the various Qwest Corporation cost dockets. In 2003, I began working  
20 with the loop modeling team working with the loop model and creating documentation  
21 for the Qwest Corporation loop program, LoopMod. In 2004, I began work as a technical  
22 analyst and developer in the Public Policy department. Presently, my responsibilities

23 include technical and cost analyses, as well as providing subject matter expert support on  
24 collocation issues in regulatory proceedings.

25

26 **Q. HAVE YOU EVER FILED TESTIMONY FOR QWEST COMMUNICATIONS**  
27 **CORPORATION BEFORE?**

28 A. No, I have not previously filed testimony for Qwest Communications Corporation  
29 (“QCC”).

30

31 **Q. YOU MENTIONED BOTH QWEST CORPORATION AND QCC. PLEASE**  
32 **BRIEFLY DESCRIBE THE RELATIONSHIP BETWEEN THE TWO**  
33 **COMPANIES.**

34 A. Qwest Corporation is the ILEC in a fourteen state region occupying most of the western  
35 and northwestern United States. Qwest Corporation has no business operations in  
36 Illinois, and is not participating in this proceeding. QCC is an interexchange carrier,  
37 operator services provider and a CLEC. QCC is certificated to provide  
38 telecommunications services in Illinois. QCC is collocated in [BEGIN  
39 **CONFIDENTIAL] XX [END CONFIDENTIAL] SBC Illinois (“SBC”) central offices,**  
40 and provides both facilities-based and resold services in competition with SBC and others  
41 in Illinois.

42

43 Qwest Corporation and QCC are both direct subsidiaries of Qwest Services Corporation,  
44 which is a direct subsidiary of the ultimate corporate parent company, Qwest  
45 Communications International Inc.

46 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

47 A. The purpose of my testimony is to demonstrate that, contrary to SBC's testimony, the  
48 proposed SBC collocation tariff modifications will not be revenue neutral or anywhere  
49 near revenue neutral to SBC or cost neutral to CLECs in Illinois. Instead, I would fully  
50 expect CLECs to incur far greater collocation power consumption expenses and SBC to  
51 obtain far greater revenue. I expect that revenue shift will far exceed the 38% under-  
52 billing SBC claims in its testimony. It certainly will for QCC, as I illustrate below.

53  
54 I have organized the main body of my testimony into two sections. The first illustrates  
55 the net effect of the SBC proposal on QCC, and demonstrates that the proposal is far from  
56 revenue or cost neutral. The second substantive section provides explanation, from a  
57 technical perspective, why the simple conversion from kilowatt hours ("kWh") to Amps  
58 would not be revenue neutral in this case. In this latter section, I discuss the different  
59 types of power loads using, for illustrative purposes, common electrical equipment with  
60 which most of us are familiar. In addition, I have included an example using equipment  
61 specific to the telecommunications industry.

62

63 **II. THE SBC PER AMP PROPOSAL WILL NOT BE COST OR REVENUE**  
64 **NEUTRAL.**

65

66 **Q. DOES SBC ARGUE THAT ITS PER AMP PROPOSAL WILL BE REVENUE**  
67 **NEUTRAL?**

68 A. Yes, SBC does claim this. Specifically, at page 7 of her Direct Testimony, SBC witness  
69 Stephanie Brissenden describes the proposal as doing "nothing to alter the level of the

70 approved per KWH cost; it merely converts an existing approved cost (per KWH) to a  
71 different unit of measure (per amp).” She then states, “[t]here is no increased SBC  
72 Illinois cost being attributed to CLECs’ power usage with this simple conversion  
73 proposal...[which] will result in a neutral net effect, from a cost perspective, to both the  
74 CLECs and SBC Illinois.”

75

76 **Q. DO YOU AGREE WITH MS. BRISSENDEN THAT THIS “SIMPLE**  
77 **CONVERSION” WILL BE REVENUE AND COST NEUTRAL?**

78 A. No, I do not agree. SBC’s conversion proposal will be far from revenue or cost neutral to  
79 the CLECs or SBC Illinois, and will significantly advantage SBC to the detriment of, not  
80 only QCC, but, presumably, all CLECs relying on SBC collocation in Illinois. In fact,  
81 SBC claims that the power metering units (“PMUs”) it designed and installed currently  
82 under-measure DC power consumption by **36% or 38%** on average.<sup>1</sup> Yet, SBC’s  
83 conversion proposal would increase QCC’s DC power costs **over 8900%** if QCC makes  
84 no changes to its current power requests and **approximately 2700%**, even if QCC takes  
85 advantage of SBC’s power fuse reduction offer.<sup>2</sup> The calculations associated with these  
86 increases are discussed in greater detail below.

87

---

<sup>1</sup> See Direct Testimony of Jeanne Muellner, SBC Illinois Exhibit 4.0, at 15 (“Leakage current is present in CLEC collocation arrangements. The leakage ranged as high as 90% and averaged 38%”); SBC Revised Response to QCC Data Request 2.19 (“As stated in the direct testimony of Mr. Parker [citation omitted], AT&T Illinois relies on the 2002 Superior central office study (36%) when estimating its revenue shortfall.”).

<sup>2</sup> Proposed Tariff Ill. CC. No. 20, Part 23, Section 4.1.C.18-C.20 (Original Sheet 31.6).

88 Q. CAN YOU QUANTIFY THE COST IMPACT ON QCC OF SBC'S PER AMP  
89 PROPOSAL?

90 A. Yes, I can. The SBC rate conversion proposal would result in QCC's power consumption  
91 charges increasing by anywhere from 2700% to 8900%. These calculations are broken  
92 down more specifically in Schedule VHB-1, attached.

93  
94 The wide range of the increase (2700% to 8900%) will depend upon to what extent QCC  
95 is able to alter its power request from SBC in the various central offices. As Schedule  
96 VHB-1 illustrates, QCC currently has ordered DC power ranging from [BEGIN

97 **CONFIDENTIAL]** XXX  
98 XXX  
99 XXX  
100 XXX  
101 XXX  
102 XXX  
103 XXX  
104 XXXXXXXXXXXXXXXXXXXXXXX.

105  
106 XXX<sup>3</sup> XXXXXXXXXXXXXXXXXXXXXXX  
107 XXX

<sup>3</sup> The Commission should bear in mind that QCC invested significant sums to obtain and build out its collocation spaces. Decommissioning involves significant expense, as can fuse reductions and subsequent fuse expansions. Prematurely decommissioning or downsizing sites, when QCC has no firm business plans to abandon service in a particular wire center, is not economically reasonable, especially given the cost QCC will have to incur to subsequently increase its power order should it choose to expand service from that wire center.



108 XXX  
109 XXX  
110 XXX  
111 XXX  
112 XXX  
113 XXX  
114 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX [END CONFIDENTIAL]

115

116 **Q. WON'T THE INCREASED RECURRING CHARGES YOU PREDICT FOR QCC**  
117 **SIMPLY COVER THE AMOUNT SBC STATES ITS PMUS ARE**  
118 **UNDERMEASURING TODAY?**

119 A. No, QCC's increased cost will far exceed the amount SBC claims it is losing as a result  
120 of current leakage. As noted above, SBC claims (based on the study conducted by Ms.  
121 Muellner and the earlier Telcordia study SBC commissioned) the PMUs are under-  
122 measuring, thus, SBC is under-billing, DC power consumption by 38%. Actually, SBC's  
123 own evidence seems to cut that percentage dramatically. In its conclusion, the Telcordia  
124 study describes the DC leakage issue as follows, [BEGIN CONFIDENTIAL] XXXXX  
125 XXX  
126 XXX  
127 XXXX<sup>4</sup> [END CONFIDENTIAL] Completely leaving aside how indefinite, imprecise,  
128 and equivocal Telcordia's leakage findings appear to be, SBC's own evidence suggests  
129 (even if the Commission agrees that a leakage problem exists and leads to 36% or 38%

---

<sup>4</sup> See Direct Testimony of Marvin Nevels, Schedule MN-6, at 26.

130 under-measurement where leakage occurs), the average under-billing should be found to  
131 be no more than [BEGIN CONFIDENTIAL] XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX  
132 XXX  
133 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX [END CONFIDENTIAL] The net effect of  
134 SBC's proposal on QCC will obviously dwarf SBC's alleged measure of under-billing, to  
135 the extent the Commission believes SBC has supported its claim of DC leakage.

136

137 **Q. DID SBC SUGGEST OR EVEN EXPLORE ANY ALTERNATIVE SOLUTIONS**  
138 **TO THE ALLEGED LEAKAGE PROBLEM PRIOR TO FILING ITS PER AMP**  
139 **PROPOSAL?**

140 A. Apparently, SBC did not explore, nor consider, alternative solutions. No alternatives  
141 were identified in SBC's testimony and, in discovery, SBC failed to identify whether it  
142 even considered any alternative fixes to the leakage issue on which this proceeding is  
143 based.<sup>5</sup> SBC seems to have ignored the simplest, least disruptive and most obvious fix,  
144 specifically, the addition of a factor to the monthly recurring charge for power  
145 consumption. If, for example, the Commission finds that SBC has proven the PMUs  
146 under-measure DC power consumption by 36%, SBC could eliminate the problem  
147 entirely, without any undue increased cost for CLECs or SBC, by increasing the recurring  
148 charge for power consumption from \$.28 per kWh by 36% to \$.38 per kWh. As  
149 mentioned above, it appears, from SBC's own direct case, there is at most a [BEGIN  
150 CONFIDENTIAL] XXX  
151 XXX

152 XXXXXXXXXXXXXXXXXXXXXXXXXXXXXXXX [END CONFIDENTIAL] This simple  
153 solution would permit SBC to recover all future lost revenue without fundamentally  
154 shifting the power billing methodology in Illinois from a usage-based system to a  
155 capacity-based system.

156  
157 **III. A BASIC UNDERSTANDING OF POWER REQUIREMENTS EXPLAINS WHY**  
158 **SBC'S PROPOSAL IS NOT REVENUE OR COST NEUTRAL.**  
159

160 **Q. IN THE SECTION ABOVE, YOU INDICATED THAT QCC'S POWER COSTS**  
161 **WOULD DRAMATICALLY INCREASE, EVEN IF QCC TAKES ADVANTAGE**  
162 **OF SBC'S POWER FUSE REDUCTION PROPOSAL. HOW IS THAT**  
163 **POSSIBLE IF SBC IS SIMPLY SUGGESTING A CONVERSION FROM ONE**  
164 **UNIT OF MEASURE TO ANOTHER?**

165 A. Understanding the answer to this question is really the key to understanding why SBC's  
166 "simple conversion" from per-kWh to per-Amp measurement is anything but a simple  
167 conversion without revenue and cost impacts. Underlying SBC's incorrect assertion that  
168 its proposal will be revenue and cost neutral is the false assumption that  
169 telecommunications equipment draws power at the maximum load required twenty-four  
170 hours a day, seven days a week. This assumption of a maximum and linear power load is  
171 erroneous, as I will explain below.

172

---

<sup>5</sup> SBC's response to QCC Data Request 1.16.

173 **Q. AS BACKGROUND, PLEASE BRIEFLY EXPLAIN THE BASIC CONCEPTS**  
174 **PERTAINING TO TELECOMMUNICATIONS EQUIPMENT POWER.**

175 A. The power purchased from the electric utility is Alternating Current (AC). After the AC  
176 power reaches the telephone company's central office, it is converted to Direct Current  
177 (DC). It is DC power that is delivered to the collocation sites in the central offices to  
178 power CLECs' telecommunications equipment. Power, measured in Watts, is comprised  
179 of Voltage and Current. Power is equal to Voltage times Current. Voltage is measured in  
180 Volts (V). If the voltage is Direct Current (DC), as with the batteries and  
181 telecommunications equipment, the unit of measurement is VDC. Telecommunications  
182 equipment generally requires (nominally) -48 VDC. Current is measured in amperes  
183 (Amps). The measure of power consumed over time is Watt-hours. Since the  
184 measurement is taken over time, a large number of Watts can be consumed. To keep the  
185 numbers manageable, wattage is typically divided by 1000 and "kilo" is added to the unit  
186 of measure: 1000-Watt-hour, or kilowatt-hour, or kWh. The kWh is equivalent to one  
187 kilowatt (1 kW) of power expended for one hour of time.

188  
189 Equipment power specifications generally list recommendations for the power, the  
190 voltage, and the amperage. Below is an example of how a power specifications list might  
191 look:

- 192 ○ Recommended Input Voltage: -48 VDC
- 193 ○ Acceptable Input Voltage Range: -40 to -56.7 VDC
- 194 ○ Maximum Power Consumption: 1060 W

195           ○ Recommended Amperage: 30 A

196

197 **Q. DOES ALL ELECTRICAL EQUIPMENT CONSUME POWER AT A**  
198 **CONSTANT RATE?**

199 A. No, all electrical equipment does not draw power at a constant rate, although some does.  
200 Devices such as incandescent light bulbs, toasters, and heating devices are classified as  
201 resistive loads, or constant loads. A “load”, as used here, is a device that consumes  
202 power. Generally speaking, these loads will consume power at a constant rate. The rated  
203 power of a resistive device, in Watts, is the amount of power the device will typically  
204 consume. For example, a 60 Watt light bulb will draw the rated power of 60 Watts at a  
205 constant rate while lit.

206

207 Other electrical equipment, such as household appliances, computers and  
208 telecommunications equipment are reactive loads.<sup>6</sup> These power loads are non-linear,  
209 meaning they do not consume power at a constant rate. For these types of electrical  
210 equipment, the running loads may be small compared to the starting load (i.e., the load  
211 when the equipment is initially started up). The required starting power of reactive loads  
212 can be many times higher than the running load.

213

---

<sup>6</sup> See, for example, [www.simplexdirect.com/LoadBank/types.html](http://www.simplexdirect.com/LoadBank/types.html).

214 **Q. PLEASE CLARIFY THE DIFFERENCE BETWEEN A REACTIVE LOAD AND**  
215 **A RESISTIVE LOAD.**

216 A. For ease of reference, I will use common, household examples. The light bulb, a resistive  
217 load mentioned above, requires no additional wattage (power) for lighting. The running  
218 wattage requirements are as indicated on the bulb. With the exception of a dimmer, the  
219 intensity of the light remains constant as does the power the light bulb consumes. For the  
220 light bulb, the startup load and the running load are the same. So, if one were to order  
221 power for this light bulb, the rated wattage on the bulb could be ordered.

222  
223 On the other hand, a refrigerator is an example of a reactive load. Its running power  
224 requirement is approximately 700 Watts with an additional starting wattage requirement  
225 of 2200 Watts. The power load of the refrigerator will vary after startup depending on  
226 such variables as the outside temperature, how full the refrigerator is and how many times  
227 the refrigerator door is opened. If you stand by the refrigerator long enough, you will hear  
228 when the variations in the power load occur as it kicks on and off to maintain the preset  
229 internal temperature. As the outside temperature rises, more power is required to  
230 maintain the preset internal temperature.

231  
232 **Q. IS THERE A DIFFERENCE BETWEEN THE MANUFACTURER'S**  
233 **RECOMMENDED AMPERAGE, THE MAXIMUM POWER CONSUMPTION**  
234 **AND THE POWER ACTUALLY CONSUMED BY ELECTRICAL EQUIPMENT?**

235 A. Yes, there is. Since reactive loads do not consume power at a constant rate over time,  
236 there can be a significant difference among the recommended amperage, maximum power

237 requirements for the equipment, and the actual power consumed during normal  
238 operations. Today, CLECs pay SBC Illinois for actual power consumed. Under SBC's  
239 proposal, CLECs would pay SBC for the combined recommended amperage of all the  
240 equipment installed in its collocation space. Let me explain the differences among  
241 recommended amperage, maximum power requirements and actual power consumed.

242  
243 The recommended amperage is the manufacturer's recommended power level the power  
244 plant must be provisioned to deliver to the equipment for proper operation of the  
245 equipment. In other words, the recommended amperage is the power level QCC must  
246 order to operate the equipment properly. The recommended amperage is a higher number  
247 than the maximum power consumption to provide a necessary buffer at startup or at very  
248 low voltage during a long battery discharge.

249  
250 The maximum power consumption, a lesser number than the recommended amperage,  
251 represents the expected maximum amount of power the equipment would draw when  
252 operating fully provisioned and experiencing its maximum usage under normal operating  
253 conditions. For example, in the case of a multiplexer, maximum power consumption  
254 would be expected to occur when all card slots are filled and the traffic through each card  
255 is operating at its maximum.

256

257 The actual power consumed, a lesser amperage than the maximum power consumption,  
258 would vary over time with the configuration of the equipment, as well as the usage, or  
259 traffic as in the case of the multiplexer mentioned above.

260  
261 SBC's own technical publication (Tech Pub: SBC-TP-76400: Detail Engineering  
262 Requirements, dated November 10, 2005) recognizes the need to provision and fuse  
263 power for SBC's own telecommunications equipment at a power level higher than the  
264 equipment actually consumes during normal operating use. An excerpt of that technical  
265 publication (Section 12, page 12-11, section 6.3.1) is attached as Schedule VHB-2. The  
266 List 2 current drain, which is synonymous with recommended amperage, is the level of  
267 fusing required by the equipment manufacturer to take into consideration the worst  
268 case current drain. The power distribution cables must be fused at this level  
269 for overcurrent protection.

270

271

272 **Q. USING TELECOMMUNICATIONS EQUIPMENT, CAN YOU STEP THROUGH**  
273 **THE POWER SPECIFICATIONS MENTIONED ABOVE AND HOW THEY**  
274 **RELATE TO THE POWER CONSUMED AND THE POWER ORDERED?**

275 A. Yes, with the background provided above, I will return the example of the multiplexer. A  
276 multiplexer is a device commonly used in telecommunications applications. The  
277 multiplexer enables a number of communications signals to be combined into a single  
278 broadband signal and transmitted over a single circuit. When the single broadband signal



279 reaches its destination, it can be dissected into the original signals, preserving the  
280 integrity of each separate signal.

281  
282 One example of a multiplexer is the Cisco ONS 15454 (formerly known as Cerent 454)  
283 platform. The Cisco ONS 15454 combines Internet Protocol (IP) over Synchronous  
284 Optical Network/Synchronous Digital Hierarchy (SONET/SDH) with Asynchronous  
285 Transfer Mode (ATM), Frame Relay and Time Division Multiplexing (TDM). The unit  
286 contains a 240 Gbps (gigabits per second) shelf with multiple, general-purpose card slots  
287 for interfaces from DS1 to OC-192. Stated another way, the Cisco ONS 15454 is a fast,  
288 multipurpose piece of telecommunications equipment with multiplexing capabilities.

289  
290 According to the technical specifications for the ONS 15454, the manufacturer's  
291 recommended power requirements (referred to as the Recommended Amperage) for  
292 proper operation of the device is 30 Amps. To order the required power accurately  
293 commensurate with the power requirements of QCC's collocated equipment, QCC would  
294 have to order power at a minimum of 30 Amps for this single piece of equipment. The  
295 Maximum Power Consumption for the same system is 1060 Watts. The 1060 Watts of  
296 power equates to 20 Amps at a normal central office operating voltage of -52.8 VDC.<sup>7</sup>  
297 Please note, the Recommended Amperage (30 Amps) is a 50% increase over the  
298 Maximum Power Consumption (20 Amps), even assuming the equipment is running at  
299 maximum operating power consumption twenty-four hours a day, seven days a week.

---

<sup>7</sup> Amps (20) = Watts (1060) / Volts (52.8).

300

301 **Q. USING THE ONS 15454 EXAMPLE ABOVE, PLEASE DISCUSS HOW THE**  
302 **POWER ORDERED COMPARES TO THE POWER ACTUALLY CONSUMED.**

303 A. The ONS 15454 can be configured in a number of different ways depending on the cards  
304 installed. The operating power load will vary with the cards installed in the shelf and the  
305 traffic on the cards. The ONS 15454 would be operating at its Maximum Power  
306 Consumption (20 Amps) when the shelf is fully carded and usage is at its maximum.  
307 Based on QCC's experience with this equipment, traffic variations through the shelf can  
308 result in a 20% swing in power consumption, thus reducing the operating power load  
309 from the 20 Amp Maximum Power Consumption to around 16 Amps.

310  
311 To summarize, based on the technical specifications of the ONS 15454 and the usage of  
312 the shelf, the operating semi-continuous power load operates around 16 Amps for  
313 extended periods of time. This does not take into account the lesser loads that would be  
314 consumed when the shelf is not fully carded and utilized. Yet, QCC would be required,  
315 under SBC's proposal, to order and pay for power for this equipment at a minimum of 30  
316 Amps. The provisioned amperage (30 Amps) required to operate the equipment properly,  
317 as recommended by the manufacturer, is nearly twice the amperage of the average  
318 operating power load (16 Amps) when fully carded and utilized.

319  
320 This disparity is even more dramatic in the event QCC is using equipment in a given  
321 collocation site at less than its full capacity. If, for instance, QCC is serving fewer

322 customers than it has in the past (or hopes to in the future) from a particular central office,  
323 its average power draw will be less than 16 Amps. Nevertheless, because SBC's proposal  
324 will require collocators to pay for all recommended amperage and will not in any way  
325 discount the per-Amp charge to reflect the reality that telecommunications equipment  
326 does not constantly draw power at that recommended amperage, the proposal will result  
327 in QCC paying as if the equipment were drawing 30 Amps twenty-four hours a day, seven  
328 days a week. It is for this reason that SBC's "simple conversion" proposal is not revenue  
329 neutral for SBC and not cost neutral for CLECs.

330  
331 The disparity among recommended amperage, maximum power consumption and actual  
332 power consumed is not limited to the Cisco multiplexer. I have attached as Schedule  
333 VHB-3 a case study performed by Convergence IP Technology (a systems integrator and  
334 managed services provider) describing the technical specifications of two Fujitsu  
335 multiplexers. On pages 3 and 5 of Schedule VHB-3, under the heading "Power  
336 Consumption," Convergence distinguishes between the "maximum" power consumption  
337 and the significantly lower "typical" power consumption. This case study indicates that,  
338 during Convergence's testing, one Fujitsu multiplexer *typically* ran 21% below its  
339 maximum power consumption, while the other Fujitsu multiplexer *typically* ran 73%  
340 below its maximum power consumption.

341  
342  
343

344 **IV. CONCLUSION**

345

346 **Q. WILL YOU PLEASE SUMMARIZE YOUR TESTIMONY?**

347 A. Yes, I will. My testimony establishes that, contrary to Ms. Brissenden's testimony for  
348 SBC, the SBC proposal will not be revenue neutral or anywhere near revenue neutral to  
349 SBC or cost neutral to CLECs in Illinois. Instead, CLECs will incur far greater  
350 collocation power consumption expenses and SBC will obtain far greater revenue. This  
351 significant shift will occur because, while SBC characterizes its proposal as a simple  
352 conversion from one unit of measure (kWh) to another (Amp), the per-Amp methodology  
353 will greatly benefit SBC by allowing it to bill CLECs for power not actually consumed.  
354 This will lead to a dramatic increase in expense for CLECs and a dramatic increase in  
355 revenue for SBC in Illinois. If SBC is truly concerned its PMUs are under-measuring DC  
356 power consumed by CLECs by 36%, it could have simply recommended that the monthly  
357 recurring charge of \$.28 per kWh be increased by 36%. Instead, SBC proposed a change  
358 in methodology that will increase CLEC costs, in QCC's case, between 2700% and  
359 8900%.

360

361 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

362 A. Yes, it does.

363

**BEFORE THE ILLINOIS COMMERCE COMMISSION**

**Docket No. 05-0675**

**SURREBUTTAL TESTIMONY OF  
VICTORIA HUNNICUTT-BISHARA**

**FOR**

**QWEST COMMUNICATIONS CORPORATION**

**QCC Exhibit 1.1**

**March 29, 2006**

1 **I. INTRODUCTION**

2  
3 **Q. PLEASE STATE YOUR NAME.**

4 A. My name is Victoria Hunnicutt-Bishara.

5  
6 **Q. ARE YOU THE SAME VICTORIA HUNNICUTT-BISHARA WHO SUBMITTED**  
7 **RESPONSE TESTIMONY IN THIS DOCKET ON FEBRUARY 2, 2006?**

8 A. Yes, I am.

9  
10 **Q. WHAT IS THE PURPOSE OF YOUR SURREBUTTAL TESTIMONY?**

11 A. My testimony responds primarily to the testimony of SBC witness Roman Smith.

12 Specifically, I will address SBC's new fusing proposal.

13  
14 **II. SBC'S NEW FUSING PROPOSAL**

15  
16  
17 **Q. IS MR. SMITH'S REBUTTAL TESTIMONY REGARDING FUSING**  
18 **CONSISTENT WITH HIS DIRECT TESTIMONY ON FUSING?**

19 A. No, it is not consistent. It appears SBC has revised its original fusing proposal.

20  
21 **Q. HOW DOES MR. SMITH'S REBUTTAL TESTIMONY MODIFY SBC'S FUSING**  
22 **PROPOSAL?**

23 A. In his direct testimony, Mr. Smith stated, "Pursuant to its internal engineering practices,  
24 SBC Illinois plans to fuse the power leads at least **125% of the requested amount** in  
25 order to build in a margin for growth. This is an internal practice; it is not a requirement."  
26 [emphasis added] (Page 12, lines 256-258)

27

28 In his rebuttal testimony, Mr. Smith states, “AT&T Illinois is willing to maintain existing  
29 fuses provided they are no greater than 100% of the capacity of the power cable and  
30 provided that the fuse size is not more than **200% of actual usage** specified by the  
31 CLEC.” [emphasis added] (Page 11, lines 196-198) Originally, SBC was proposing to  
32 size the fuse for the power leads at 125% of the request amount. In the revised proposal,  
33 the fuse size is limited by “actual usage.”

34

35 **Q. IS SBC’S MODIFIED FUSING PROPOSAL FOR CLECS CONSISTENT WITH**  
36 **SBC’S OWN ENGINEERING REQUIREMENTS WITH RESPECT TO FUSING**  
37 **FOR ITS OWN EQUIPMENT?**

38 A. No, it is not. SBC’s internal engineering requirements, as set out in SBC’s own technical  
39 publication (SBC-TP-76400, dated November 11, 2005)<sup>1</sup> direct SBC personnel to  
40 determine the minimum fuse size based on the List 2 Drain, not usage. Specifically,  
41 “Overcurrent<sup>2</sup> protection (fuses or circuit breakers) and secondary distribution cables are  
42 sized using List 2 current drain. List 2 current drain represents the peak current for a  
43 circuit under worst-case operating conditions.” (Section 6.3.1, page 12-11).

44

45 **Q. IS SBC’S MODIFIED FUSING PROPOSAL FOR CLECS CONSISTENT WITH**  
46 **NATIONAL FIRE SAFETY STANDARDS?**

47 A. No, SBC’s fusing proposal is not consistent with National Fire Protection Agency  
48 (“NFPA”) Code 70:National Electrical Code (“NEC”). Section 215.3, Overcurrent

---

<sup>1</sup> An excerpt from SBC-TP-76400 is attached to my surrebuttal testimony as Schedule VHB-4.

<sup>2</sup> Overcurrent is a condition which exists on an electrical circuit when the normal load current is exceeded. Overcurrents take on two separate characteristics - overloads and short circuits.

49 Protection (page 99), of the NEC 2005 Handbook (NFPA 70:National Electrical Code)<sup>3</sup>  
50 states, “Where a feeder supplies continuous loads or any combination of continuous and  
51 noncontinuous loads, the rating of the overcurrent device **shall not be less than** the  
52 noncontinuous load plus 125 percent of the continuous load.” [emphasis added] A  
53 *continuous load* is defined by the Institute of Electrical and Electronics Engineers (IEEE)  
54 The Authoritative Dictionary of IEEE Standards Terms (IEEE 100), Seventh Edition, to  
55 be “A load where the current continues for 3 h[ours] or more.” A *noncontinuous load* is  
56 a load not classified as continuous and is the difference, in amps, between the List 1 drain  
57 (continuous load) and the List 2 drain. More specifically, continuous and noncontinuous  
58 loads are ranges. The amperage limit for the continuous load is the rated List 1 current  
59 drain of the equipment. The amperage range for the noncontinuous load is the amperage  
60 between the List 1 current drain and the List 2 current drain.

61  
62 SBC’s revised fusing proposal for CLECs bases the fuse size on actual usage at any  
63 moment in time (regardless of whether the collocated equipment is being under-utilized,  
64 is not fully carded or is serving few customers), not the peak current of the load (List 2  
65 drain) as specified by the NFPA and network element manufacturers.

66  
67

68 **Q. WHAT ARE LIST 1 AND LIST 2 CURRENT DRAINS?**

69 A. List 1 and List 2 current drains, sometimes referred to simply as List 1 and List 2 drains,  
70 are equipment specifications determined by the equipment manufacturer providing the

---

<sup>3</sup> Excerpts from the 2005 and 1990 NEC Handbooks (NFPA 70) are attached to my surrebuttal testimony as Schedule VHB-5.



71 maximum power usages for two usage scenarios. The List 1 current drain, in amperes, is  
72 the average “busy-hour” current draw during normal plant operation, assuming maximum  
73 configuration of the equipment. The List 2 current drain, in amperes, is the peak current  
74 under worst case conditions of voltage, traffic, and equipment configuration.

75

76 **Q. WHAT IS THE PURPOSE OF THE LIST 1 AND LIST 2 DRAIN**  
77 **SPECIFICATIONS?**

78 A. In the telecommunications industry, List 1 and List 2 drains are the designations of the  
79 load current drains. These are used to size various elements of the battery plant.  
80 Generally speaking, the List 1 current drain is used to size batteries and rectifiers in the  
81 plant. The List 2 current drain is used to size the DC load feeder cables and the circuit  
82 protection device (fuse) for the DC power arrangement. The fuse size is also dependent  
83 upon the ampacity of the smallest conductor comprising the protected feeder. Protectors  
84 should be rated as high as allowable to avoid nuisance tripping due to high load  
85 conditions or inrush current during startup.

86

87 **Q. CAN YOU GIVE AN EXAMPLE OF A FUSE SIZE CALCULATION USING**  
88 **LIST 1 DRAIN (CONTINUOUS LOAD), LIST 2 DRAIN, AND**  
89 **NONCONTINUOUS LOAD?**

90 A. Yes, I can. Qwest Communications Corporation’s (QCC) collocation arrangements  
91 generally consist of multiple, separately-fused bays of equipment in series. Consider, as  
92 an example, within one of those bays is a circuit that feeds equipment with a List 1  
93 current drain (continuous load) of 20 amps and a List 2 current drain of 30 amps. The  
94 noncontinuous load would be the difference between the List 2 current drain and the List  
95 1 current drain, or 10 amps (30 amps – 20 amps). Using these specifications and the

96 NFPA code requirements (stated above), the minimum allowable fuse size for this  
97 hypothetical QCC DC power arrangement is calculated as follows:

98 = noncontinuous load + (1.25 x continuous load)  
99 = (List 2 Drain – List 1 Drain) + (1.25 x List 1 Drain)  
100 = (30 – 20) + (1.25 x 20)  
101 = 10 + 25  
102 = 35 amps.

103

104 Under SBC’s fusing proposal, however, this QCC arrangement would not necessarily be  
105 fused at or above 35 amps. If, for example, the equipment in this arrangement were not  
106 maximally configured with respect to cards and shelves, but only partially-configured,<sup>4</sup>  
107 and the actual usage was not measured at “busy-hour,” that equipment may only be  
108 measured at 5 amps. Under SBC’s proposal – which focuses only on actual usage at any  
109 moment in time – the fuse could be no larger than 10 amps, far below the minimum  
110 acceptable fuse size under the NFPA code.

111

112 **Q. WHAT ARE YOUR CONCERNS WITH SBC’S MOST RECENT FUSING**  
113 **PROPOSAL?**

114 A. I have three major concerns, among others, with SBC’s most recent fusing proposal.  
115 These concerns are legal, financial and operational. First, if the DC power arrangements  
116 are fused based upon the usage at any point in time, and not the List 2 drain of the load, it

---

<sup>4</sup> The minimal configuration could be due to a smaller number of customers being served during a particular period of time.

117 is probable that the fusing would not be in compliance with NFPA 70-2005, Article  
118 215.3. As a result, the fusing would violate Administrative Code Part 785.20(b)(1),  
119 which obligates companies to abide by NFPA 70.<sup>5</sup> In other words, collocators will be  
120 forced to either ignore SBC's fusing limitations or ignore the Commission's electrical  
121 and fire safety requirements.

122  
123 Second, on a financial level, changes in a collocator's power draw (for instance, because  
124 it adds cards to an existing, but under-utilized, multiplexer) will require the collocator to  
125 pay SBC to re-fuse the collocator's collocation power arrangement. For each power  
126 delivery arrangement (a single collocation arrangement may include multiple power  
127 delivery arrangements), SBC would charge the collocator an Order Charge of \$300.50  
128 (physical caged and shared) or \$115.26 (cageless and virtual) and a Power Delivery  
129 charge of \$1,802.03.<sup>6</sup> Regular or periodic re-fusing – which is unnecessary from a safety  
130 perspective and, in fact, inconsistent with national fire protection standards and the  
131 Commission's rules – will obviously prove quite expensive for collocators.

132

133 Third, on an operational level, the low fusing amperage will make unnecessary and  
134 harmful overloads more likely and more common. An overload is an overcurrent that is

---

<sup>5</sup> Section 785.20(b)(1) of Title 83 of the Administrative Code states that “[t]he Agencies adopt as their rules the following portions of the NFPA Fire Codes (1991) edition: ...Code 70, National Electric Code (effective Feb. 21, 1991).” Section 785.5 defines the “Agencies” as “the Illinois Commerce Commission, the Office of the State Fire Marshal, and the Illinois Emergency Management Agency.” Article 215.3 of the NFPA 70-2005 is substantively identical to Article 220-10(b) of the NFPA 70-1990. See Schedule VHB-5.

<sup>6</sup> See Ill. C.C. No. 20, Part 23, Section 4. SBC confirmed the applicability of these charges in its response to QCC Data Request 3.14.

135 confined to normal current paths and could occur when a single high amperage device is  
136 on a circuit that is marginally sized for the demand. The purpose of overcurrent  
137 protection devices is to prevent conductor insulation failure caused by overloads or short  
138 circuits. An overload condition would be the result of a marginally fused power feed  
139 during a power outage.

140  
141 **Q. WHAT ARE THE IMPACTS OF A BLOWN FUSE TO QWEST**  
142 **COMMUNICATIONS CORPORATION (“QCC”)?**

143 A. The impacts of power outages due to a blown fuse are numerous, including but not  
144 limited to equipment damage, economic loss due to lost production, and irreparable  
145 damage to the reputation of QCC with respect to service reliability.

146  
147 **Q. COULD A BLOWN FUSE REALLY DO DAMAGE TO DIGITAL**  
148 **TELECOMMUNICATIONS EQUIPMENT?**

149 A. Absolutely. Years ago, equipment was not as susceptible to power outages as is the  
150 sensitive digital equipment of today. Any equipment containing microprocessors, such as  
151 computers and telecommunications equipment, is especially vulnerable to power down  
152 via a blown fuse. The May 24, 1999 article in Telephony Magazine Online “**CIRCUIT**  
153 **PROTECTION RUNS DEEP**” by Dan O’Shea<sup>7</sup> speaks to this issue specifically:

154 “The telecom industry’s migration to digital networking has taken several  
155 years but is now nearly worldwide. The shift to digital networks triggers  
156 numerous benefits that affect network efficiency, performance, capacity and  
157 reliability. However, one side effect of this trend is the fact that distributed  
158 electronics are more sensitive to fuse outages.

---

<sup>7</sup> Mr. O’Shea’s article can be reviewed in its entirety at [http://telephonyonline.com/mag/telecom\\_circuit\\_protection\\_runs/index.html](http://telephonyonline.com/mag/telecom_circuit_protection_runs/index.html).

159 Also, the migration to new network architectures and equipment means that  
160 different network elements are constantly being replaced or installed, brought  
161 on-line or taken off-line. This type of situation is conducive to fuse overloads  
162 and other potential problems.”

163  
164  
165

**Q. DOES BELLCORE HAVE ANY DOCUMENTATION RELATING TO THE FUSING OF TELECOMMUNICATIONS EQUIPMENT?**

166 A. Yes, in its definition of List 2 drain, Bellcore (previously known as Bell Communications  
167 Research, now known as Telcordia) states<sup>8</sup>:

168 “These drains are used to size feeder cables and fuses. These drains represent  
169 the peak current for a circuit or group of circuits under worst case operating  
170 conditions. For example, a constant power load requires maximum current at  
171 minimum operating voltage.”

172  
173  
174

**Q. WHAT IS MEANT BY “MAXIMUM CURRENT AT MINIMUM OPERATING VOLTAGE” IN BELLCORE’S DEFINITION, ABOVE?**

175 A. During the power outages, the power to the telecommunication equipment is supplied by  
176 batteries. For a time, a diesel engine would be supplying additional backup power for the  
177 batteries. Once the power backup plant is running solely off battery power, the batteries  
178 begin to discharge. The voltage begins to drop from about -52.8 VDC , past the nominal  
179 -48 VDC, down to equipment failure at -42.75 VDC. Since power (Watts) is voltage  
180 (volts) times current (amps) ( $W=V \times A$ ), as the voltage drops, the current (amperes)  
181 increases to maintain the power level. In other words, as the voltage approaches a  
182 minimum, the current approaches a maximum. That maximum current for any piece of  
183 equipment, again, is referred to as the List 2 drain of the equipment.

184

---

<sup>8</sup> An excerpt from Bellcore Practice BR 790-100-656 is attached to my surrebuttal testimony as Schedule VHB-6.

185 **Q. HOW DOES SBC'S FUSING PROPOSAL, BASED ON ACTUAL USAGE,**  
186 **IMPACT THE EFFICACY OF THE POWER BACKUP?**

187 A. The power backup system could be rendered useless. As mentioned above, during a  
188 power drain due to a power outage, the current (in amps) increases as the voltage  
189 decreases. If QCC is not able to fuse its DC power arrangements based on List 2 drain,  
190 as required by NFPA, Commission rule (Section 785.20(b)(1)), SBC's internal  
191 requirements and manufacturer's specifications, during an extended power outage, the  
192 elevated amperage would blow the fuse resulting in QCC's collocated equipment being  
193 powered down in a matter of minutes, not hours. SBC's own equipment – used to serve  
194 *its* own retail customers – will likely remain unaffected given that SBC fuses based on  
195 List 2 drain, according to SBC's own technical publication. See Schedule VHB-4.

196

197 **Q. DOES BELLCORE SPEAK TO ANY OTHER INSTANCES WHERE THE**  
198 **NONCONTINUOUS LOAD IS GENERATED?**

199 A. Yes. In the same definition of List 2 drain, mentioned above, Bellcore states:

200 "List 2 current may also be generated by circuit operating variability (traffic,  
201 test condition, etc.) while at normal float voltage<sup>9</sup>."

202

203 In the definition above, Bellcore acknowledges the power load of the equipment varies  
204 enough to generate noncontinuous (List 2) current while at normal, non-emergency,  
205 operating conditions. As with the battery discharge mentioned above, the reduced fusing  
206 proposed by SBC could result in a blown fuse even during normal operating conditions.

207

---

<sup>9</sup> In backup applications, the batteries are kept at a constant state of maximum potential in order to ensure maximum power reserve. This state of maximum potential is called *float voltage*.

208 **Q. CAN YOU GIVE AN EXAMPLE OF AN INSTANCE WHERE**  
209 **NONCONTINUOUS LOAD (LIST 2 DRAIN) COULD BE GENERATED UNDER**  
210 **NORMAL OPERATING CONDITIONS?**

211 A. Absolutely. An electric motor is a good example. Many electronic components, like  
212 computers and telecommunications equipment, generate heat. In order to protect  
213 equipment from overheating, the equipment contains fans to maintain the appropriate  
214 operating temperature. Most fans are operated by a thermostat. Because of the  
215 thermostat, the fans will turn on and off as needed generating noncontinuous (List 2)  
216 current. Fans are operated by electric motors. When most motors start, they draw current  
217 in excess of the motor's full-load current rating. This current draw is for a very short  
218 interval, relative to the equipment, but the duration could be long enough to blow the fuse  
219 if the DC power feed is marginally fused as SBC's revised fusing proposal requires.

220  
221 In addition to the extra current (List 2 current or noncontinuous load) required to start the  
222 motors running the fans, there are other inrush currents associated with the equipment.  
223 On startup, electronics require a small instance in time to charge the capacitors. Again,  
224 this initial charge generates the List 2 current drain.

225 **Q. IS THERE NOT A SECOND, REDUNDANT, POWER FEED TO THE**  
226 **COLLOCATORS' COLLOCATION ARRANGEMENTS?**  
227

228 A. Yes. As I understand it, redundant power feeds serving telecommunications equipment  
229 are an industry standard. In SBC's "Common Systems Equipment Interconnection

230 Standards for the SBC Local Exchange Companies” (SBC-TP-76450, Section 2.1.2, page  
231 7),<sup>10</sup> it states:

232 “Redundant power feeders are **required** for all equipment serving network  
233 elements. The term network element refers to all switching, transport, data,  
234 operator services equipment, and any adjuncts for those elements.” [emphasis  
235 added]

236  
237 As indicated in the footnote in Schedule VHB-6, the redundant power feeds are to ensure  
238 uninterrupted power to either the A or B side to maintain power to the  
239 telecommunications equipment in the event of a power loss of either power feeds.

240  
241 **Q. WOULD THIS REDUNDANT POWER FEED TO THE COLLOCATORS’**  
242 **COLLOCATION ARRANGEMENTS HANDLE ANY INCREASE IN CURRENT?**

243 A. Not necessarily. During normal operating conditions, it is possible for the second feed to  
244 cover the inrush current. But, the redundant feed is provisioned to ensure uninterrupted  
245 power during abnormal operating conditions. The footnote in Schedule VHB-6 (SBC’s  
246 technical publication) states, “The maximum List 2 current supported at the BDFB  
247 cannot exceed 50% of the supply fuse rating regardless of the size. This will insure  
248 uninterrupted power to either the A or B side in the event of a power loss of either power  
249 feeds.”

250  
251 Further, by relying solely on the redundant power feed to handle any increased current,  
252 collocators cannot realize the full backup protection of both the backup power plant and  
253 the power feed redundancy.

---

<sup>10</sup> An excerpt from the SBC-TP-76450 is attached to my surrebuttal testimony as Schedule VHB-6.



254 **III. CONCLUSION**  
255

256 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

257 **A. Yes, it does.**