



STATE OF WASHINGTON
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION
1300 S. Evergreen Park Dr. S.W., P.O. Box 47250 • Olympia, Washington 98504-7250
(360) 664-1160 • TTY (360) 586-8203

Ref. No. PG-110017

CERTIFIED MAIL

August 28, 2013

Gary Kaiser
Vice President
Georgia-Pacific Consumer Products (Camas) LLC
401 NE Adams Street
Camas, WA 98607

Dear Mr. Kaiser:

RE: Request to Temporarily Raise Gas Pipeline Pressure to Accommodate Use of In-Line Inspection Tool


The Washington Utilities and Transportation Commission (UTC) staff have been informed that Georgia Pacific Consumer Products LLC in Camas (GP) is preparing to run an in-line inspection (ILI) tool in their natural gas pipeline. This testing is to be performed in accordance with the stipulated agreement entered into between the UTC and GP under docket PG-110017.

Commission staff have reviewed ILI procedures and approve the temporary pressure increase for the purpose of running the ILI tool(s) subject to the conditions detailed under Item 6 of the order.

GP will be expected to leak survey the natural gas pipeline after the pressure increase, but prior to the ILI run. They must eliminate any leaks detected prior to the ILI run. Anomalies must be managed in accordance with 49 CFR §192.933 and a copy of the ILI report must be submitted to the commission within 30 days of receipt.

Please contact Joe Subsits at (360) 664-1322 if you have any questions.

Sincerely,


Steven V. King
Executive Director and Secretary

cc: Steve Ringquist, Reliability Leader, Georgia Pacific Consumer Products (Camas) LLC
Carson Blocker, Reliability Engineer, Georgia Pacific Consumer Products (Camas) LLC
Roy Rogers, P.E. Consultant Cathodic Protection Engineering, Inc.
Robert L. Cosentino, Cosentino Consulting