

# GAS STORAGE FIELD REVIEW

Add solid samples to the internal corrosion part of the form. A completed **Standard Inspection Report** is to be submitted to the Director within 60 days from completion of the inspection. A **Post Inspection Memorandum (PIM)** is to be completed and submitted to the Director within 30 days from the completion of the inspection, or series of inspections, and is to be filed as part of the **Standard Inspection Report**.

Inspection Report		Post Inspection Memorandum	
<b>Inspector/Submit Date:</b> Al Jones / July 13, 2009	<b>Sr Eng Review Date:</b> David Lykken / July 14, 2009		
	<b>Peer Review/Date:</b> Tom Finch		
	<b>Director Approval/Date:</b> Chris Hoidal		
POST INSPECTION MEMORANDUM (PIM)			
<b>Name of Operator:</b> Puget Sound Energy		<b>OPID #:</b> 22189	
<b>Name of Unit(s):</b> Jackson Prairie Storage Facility		<b>Unit #(s):</b> 3387	
<b>Records Location:</b> Jackson Prairie Storage Facility			
<b>Unit Type &amp; Commodity:</b> Interstate Natural Gas Storage			
<b>Inspection Type:</b> Standard		<b>Inspection Date(s):</b> June 8-11, 2009	
<b>PHMSA Representative(s):</b> Al Jones, WUTC		<b>AFO Days:</b> 4	

**Summary:**  
 No probable noncompliance were identified and five Areas of Concerns are addressed with recommendations for future evaluation listed the Findings, below.

**Record Review:**  
 Included cathodic protection for plant piping and transmission pipeline including casings and rectifiers, maintenance of valves, pressure recording charts, Emergency Plan, Safety related condition reports, and Welding results,

**Field Inspection:**  
 Included new wellhead construction, new turbine/compressor station, CP for piping and rectifier units, ROW, firefighting equipment, pipe supports, and facility security systems.

**Future Inspection:**  
 It was recommended that future inspections be scheduled in the Fall of the year as in previous years.

**Findings:**  
 Area of Concerns:

1. The compressor stations are equipped with automatic exhaust ventilation systems that are activated by temperature setting within each building. The exhaust fans will not activated if gas accumulates in the buildings. The gas detectors are designed to ESD the station at 40% LEL. While testing of the gas sensors, the station's ESD was activated, detected in the control room, and the ventilation blowers were not activated to exhaust the gas. The ventilation system is currently wired to operate to vent heat at a predetermined temperature setting, not for the ventilation of gas. CFR 192.173 Compressor Stations: Ventilation, address employees safety where gas could accumulate in a room. Staff recommends that all compressor buildings be wired to automatically activate the exhaust ventilation systems when gas is detected in the building at least 40% LEL.
2. Several above ground pipe supports were found with atmospheric corrosion between the support and the bottom of the pipe. Insulating saddles have been installed at similar location except at: wells #88, well #89, and SU #10 (Zone 1 storage piping).
3. The Gas Field Procedure Manual list several reasons for Abnormal Operating Conditions (Section 4515.1205) when a positive pipe-to-soil reading is observed while using a copper-copper sulfate cell. The list is not comprehensive and omits lessons learned from another PSE's rectifier problem. It is recommended that the manual include the possibility that a rectifier could be incorrectly wired to the pipeline and the anode. Jackson Prairie Storage rectifiers (49 units???) operate at 440 vAC, safety precautions need to be reviewed with the operator, and verify rectifier output wires to the pipe and anode are properly identified.
4. The Gas Operation Standards revised section (effective 3/1/2009) for compliance with CFR 192.615 (b)(3) Emergency Plans - review employee activities to determine whether the procedures were effectively followed in each emergency. The Standards Manual require periodic refresher training such as table top or simulation exercises be provided and verify the effectiveness of the

## GAS STORAGE FIELD REVIEW

**Findings:**

training. Staff recommends such exercises be documented for attendance; identify the emergency skills reviewed, the effectiveness of the training i.e. what worked and what needs to be improved.

5. The only exception to the minimum CP threshold was at the Triethylene Glycol (TEG) piping located near the concrete footings within the plant facility. The TEG lines are not considered jurisdictional piping, but could impact the plant's operation if the line were to fail from a corrosion leak. Staff recommend the low pipe-to-soil values (-0.576 vDC and -0.76 vDC) found on a 2" diameter pipe near coalescer tower #10, be mitigated by placing anodes in proximity to the pipelines.

<b>Name of Operator:</b> Puget Sound Energy - Jackson Prairie Storage Facility	
<b>OP ID No. <sup>(1)</sup> 22189</b>	<b>Unit ID No. <sup>(1)</sup> 33875</b>
<b>HQ Address:</b> Puget Sound Energy PO Box 90868, EST-07W Bellevue, WA 98009-0868	<b>System/Unit Name &amp; Address: <sup>(1)</sup></b> Jackson Prairie Storage Facility 239 Zandecki Road Chehalis, WA 98532
<b>Co. Official:</b> Burt A. Valdman, Executive VP & COO <b>Phone No.:</b> 425-462-3193 <b>Fax No.:</b> <b>Emergency Phone No.:</b> 800-552-7171	<b>Activity Record ID No.:</b> PG-090328 <b>Phone No.:</b> 360-262-3365 <b>Fax No.:</b> 360-262-0119 <b>Emergency Phone No.:</b> 360-262-3365
<b>Persons Interviewed</b>	<b>Title</b>
Jim Janson	Manager, Jackson Prairie Storage Operations
Rick Braaten	Supervisor
Darryl Hong	Compliance Coordinator
<b>PHMSA Representative(s) <sup>(1)</sup> Al Jones/UTC      Inspection Date(s) <sup>(1)</sup> June 8-11, 2009</b>	
<b>Company System Maps (Copies for Region Files):</b>	

<sup>1</sup> Information not required if included on page 1.

## GAS STORAGE FIELD REVIEW

**Counties of Operation: (list each field separately)**

Jackson Prairie Natural Gas Storage Facility is located in Lewis County, Washington, about 10 miles south of Chehalis, or about 100 miles south of Seattle.

**Storage Field(s) Description: (list each field separately)**

Jackson Prairie storage is the 14th largest storage reservoir in the United States in terms of capacity for natural gas withdrawal and delivery to consumers. The facility is co-owned with equal rights with Puget Sound Energy, Avista Utilities, and Williams Northwest Pipeline. The facility was authorized for underground storage of natural gas in 1963 and certified for commercial service in 1970. Today, the facility has storage for 23 billion cubic feet and is expanding capacity to 25 billion cubic feet by 2012 with an additional 48 billion cubic of "cushion" to provide pressure in the reservoirs. The facility consists of a series of deep, underground reservoirs of porous sandstone deposits approximately 1,000 to 3,000 feet below the ground surface. The storage facility has 102 wells spread across 3,200 acres for injection and withdrawal points for natural gas. The facility can meet up to 25% of the Pacific Northwest's peak natural gas demand on the coldest winter days. Major components of the facility includes: four transmission pipeline, well points, gathering lines, filtration, coalesce, dehydration, compression units for injection to the storage field or interstate pipeline, and SCADA control unit.

**Inspection Summary:**

**Expansion:**

Since the last inspection in August 2007, the Storage capacity has expanded its working storage by approximately 28%, constructed ten new injection wells, replaced three 1966 vintage Saturn turbines with three new 1,600Hp Saturn T20 units, and commissioned the 10,500HP Taurus turbine/compressor unit.

**Slug Catcher:**

Internal corrosion and design of the slug catcher has been identified in previous inspections. The long term plan is to replace the slug catcher with an above ground unit. I was informed the unit will not be replace within the next five years because of budget issues. The slug catcher was placed into service in 1999 with schd 40 X52 pipe, 0.750" wt.. A corrosion coupon was installed near the bottom of the unit on December 8, 2003. The coupon material (per vendor, Rhorback) is made from mild steel (1018) with chemical properties similar to any carbon steel. The average corrosion rate of seventeen coupons is approximately 2.77 mills per year (mpy) excluding the corrosion rate between September 22 and December 8, 2008 where the rate was 15.01 mpy. It is difficult to correlate the rate of corrosion between coupons and the slug catcher. The coupons verify corrosion is present at the slug catcher and one coupon indicated pitting. The slug catcher is located near the main entrance and the control room to the plant and needs to be given a high priority for employee safety. With the expansion of the storage facility the rate of corrosion at the slug catcher should increase.

**Cathodic Protection Review:**

Numerous pipe-to-soil potentials were taken (see field data report) and were found to be in compliance. The only exception to the minimum CP was at the Triethylene Glycol (TEG) piping located near the concrete footings within the plant facility. The TEG lines are not considered jurisdictional piping, but could impact the plant's operation if the line were to fail from a corrosion leak.

**The attached evaluation form should be used in conjunction with 49CFR Parts 191 and 192.**

**PIPE TYPE**

	Bare steel	Coated steel	Ineffectively Coated	Pre70-ERW	Plastic	Other: must specify type
Footage/Mileage		14.4 Miles				

**PIPE SPECIFICATIONS (2" AND LARGER)**

Diameter(s)	14-inch	16-inch	20-inch	24-inch		
Pipe Grade(s)	X-46	X-52	X-56	X-70		
Wall Thickness(s)	0.250 inch	0.312 inch	0.375 inch	0.250-0.365 inch		
Footage/Mileage	9,031 Ft	9,029 Ft	9,053 Ft	9,014 Ft		

## GAS STORAGE FIELD REVIEW

### WELL STIMULATION

#### ACIDIZING

Acidizing treatments used to stimulate the wells?       Yes       No

Type(s) of acids used in treating the wells:      15% HCl

Type(s) of inhibitors used with the acid(s):      Varies

Frequency of the treatments:      Rare. Last used in late 1990's      Volume of acid per treatment:      <600 Gal.

Well cleanup procedure following treatment:      Yes, flowed back into the well procedure.

If treatment is flowed back into the well/injection line, criteria used to determine that the treatment will not cause internal corrosion or erosion of the pipe:      Nothing specific

#### FRACTURING

Fracturing treatments used to stimulate the wells?       Yes       No

Type(s) of fracturing fluids used in treating the wells:      N/A

Type(s) of inhibitors used with the fracturing fluid(s):      N/A

Frequency of the treatments:      N/A      Amount of sand per treatment:      N/A

Well cleanup procedure following treatment:      N/A

If treatment is flowed back into the well/injection line, criteria used to determine that the treatment will not cause internal corrosion or erosion of the pipe:      N/A

# GAS STORAGE FIELD REVIEW

## GAS and LIQUID HANDLING FACILITIES

### GAS COMPRESSION

Location of compressors: Jackson Prarie Compressor Station

Number, Size (HP), and Date of Installation of Units:	C-1	670Hp	10/65	Walkinshaw reciprocating engine used at Zone 9 for reinjection of gas.
	C-2	1,000Hp	11/66	Saturn turbine/compressor. In 2008 was replaced with 1,600Hp Saturn T20
	C-3	1,000Hp	9/66	Saturn turbine/compressor. In 2008 was replaced with 1,600Hp Saturn T20
	C-4	1,000Hp	11/66	Saturn turbine/compressor. In 2008 was replaced with 1,600Hp Saturn T20
	C-5	1,300Hp	12/68	Saturn turbine/compressor
	C-6	4,417Hp	11/73	Centaur turbine/compressor
	C-7	4,417Hp	11/75	Centaur turbine/compressor
	C-8	7,000Hp	11/99	Taurus-60 turbine/compressor
	C-9	10,500Hp	11/08	Taurus-70 turbine/compressor
	IR-1	145Hp	1/01	Caterpillar engine for recycle gas within the storage field.
	IR-2	145Hp	1/02	Caterpillar engine for recycle gas within the storage field.
	IR-3	75Hp	3/09	Electric compressor for recycle gas within the storage facility

### GAS DEHYDRATION

Location of dehydration units: Jackson Prarie Compressor Station

Type(s) of dehydration process used: Glyco, bubble cap tray, triethylene glycol at 1,150 MMCF/Day.

Number of dehydration units: 12 towers

Dehydration capacity: One Billion Cubic Feet per Day

### GAS SWEETENING (Acid Gas Treating)

Location of sweetening units: N/A

Type(s) of sweetening process used: N/A

Number of sweetening units: N/A

Sweetening capacity: N/A

### GAS / LIQUID SEPARATION

**SCRUBBERS / SEPARATORS:** Yes

Location of scrubbers/separators: At each gas well site has a two-phase separator and at the plant facility there three vortex separators for water removal.

Type(s) of scrubbers/separators used: Two-Phase separators

Number of scrubbers/separators: 54

Separation capacity: 20 to 80 Million CF/Day

**DRIPS:** Yes

Location of drips: Station and at low elevations along the pipeline

Type(s) of drips used: Slug-Catcher at the Plant Station

Number of drips: One at the Plant Station and three field sites.

Frequency of draining or blowing drips: As needed

# GAS STORAGE FIELD REVIEW

## FIELD OPERATING PARAMETERS

### PRESSURES, RATES and TEMPERATURES

	Pressure, psi		Flow Rate, MMcf/day		Temperature, °F	
	Injection	Withdrawal	Injection	Withdrawal	Injection	Withdrawal
Maximum	855	800	450	1,150	110	110
Maximum	370	370	50	50	40	40

Maximum Allowable Operating Pressure (Field): 800 psig

### WATER, CO<sub>2</sub>, and O<sub>2</sub> CONTENT

	Water, lbs./MMcf	CO <sub>2</sub>	H <sub>2</sub> S, ppm	O <sub>2</sub> , %
Injection Cycle	7 #	0.04%	0	Negligible
Withdrawal Cycle	28 to 30 #	0.04%	0	Negligible

## FIELD OPERATING AND MAINTENANCE HISTORY

### LEAKS (NON-RUPTURES)

Are leak surveys of the field being conducted? (49 CFR 192.706)     Yes     No

Have any leaks been found over the past 5 years?     Yes     No    Number of leaks: 0

Types of leaks that have occurred?  
N/A

Cause(s) of the leaks:  
N/A

Location(s) of the leaks:  
N/A

Has a trend analysis been performed?     Yes     No

If a trend analysis has been done, what do the results indicate?

### FAILURE/RUPTURES

Have any failures occurred over the past 5 years?     Yes     No    Number of failures: 0

Type(s) of failures that have occurred:

Cause(s) of the failures:

Location(s) of the failures:

Has a trend analysis been performed?     Yes     No

If a trend analysis has been done, what do the results indicate?

### LINE REPLACEMENTS

Have any lines been replaced over the past 5 years?     Yes     No    Number of replacements: 1

Type(s) of replacements:  
14" Diameter Tee

Location(s) of the replacements:  
Approximately 500 yds. west of compressor Station

Reason(s) for replacements:  
To make Certification Data Current.

### LINE REPAIRS

## GAS STORAGE FIELD REVIEW

FIELD OPERATING AND MAINTENANCE HISTORY			
Have any lines been repaired over the past 5 years?		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
		Number of repairs: 1	
Type(s) of repairs: 14" diameter Tee Replacement			
Location(s) of the repairs: Approximately, 500 yds west of Compressor Station			
Reason(s) for the repairs: To make Certification Data Current.			
VALVE REPLACEMENTS			
Have any valves been replaced over the past 5 years?		<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
		Number of replacements: 1	
Type(s) of valve replacements: 14" diameter Valve at Meter Station & Williams Tap.			
Location(s) of the replacements: Williams Tap			
Reason(s) for the replacements: For Pressure Protection with actuator set at MAOP.			
GAS and LIQUID HANDLING FACILITY UPSETS			
	Gas Dehydration Units	Gas Sweetening Units	Separators
Number of upsets – past 3 years	None	N/A	None
Cause(s) of the upsets:			
Has a trend analysis been performed?		<input type="checkbox"/> Yes	<input type="checkbox"/> No
If a trend analysis has been done, what do the results indicate?			

### CORROSION CONTROL AND MONITORING

EXTERNAL CORROSION					
Are the field piping and related storage field facilities cathodically protected? (49 CFR 192 Subpart I)			<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Type(s) of cathodic protection used:		<input checked="" type="checkbox"/> Impressed Current	<input type="checkbox"/> Galvanic Anodes	<input type="checkbox"/> Combination	
Criteria used to determine adequate cathodic protection: -850 mVdc, ON					
Does the field piping system contain any bare or ineffectively coated pipe?			<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Location(s) of the bare or ineffectively coated pipe: N/A					
Amount of bare or ineffectively coated pipe: N/A					
Are corrosion monitoring procedures established for the field piping and related storage field facilities?			<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
MONITORING					
Pipe-to-soil readings	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	Exposed pipe reports	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Close interval surveys	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Leak surveys	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Line current surveys	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	Instrumented inspection surveys	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Remedial measures taken to mitigate corrosion:					
A corrosion coupon was installed near the bottom of the slug catcher unit.					

# GAS STORAGE FIELD REVIEW

## INTERNAL CORROSION

Are corrosion monitoring procedures established for the field piping and related storage field facilities?  Yes  No

### MONITORING

Corrosion coupons <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Pipe replacement reports surveys <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Gas samples <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Leak surveys <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Water samples <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Instrumental inspection surveys <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Solids samples <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

### CORROSION COUPONS

Frequency coupons are analyzed:  
Quarterly

Location(s) where coupons are installed:  
At Slug-Catcher.

### GAS SAMPLES

Frequency of sampling: Random

Location(s) where the samples taken:  
At Wellheads.

Are the gas samples analyzed for:

Carbon dioxide (CO <sub>2</sub> )	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Hydrogen sulfide (H <sub>2</sub> S)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Oxygen (O <sub>2</sub> )	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Water vapor	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

Amount of the following present in the gas:

Carbon dioxide (CO <sub>2</sub> )	<u>Not detected in February 2006.</u>
Hydrogen sulfide (H <sub>2</sub> S)	<u>Not detected</u>
Oxygen (O <sub>2</sub> )	<u>Not detected</u>
Water vapor	<u>Varies. Water is collected at low points near wellhead and drained from pipeline.</u>

What carbon dioxide (CO<sub>2</sub>) partial pressure criteria are used to establish carbon dioxide (CO<sub>2</sub>) corrosivity ranges?

N/A

What is the carbon dioxide (CO<sub>2</sub>) corrosivity ranges?

N/A

What is the carbon dioxide (CO<sub>2</sub>) partial pressure? Insignificant

### WATER/LIQUIDS SAMPLES

Frequency of sampling: As needed

Locations where the samples are taken:

At well heads.

What constituents are the water samples analyzed for? (Refer to the Water Analysis Checklist)

Last tested in January 1985

Concentration of the following present in water:

Iron (Fe <sup>++</sup> )	<u>1.0 ppm</u>
Manganese (Mn <sup>++</sup> )	<u>0.18 ppm</u>
Chlorides (Cl <sup>-</sup> )	<u>19,000 ppm</u>
Sulfates (SO <sub>4</sub> <sup>=</sup> )	<u>2 ppm</u>

Amount of the following gases dissolved in the water:

Carbon dioxide (CO <sub>2</sub> )	<u>Varies 0.06 - 0.47 ppm</u>
Hydrogen sulfide (H <sub>2</sub> S)	<u>0</u>
Oxygen (O <sub>2</sub> )	<u>Not tested</u>

Is the pH of the water below 6.8?  Yes  No

Is hydrostatic test water sampled for the presence of bacteria?  Yes  No



## GAS STORAGE FIELD REVIEW

INTERNAL CORROSION	
Are liquids tested for evidence of excessive glycol in the pipeline, which if deteriorated, could lower the pH? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<b>SOLIDS SAMPLES (collected at pig receivers)</b>	
Frequency of sampling: N/A. No pigging has been preformed.	
Locations where the samples taken:	
Are solids observed and/or tested for the following components?	
Iron Oxide <input type="checkbox"/> Yes <input type="checkbox"/> No	Scales <input type="checkbox"/> Yes <input type="checkbox"/> No
Iron Sulfide <input type="checkbox"/> Yes <input type="checkbox"/> No	Sand <input type="checkbox"/> Yes <input type="checkbox"/> No
Is the volume of solids increasing or decreasing between pig runs?	
Comments:	

INSTRUMENTED INSPECTION SURVEYS
Frequency surveys are conducted: N/A
Lines that have been surveyed and when the survey was conducted:

INHIBITOR PROGRAM
Has a corrosion inhibitor program been established for the field piping and related storage field facilities? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
When did the program start?
Type(s) of treatment method used: <input type="checkbox"/> Batch <input type="checkbox"/> Continuous
Type(s) of inhibitors used:
Are liquid samples periodically taken to test for residual corrosion inhibitor, to help determine effectiveness? <input type="checkbox"/> Yes <input type="checkbox"/> No

MAINTENANCE PIGGING
(See also solids and water sampling, inhibitor sections)
Does operator have a maintenance pigging program designed to sweep the lines of sediments and/or scale? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Does operator adhere to the pigging program? <input type="checkbox"/> Yes <input type="checkbox"/> No
Comments:

## GAS STORAGE FIELD REVIEW

<b>CONTROLLING GAS VELOCITY – INTERNAL CORROSION AND EROSION</b>		
Have target flow rates been determined for the field piping system?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Are injection/withdrawal flow rates kept within the targeted flow rates, to minimize sediment and water build-up, and to manage erosion?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Has erosion been observed during replacement of components (lines, valves, fittings, etc.)?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
Locations where erosion has been found:		
Remedial measures taken to mitigate erosion:		

<b>ATMOSPHERIC CORROSION</b>		
Are corrosion monitoring procedures established for the field piping and related storage field facilities?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Location(s) where corrosion has been found: Various Locations		
Remedial measures taken to mitigate corrosion: Yes, replaced pipe rapping at soil/air interface and atmospheric corrosion where painting is required.		

<b>SAFETY DEVICES and SYSTEMS</b>		
-----------------------------------	--	--

<b>SURFACE FACILITIES</b>		
Has a system safety analysis of the field piping and related storage facilities been performed:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Has a safety analysis function evaluation chart for the field piping and related storage field facilities been prepared?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No

<b>PRESSURE SAFETY DEVICES:</b>		
<b>COMPRESSORS</b>		
Is each compressor, per 49 CFR 192.169, equipped with pressure safety devices for overpressure protection?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Pressure protection provided by:	Location of pressure safety devices:	
Primary <b>Compressor Controls</b>	Primary <b>At Skid</b>	
Secondary <b>Station Controls (Solfwear)</b>	Secondary <b>At SCADA Station</b>	

<b>PRESSURE VESSELS</b>		
Is the working pressure of each pressure vessel (dehydrator, scrubber, etc.) greater than the MAOP?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Is each pressure vessel equipped with pressure safety devices for overpressure protection?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Pressure protection provided by:	Location of pressure safety devices:	
Primary <b>Station Over Pressure Protection via ESD or SSD.</b>	Primary <b>Station Blow Down Tower.</b>	
Secondary <b>Relief valves at vessels</b>	Secondary <b>At four cooler stations.</b>	

<b>HEADERS, LATERALS and WELL LINES</b>		
Are the headers, laterals and well lines equipped with pressure safety devices for overpressure protection?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
Pressure protection provided by:	Location of pressure safety devices:	

## GAS STORAGE FIELD REVIEW

### SURFACE FACILITIES

Primary Station Over Pressure via ESD or SSD.	Primary At Compressor Station Facility
Secondary Station Over Pressure via ESD or SSD.	Secondary At Compressor Station Facility
<b>GAS DETECTION SAFETY DEVICES:</b>	
Is each compressor, per 49 CFR 192.736, building equipped with gas detection safety devices?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Are other buildings that contain gas handling equipment equipped with gas detection safety devices?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Type(s) of gas detection safety devices: <input checked="" type="checkbox"/> Combustible gas (L.E.L.) <input type="checkbox"/> Hydrogen Sulfide (H <sub>2</sub> S) <input type="checkbox"/> Other:	
Type(s) of alarms used to notify personnel to the presence of gas: <input type="checkbox"/> Visual <input type="checkbox"/> Audible <input checked="" type="checkbox"/> Combination	
<b>FIRE DETECTION SAFETY DEVICES:</b>	
Is each compressor building equipped with fire detection safety devices?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Are other buildings that contain gas handling equipment equipped with fire detection safety devices:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Type(s) of fire detection safety devices: <input checked="" type="checkbox"/> Flame <input type="checkbox"/> Heat <input type="checkbox"/> Smoke <input type="checkbox"/> Fusible Material <input type="checkbox"/> Other: UV & IR	
Type(s) of alarms used to notify personnel to the presence of fire: <input type="checkbox"/> Visual <input type="checkbox"/> Audible <input checked="" type="checkbox"/> Combination	
<b>EMERGENCY SHUTDOWN SYSTEM:</b>	
Is each compressor station, per 49 CFR 192.167, equipped with a remote controlled emergency shutdown system?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Does the gas detection system activate the compressor station emergency shutdown system?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Does the fire detection system activate the compressor station emergency shutdown system?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

### WELLS

Is each well equipped with a well storage safety valve?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
If not, are there plans to equip each well with a well storage safety valve?	<input type="checkbox"/> Yes <input type="checkbox"/> No
Reasons why wells should not be equipped with well storage safety valve(s)?	

# GAS STORAGE FIELD REVIEW

## ADDITIONAL COMMENTS

Compressor stations are set to ESD at 40% LEL.

## GAS STORAGE FIELD REVIEW

### WATER ANALYSIS CHECKLISTS

Constituent			Does Operator test for . . .		Operator's "threshold"	Constituent			Does Operator test for . . .		Operator's "threshold"
			Yes	No					Yes	No	
Sodium		Na <sup>+</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Chloride		Cl <sup>-</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Potassium		K <sup>+</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Sulfate		SO <sub>4</sub> <sup>=</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Calcium		Ca <sup>++</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Carbonate		CO <sub>3</sub> <sup>=</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Magnesium		Mg <sup>++</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Bicarbonate		HCO <sub>3</sub> <sup>-</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Iron		Fe <sup>++</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Hydroxide		OH <sup>-</sup>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Barium		Ba <sup>++</sup>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		Dissolved Oxygen		O <sub>2</sub>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Strontium		Sr <sup>++</sup>	<input type="checkbox"/>	<input checked="" type="checkbox"/>		Dissolved Carbon Dioxide		CO <sub>2</sub>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Manganese		Mn <sup>++</sup>	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Dissolved Hydrogen Sulfide		H <sub>2</sub> S	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Lead		Pb	<input checked="" type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>	<input type="checkbox"/>	
Zinc		Zn	<input checked="" type="checkbox"/>	<input type="checkbox"/>					<input type="checkbox"/>	<input type="checkbox"/>	

Other	Does Operator test for . . .		Operator's "threshold"	Other	Does Operator test for . . .		Operator's "threshold"
	Yes	No			Yes	No	
Acidity	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Alkalinity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
pH	<input checked="" type="checkbox"/>	<input type="checkbox"/>		Salinity	<input checked="" type="checkbox"/>	<input type="checkbox"/>	19,000 ppm
Total Dissolved Solids (TDS)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	34,000 ppm	Acid-producing Bacteria	<input type="checkbox"/>	<input checked="" type="checkbox"/>	
Sulfate-reducing Bacteria	<input type="checkbox"/>	<input checked="" type="checkbox"/>					

Excessive values of the above-listed constituents and properties, dependent upon operating conditions and other factors that may be unique to the storage field, could indicate a corrosive condition in the pipeline.

## GAS STORAGE FIELD REVIEW

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked  
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

PIPELINE INSPECTION (Field)		S	U	N/A	N/C
.143(b)/.476	Design and construction of new and replaced transmission line and components.	X			
.179	Valve Protection from Tampering or Damage	X			
.463	Cathodic Protection	X			
.465	Rectifiers	X			
.479	Pipeline Components Exposed to the Atmosphere	X			
.605	Knowledge of Operating Personnel	X			
.707	ROW Markers, Road and Railroad Crossings	X			
.719	Pre-pressure Tested Pipe ( <b>Markings and Inventory</b> )	X			
.739/.743	Pressure Limiting and Regulating Devices (spot-check field installed equipment vs. inspection records)			X	
.745	Valve Maintenance	X			
.751	Warning Signs	X			
.801 - .809	Operator Qualification - Use PHMSA Form 15 Operator Qualification Field Inspection Protocol Form	X			

**Comments:**

Pressure regulators and limiting devices are for the Intermediate Distribution System that is covered in PSE's Lewis County Inspection.

COMPRESSOR STATIONS INSPECTION (Field)		S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")					
.143(b)/.476	Design and construction of new and replaced transmission line and components (excludes offshore or facilities installed or replaced before 05/23/07).	X			
.163 (c)	Main operating floor must have (at least) two (2) separate and unobstructed exits	X			
	Door latch must open from inside without a key	X			
	Doors must swing outward	X			
(d)	Each fence around a compressor station must have (at least) 2 gates or other facilities for emergency exit	X			
	Each gate located within 200 ft of any compressor plant building must open outward	X			
(e)	When occupied, the door must be opened from the inside without a key	X			
	Does the equipment and wiring within compressor stations conform to the <b>National Electric Code, ANSI/NFPA 70?</b>	X			
.165(a)	If applicable, are there liquid separator(s) on the intake to the compressors?	X			
.165(b)	Do the liquid separators have a manual means of removing liquids?	X			
	If slugs of liquid could be carried into the compressors, are there automatic dumps on the separators, Automatic compressor shutdown devices, or high liquid level alarms?	X			
.167(a)	ESD system must:				
	- Discharge blowdown gas to a safe location	X			
	- Block and blowdown the gas in the station	X			
	- Shut down gas compressing equipment, gas fires, electrical facilities in compressor building and near gas headers	X			
	- Maintain necessary electrical circuits for emergency lighting and circuits needed to protect equipment from damage	X			
ESD system must be operable from at least two locations, each of which is:					
	- Outside the gas area of the station	X			
	- Not more than 500 feet from the limits of the station	X			
	- ESD switches near emergency exits?	X			

## GAS STORAGE FIELD REVIEW

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

<b>COMPRESSOR STATIONS INSPECTION (Field)</b>		S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")					
.167 (b)	For stations supplying gas directly to distribution systems, is the ESD system configured so that the LDC will not be shut down if the ESD is activated?			N/A	
.171(a)	Does the compressor station have adequate fire protection facilities? If fire pumps are used, they must not be affected by the ESD system.			X	
(b)	Do the compressor station prime movers (other than electrical movers) have over-speed shutdown?	X			
(c)	Do the compressor units alarm or shutdown in the event of inadequate cooling or lubrication of the unit(s)?	X			
(d)	Are the gas compressor units equipped to automatically stop fuel flow and vent the engine if the engine is stopped for any reason?	X			
(e)	Are the mufflers equipped with vents to vent any trapped gas?	X			
.173	Is each compressor station building adequately ventilated?	X			
.457	Is all buried piping cathodically protected?	X			
.481	Atmospheric corrosion of aboveground facilities	X			
.603	Does the operator have procedures for the start-up and shut-down of the station and/or compressor units?	X			
	Are facility maps current/up-to-date?	X			
.615	Emergency Plan for the station on site?	X			
.619	Review pressure recording charts and/or SCADA	X			
.707	Markers	X			
.731	Overpressure protection – reliefs or shutdowns	X			
.735	Are combustible materials in quantities exceeding normal daily usage, stored a safe distance from the compressor building?	X			
	Are aboveground oil or gasoline storage tanks protected in accordance with NFPA standard No. 30?	X			
.736	Gas detection – location	X			

**Comments:**

Intermediate distribution pressure gas is covered in PSE's Lewis County Inspection.

<b>REPORTING PERFORMANCE AND RECORDS</b>		S	U	N/A	N/C
191.5	Telephonic reports to NRC (800-424-8802)			X	
191.15	Written incident reports; supplemental incident reports (DOT Form PHMSA F 7100.2)			X	
191.17 (a)	Annual Report (DOT Form PHMSA F 7100.2-1)	X			
191.23	Safety related condition reports			X	
192.727 (g)	Abandoned facilities, onshore crossing commercially navigable waterways reports			X	

<b>CONSTRUCTION PERFORMANCE AND RECORDS</b>		S	U	N/A	N/C
.225	Test Results to Qualify Welding Procedures	X			
.227	Welder Qualification	X			
.241 (a)	Visual Weld Inspector Training/Experience	X			
.243 (b)(2)	Nondestructive Technician Qualification	X			
	(c) NDT procedures	X			
(f)	Total Number of Girth Welds	X			
(f)	Number of Welds Inspected by NDT	X			

# GAS STORAGE FIELD REVIEW

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CONSTRUCTION PERFORMANCE AND RECORDS		S	U	N/A	N/C
(f)	Number of Welds Rejected	X			
(f)	Disposition of each Weld Rejected	X			
.303	Construction Specifications	X			
.325	Underground Clearance	X			
.327	Amount, Location, Cover of each Size of Pipe Installed	X			
.455	Cathodic Protection	X			

OPERATIONS and MAINTENANCE PERFORMANCE AND RECORDS		S	U	N/A	N/C
.603(b)	.605(a) Procedural Manual Review – Operations and Maintenance (1 per yr/15 months)	X			
.603(b)	.605(c) Abnormal Operations	X			
.603(b)	.605(b)(3) Availability of construction records, maps, operating history to operating personnel	X			
.603(b)	.605(b)(8) Periodic review of personnel work – effectiveness of normal O&M procedures	X			
.603(b)	.605(c)(4) Periodic review of personnel work – effectiveness of abnormal operation procedures	X			
.709	.614 Damage Prevention (Miscellaneous)	X			
.709	.609 Class Location Study (If Applicable)	X			
.603(b)	.615(b)(1) Location Specific Emergency Plan	X			
.603(b)	.615(b)(2) Emergency Procedure training, verify effectiveness of training	X			
.603(b)	.615(b)(3) Employee Emergency activity review, determine if procedures were followed.	X			
.603(b)	.615(c) Liaison Program with Public Officials	X			
.605(a)	.616 Public Awareness Program also in accordance with API RP 1162				
	.616(e & f) Documentation properly and adequately reflects implementation of operator’s Public Awareness Program requirements - Stakeholder Audience identification, message type and content, delivery method and frequency, supplemental enhancements, program evaluations, etc. (i.e. contact or mailing rosters, postage receipts, return receipts, audience contact documentation, etc. for emergency responder, public officials, school superintendents, program evaluations, etc.). See table below:	X			
	X				
	X	<b>Baseline Message Frequency (starting from effective date of Plane)</b>			
	X	2 years			
	X	Annual			
	X	3 years			
	X	Annual			
	X	As required of One-Call Center			
	X	<b>Baseline Message Frequency (starting from effective date of Plane)</b>			
	X	Annual			
	X	Annual			
	X	3 years			
	X	Annual			
	X	As required of One-Call Center			
.616(g)	The program must be conducted in English and any other languages commonly understood by a significant number of the population in the operator's area?	X			
.517	Pressure Testing	X			
.709	.619 Maximum Allowable Operating Pressure (MAOP)	X			
.709	.625 Odorization of Gas			X	
.709	.705 Patrolling (Refer to Table Below)	X			



## GAS STORAGE FIELD REVIEW

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE PERFORMANCE AND RECORDS				S	U	N/A	N/C
		Class Location	At Highway and Railroad Crossings	At All Other Places			
		1 and 2	2/yr (7½ months)	1/yr (15 months)			
		3	4/yr (4½ months)	2/yr (7½ months)			
		4	4/yr (4½ months)	4/yr (4½ months)			
.709	.706	Leak Surveys (Refer to Table Below)			X		
		Class Location	Required	Not Exceed			
		1 and 2	1/yr	15 months			
		3	2/yr*	7½ months			
		4	4/yr*	4½ months			
* Leak detector equipment survey required for lines transporting un-odorized gas.							
.603b/.727g	.727	Abandoned Pipelines also Underwater Facility Reports if applicable					X
.709	.731(a)	Compressor Station Relief Devices (1 per yr/15 months)			X		
.709	.731(c)	Compressor Station Emergency Shutdown (1 per yr/15 months)			X		
.709	.736(c)	Compressor Stations – Detection and Alarms (Performance Test)			X		
.709	.739	Pressure Limiting and Regulating Stations (1 per yr/15 months)					X
.709	.743	Pressure Limiting and Regulator Stations – Capacity (1 per yr/15 months)					X
.709	.745	Valve Maintenance (1 per yr/15 months)			X		
.709	.749	Vault Maintenance (≥200 cubic feet)(1 per yr/15 months)					X
.603(b)	.751	Prevention of Accidental Ignition (hot work permits)			X		
.603(b)	.225(b)	Welding – Procedure			X		
.603(b)	.227/.229	Welding – Welder Qualification			X		
.603(b)	.243(b)(2)	NDT – NDT Personnel Qualification			X		
.709	.243(f)	NDT Records (Pipeline Life)			X		
.709		Repair: pipe (Pipeline Life); Other than pipe (5 years)			X		

**Comments:**  
 Gas is not odorized at Jackson Prairie, no pipelines have been abandoned, pressure limiting and regulators are on the LP distribution system operated by PSE for Lewis County, and there are no existing vaults greater than 200 cubic foot in size.

CORROSION CONTROL PERFORMANCE AND RECORDS				S	U	N/A	N/C
.491	.491(a)	Maps or Records			X		
.491	.459	Examination of Buried Pipe when Exposed			X		
.491	.465(a)	Annual Pipe-to-soil Monitoring (1 per yr/15 months)			X		
.491	.465(b)	Rectifier Monitoring (6 per yr/2½ months)			X		
.491	.465(c)	Interference Bond Monitoring – Critical (6 per yr/2½ months)					X
.491	.465(c)	Interference Bond Monitoring – Non-critical (1 per yr/15 months)					X
.491	.465(d)	Prompt Remedial Actions			X		
.491	.465(e)	Unprotected Pipeline Surveys, CP active corrosion areas (1 per 3 cal yr/39 months)					X
.491	.467	Electrical Isolation (Including Casings)			X		
.491	.469	Test Stations – Sufficient Number			X		
.491	.471	Test Lead Maintenance			X		

## GAS STORAGE FIELD REVIEW

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked  
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL PERFORMANCE AND RECORDS			S	U	N/A	N/C
.491	.473	Interference Currents	X			
.491	.475(a)	Internal Corrosion; Corrosive Gas Investigation			X	
.491	.475(b)	Internal Corrosion; Internal Surface Inspection; Pipe Replacement			X	
.476(d)	.476	Internal Corrosion Control: Design and construction of transmission line			X	
.491	.477	Internal Corrosion Control Coupon Monitoring (2 per yr/7½ months)	X			
.491	.481	Atmospheric Corrosion Control Monitoring (1 per 3 cal yr/39 months onshore; 1 per yr/15 months offshore)	X			
.491	.483/.485	Remedial: Replaced or Repaired Pipe; coated and protected; corrosion evaluation and actions	X			

**Comments:**

There are no interference bonds in place or unprotected pipelines. Internal corrosion control coupons are collected from the slug catcher and no known internal corrosion from pipe replacement. Low points near wellheads are designed to collect water from pipelines placed on a slope to drain to the low points.

PART 199 – DRUG and ALCOHOL TESTING REGULATIONS and PROCEDURES		S	U	N/A	N/C
Subparts A - C	Drug & Alcohol Testing & Alcohol Misuse Prevention Program – Use PHMSA Form # 13, PHMSA 2008 Drug and Alcohol Program Check				

## Recent PHMSA Advisory Bulletins (Last 2 years)

Leave this list with the operator.

<b><u>Number</u></b>	<b><u>Date</u></b>	<b><u>Subject</u></b>
ADB-07-01	April 27, 2007	Pipeline Safety: Senior Executive Signature and Certification of Integrity Management Program Performance Reports
ADB-07-02	September 6, 2007	Pipeline Safety: Updated Notification of the Susceptibility to Premature Brittle-Like Cracking of Older Plastic Pipe
ADB-07-02	February 29, 2008	Correction - Pipeline Safety: Updated Notification of the Susceptibility to Premature Brittle-Like Cracking of Older Plastic Pipe
ADB-08-01	May 13, 2008	Pipeline Safety - Notice to Operators of Gas Transmission Pipelines on the Regulatory Status of Direct Sales Pipelines
ADB-08-02	March 4, 2008	Pipeline Safety - Issues Related to Mechanical Couplings Used in Natural Gas Distribution Systems
ADB-08-03	March 10, 2008	Pipeline Safety - Dangers of Abnormal Snow and Ice Build-Up on Gas Distribution Systems
ADB-08-04	June 5, 2008	Pipeline Safety - Installation of Excess Flow Valves into Gas Service Lines
ADB-08-05	June 25, 2008	Pipeline Safety - Notice to Hazardous Liquid Pipeline Operators of Request for Voluntary Adv Notification of Intent To Transport Biofuels
ADB-08-06	July 2, 2008	Pipeline Safety - Dynamic Riser Inspection, Maintenance, and Monitoring Records on Offshore Floating Facilities

For more PHMSA Advisory Bulletins, go to <http://ops.dot.gov/regs/advise.htm>

