

RV 76

Valve No.	Location of Valve	Valve Manu.	Serial No.	Model No.	S.V. Inlet-Outlet	Orifice	Set Pres.	Test Pres.	Rain Cap	Insp. Date	Cond.	Initial
S.R.V 073	SPARE State Vessel No. NB/Mfg. No.	Consolidated	TJ54431 Remarks:	1990C-1-XAI	1" M * 1" F	0.110	1747					
S.R.V 074	Dehy. #9 Tower State Vessel No. NB/Mfg. No.	Consolidated 27120-97W 1674	TJ54461 Remarks:	1997C-1-XDAI	1.5" M * 2" F	0.110	1000	1052.4	GC	6/24/2009	GC	RW
S.R.V. 075	S.U. #70 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27127-97W 4774	N/A Remarks:	6CV-00	1.5" M * 2" F	0.785	1000	1031.1	GC	5/15/2009	GC	RW
S.R.V 076	Dehy #1 Tower State Vessel No. NB/Mfg. No.	Consolidated 32684-66W 5358	TN-56153 Remarks:	Type1-1993C-XDA1	1" M * 1.5" F	0.292	1000	988.1	GC	2/11/2010	GC	RW
S.R.V 077	S.U.#71 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27121-97W 4775	N/A Remarks:	6CV-00	1.5" M * 2" F	0.785	1000	972.8	GC	6/1/2009	GC	RW
S.R.V 078	S.U.#911 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27123-97W 12667	N/A Remarks:	7CV-00	2" M * 2" F	0.785	1480	1360.4	GC	5/29/2009	GC	RW
S.R.V 079	Regen 2 Pump #1 State Vessel No. NB/Mfg. No.	Wellmark	S19428-01 Remarks:	W9501 RSB 1200	1" M * 1" F		1050	1049	NA	5/19/2009	GC	RW
S.R.V 080	Regen 2 TEG Hp. Filter State Vessel No. NB/Mfg. No.	Wellmark	S15986-1 Remarks:	W9501 RSB 1200	1" M * 1" F		900	871	GC	5/19/2009	GC	RW
S.R.V 081	SPARE State Vessel No. NB/Mfg. No.	Wellmark	92854-2 Remarks:	W9502-RS-150	2" M * 2" F		125					RW
S.R.V 082	S.U.#79 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13090	8069809 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	963.9	GC	5/15/2009	GC	RW
S.R.V 083	S.U.#78 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13089	8069806 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	976.7	GC	6/4/2009	GC	RW
S.R.V 084	Regen 2 Reciever Column State Vessel No. NB/Mfg. No.	Wellmark	S19586-5 Remarks:	W9501-RSA 25	1" M * 1" F		15	13.9	GC	5/15/2009	GC	RW
S.R.V 085	S.U.#76 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13171	N/A Remarks:	6CV00	1.5" M * 2" F	0.785	1000	983.5	GC	6/4/2009	GC	RW
S.R.V 086	S.U.#75 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13099	8069811 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	1010.7	GC	6/1/2009	GC	RW
S.R.V 087	S.U.#74 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13168	N/A Remarks:	6CV00	1.5" M * 2" F	0.785	1000	973.4	GC	6/1/2009	GC	RW

On the shelf in the warehouse

On the shelf in the warehouse

Valve No.	Location of Valve	Valve Manu.	Serial No.	Model No.	R.V. Inlet-Outlet	Orifice	Set Pres.	Test Pres.	Rain Cap	Insp. Date	Cond.	Calcs.	Initial
S.R.V 073	SPARE State Vessel No. NB/Mfg. No.	Consolidated	TJ54431 Remarks:	1990C-1-XAI	1" M * 1" F	.110	1747	SPARE					
S.R.V 074	Dehy. #9 Tower State Vessel No. NB/Mfg. No.	27120-97W 1674	TJ54461 Remarks:	1997C-1-XDAI	1.5" M * 2" F	.110	1000	1077.2	GC	6/2/2008	GC	JJ	RW
S.R.V. 075	S.U. #70 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27127-97W 4774	N/A Remarks:	6CV-00	1.5" M * 2" F	0.785	1000	968.3	GC	5/20/2008	GC	JJ	RW
S.R.V 076	Dehy #1 Tower State Vessel No. NB/Mfg. No.	Consolidated 32684-66W 5358	TN-56153 Remarks:	Type1-1993C-XDA1	1" M * 1.5" F	.292	1000	1037	GC	6/10/2008	GC	JJ	RW
S.R.V 077	S.U #71 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27121-97W 4775	N/A Remarks:	6CV-00	1.5" M * 2" F	0.785	1000	962.3	GC	5/29/2008	GC	JJ	RW
S.R.V 078	S.U #911 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 27123-97W 12667	N/A Remarks:	7CV-00	2" M * 2" F	0.785	1480	1378	GC	5/28/2008	GC	JJ	RW
S.R.V 079	Regen 2 Pump #1 State Vessel No. NB/Mfg. No.	Wellmark	S19428-01 Remarks: Capacity is 2818 SCFM	W9501-RSB 1200	1" M * 1" F		1050	1049	NA	5/19/2009	GC		RW
S.R.V 080	Regen 2 TEG Hp. Filter State Vessel No. NB/Mfg. No.	Wellmark	S15986-1 Remarks: Capacity is 2421 SCFM	W9501-RSB 1200	1" M * 1" F		900	871	GC	5/19/2009	GC		RW
S.R.V 081	SPARE State Vessel No. NB/Mfg. No.	Wellmark	92854-2 Remarks:	W9502-RS-150	2" M * 2" F		125	SPARE					RW
S.R.V 082	S.U.#79 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13090	8069809 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	943.6	GC	5/20/2008	GC	JJ	RW
S.R.V 083	S.U #78 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13090	8069806 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	939.3	GC	5/21/2008	GC	JJ	RW
S.R.V 084	Regen 2 Receiver Column State Vessel No. NB/Mfg. No.	Wellmark	S19566-5 Remarks: Capacity is 78 SCFM	W9501-RSA 25	1" M * 1" F		15	139	GC	5/15/2009	GC		RW
S.R.V 085	S.U.#76 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13171	N/A Remarks:	6CV00	1.5" M * 2" F	0.785	1000	982.5	GC	5/21/2008	GC	JJ	RW
S.R.V 086	S.U.#75 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13099	8069811 Remarks:	6CV00	1.5" M * 2" F	0.785	1000	930.7	GC	5/26/2008	GC	JJ	RW
S.R.V 087	S.U #74 HP Sep. State Vessel No. NB/Mfg. No.	Hydroseal 13168	N/A Remarks:	6CV00	1.5" M * 2" F	0.785	1000	936.3	GC	5/26/2008	GC	JJ	RW