

OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

Page: 1 of 1

NOTES-FIELD INSPECTION

Company: City of Buckley

Date(s): May 11, 2011

Unit: City of Buckley Gas Distribution System

Field Readings										
Line & Location	Line Size	In.	CP Volts		Casing	Rectifier		Pressures		Remarks
			P/S			Volts	Amps	Set	Actual	
Enumclaw Limiting Station at Mud Mtn Rd.	6		-	1605mV						We had to use this location to check for isolation from Buckley's system because the operator did not have the equipment on hand to take PSPs at the vault.
South End White River Bridge	6		-	1214mV						
South End White River Bridge	6			-504mV						
Rainier School Rectifier (City Shop)	4					41	1.8	42.3	1-R	No coarse or fines on this type of rectifier to note .18%
Odorant (Sniff Test - City Shop)										