

# WUCC Complaint Form

## Requester Information

---

Your Name:

Tyler Proszek

Your Company:

Avista Utilities

Your Phone Number:

5094958688

Your Email:

Tyler.Proszek@avistacorp.com

Your Address:

2406 N Dollar Rd

Your City:

Spokane Valley

Your State:

WA

Your Zip:

99212

Was a locate requested from the call center?  Yes  No

Ticket Number:

24205370

Ticket Date:

05/20/2024

## Violation Information

---

Alleged Violation/Damage:

RCW 19.122.030 Must call for marking two (2) full business days prior to digging.

Other

Section of Law Violated:

(2) An excavator shall use reasonable care t

Alleged Violation Date:

06/11/2024

Address of alleged violation:

11911 N Stevens Ct

City of Alleged Violation:

Spokane

State of Alleged Violation:

Washington

Zip of Alleged Violation:

99218

Basic Description:

M&L Construction failed to use reasonable care while excavating and damaged Avista's 3/4in PE gas service, causing an uncontrolled release of natural gas. The gas line was damaged with the use of mechanical equipment within the tolerance zone of the accurately located gas service, marked within two full business days. The damage occurred in a front yard, under grass, with sandy soil conditions surrounding the gas line. Use of mechanical equipment to damage the gas service is evident by the damage sustained and displayed in the supporting documentation.

## Alleged Violator

Company Name:

M&L Construction

Company Phone Number:

(509)818-6455

Company Email:

stephanie@mlnorthwest.com

Company Address:

Company City:

Spokane

Company State:

Washington

Company Zip:

99217

Names of Employees on Site:

Austin Hattenburg

## Other

Additional Information:

By submitting this form I acknowledge that the statements that I alleged are true and accurate to the best of my knowledge.