

**BEFORE THE
WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION**

McLEODUSA)	
TELECOMMUNICATIONS)	
SERVICES, INC.,)	
Petitioner,)	Docket No. UT-063013
v.)	
QWEST CORPORATION,)	
Respondent.)	

**DIRECT TESTIMONY
OF
SIDNEY L. MORRISON**

On behalf of

McLeodUSA Telecommunications Services, Inc.

April 28, 2006

PUBLIC VERSION

TABLE OF CONTENTS

I. INTRODUCTION AND QUALIFICATIONS 1

II. PURPOSE AND SUMMARY OF CONCLUSIONS AND
RECOMMENDATIONS 5

III. CENTRAL OFFICE POWER OVERVIEW 8

A. General Power Concepts and Their Application to Telecommunications
Equipment8

B. Central Office Power Infrastructure.....13

C. Qwest/McLeodUSA DC Power Measuring Amendment and “As
Consumed” Versus “As Ordered” Billing25

IV. MCLEODUSA’S APPLICATION OF THE DC POWER PLANT RATE
ELEMENT IS CONSISTENT WITH THE MANNER IN WHICH DC POWER
PLANT IS ENGINEERED..... 29

A. It is critical to distinguish the sizing of DC power plant from the sizing of
DC power distribution.....29

B. Proper DC power sizing and engineering supports McLeodUSA’s
recommended application of the DC power plant usage charge.....52

C. Qwest’s Power Reduction offering is not a suitable option to billing DC
power usage charges on an “as consumed” basis55

Exhibits

- Exhibit SLM-1** *Curriculum Vitae* of Sidney L. Morrison
- Exhibit SLM-2** Glossary of power terms
- Exhibit SLM-3** Testimony of Qwest Communications Corporation witness
Victoria Hunnicutt-Bishara in Illinois Commerce Commission
Docket No. 05-0675

Figures

- Figure 1** Diagram of central office power infrastructure
- Figure 2** Diagram of AC power components
- Figure 3** Diagram of DC power plant components
- Figure 4** Diagram of DC power distribution components
- Figure 5** Diagram of Network Voltage Drops
- Figure 6** McLeodUSA Collocated Equipment and Power Requirements
- Figure 7** McLeodUSA “as ordered” versus “as consumed” amperage

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

I. INTRODUCTION AND QUALIFICATIONS

Q. PLEASE STATE YOUR NAME, BUSINESS ADDRESS, AND OCCUPATION.

A. My name is Sidney L Morrison. My business address is 550 Sunset Lakes Boulevard SW, Sunset Beach, North Carolina 28468-4900. I am currently employed by QSI Consulting, Inc. (QSI) as a Senior Consultant and the Firm's Chief Engineer.

Q. PLEASE SUMMARIZE YOUR PROFESSIONAL EXPERIENCE.

A. I have over 30 years of experience in the telecommunications industry. I began my telecommunications career in 1966 in Charlotte, North Carolina as a cable helper for Southern Bell Telephone and Telegraph. Southern Bell was an incumbent local exchange carrier (ILEC) managing numerous exchanges throughout North Carolina. My duties involved splicing underground, buried and aerial cable. I also worked as a switching technician and special services technician.

Beginning in August of 1970, I transferred to Mountain Bell in Denver, Colorado as a central office technician. In 1972, I was promoted to supervise main distribution frame (MDF) operations. My duties included supervising the installation of Plain Old Telephone Service (or POTS), Special Services, Central Office area cuts, MDF replacements and many other projects. In 1980 and 1981, I performed time and motion studies for service provisioning on approximately 75 of Mountain Bell's MDF operations. These time and motion studies included components for running jumpers and administrative activities on each of these frames. From 1983 until 1986, I was the switching control center and MDF subject matter expert for US West. In this position, I was responsible for staff level support for service provisioning and maintenance,



26 including the development of enhancements for operational support systems (OSS)
27 supporting these activities. From 1986 until 1993, I was responsible for the US West
28 Automatic Message Accounting (AMA) teleprocessing organization for the fourteen state
29 US West region.

30 In 1993, I retired from US West and began contract engineering work and
31 consulting. In 1995, I took an assignment in Kuala Lumpur, Malaysia as a
32 contractor/consultant with a team of specialists to build a competitive local exchange
33 carrier (CLEC) network consisting of a Global System for Mobil (GSM) communications
34 services, fixed network services, cable television (CATV) services and data services
35 integrated into a common transport backbone. One of my primary responsibilities in
36 Malaysia was organizing and implementing a field operations group (FOG) that was
37 responsible for the installation and maintenance of all fixed network and CATV services.
38 My responsibilities included the planning, organizing, staffing and implementation of the
39 FOG, including an installation and maintenance group, assignment center, dispatch
40 center, test center and a repair center. I also had the responsibility of developing business
41 processes and OSS system requirements for provisioning and maintenance supporting the
42 FOG. After launching the FOG, I managed the day-to-day operations of the department,
43 ultimately refining the organization into an ISO 9002¹ qualified organization. In January
44 1997, the Binariang Maxis FOG became the first certified ISO 9002 service organization
45 in Southeast Asia.

46 I returned from Malaysia in June of 1997 and worked for approximately two
47 years as a contract outside plant/central office equipment (OSP/COE) engineer, and
48 trained new engineers for US West collocation efforts.

¹ International Organization Standards, ISO 9002 is the standard set of requirements for an organization whose business processes range from, production, installation and servicing.

49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70

In May 1999, I accepted a contract in Switzerland building a new CLEC under the market name of diAx telecommunications. My responsibilities involved project management to establish OSS supporting all wireless, wireline, and data services offered by diAx. I also provided consulting services developing business processes supporting the establishment of the diAx Internet Provider Operations Center (IPOC) and diAx data services offerings. I established system requirements based on IPOC business processes for fault management systems, provisioning systems, capacity inventory systems, customer service inventory systems and workflow engines controlling overall maintenance and provisioning processes.

In December 2000, I returned from Switzerland and began working for QSI Consulting Inc. as a Senior Consultant. I provide telecommunications companies with engineering advice and counsel for direct network planning, management and cost-of-service support. My specific areas of expertise include network engineering, facility planning, project management, business system applications, incremental cost research and issues related to the provision of unbundled network elements.

Attached to my testimony as Exhibit SLM-1 is a copy of my *Curriculum Vitae*, which contains a comprehensive description of my work experience and educational background.

Q. DO YOU HAVE DIRECT EXPERIENCE IN PLANNING AND ENGINEERING COLLOCATIONS FOR US WEST (N/K/A QWEST) CENTRAL OFFICES?²

² The FCC approved the acquisition of US West by Qwest in March of 2000.

71 A. Yes. As mentioned above and in Exhibit SLM-1, I worked for 22 years in US West's
72 Network Management Group. In 1997, I contracted to US West as a central office
73 engineer, where I was responsible for collocation planning and engineering in the
74 common systems planning and engineering center. My duties in this capacity included
75 Central Office Equipment Facility Management (COEFM) collocation design, floor space
76 planning and allocation, power engineering, tie cable engineering, collocation cage
77 placement, Heating Ventilation and Air Conditioning (HVAC) and collocation AC power
78 and overhead lighting. During this time frame, collocation business processes were being
79 developed, and I provided input to the development of engineering business processes
80 used in the implementation of collocation engineering practices and procedures within
81 the US West Common Systems Planning and Engineering Center (CSPEC) organization.

82 During my time as a central office engineer, I acquired first-hand experience in
83 observing the power usage trends of Qwest (then US West) central offices and
84 recommending power augments for those offices based on my observations and sound
85 engineering principles and practices. The proper planning and sizing of DC power
86 components in the central office is crucial to proper resolution of the disputed issues in
87 this proceeding, and I can speak to this issue based on direct working experience in
88 planning and sizing the power requirements of a central office.

89
90 **Q. HAVE YOU PREVIOUSLY TESTIFIED AS AN EXPERT WITNESS ON**
91 **COLLOCATION POWER ISSUES BEFORE OTHER STATE REGULATORY**
92 **COMMISSIONS?**

93 A. Yes. Most recently, I submitted expert testimony providing the engineering framework
94 supporting McLeodUSA's complaints against Qwest in Utah Docket No. 06-2249-01 and

95 Iowa Docket No. FCU-06-20, which cases involve the same collocation power issue.
96 Before that, I sponsored testimony before the Indiana Utility Regulatory Commission
97 (Cause No. 42398), in which I described the results of the collocation power audits
98 performed for a CLEC client in that state and explained that the CLEC did not, and
99 indeed could not, utilize the amount of power for which it was being billed by
100 AT&T/SBC Indiana. I wrote a similar audit report for a client for Public Utilities
101 Commission of Ohio Docket No. 03-802-TP-CSS. The issues in this docket are identical
102 to those in the companion Iowa and Utah dockets and very similar to those I have
103 testified to in other regions, in that in all instances, the incumbent local exchange carrier
104 is billing the CLEC for an amount of power that the CLEC does not, and indeed could
105 not, use. Throughout my testimony, I will reference positions taken on these issues by
106 Qwest in other states because I fully expect Qwest will take identical positions in its
107 testimony here.

109 **II. PURPOSE AND SUMMARY OF CONCLUSIONS AND RECOMMENDATIONS**
110

111 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

112 A. QSI was retained by McLeodUSA to support the cost, policy and engineering framework
113 underlying McLeodUSA's complaint against Qwest regarding the misapplication and
114 excessiveness of Qwest's Direct Current (DC) power plant charges. Michael Starkey,
115 from QSI, is filing testimony simultaneous with mine that will address the policy and cost
116 framework, and my testimony addresses the engineering framework.

117 The purpose of my testimony is to, first, provide a general overview of electricity
118 and power concepts and terminology that are important to a complete understanding of
119 the disputed issues. Second, I will provide descriptions and diagrams of the components

120 of a central office power infrastructure, with an explanation of how these components are
121 engineered and sized. Once the components of the central office power infrastructure are
122 addressed, I will identify the components of the central office to which McLeodUSA's
123 complaint applies – DC power plant –and explain from an engineering perspective why:
124 (a) it is inappropriate from an engineering perspective for Qwest to bill McLeodUSA for
125 DC power plant usage on an “as ordered” basis instead of on an “as consumed” basis, (b)
126 there is nothing improper about ordering more power capacity in the DC power
127 distribution than the CLEC can or will actually use, (c) Qwest power engineers would not
128 augment the power plant of the central office based on individual power-related orders
129 from McLeodUSA, other CLECs, or Qwest, and (d) why Qwest's power reduction
130 offering is not a suitable alternative to billing DC power plant based on McLeodUSA's
131 actual usage.

132

133 **Q. PLEASE SUMMARIZE YOUR CONCLUSIONS.**

134 A. My testimony concludes that McLeodUSA's recommended application of the DC power
135 plant usage charge is consistent with the manner in which DC power plant is sized, and in
136 turn, the manner in which Qwest incurs power plant costs. As my testimony will
137 demonstrate, it is critical to distinguish between power *plant* facilities, which are shared
138 among all power users in a particular central office and sized on an “as consumed” basis,
139 from power *distribution* facilities, which are dedicated to a particular power user and
140 sized on an “as ordered” basis. I will show that McLeodUSA makes the proper
141 distinction between those two power-related infrastructure components by recommending
142 that a power plant usage rate element be applied on an “as consumed” basis, while power
143 distribution facilities may be recovered on an “as ordered” basis. Further, my testimony

144 concludes that since the DC power plant facilities are sized according to forecasted actual
145 peak *usage* of all users in a central office, there is no relationship between *orders* for
146 power by CLECs and DC power plant augment/investment. This is a very important
147 point because, based on the other complaint filings to date, I expect Qwest witnesses will
148 submit testimony in this proceeding claiming that DC power plant is sized based on
149 CLEC power *orders* – not forecasted actual peak power usage. My direct testimony will
150 demonstrate, however, that Qwest’s position is in direct conflict with Qwest’s own
151 engineering manuals and guidelines as well as inconsistent with the positions taken by
152 Qwest’s CLEC affiliate (“QCC”) in testimony on DC power issues elsewhere. My
153 testimony will also show that the Commission should interpret the DC power
154 measurement amendment, and, in turn, require Qwest to apply the DC power plant usage
155 charge, in a manner consistent with the way in which the DC power plant is sized (or the
156 way in which Qwest incurs DC power plant costs). My testimony will demonstrate that
157 McLeodUSA’s recommendation adheres to this principle and Qwest’s recommendation
158 does not. Finally, I will explain that that Qwest’s Power Reduction is an unnecessary,
159 risky and costly process that causes more problems instead of solving the existing
160 problem related to Qwest’s application of the DC power plant usage charge. As such, it
161 is not a satisfactory alternative for addressing the problem of over-billed power charges
162 when compared to a proper interpretation of the contract amendment at issue in this
163 proceeding which should provide for “usage based” billing.

164

165

166

III. CENTRAL OFFICE POWER OVERVIEW

167

168

169

A. *General Power Concepts and Their Application to Telecommunications Equipment*

170

Q. IS A GENERAL UNDERSTANDING OF ELECTRICITY AND POWER

171

CONCEPTS AND TERMINOLOGY IMPORTANT TO THIS PROCEEDING?

172

A. Yes. While I am an engineer by trade, my testimony will use layman's terms and

173

descriptions when possible to limit the use of industry and technical jargon. However,

174

there are certain technical terms and engineering concepts related to electricity and power

175

that are important for a full understanding of the issues in dispute in this proceeding.

176

Accordingly, I will provide a quick overview of the "building blocks" of power and then

177

explain how these terms and concepts are relevant within the context of

178

telecommunications equipment and collocation power. For ease of reference, I have

179

attached to my testimony Exhibit SLM-2, which is a glossary of technical terms I use in

180

my testimony.

181

182

Q. WHAT IS POWER AND HOW IS IT MEASURED?

183

A. In its most basic form, power is the rate at which work is done – whether that power is

184

electrical or mechanical. Work is done whenever a force causes motion, and work is not

185

done when a force does not cause motion. For instance, if a mechanical force is used to

186

lift or move a weight, the force causes motion, and therefore, work is done. However, the

187

force of a compressed spring acting between two fixed objects does not cause motion

188

and, therefore, does not constitute work.

189 As it relates to electricity, electrical force is measured in voltage, which forces
190 current to flow (i.e., electrons to move) in a closed circuit. When voltage (or force) exists
191 between two points and current flows, then work is done. However, when voltage exists
192 between two points, but current cannot flow, no work is done. This is analogous to the
193 compressed spring example above that produced no motion.

194 When work is done by voltage causing electrons to move, the instantaneous rate
195 at which this work is done is called the electrical power rate, and its unit of measure is the
196 watt. The relationship between power, voltage and current can be expressed by the
197 following equation: $Power = Voltage \times Current$; where power is measured in watts,
198 voltage is measured in volts and current is measured in amperes.

199

200 **Q. PLEASE DESCRIBE THE FUNDAMENTAL DIFFERENCE BETWEEN**
201 **ALTERNATING CURRENT (AC) VERSUS DIRECT CURRENT (DC).**

202 A. Alternating current (AC) is a specific type of electric current in which the direction of the
203 current's flow is reversed, or alternated, on a regular basis. Direct current is no different
204 electrically from alternating current except for the fact that it flows in the same direction
205 at all times. Nearly all modern electronic devices require direct current for their
206 operation, but alternating current is what is provided by the electric utility. Therefore,
207 rectifiers are used to convert AC power to DC power so that electronic devices can use
208 it.³ The issue of AC power and DC power is relevant because the power that is delivered
209 to a telephone central office by the electric utility is AC power, but telecommunications
210 equipment generally uses DC power (i.e., -48 VDC), and therefore, AC power must be
211 converted to DC power at the central office.

³ [http://www.energyvortex.com/energydictionary/alternating_current_\(ac\)_direct_current_\(dc\).html](http://www.energyvortex.com/energydictionary/alternating_current_(ac)_direct_current_(dc).html)

212

213

Q. HOW DOES ELECTRICAL EQUIPMENT CONSUME POWER?

214

A. This will depend on the type of electrical equipment. Typically, however, the power consumed by telecommunications equipment is largely dependent on two factors. First, the power consumed by telecommunications equipment is dependent on the number of active subscribers (or the percent fill) of the equipment. Second, telecommunications equipment power usage is dependent on actual traffic or usage the equipment is supporting. In other words, the consumption of electrical power is dependent upon the “work” undertaken by the equipment, and specific to telecommunications equipment, more (or less) work is generally dependent upon the fixed number of subscribers the equipment must be equipped to support, and the amount of activity required by that customer base.

215

216

217

218

219

220

221

222

223

224

225

Q. PLEASE DEMONSTRATE HOW TELECOMMUNICATIONS EQUIPMENT CONSUMES POWER USING AN ILLUSTRATIVE PIECE OF EQUIPMENT?

226

227

A. A Digital Subscriber Line Access Multiplexer (DSLAM) is a common piece of telecommunications equipment that exhibits power usage characteristics that are representative of how telecommunications equipment typically consumes power. A DSLAM receives signals from multiple customer Digital Subscriber Line (xDSL) connections and aggregates the signals on a high-speed backbone using multiplexing techniques. With the addition of a splitter, this combination of equipment allows voice (low band) and data (high band) signals to be carried over a copper twisted pair. To demonstrate my point, I will use a popular DSLAM model - the Alcatel 7300 Advanced

228

229

230

231

232

233

234

235 Services Access Manager (ASAM),⁴ which according to Alcatel, is “the most widely
236 deployed digital subscriber line access multiplexer (DSLAM) in the world...”⁵ This
237 Alcatel DSLAM is capable of serving 5,000 lines per network interface with subtending
238 shelves.⁶ Regarding the first point – that power consumed is dependent on the percent fill
239 of the equipment – this DSLAM at 50% fill (or serving 2,500 of the possible 5,000 lines)
240 uses less power than if it were at 100% fill (or serving all 5,000 customers), everything
241 else equal.

242 Regarding the second point – that power consumption is dependent on the traffic
243 handled – the DSLAM will use less power when handling relatively lower levels of
244 traffic, or in other words, whether the DSLAM is serving 2,500 or 5,000 customers, the
245 power consumption is less when the circuits are idle and thus experiencing little or no
246 activity from those customers, everything else equal. Even considering that the DSLAM
247 may be fully utilized at 100% fill, the actual traffic patterns of customers varies with
248 periods of minimum use and rises to an average period of peak demand. Hence, two
249 Alcatel 7300 DSLAMs both supporting 2,500 customers may experience very different
250 power requirements depending upon the usage patterns of the individual subscribers they
251 support.

252

⁴ I use this Alcatel DSLAM model for illustrative purposes because it is a popular model and because there is considerable public information available about the technical specifications of this particular DSLAM model. McLeodUSA may or may not use this particular Alcatel model somewhere in its collocations – though the particular DSLAM McLeodUSA does use in its collocations would exhibit power usage characteristics identical to those described above.

⁵<http://www.alcatel.com/products/productsummary.jhtml?relativePath=/com/en/appxml/opgproduct/alcatel7300advancedservicesaccessmanerasamansiversiontcm228115681635.jhtml>

⁶ Alcatel 7300 ASAM product guide, p. 3. This DSLAM serves a maximum of 2,592 lines without subtending shelves.

253 **Q. ARE THESE FLUCTUATIONS IN POWER CONSUMPTION DUE TO**
254 **PERCENT FILL AND ACTUAL USAGE PARTICULARLY CHARACTERISTIC**
255 **OF TELECOMMUNICATIONS EQUIPMENT?**

256 A. These general power consumption characteristics are largely common across
257 telecommunications equipment, and they are particularly marked in a collocation
258 environment. This results from the fact that, within a CLEC collocation, the CLEC
259 equipment may have very low initial power requirements as the CLEC attempts to build a
260 customer base relative to that central office. Yet, as the carrier's business grows, the
261 percent fill increases and the actual usage for that equipment will increase, as will the
262 power draw required to electrify the equipment. Hence, with regard to most
263 telecommunications equipment, and collocated telecommunications equipment in
264 particular, the percent fill and the level of actual traffic generated by these customers will
265 change over time.

266
267 **Q. YOU EXPLAIN ABOVE THAT TELECOMMUNICATIONS EQUIPMENT DOES**
268 **NOT CONSUME POWER AT A CONSTANT RATE AND THAT POWER DRAW**
269 **REQUIREMENTS CHANGE OVER TIME. WHY IS THAT IMPORTANT IN**
270 **THIS CASE?**

271 A. The manner in which telecommunications equipment uses power is important to this case
272 because one of the key issues in dispute in this case is how DC power plant is sized by
273 Qwest. And because telecommunications equipment does not consume power at a
274 constant rate, the DC power consumption of central offices also varies. This variation in
275 DC power consumption of central offices impacts the manner in which Qwest engineers
276 size DC power plant in Qwest central offices. In sum, the power engineer must make

277 sure that the central office is capable of accommodating the forecasted actual peak usage
278 of the central office so that when power consumption peaks, Qwest's central office power
279 system can accommodate that peak level. Sizing DC power plant below this level would
280 be under-sizing the DC power plant and could lead to constraints on Qwest's ability to
281 provide power, and sizing DC power plant above this level would be wasteful and
282 inefficient. This peak capacity level by which power engineers size DC power plant is
283 referred to as the "average busy hour,"⁷ and represents the level when the load on the
284 central office telecommunications equipment is at its greatest. Busy hours can vary by
285 central office, and as such, proper DC power planning calls for power engineers to plan
286 for DC power plant in sufficient amounts to accommodate the average busy hour of that
287 particular central office.

288

289 **B. Central Office Power Infrastructure**

290

291 **Q. PLEASE DESCRIBE THE FUNDAMENTAL COMPONENTS OF A TYPICAL**
292 **CENTRAL OFFICE POWER INFRASTRUCTURE?**

293 **A.** There are four primary components of a typical central office power infrastructure.

294 Those components are as follows:

- 295 1. **Commercial Alternating Current (AC) Power:** this category consists of
296 the AC power procured from the electric utility and can include ancillary
297 distribution equipment including, conduit, cabling, fasteners and protective
298 equipment.⁸
299

⁷ The average busy hour drain is established by determining the profile of the office load for the busy day of the busy season (excluding abnormally busy operating days such as Mother's Day and Christmas).

⁸ Bellcore, Central Office Environment Detail Engineering Generic Requirements, Generic Requirements GR-1502-CORE, Issue 1, June 1994.

- 300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
2. **Standby AC Power:** this category consists of AC distribution equipment including engine/alternator, fuel tanks, fuel, AC switching and distribution equipment, that can be used in case of a failure of the office’s primary power source (i.e., the commercial source).
 3. **Direct Current (DC) Power Plant:** this category consists of equipment used to convert AC power to DC power regardless of whether the AC power is obtained from the commercial source or standby source. DC power plant generally consists of the following equipment: (i) rectifiers, which are used for the AC/DC conversion;⁹ (ii) batteries, which “provide the necessary current to power telephone switches [or equipment,]” “serve as a filter to smooth out fluctuations in the commercial power[.]” “remove the ‘noise’ that power often carries[.]” and “provide necessary backup power should commercial power fail[.]”¹⁰ and (iii) controllers, which manage the DC power.
 4. **DC Power Distribution:**¹¹ this category is the power infrastructure that consists of DC power cables and fuses in the Battery Distribution Fuse Bays (BDFBs) and circuit breakers in the Power Boards (PBs). The DC power distribution cabling consists of paired copper cables in insulated sheaths that complete a power circuit from the BDFB/PB to the telecommunications equipment lineups or CLEC collocation cages. One portion of each pair represents the “battery” or distribution of power and the other portion of each pair represents the “ground” or power return to the power source. Given the importance of un-interruptible power to the telecommunications equipment, power cables come in pairs for redundancy purposes. The primary cable feed is known as the “A” lead and the backup power cable is known as the “B” lead. If the A lead fails, the B lead should continue to power the equipment.
The BDFB is a fuse bay that contains fuses to protect power leads and cables from power surges and provides a distribution point where a large DC power lead can be broken down into smaller increments of power for distribution to telecommunications equipment. The BDFB allows for users of power in the central office to use smaller, more cost-effective power leads to power their equipment, while the fuses housed therein protect the power cables and telecommunications equipment from power currents that exceed the rated amperage of the fuses. The BDFB also contains alarms and monitors and usually contains ampere meters for manual monitoring.¹² The PB is similar to and provides the same functionality as the BDFB but is typically used for larger current distribution to equipment and collocations. For instance, as indicated in the Qwest/McLeodUSA DC Power Measuring Amendment, Qwest utilizes a BDFB for power orders in increments equal to

⁹ Newton’s Telecom Dictionary, 20th ed., p. 690.

¹⁰ Newton’s Telecom Dictionary, 20th ed., p. 103.

¹¹ DC power distribution is also referred to as delivery, and the terms DC power distribution and DC power delivery can be used interchangeably.


¹² Bellcore, Central Office Environment Detail Engineering Generic Requirements, Generic Requirements GR-1502-CORE, Issue 1, June 1994.

341
 342
 343

or less than 60 amps and uses PBs for orders in increments greater than 60 amps.¹³

344
 345
 346

Figure 1 is a diagram of a typical central office power infrastructure, color-coded so as to distinguish the primary components of the central office power infrastructure from one another.



347
 348

¹³ DC Power Measuring Amendment to the Interconnection Agreement between Qwest Corp. and McLeodUSA Telecommunications Services, Inc., Attachment 1, Sections 1.1 and 1.2.

349 As Figure 1 shows, the four basic power components – (1) AC commercial power (shown
350 in black), (2) standby AC power (shown in green), (3) DC power plant (shown in blue),
351 and (4) DC power distribution (shown in red) - work together to power the
352 telecommunications equipment in a central office. It is important to note that the first 3
353 categories are shared among all power users in a central office, while the fourth category
354 – DC power distribution – is dedicated to a specific customer (or group of customers).
355 And while a CLEC collocation cage is depicted in Figure 1, the same AC power and DC
356 power-related equipment are also used to serve Qwest’s power needs in a nearly identical
357 fashion.

358

359 **Q. YOU MENTIONED REDUNDANCY RELATED TO AC POWER SOURCES**
360 **AND DC POWER DISTRIBUTION CABLES. WHY DO CENTRAL OFFICE**
361 **POWER SYSTEMS EXHIBIT THIS LEVEL OF REDUNDANCY?**


362 A. Redundancy is a basic concept in much of the telecommunications network. Given that
363 electronic equipment commonly found in ILEC central offices is essential to providing
364 service to customers (e.g., switches, processors, optical feeder networks), the power
365 system is designed with redundancy so that this equipment can continue to function even
366 if the primary source or delivery method fails.

367

368 **Q. PLEASE ELABORATE ON EACH OF THE CATEGORIES OF CENTRAL**
369 **OFFICE POWER COMPONENTS.**

370 A. Figure 2 is a diagram of the components of AC power.

Figure 2



371
372

373

374

375

376

377

378

379

380

381


As Figure 2 shows, AC power is delivered to the central office by the electric utility (or the standby AC power source)¹⁴ and is converted to DC power which is used by telecommunications equipment in the central office. AC power is delivered to the central office on a demand basis controlled by the requirements of the AC service within the office (e.g., AC lights, HVAC, elevators), and the demand requirements of the DC power plant serving telecommunications equipment.

Q. PLEASE ELABORATE ON DC POWER PLANT.

A. Figure 3 below is a diagram of the DC power plant.

¹⁴ Standby AC power consists of an arrangement of a engine, diesel, gasoline or jet turbine, and fuel tanks for producing mechanical power connected to a generator set for producing AC power and a switching mechanism, usually automated, to transfer AC service from a failed utility and to transfer service back to a successfully-recovered utility service.

Figure 3



382
383

384

385

386

387

388

389

390

391

392

393

394

395

396

397

398

The components of the DC power plant convert the AC power to DC power. The DC Power Plant is designed by power engineers to provide DC Power sufficient to accommodate the forecasted actual peak *usage* of all telecommunications equipment housed in that particular central office. Again, DC power plant equipment is common to the entire Qwest central office and is used to support the equipment of Qwest as well as the CLECs (and others).

Q. YOU STATE ABOVE THAT POWER ENGINEERS DESIGN THE DC POWER PLANT OF A CENTRAL OFFICE BASED ON THE FORECASTED ACTUAL PEAK USAGE FOR THAT OFFICE. PLEASE ELABORATE ON THIS PROCESS.

A. In a basic example of a Qwest central office, Qwest power engineers monitor the actual usage of DC power and observe the peak power usage that takes place at the average busy hour. Qwest engineers would then take steps to ensure that the DC power plant is


399 capable of handling the usage that occurs at this peak period. In other words, DC power
400 plant is sized based on the maximum power draw that takes place on a CO-wide basis
401 during the busy hour. I will also refer to this in my testimony as the List 1 drain – or the
402 amperage that the equipment uses when the power plant is operating normally at
403 maximum capacity (discussed in more detail below). So, in other words, DC power plant
404 is sized based on List 1 drain. Power engineers oftentimes utilize a fill factor to build in a
405 “cushion” of excess capacity between the busy hour load and the actual capacity of the
406 DC power plant. Or, perhaps more appropriately, those engineers identify a “target”
407 usage level which may indicate to them that the existing power plant, given forecasted
408 peak usage, may fall short in a busy hour scenario. Hence, when usage hits that “target”
409 level, they begin to explore augmentation alternatives. Importantly, however, Qwest DC
410 power engineers do not augment the DC power plant infrastructure based on particular
411 power orders of a CLEC or Qwest. Given that DC power plant is sized based on
412 forecasted actual peak usage for all equipment in the office, there is no relationship
413 between Qwest’s investment/augmentation in DC power plant and individual orders for
414 power (whether they be from Qwest or a CLEC). I will demonstrate below in Section IV
415 that my testimony on the proper sizing of DC power plant and DC power distribution is
416 backed by Qwest’s own engineering manuals and guidelines.

417

418 **Q. PLEASE ELABORATE ON DC POWER DISTRIBUTION.**

419 A. Figure 4 below is a diagram of the components of the DC power distribution
420 infrastructure.

Figure 4



421
422 As indicated in Figure 4, once the AC power is converted to DC power, that DC power is
423 delivered to CLEC collocation equipment via power distribution cables. These power
424 cables are protected from over-current situations by circuit breakers housed in power
425 boards and fuses that are housed in the BDFBs. Unlike the DC power plant components
426 which are a shared resource powering the equipment of all users in the office, the DC
427 power distribution components are generally specific to a particular power user (or group
428 of users), and it is, therefore, critical to distinguish the DC power *plant* from the DC
429 power *distribution* when discussing how DC power systems are sized and how charges
430 for DC power should be assessed to recover costs related to sizing these DC power
431 system components.

432
433 **Q. HOW IS DC POWER DISTRIBUTION SIZED?**

434 A. The short answer to this question is that DC power distribution is sized based on List 2
435 drain. The List 2 Drain is the maximum current that the equipment will draw when the

436 power plant is in worst case condition of voltage and traffic distress - when the DC power
437 plant's batteries are approaching a condition of total failure (List 2 drain will be discussed
438 in more detail below in Section IV). That being said, the process of actually sizing DC
439 power distribution cables is a bit more complex.

440 The basic idea behind distribution cable design is to make the voltage drop in the
441 cable as small as possible, while at the same time installing the power cable with the
442 smallest diameter allowable within specific parameters. Given that the cost of power
443 cables and power cable installation increases significantly as cable diameter increases, the
444 smallest cable capable of maintaining the minimum voltage drop is chosen to minimize
445 the cable cost, as well as to control the amount of space the cables occupy in the power
446 distribution cable racks.

447

448 **Q. PLEASE ELABORATE ON THE SPECIFIC PARAMETERS WITHIN WHICH**
449 **POWER DISTRIBUTION CABLES MUST BE SIZED.**

450 A. DC power distribution cables are sized using a formula and process related to the amount
451 of voltage drop that will be allowed across the power distribution cables. That formula
452 for calculating copper feeder cables is as follows:

453
$$CM = [K \times \text{Amperes} \times \text{Feet}] / \text{Voltage Drop}$$

454

455 Where:

456

457 CM = Circular Mills

458

459 K = 11.1, the conductance constant for copper cables

460

461 Amperes = List 2 drain

462

463 Feet= Distance of loop as measured from the relay rack top of each connection
464 point and is not inclusive of the relay rack drop length.
465

466 Voltage Drop = Allowable voltage drop from Power Board to BDFB and the
467 allowable voltage drop from the BDFB to the Equipment or Load.
468

469 There are three key variables in the power cable sizing formula that leads to the correct
470 sizing of power distribution cables. *First*, the amount of current (measured in amperes)
471 that must be distributed through the cable is the primary variable. As an engineer
472 increases the amount of current needed for distribution across the power cable, the larger
473 the required cable diameter or cross sectional area that must be utilized to carry the added
474 current. The amount of current (in amperes) used in the formula is referred to the List 2
475 Drain. When a DC power plant is in distress, as is the case with List 2 drain, the terminal
476 voltage of the batteries begins to decrease. For the telecommunications equipment load
477 to continue to draw the same amount of DC power, the current increases proportionately
478 (recall that $\text{Power} = \text{Voltage} \times \text{Current}$, wherein a drop in voltage requires a subsequent
479 increase in current to keep the available power at a constant level). This increase in
480 current and decrease in voltage occurs automatically in the telecommunications
481 equipment, so it can continue operating properly. However, the power cable diameters
482 must be sized to accommodate the additional current required in this worst case situation
483 (or List 2 Drain). The List 2 drain is also known as the recommended amperage because
484 it is the amperage level McLeodUSA must order to operate the equipment properly and in
485 accordance with manufacturer's recommendations and safety standards. The
486 recommended amperage is set at a higher amperage level (compared to the amperage that
487 will actually be used by the equipment under normal circumstances) because it takes into
488 account the worst case scenario, such as low voltage during a battery discharge.


489 *Second*, the longer the DC power cable, the greater the voltage drop that will
490 occur, all other factors held constant. This means that, the longer the distribution cable

491 through which the DC current must travel (measured in feet in the formula), the greater
492 the cables resistance, thereby causing an increased voltage drop from the desired voltage
493 level and corresponding increases in heat.

494 *Third*, the larger the diameter of the DC power distribution cable, the lower the
495 voltage drop that will occur, assuming all else equal. That is, if the current has more
496 cable cross-sectional area through which to travel, there is less resistance, thereby causing
497 a smaller voltage drop and less heat.

498 When sizing power cables, a power engineer, using the formula above, must
499 identify the allowable maximum voltage drop between the BDFB/PB and the
500 telecommunications equipment or CLEC collocation. This allows the engineer to size the
501 smallest diameter power cable based on the cable length that must be traversed with a
502 given amperage. Figure 5 depicts an illustration of a typical voltage drop from the Power
503 Board to BDFB and from the BDFB to the equipment.

Figure 5
Distribution Network Voltage Drops



504 In sum, the power distribution cables have a measurable resistance across them that must
505 be controlled. This resistance causes a voltage drop that occurs between the DC Power
506
507

508 Plant and the telecommunications equipment, which, if not managed, causes heat buildup
509 in the distribution cables, and could lead to fire and/or service outages.

510

511 **Q. IS THERE ANOTHER FACTOR THAT IS TAKEN INTO ACCOUNT WHEN**
512 **SIZING DC POWER DISTRIBUTION INFRASTRUCUTRE?**

513 A. Yes. Importantly, when a collocator orders a DC power distribution arrangement (or DC
514 power cables), the CLEC is not ordering the DC power distribution capacity that the
515 CLEC needs immediately based on current demand, but rather the DC power distribution
516 capacity that the CLEC will ultimately require in the collocation arrangement when it
517 matures. This is reasonable because it is extremely costly and risky to routinely re-
518 engineer and physically modify its DC power distribution arrangements (e.g., swapping
519 out power cables or resizing fuses/breakers). These costs and risks can be avoided by
520 sizing the DC power cables for their ultimate demand.

521

522 **Q. HAVE CENTRAL OFFICE POWER PLANNING PRINCIPLES AND**
523 **PROCEDURES MATERIALLY CHANGED DUE TO THE INTRODUCTION OF**
524 **COMPETITION?**

525 A. No. In Iowa, Qwest insinuated that the credibility of my expert testimony should
526 somehow be questioned because my experience with regard to central office power
527 planning primarily predates the Telecommunications Act and the advent of collocated
528 CLECs. The Commission should be aware that in case Qwest makes a similar
529 insinuation here, Qwest's claim is not only factually inaccurate but also irrelevant. As
530 the description of my experience above indicates, I contracted with Qwest f/k/a US West

531 in the post-CLEC era (from August 1997 through May 1999) as a central office engineer,
532 responsible for collocation planning and engineering in the common systems planning
533 and engineering center. Moreover, the Telecommunications Act of 1996 and the advent
534 of collocated CLECs did not necessitate material changes to the power planning
535 guidelines or procedures that Qwest and other ILECs had used for years prior to that
536 time. The host of Bellcore and Qwest engineering manuals and technical documents I
537 reference above date back prior to 1996 (some going back to 1989), and are still relevant
538 today, which shows that the introduction of collocated CLECs (due to the introduction of
539 competition in local telecommunications markets) did not change the way in which
540 central office DC power is engineered or how DC power plant is sized. Regardless of
541 whether there is one (1) power user or ten (10) power users in a central office, DC power
542 plant is sized based on the List 1 drain of all telecommunications equipment being
543 powered in the central office, and as such, DC power plants are designed to accommodate
544 loads, and not particular carriers. Therefore, it is truly irrelevant within the context of DC
545 power plant sizing whether the equipment powered is the ILEC's or a CLEC's – or
546 whether experience in designing central office power plants occurred in pre-CLEC or
547 post-CLEC days – because the guidelines would be the same under each scenario.

548

549 *C. Qwest/McLeodUSA DC Power Measuring Amendment and “As Consumed”*
550 *Versus “As Ordered” Billing*

551

552 **Q. PLEASE DESCRIBE YOUR UNDERSTANDING OF THE INTERCONNECTION**
553 **AGREEMENT AMENDMENT SIGNED BETWEEN QWEST AND**
554 **MCLEODUSA RELATIVE TO THE ISSUE OF POWER MEASUREMENT (AND**
555 **WHICH SERVES AS THE BASIS FOR MCLEODUSA’S COMPLAINT).**

556 A. For McLeodUSA collocation arrangements with power feeds greater than sixty (60)
557 amps, the Qwest and McLeodUSA Amendment¹⁵ requires that Qwest monitor
558 McLeodUSA's DC power usage at the power board on a semi-annual basis (unless
559 otherwise requested by McLeodUSA). Per the terms of the amendment, these
560 measurements support a process whereby Qwest measures and records McLeodUSA's
561 actual power consumption and assesses "Power Usage" charges according to that actual
562 usage. The measured usage rate structure required by the Amendment is in contrast to
563 previous situations wherein Qwest assessed all "Power Usage" elements on an "as
564 ordered," as opposed to "as consumed" basis.

565

566 **Q. DO YOU UNDERSTAND THAT ONE OF THE PRIMARY POINTS OF**
567 **CONTENTION BETWEEN MCLEODUSA AND QWEST IN THIS**
568 **PROCEEDING IS WHETHER OR NOT THE "POWER PLANT" CHARGE**
569 **SHOULD BE ASSESSED ON AN "AS CONSUMED" VERSUS AN "AS**
570 **ORDERED" BASIS?**

571 A. Yes, that is my understanding.

572

573 **Q. AND DO YOU FURTHER UNDERSTAND THAT THIS PRIMARY ISSUE**
574 **RESULTS FROM DISPARATE INTERPRETATIONS OF THE SAME POWER-**
575 **MEASUREMENT AMENDMENT?**

576 A. Yes, that is also my understanding.

577

¹⁵ DC Power Measuring Amendment to Qwest/McLeodUSA interconnection agreement.

578 **Q. DO YOU ADDRESS COST-CAUSATION OR ECONOMIC-COST RELATED**
579 **ASPECTS OF THIS COMPLAINT?**

580 A. No, Mr. Starkey will address those issues in his testimony. However, I do provide
581 through my testimony the engineering foundation upon which Mr. Starkey bases his
582 conclusions related to cost-causation and proper cost recovery.

583
584 **Q. IS THERE ANY ENGINEERING BASIS FOR MCLEODUSA'S**
585 **INTERPRETATION OF THE AGREEMENT AMENDMENT?**

586 A. Yes, in fact, I am surprised that any engineer with an understanding of how central office
587 power plant and power distribution infrastructure are designed would interpret the
588 amendment as Qwest is. The key here is to compare how each party recommends the DC
589 power plant usage charge be applied (i.e., Qwest's "as ordered" recommendation or
590 McLeodUSA's "as consumed" recommendation) to each party's proposal on how the DC
591 power plant is sized in the central office, and in turn, how Qwest invests in DC power
592 plant.

593
594 **Q. PLEASE SUMMARIZE MCLEODUSA'S VIEW ON "AS CONSUMED" VERSUS**
595 **"AS ORDERED" BILLING FOR THE DC POWER PLANT USAGE CHARGE.**

596 A. McLeodUSA's "as consumed" recommendation means that the DC power plant usage
597 charge would be applied to the amps that McLeodUSA actually uses. Power plant related
598 equipment is sized and constructed based upon the shared usage demands of the entire
599 office, and as such, it is perfectly logical that users who consume more power will pay
600 more, while users who consume less power should pay less (i.e., these costs should be
601 recovered on an "as consumed" basis). Likewise, because power distribution systems are

602 largely dedicated to individual users or groups of users, and must be sized to the original
603 orders of the user, then those costs are legitimately recovered on an “as ordered” basis. I
604 have read the Power Measurement Amendment referenced above and I interpret it to
605 provide for exactly this situation.

606

607 **Q. WHEN QWEST CLAIMS THAT DC POWER PLANT IS SIZED ACCORDING**
608 **TO CLEC ORDERS FOR POWER, WHAT DOES THAT ACTUALLY MEAN?**

609 A. The CLEC power orders that Qwest claims serve as the trigger for DC power plant
610 augments/investment are orders for *DC power distribution* (i.e., power cables), and as
611 such, Qwest is saying that DC power *plant* is sized according to orders for power
612 *distribution* cables. Or in other words, Qwest claims that if a CLEC orders a 175 Amp
613 power cable to power its collocation cage, Qwest will build 175 Amps of capacity into its
614 DC power plant infrastructure.¹⁶ However, this is not the case, and Qwest is attempting
615 to confuse the two issues of DC power plant and DC power distribution. As was
616 explained above (and will be demonstrated in more detail below through the use of
617 Qwest’s own engineering manuals), DC power distribution is sized based on List 2 drain
618 and DC power plant is sized based on List 1 drain. By claiming that DC power plant is
619 sized based on CLEC orders for power distribution (or List 2 drain), Qwest is either
620 misunderstanding or intentionally mischaracterizing its own engineering practices such
621 that they appear to support Qwest’s interpretation of the Amendment, wherein Qwest
622 would prefer to continue applying the DC power *plant* usage charge based on ordered DC
623 power *distribution*. Fortunately, Qwest’s engineers who work with power plant on a

¹⁶ In fact, in Iowa, Qwest witness Robert Hubbard testified that “even 175 amps...will definitely trigger a power plant capacity growth job.” Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, page 8.

624 daily basis document their actual practices in accordance with sound engineering
625 standards and those records refute Qwest's claims in this regard.

626 In the following section of my testimony, I will demonstrate that Qwest's "as
627 ordered" billing recommendation fails to adhere to Qwest's engineering manuals and
628 guidelines and does not square with positions on DC power expressed by Qwest
629 Washington's affiliate, Qwest Communications Corporation.

630

631 **IV. MCLEODUSA'S APPLICATION OF THE DC POWER PLANT RATE**
632 **ELEMENT IS CONSISTENT WITH THE MANNER IN WHICH DC POWER**
633 **PLANT IS ENGINEERED**
634

635 **A. *It is critical to distinguish the sizing of DC power plant from the sizing of DC***
636 ***power distribution***
637

638 **Q. YOU EXPLAINED ABOVE THAT DC POWER PLANT IS SIZED**
639 **DIFFERENTLY THAN DC POWER DISTRIBUTION, CAN YOU EXPLAIN**
640 **WHY AND HOW THIS IMPACTS MCLEODUSA'S COMPLAINT?**

641 **A.** Yes. I explained that DC power plant is sized by power engineers monitoring the DC
642 power load requirements of the central office at peak capacity – based on List 1 drain -
643 and growing the DC power plant accordingly, and as such, DC power plant is sized
644 according to forecasted actual peak usage of the central office, in terms of the average
645 busy hour of the office. DC power distribution, on the other hand, is sized based on the
646 List 2 drain, or the power draw of the equipment when the power plant is under a worst
647 case scenario and based on the ultimate demand for power. This results in a situation
648 whereby DC power distribution capacity ordered by CLECs for their collocation, which
649 is the amperage level of the DC power cables ordered for that collocation (or "as

650 ordered” capacity) exceeds (oftentimes significantly) the DC power actually used by their
651 equipment (or “as consumed” capacity), which is the capacity level on which the DC
652 power plant is sized.¹⁷ By billing McLeodUSA the DC Power Plant charge on an “as
653 ordered” basis – or on the capacity level on which DC power *distribution* is sized -
654 Qwest is attempting to fit a square peg in a round hole. Instead, DC power plant is sized
655 on an “as consumed” basis and, therefore, it would be consistent and appropriate for the
656 DC power plant charge to apply on an “as consumed” basis. In my opinion, therefore,
657 the interpretation of the Amendment by McLeodUSA is correct.

658

659 **Q. PLEASE DISCUSS IN MORE DETAIL THE CONCEPTS OF LIST 1 DRAIN**
660 **AND LIST 2 DRAIN?**

661 A. List 1 drain and List 2 drain are industry-standard measurements used to measure the
662 power draw requirements of various types of equipment. As mentioned above, List 1
663 drain is the average busy hour current during normal plant operation. The value is used
664 to size DC power plant, such as batteries and rectifiers. List 2 drain is the peak current
665 under worst case conditions of voltage, traffic etc. This current is used to size power
666 distribution cables, plant discharge capacity and over-current protectors. Generally, List
667 1 drain corresponds with the “as consumed” capacity (at the peak level), while List 2
668 drain corresponds to the “as ordered” capacity level. So, restating the problem with
669 Qwest’s application of the DC power plant usage charge in terms of List 1 drain and List
670 2 drain: Qwest is assessing the DC power plant charge based on the List 2 drain, when in
671 reality, List 1 drain defines DC power plant sizing, augmentation and investment.

672 Therefore, assessing the DC power plant charge on a List 2 drain is inconsistent with

¹⁷ Notably, in the context of collocation, DC power distribution is dedicated to a specific user, while DC power plant is shared among all users in the central office (i.e., Qwest and CLECs alike).

673 proper engineering practices. Also, as described above, the List 2 drain significantly
674 exceeds the List 1 drain, which means that Qwest's billing of McLeodUSA for DC power
675 plant based on the higher List 2 drain results in DC power plant charges that significantly
676 exceed the charges that would result from applying the charge to the "as consumed"
677 amperage.

678

679 **Q. IS QWEST'S ASSERTION THAT QWEST SIZES DC POWER PLANT BASED**
680 **ON POWER ORDERS CONSISTENT WITH QWEST'S ENGINEERING**
681 **REQUIREMENTS AND MANUALS?**

682 A. No, it is not. Qwest's own engineering guidelines and requirements belie Qwest's
683 assertions in this regard. In discovery, McLeodUSA requested Qwest to provide various
684 technical documents used by Qwest's collocation planning and power engineers when
685 they design central offices and their associated power infrastructure.¹⁸ This
686 documentation clearly supports my view of the proper sizing and engineering of DC
687 power systems (both DC power plant and DC power distribution), and directly
688 contradicts Qwest's view.

689

690 **Q. PLEASE PROVIDE SOME EXAMPLES WHEREIN QWEST'S INTERNAL**
691 **ENGINEERING DOCUMENTATION SUPPORTS YOUR POSITION AND**
692 **REFUTES THE POSITION TAKEN BY QWEST.**

¹⁸ McLeodUSA Data Request #1 of First Set to Qwest reads as follows: "**Request 1:** Please provide the following Qwest technical documents, or their closest equivalents, used by Qwest collocation planning and power engineers. McLeodUSA understands that all of these documents were originally produced either by AT&T, Bellcore/Telcordia or US West Business Resources, Inc. and, in some cases, were adapted for Qwest's internal use. If that understanding is not correct, please clarify."

693 A. Consider “*Qwest Technical Publication: Power Equipment and Engineering Standards,*
694 *Technical Document No. 77385, Issue H, September 2003, Copyright 1996, 1998, 1999,*
695 *2000, 2001 and 2002.*”¹⁹

696 Chapter 2 of this document entitled “*DC Power Plants and Chargers*” states as
697 follows:

698 **2.4 Engineering Guidelines**

699 When sizing power plants, the following criteria shall be used:

700 **List 1** drain is used for sizing batteries and chargers; the average busy-
701 hour current at normal operating voltage should be used. Telephony List
702 1 drains are measured at 9 ccs or at 18 ccs for the first 2 hours of a
703 discharge and 6 ccs thereafter.

704 **List 2** drain is used for sizing feeder cables, circuit breakers, and fuses;
705 the current that is required for projected peak under worst operating
706 conditions should be used. Telephony List 2 drains are measured at 36
707 ccs at -42.75 V for a nominal -48 VDC plant.
708

709
710
711 On the same page, the engineering manual discusses the sizing of battery plant – a
712 component of DC power plant – as follows:

713 BATTERY PLANT SIZING — when a battery plant is initially installed,
714 the meter and bus bar should be provided based on the projected power
715 requirements for the life of the plant. Base chargers and batteries should
716 be provided based on the projected end of engineering interval connected
717 average busy-hour current drains (List 1).
718

719 **Q. IS THERE OTHER INFORMATION THAT SUPPORTS YOUR VIEW OF DC**
720 **POWER PLANT SIZING AND DIRECTLY CONTRADICTS QWEST’S VIEW?**

721 A. Yes. Take for example Bellcore’s “*DC Distribution,*” Technical Document No. 790-100-
722 656, which confirms the information above in Qwest’s Technical Publication.
723 Specifically, Section 2 “Telecommunications Equipment Loads” states as follows:

¹⁹ Provided in response to McLeodUSA Data Request #1b and available at
<http://www.qwest.com/techpub>

724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760

[REDACTED]

Furthermore, legacy document REGN 790-100-654RG “DC Plant” (published by Qwest)
states as follows:

[REDACTED]

Another excerpt from Qwest’s engineering manuals specifically warns against doing
precisely what Qwest is claiming that it does – i.e., size DC power distribution on “as
ordered” capacity, or List 2 drain. Qwest technical document REGN 790-100-655G
“Batteries” Issue No. 9 dated February 2006 (at page 22) states:

[REDACTED]

761 It is concerning that Qwest would advocate a position that its own engineering manuals
762 recommend against and that would create situations of [REDACTED]

763 [REDACTED]

764 Another one of these manuals – Bellcore technical document “Power Systems
765 Installation Planning” BR 790-100-652 (at page 5-1) elaborates on a power study
766 procedure used to size DC power systems. First it requires engineers to [REDACTED]

767 [REDACTED]

768 [REDACTED] This document also contains
769 Figure 5-2 which is a flow diagram of a “Power Study Procedure”. This flow diagram,
770 which is documentation memorializing the DC power plant sizing exercise I described,
771 shows the following steps to sizing DC power plant (pages 5-4 and 5-5): [REDACTED]

772 [REDACTED]

773 [REDACTED]

774 [REDACTED]

775 [REDACTED]

776 [REDACTED]

777 [REDACTED]. This manual also

778 includes an example of the graph (see page 6-11, Figure 6-1) that is created [REDACTED]

779 [REDACTED]

780 [REDACTED]

781 [REDACTED]

782 [REDACTED]

783 [REDACTED]

784

[REDACTED]

785

[REDACTED].

786

787

**Q. WHAT DO THESE QWEST ENGINEERING GUIDELINES AND
REQUIREMENTS SHOW?**

788

789

A. The above excerpts from Qwest's own power engineering manuals, individually and
taken together, makes several points very clear:

790

791

[REDACTED]

792

[REDACTED]

793

[REDACTED]

794

[REDACTED]

795

[REDACTED]

796

[REDACTED]

797

[REDACTED]

798

[REDACTED]

799

All three (3) of these points support my testimony and the position of McLeodUSA.

800

801

**Q. YOU POINT TO A NUMBER OF ENGINEERING REQUIREMENTS AND
MANUALS THAT SUPPORT YOUR VIEW OF THE METHOD FOR SIZING DC
POWER PLANT AND DC POWER DISTRIBUTION. DID QWEST POINT TO
ANY ENGINEERING MANUALS, REQUIREMENTS OR OTHER
DOCUMENTATION SUPPORTING ITS VIEW IN IOWA?**

802

803

804

805

806

A. No and I highly doubt that Qwest will provide any relevant cites to engineering manuals
in Washington either, primarily because there are no engineering manuals or

807

808 specifications supporting Qwest’s notion that DC power plant is sized according to power
809 orders – or List 2 drain.

810

811 **Q. YOU ALSO MENTIONED THAT QWEST’S ASSERTION THAT DC POWER**
812 **PLANT IS SIZED BASED ON POWER ORDERS IS INCONSISTENT WITH**
813 **THE POSITION QWEST’S CLEC AFFILIATE HAS TAKEN ELSEWHERE.**
814 **PLEASE ELABORATE.**

815 A. Qwest Communications Corporation (“QCC”, which is, like Qwest Corp. the ILEC, a
816 direct subsidiary of Qwest Services Corporation)²⁰ recently sponsored testimony in
817 Illinois Commerce Commission Docket No. 05-0675, which addressed AT&T/SBC
818 Illinois’ collocation DC power policy. In that case, SBC Illinois was attempting to
819 change the way in which it currently assessed collocation power charges and was
820 attempting to convert its existing measured, kWh based charge to a simple per-amp
821 charge, similar to that assessed by Qwest in Washington. The testimony of the QCC
822 witness (Victoria Hunnicutt-Bisahra) in Illinois undermines Qwest’s position, and I have
823 provided Ms. Hunnicutt-Bishara’s response and surrebuttal testimony from Illinois as
824 Exhibit SLM-3 to my direct testimony. For instance, Ms. Hunnicutt-Bishara testified as
825 follows in Illinois:²¹

826

827 **Q. WHAT IS THE PURPOSE OF THE LIST 1 AND LIST 2**
828 **DRAIN SPECIFICATIONS?**

829 A. In the telecommunications industry, List 1 and List 2 drains are
830 the designations of the load current drains. These are used to

²⁰ Qwest Services Corporation is a direct subsidiary of the ultimate parent company, Qwest Communications International, Inc.

²¹ Surrebuttal Testimony of Victoria Hunnicutt-Bishara, ICC Docket No. 05-0675, March 29, 2006, p. 4.

831 size various elements of the battery plant. Generally speaking,
832 the List 1 current drain is used to size batteries and rectifiers in
833 the plant. The List 2 current drain is used to size the DC load
834 feeder cables and the circuit protection device (fuse) for the DC
835 power arrangement. The fuse size is also dependent upon the
836 ampacity of the smallest conductor comprising the protected
837 feeder. Protectors should be rated as high as allowable to avoid
838 nuisance tripping due to high load conditions or inrush current
839 during startup.
840

841 Ms. Hunnicutt-Bishara also testified in Illinois as follows:

842 **Q. DOES BELLCORE HAVE ANY DOCUMENTATION RELATING**
843 **TO THE FUSING OF TELECOMMUNICATIONS EQUIPMENT?**

844 A. Yes, in its definition of List 2 drain, Bellcore (previously known as Bell
845 Communications Research, now known as Telcordia) states:

846
847 “These drains are used to size feeder cables and fuses.
848 These drains represent the peak current for a circuit or
849 group of circuits under worst case operating conditions.
850 For example, a constant power load requires maximum
851 current at minimum operating voltage.” (footnote
852 omitted)
853

854 The excerpts from QCC’s Illinois testimony shows that at least one Qwest –sponsored
855 witness understands that, consistent with Qwest’s engineering guidelines, List 1 drain is
856 used to size DC power plant and List 2 drain is used to size DC power distribution.
857 Indeed she cites to the same Bellcore technical document I cited to above (“*DC*
858 *Distribution*,” Technical Document No. 790-100-656) as support for her testimony and
859 attaches this document to her testimony as an exhibit. There is no plausible explanation
860 that Qwest can provide that can square its position in Washington that DC power plant is
861 sized based on CLEC power orders (or List 2 drain) and its affiliate’s testimony in
862 Illinois stating (correctly) that DC power plant is sized based on List 1 drain. Indeed,
863 based on my experience in Iowa, I suspect that Qwest Washington may not even address

864 the concepts of List 1 drain and List 2 drain in its testimony, despite their importance to
865 this proceeding, because when Qwest is forced to concede that DC power plant is sized
866 on List 1 drain and DC power distribution is sized on List 2 drain, Qwest's position in
867 Washington that McLeodUSA should pay for DC power plant based on List 2 drain is
868 exposed as fatally flawed.

869

870 **Q. ARE THERE OTHER PORTIONS OF QWEST COMMUNICATIONS CORP.'S**
871 **TESTIMONY IN ILLINOIS THAT CONFLICT WITH QWEST'S POSITION IN**
872 **WASHINGTON?**

873 A. Yes. In Illinois, Ms. Hunnicutt-Bishara testified that one of the problems with
874 AT&T/SBC-Illinois' position in the Illinois docket was SBC's "false assumption that
875 telecommunications equipment draws power at the maximum load required twenty-four
876 hours a day, seven days a week."²² Ms. Bishara explained that "[t]his assumption of a
877 maximum and linear power load is erroneous..."²³ In other words, Ms. Hunnicutt-
878 Bishara criticized AT&T/SBC Illinois for assuming in its DC power charge development
879 that Qwest's equipment collocated in AT&T/SBC Illinois central offices draws a
880 maximum load at all times. Instead, Ms. Hunnicutt-Bishara argued that Qwest's CLEC
881 equipment draws power relative to factors associated with busy-hour usage.

882 Despite the recognition by its affiliate of the falsehood of a maximum 24x7 load,
883 Qwest Washington is billing McLeodUSA for DC power plant usage as if this
884 continuous, maximum load exists.

885

²² Response Testimony of Victoria Hunnicutt-Bishara, Illinois Commerce Commission Docket No. 05-0675, on behalf Qwest Communications Corp., QCC Exhibit 1.0, Public Version, February 2, 2006, p. 8.

²³ *Id.*

886 **Q. IN IOWA, QWEST CLAIMED THAT IT MUST ENGINEER POWER PLANT**
887 **BASED ON THE AMOUNT OF POWER (DISTRIBUTION) ORDERED**
888 **BECAUSE QWEST HAS NO IDEA OF HOW FAST THE POWER**
889 **REQUIREMENTS OF MCLEOD OR ANY OTHER CLEC ARE GOING TO**
890 **GROW.²⁴ IS THIS TRUE?**

891 A. No, this is factually inaccurate. Qwest does have an idea of how fast the power
892 requirements of McLeodUSA and other CLECs will grow because CLECs must provide
893 this information to Qwest when ordering and augmenting collocations. For instance, the
894 collocation application form for a collocation new/change/augment contains Section
895 II.F.5, which requires the collocator to provide: (1) a description of the equipment it will
896 collocate, (2) the model numbers of collocated equipment, (3) functionality of collocated
897 equipment, (4) dimensions of collocated equipment and (5) quantity of collocated
898 equipment. Furthermore, Section III.B. of the collocation application form requires the
899 collocator to indicate the quantity of DS0s, DS1s and DS3s the collocator intends to
900 support. Therefore, collocated CLECs keep Qwest well-informed about how fast the
901 power requirements of collocated CLECs are going to grow.

902
903 **Q. QWEST ALSO CLAIMED IN IOWA THAT IT MUST ENGINEER DC POWER**
904 **PLANT AT THE “AS ORDERED” CAPACITY LEVEL BECAUSE EQUIPMENT**
905 **MODIFICATIONS TO THE POWER PLANT ARE TIME CONSUMING AND IT**

²⁴ See, e.g., Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, p. 9, lines 17 – 20.

906 **WOULD TAKE TOO LONG FOR QWEST TO RESPOND TO ACTUAL**
907 **DEMAND FLUCTUATIONS.²⁵ IS THIS CORRECT?**

908 A. No. Not only is Qwest made fully aware of the equipment type and amount that is
909 collocated in its central office as well as the expected number of circuits served by that
910 equipment, Qwest is given ample time to augment its DC power plant should conditions
911 require it. For instance, Section 8.4.3.4.1 of Qwest Washington's SGAT shows that
912 when certain conditions are met, Qwest has 90 days from receipt of a complete
913 collocation application to provision the request. Accordingly, Qwest cannot be taken by
914 surprise by an increase in usage at a collocation arrangement because it is aware of the
915 equipment the DC power plant is serving, and Qwest is made aware well in advance of
916 any changes to that equipment configuration.

917 Moreover, demand fluctuations are already accounted for in the proper sizing of
918 DC power plant when it is sized according to List 1 drain. In other words, by sizing DC
919 power plant based on List 1 drain, Qwest is sizing at peak capacity at the busy-hour,
920 which means that all short-term (e.g., daily, weekly, etc.) demand fluctuations are
921 accounted for and can be handled by the DC power plant.

922
923 **Q. DOES DATA EXIST THAT REFUTES QWEST'S CLAIM THAT**
924 **MCLEODUSA'S POWER USAGE COULD INCREASE TO A LEVEL THAT**
925 **WOULD PUT QWEST'S ABILITY TO PROVIDE ORDERED DC POWER IN**
926 **JEOPARDY ASSUMING THAT IT SIZED DC POWER PLANT BASED ON LIST**
927 **1 DRAIN?**

²⁵ See, e.g., Direct Testimony of Robert J. Hubbard, Iowa Utilities Board Docket No. FCU-06-20, March 23, 2006, page 8, lines 14 – 17.

928 A. Yes. In a vast majority of instances, McLeodUSA's power usage will constitute a very
929 small fraction of the total power draw requirements of the central office. This is
930 supported by the data Qwest provided in response to McLeodUSA's discovery. For
931 instance, in response to McLeodUSA's data request No. 8(a) ["For each Qwest central
932 office in Washington wherein McLeodUSA has a collocation space, please provide the
933 following information: (a) the total installed -48V DC Power capacity considering all
934 individual power plants within the office (in Amps)."], Qwest provided Confidential
935 Attachment A, which shows this data by CLLI code. And in response to McLeodUSA
936 data request No. 8(b) ["For each Qwest central office in Washington wherein
937 McLeodSUSA has a collocation space, please provide the following information: (b)
938 Actual measured load, busy day, busy hour (for most recent measurement and date of
939 measurement)"], Qwest provided Confidential Attachment B, which provides these
940 measurements by date and by CLLI. Comparing the McLeodUSA busy hour power draw
941 for a central office from Confidential Attachment B to the total installed DC power
942 capacity will show how much of the power capacity for an office McLeodUSA is actually
943 using at peak normal operating conditions. Take for example, the following four (4)
944 central offices: FDWYWA01, LGVWWA02, SPKNWAKY and TACMWAJU.
945 Confidential Attachment A indicates that the total installed DC power capacity (in Amps)
946 for these offices is [REDACTED]
947 [REDACTED]. Confidential B indicates that during July and August of 2005, Qwest
948 measured McLeodUSA's busy hour draw at these central offices to be [REDACTED]
949 [REDACTED] Hence, McLeodUSA's busy hour draw for
950 these four central offices constitutes only [REDACTED]
951 [REDACTED] of the total installed DC power capacity of the offices. As further evidence

952 that these findings are typical, Confidential Attachments A and B also indicate that for
953 the following four (4) additional CLLI Codes (SMNRWA01, SPKNWAFWA,
954 TACMWAWV and VANCWA01), McLeodUSA's busy hour power draw, as a
955 percentage of the total DC power capacity of the end office is [REDACTED]
956 [REDACTED] The data demonstrates that McLeodUSA's busy hour power
957 usage actually constitutes a very small percentage of the total installed power capacity of
958 a particular central office. Given that power engineers size DC power plant based on the
959 aggregate List 1 drain of all telecommunications equipment being powered, and given
960 that McLeodUSA's peak power usage constitutes a minute fraction of Qwest's power
961 capacity, it is clear that McLeodUSA's DC power would be an insignificant
962 consideration in the Qwest DC power plant planning/sizing process.

963
964 **Q. YOU HAVE SHOWN ABOVE THAT MCLEODUSA'S BUSY HOUR POWER**
965 **DRAW IN WASHINGTON CENTRAL OFFICES IS A VERY SMALL**
966 **FRACTION OF QWEST'S DC POWER PLANT CAPACITY IN AN OFFICE.**
967 **ASSUMING FOR THE SAKE OF ARGUMENT THAT MCLEODUSA'S POWER**
968 **USAGE INCREASED TO THE RATED AMPERAGE OF MCLEODUSA'S DC**
969 **POWER DISTRIBUTION CABLES (OR THE "AS ORDERED" AMPERAGE),**
970 **WOULD MCLEODUSA'S USAGE STILL CONSTITUTE A VERY SMALL**
971 **FRACTION OF QWEST'S DC POWER PLANT CAPACITY?**

972 **A.** Yes. However, as I have explained throughout my testimony, orders for power
973 distribution cables are based on List 2 drain or maximum power draw under worst case
974 scenario, and as such, it is highly unlikely that McLeodUSA would ever use this amount
975 of power. That being said, assuming we take Qwest's assertion that it sizes DC power

976 plant based on CLEC power orders at face value (which we should not), the power
977 requirements associated with McLeodUSA would still be a small percentage of Qwest's
978 total DC power plant capacity. For instance, assuming McLeodUSA placed an order for
979 175 Amp DC power distribution cables for the collocations above (which is a common
980 size of DC power cable for McLeodUSA collocations), McLeodUSA's power usage (175
981 Amps) would only constitute about 6 - 8% of Qwest's total DC power plant capacity for
982 that central office.

983
984 **Q. QWEST CLAIMED IN IOWA THAT IF MCLEODUSA ORDERS 175 AMPS OF**
985 **CAPACITY (OR 175 AMP DISTRIBUTION CABLE), QWEST WOULD**
986 **DEFINITELY AUGMENT ITS DC POWER PLANT CAPACITY REGARDLESS**
987 **OF MCLEODUSA'S ACTUAL USAGE. WOULD QWEST ALREADY HAVE**
988 **THE CAPACITY ON ITS DC POWER PLANT TO PROVIDE MCLEODUSA**
989 **THE POWER USAGE OVER MCLEODUSA'S HYPOTHETICAL 175 AMP**
990 **POWER CABLE WITHOUT AUGMENTING ITS DC POWER PLANT IN A**
991 **VAST MAJORITY OF INSTANCES?**

992 **A.** Yes. As demonstrated above, McLeodUSA's actual power draw constitutes a very small
993 portion of the total DC power capacity of the central office, so even if the McLeodUSA
994 DC power usage doubled or tripled (which is very unlikely in the short run), it would still
995 constitute a very small portion of total capacity and Qwest's existing capacity could
996 handle it without any augmentation of the power plant.

997 Further, as even Qwest concedes, the power requirements of the entire central
998 office are taken into account when sizing the DC power plant infrastructure to serve that
999 central office. Since this DC power plant infrastructure is sized in the aggregate (with

1000 spare capacity), individual orders by CLECs for DC power distribution cables should not
1001 trigger an investment in DC power plant unless the power plant at that particular location
1002 is already nearing an augmentation threshold because of the aggregate demand for power
1003 from all users in the central office. Because the relative size of that individual order
1004 compared to the aggregate investment in DC power plant would be relatively small, it
1005 should have little effect on the ability of the DC power plant infrastructure to serve the
1006 power needs of that office. Rather, the power requirements associated with the usage
1007 over those cables would be aggregated with the power requirements associated with the
1008 usage over all other cables in the central office (as observed relative to the average busy
1009 hour) to determine the appropriate level of investment in DC power plant. So, when
1010 added to the mix, McLeodUSA's hypothetical 175 amp order would require no additional
1011 DC power plant augment/investment. This is especially true given that Qwest will
1012 monitor the aggregate power requirements of the central office over time and augment
1013 DC power plant on a central office-wide basis.

1014

1015 **Q. QWEST'S POSITION RESTS ON THE ASSUMPTION THAT QWEST ADDS DC**
1016 **POWER PLANT EQUIPMENT WHEN MCLEODUSA ORDERS POWER TO A**
1017 **COLLOCATION ARRANGEMENT. DOES QWEST ALSO ASSUME THAT**
1018 **QWEST REMOVES DC POWER PLANT EQUIPMENT WHEN MCLEODUSA**
1019 **(OR ANY OTHER CLEC) DECOMMISSIONS A COLLOCATION**
1020 **ARRANGEMENT?**

1021 A. No, indeed Qwest specifically states that it does not remove or reduce DC power plant
1022 equipment when CLECs decommission collocation arrangements. In response to
1023 McLeodUSA data request #5, Qwest responded as follows:

1024 *Qwest does not remove or reduce its Power Plant capacity based on*
1025 *decommissioned collocations.* Qwest will reassign fuse positions for
1026 Battery Distribution Fuse Bays (“BDFB”) and Power Boards (“PBD”),
1027 based on demand. (emphasis added)
1028

1029 Therefore, what Qwest is saying is that CLEC orders for power distribution cables drive
1030 the addition of (and Qwest investment in) DC power plant equipment, but that CLEC
1031 requests to decommission collocation (thereby removing collocated equipment and
1032 rendering the DC power distribution arrangement to that collocation cage useless) would
1033 not trigger the removal of DC power plant equipment. Following Qwest’s logic, what
1034 would result is an ever-increasing DC power plant capacity that has no relationship to the
1035 power requirements of the central office – regardless of whether those “power
1036 requirements” are based on List 1 drain as I contend or List 2 drain as Qwest contends.

1037 Furthermore, Qwest’s assertion in this regard conflicts again with its engineering
1038 guidelines -specifically Bellcore’s “Power Systems Installation Planning” manual (at
1039 page 6-2), which states that [REDACTED]

1040 [REDACTED]
1041 [REDACTED]
1042 [REDACTED] Thus,

1043 the busy-hour drain is calculated by Qwest and, in turn, the DC power plant is sized by
1044 Qwest, based on equipment in service. Again, this information contradicts Qwest’s
1045 position which paints a picture of DC power plant being based on CLEC power orders,
1046 with Qwest being left “holding the bag” with regard to DC power plant investment when
1047 CLECs do not use the power capacity they ordered or if the DC power plant usage charge
1048 is applied on an “as consumed” basis. What Qwest power engineers actually do is

1049 [REDACTED]

1050 [REDACTED]. Hence, if CLEC A
1051 decommissions its collocation cage, the feeder serving those collocations would not have
1052 in-service equipment associated with it, and would therefore not be captured in the List 1
1053 drain or included when sizing DC power plant.

1054

1055 **Q. YOU EXPLAIN ABOVE THAT QWEST'S POSITION IS UNDERMINED BY ITS**
1056 **ENGINEERING MANUALS AS WELL AS QWEST EXPERT TESTIMONY IN**
1057 **ILLINOIS. IS QWEST'S POSITION IN THIS CASE ALSO UNDERMINED BY**
1058 **ITS DISCOVERY RESPONSES?**

1059 A. Yes. As mentioned above, Qwest's response to McLeodUSA data request number 5
1060 indicates that Qwest does not remove DC power plant equipment when a CLEC
1061 decommissions a collocation arrangement. Therefore, following Qwest's logic that DC
1062 power plant investment is based on CLEC power orders and that Qwest would definitely
1063 augment its DC power plant capacity to accommodate a CLEC order for 175 amp DC
1064 power distribution cable, if that CLEC subsequently decommissioned its collocation
1065 arrangement, there should be 175 amps of excess capacity in the DC power plant for that
1066 central office. If McLeodUSA or another CLEC subsequently requests a collocation
1067 arrangement in that office – everything else equal – there should be 175 amps of capacity
1068 in the DC power plant to serve McLeodUSA without any DC power plant
1069 augment/addition/investment. According to Qwest, instead of using the 175 amps of
1070 excess capacity freed up by the original CLEC, Qwest would build in another 175 amps
1071 of DC power plant capacity to meet McLeodUSA's request. This would be wasteful and
1072 inefficient – not to mention inconsistent with Qwest's engineering guidelines. And this
1073 example is conservative because it only assumes one decommissioned collocation

1074 arrangement. If we modify the scenario to assume that five (5) CLECs decommissioned
1075 collocation arrangements, each with 175 amps of DC power distribution capacity, Qwest
1076 would apparently ignore the 875 amps of “freed up” DC power plant capacity due to
1077 collocation decommissioning and, instead, build in another 175 amps of DC power plant
1078 capacity to meet McLeodUSA’s request.

1079
1080 **Q. WHAT TYPE OF EQUIPMENT DOES MCLEODUSA TYPICALLY USE IN ITS**
1081 **COLLOCATION SITES IN WASHINGTON AND HOW DOES THIS RELATE**
1082 **TO THE DISCUSSION ABOVE?**

1083 A. McLeodUSA typically uses a collocation design that contains the equipment listed in
1084 Figure 6 below.

Fig. 6 Typical McLeodUSA Collocated Equipment and Associated Power Requirements			
Collocated Equipment	Fuse Size	Manufac. Maximum Power Draw (DC amps)	McLeodUSA Est. DC Power Draw
[REDACTED]			

1085
1086
1087 Figure 6 provides the following information regarding McLeodUSA’s typical collocation
1088 design. The collocated equipment and model is provided in column 1, the Fuse Size
1089 amperage is provided in column 2, the manufacturer’s maximum DC power draw (in
1090 amps) is provided in column 3, and the estimated DC power draw (in amps) is provided
1091 in column 4. The fuse size refers to the amperage for which the fuse panel is fused, the

1092 manufacturer's maximum power draw is the same as the List 2 drain, and the estimated
1093 DC power draw amperage is based on actual power readings made by McLeodUSA.

1094

1095 **Q. WHAT DOES FIGURE 6 SHOW?**

1096 A. Figure 6 demonstrates the point I have made in my testimony above, i.e., "as ordered"
1097 amperage bears no relationship to "as consumed" amperage. The "fused amps" power
1098 capacity is ■ Amps. As I have explained, carriers must design DC power distribution
1099 equipment such that it protects the power cables above and beyond what would be
1100 required under a "worst case scenario" draw or List 2 Drain. The List 2 drain is ■
1101 Amps., which means that, in this typical arrangement, McLeodUSA's fused amperage is
1102 over ■ greater than List 2 drain.²⁶ Moreover, Figure 6 shows that McLeodUSA was
1103 required to design its power distribution at an amperage level that is ■ greater than
1104 the actual McLeodUSA power draw, and the List 2 drain is ■ greater than
1105 McLeodUSA's actual power draw at the busy hour. While this difference between "as
1106 ordered" and "as consumed" DC power reflects a typical McLeodUSA collocation
1107 arrangement, this difference can vary by collocation site with the potential for differences
1108 between "as ordered" and "as consumed" amperages far larger than those identified
1109 above.

1110

1111 **Q WHY DOES MCLEODUSA HAVE A FUSE PANEL AND FUSES IN THEIR**
1112 **COLLOCATION ARRANGEMENT?**

1113 A. McLeodUSA typically uses a mini-BDFB in their collocation arrangement for power
1114 management purposes, which accepts the DC power from Qwest and (i) distributes power

²⁶ The List 2 Drain serves as one of the factors in sizing of power distribution cables as indicated in the power cable sizing formula, see *supra*.

1115 to each individual relay, (ii) fuses the power at each relay to provide fuse panel protection
1116 and (iii) distributes DC power to the telecommunications equipment listed in Figure 5
1117 above. This provides flexibility to McLeodUSA to better manage the power within its
1118 collocation cage and fuse the power at a level consistent with the need of the individual
1119 equipment.

1120

1121 **Q. EXPLAIN THE MCLEODUSA ESTIMATED DC POWER DRAW IN COLUMN 4**
1122 **OF FIGURE 6.**

1123 A. Column 4 of Figure 6 (McLeodUSA Estimated DC Power Draw) is the actual DC current
1124 in amperes as measured by a McLeodUSA technician using a clamp on ampere meter.
1125 This measurement was made by McLeodUSA during the busy hour period of
1126 approximately 10AM and Noon. As explained above, the measured actual DC power
1127 draw in amperes or “as consumed” power in column 4 is considerably less than “as
1128 ordered” amperage.

1129

1130 **Q. HOW CAN YOU BE SURE THAT THE DC POWER DATA TREND**
1131 **REFLECTED IN FIGURE 6 – THAT FUSED AMPS AND LIST 2 DRAIN BOTH**
1132 **SIGNIFICANTLY EXCEED ACTUAL POWER DRAW – IS REPRESENTATIVE**
1133 **OF THE TYPICAL MCLEODUSA COLLOCATION SITE?**

1134 A. I performed my own analysis of the actual DC power draw requirements of a
1135 McLeodUSA collocation site and arrived at very similar findings. On February 28, 2006,
1136 I visited three (3) McLeodUSA collocation sites in Denver, Colorado: (i) Denver Curtis
1137 Park, (ii) Denver Capitol Hill and (iii) Denver South. During these visits, I had an
1138 opportunity to take my own measurements of the actual DC power draw of

1139 McLeodUSA’s collocated equipment and the distribution of that DC current within the
 1140 collocation cages to the collocated equipment being powered. I then compared these
 1141 measurements to the amperage of the DC power distribution cables. The results of this
 1142 comparison show that DC power distribution capacity for each of these collocation sites
 1143 significantly exceed McLeodUSA’s actual DC power draw at the busy hour.

1144

1145 **Q. PLEASE ELABORATE ON THESE POWER MEASUREMENTS?**

1146 A. I personally measured the actual current in amperage being delivered from Qwest to these
 1147 McLeodUSA collocation sites via a Fluke clamp-on meter for both the A and B power
 1148 distribution leads during the busy-hour period of between 10AM and Noon (exact time of
 1149 measurements provided below). I then checked the power distribution cable tags at the
 1150 McLeodUSA mini-BDFBs for the power ratings of each cable. The tags are an
 1151 installation requirement and state the design capability of the power distribution cables in
 1152 amperes. The power data collected from the actual power measurements as well as the
 1153 power distribution cable tags is provided below in Figure 7.

Figure 7. McLeodUSA “as ordered” versus “as consumed” amperage

Qwest Central Office	“As ordered” Amperage	“As consumed” Amperage	Date & Time of Measurement	% Fused Vs Measured E = C/B
A	B	C	D	E
Denver Curtis Park	██████████	██████████	2/28/2006 10:31AM	██████████
Denver Capitol Hill	██████████	██████████	2/28/2006 10:52AM	██████████
Denver South	██████████	██████████	2/28/2006 11:48AM	██████████

1154

1155

1156

Q. PLEASE EXPLAIN THE DATA PRESENTED IN FIGURE 7.

1157

A. Column A of Figure 7 provides the name of the Qwest central office in which the McLeodUSA collocation sites I visited reside. Column B is the amperage of the DC power distribution cables (“as ordered” amperage), as taken from the power distribution cable tags, which represents the current distribution capacity to the McLeodUSA collocation cage (i.e., the “as ordered” capacity). Column C is the actual measured amperage or “as consumed” power of the McLeodUSA collocation arrangement, as measured by me at the date and time specified in Column D. Finally, Column E represents the percent of total “as ordered” amps that McLeodUSA’s collocation was actually using at the time of the power measurement.

1158

1159

1160

1161

1162

1163

1164

1165

1166

Column E of Figure 7 shows that, for each McLeodUSA collocation site, the actual “as consumed” usage is about [REDACTED] of the “as ordered” amperage. In other words, the “as ordered” capacity of the power distribution cables exceeds the “as consumed” capacity by about [REDACTED]. This difference between “as consumed” and “as ordered” is even greater than the [REDACTED] difference attributed to a typical McLeod collocation site above in Figure 6.

1167

1168

1169

1170

1171

1172

1173

Q. DO THESE RESULTS INDICATE THAT MCLEODUSA HAS SIMPLY “OVER-ORDERED” DC POWER DISTRIBUTION CAPACITY FROM QWEST?

1174

1175

A. No. Recall that McLeodUSA is required by engineering specifications and manufacturers’ requirements to order power distribution capacity at amperage levels that significantly exceed the actual power draw of its collocated equipment at peak periods. In any event, DC power distribution facilities are sized differently and McLeodUSA

1176

1177

1178

1179 compensates Qwest for costs related to DC power distribution facilities through separate
1180 charges.

1181

1182 **Q. ARE THE RESULTS FROM YOUR AUDIT OF THE COLORADO**
1183 **COLLOCATIONS REPRESENTATIVE OF WASHINGTON?**

1184 A. Yes, I have reviewed a list of collocation equipment within Washington collocations and
1185 it is comparable to the equipment in the Colorado locations. Given the nature of these
1186 devices, the power draw from equipment in a Colorado collocation would be
1187 representative of McLeodUSA's Washington collocations.

1188

1189 **B. *Proper DC power sizing and engineering supports McLeodUSA's***
1190 ***recommended application of the DC power plant usage charge***

1191

1192 **Q. YOU EXPLAINED ABOVE THAT DC POWER DISTRIBUTION IS SIZED**
1193 **BASED ON LIST 2 DRAIN AND THAT DC POWER PLANT IS SIZED BASED**
1194 **ON FORECASTED ACTUAL PEAK USAGE. HOW DOES THIS RELATE TO**
1195 **MCLEODUSA'S COMPLAINT?**

1196 A. This shows that there is no relationship between the CLEC's order for power distribution
1197 and the power plant capacity the CLEC actually uses or the power the CLEC should be
1198 required to pay for. Therefore, Qwest's application of the rate for DC power plant needs
1199 to recognize the distinction between the ordering of the DC Power distribution network,
1200 which sizes the power distribution cables extended into the CLEC collocation
1201 arrangement on List 2 drain, *separately* from the demand for DC Power itself (i.e., List 1
1202 drain). Any connection between the engineered size of the DC Power distribution
1203 network and the rate for DC power plant usage is inappropriate and inconsistent with the

1204 way in which DC power is sized and consumed. The crux of McLeodUSA's complaint
1205 stems from the fact that Qwest is assessing a DC power plant usage charge, based on the
1206 "as ordered" amps, when the 2004 DC Power Measurement Amendment and proper
1207 engineering practice calls for Qwest to assess this charge based on the actual power
1208 consumed (or "as consumed" amps).

1209

1210 **Q. DOES THE FACT THAT CLECS ORDER DC POWER DISTRIBUTION**
1211 **CAPACITY BASED ON A HIGHER LIST 2 DRAIN IMPACT QWEST'S DC**
1212 **POWER PLANT PLANNING/AUGMENTS/INVESTMENTS?**

1213 A. No. Again, DC power plants are sized based on forecasted actual peak usage, i.e.,
1214 average busy hour for the entire central office and is not dependent on the amount of
1215 amps ordered by a particular CLEC for distribution facilities for a collocation. Therefore,
1216 the central office engineers observe the peak power requirements of the central office
1217 power plant as a whole and augment the DC power plant if the peak usage approaches a
1218 level that would exceed the current power capacity. DC power plant augments are not
1219 driven by individual orders for power distribution cables and/or fuses by CLECs (or
1220 Qwest).²⁷ Simply put, Qwest does not plan or augment its power requirements or power
1221 plant based on individual power orders of CLECs and hence, its power plant investments
1222 are not incremental to those orders (as described in more detail by Mr. Starkey).

1223

²⁷ Note: a possible exception to this general rule is if Qwest would install an entire switch or major switch addition, or similar, very large-scale equipment addition. My testimony above pertains to the normal, or average, growth in power plant capacity that typically occurs within a central office, the type of growth experienced by McLeodUSA collocated equipment.

1224 **Q. WILL QWEST BE FULLY COMPENSATED FOR DC POWER PLANT COSTS**
1225 **IF IT ASSESSES THE DC POWER PLANT USAGE CHARGE ON AN “AS**
1226 **CONSUMED” BASIS INSTEAD OF AN “AS ORDERED” BASIS?**

1227 A. Michael Starkey addresses cost recovery in his testimony. However, it has been my
1228 experience in the past that one of the arguments ILECs use to argue against billing DC
1229 power usage on an “as consumed” basis is that such a rate structure will result in stranded
1230 DC power plant investment. The basic (and erroneous) premise of the ILEC argument is:
1231 CLECs order power distribution cables based on the relatively higher “as ordered”
1232 amperage, ILECs must build out their DC power plant to meet these power requirements,
1233 and therefore, assessing DC power plant charges based on the relatively lower “as
1234 consumed” amperage would result in stranded costs for DC power plant. There is no
1235 engineering validity to such an argument.

1236
1237 **Q. WHY DO YOU SAY THAT THERE IS NO ENGINEERING VALIDITY TO**
1238 **QWEST’S ARGUMENT?**

1239 A. As explained above, ILECs do *not* augment the shared DC power plant of their central
1240 offices based on the ordered capacity of the power distribution cables, and as such, Qwest
1241 would not have augmented (or invested in) its DC power plant based on McLeodUSA’s
1242 (or any other CLEC’s) collocation power orders. Accordingly, there is no stranded
1243 investment related to billing DC power plant based on an “as consumed” basis because
1244 this so-called stranded investment was never made in the first place, assuming Qwest is
1245 monitoring and sizing its DC power plant consistent with proper engineering practices.

1246

1247 C. *Qwest's Power Reduction offering is not a suitable option to billing DC power*
1248 *usage charges on an "as consumed" basis*
1249

1250 Q. QWEST OFFERS A "POWER REDUCTION" AMENDMENT THAT CLECS
1251 CAN INCORPORATE INTO THEIR INTERCONNECTION AGREEMENTS.
1252 QWEST HAS ARGUED THAT THIS AMENDMENT SHOULD ALLOW
1253 MCLEODUSA TO MORE CLOSELY ALIGN ITS "AS ORDERED" USAGE
1254 WITH ITS "AS CONSUMED" USAGE SO AS TO AVOID THE TYPES OF
1255 ISSUES YOU DESCRIBE ABOVE. PLEASE BRIEFLY DESCRIBE POWER
1256 REDUCTION.

1257 A. Qwest's "Power Reduction" offering allows CLECs to eliminate or reduce multiple feeds
1258 from 60 to zero amps or reduce main feeds from 60 to 20 amps.²⁸ According to Exhibit
1259 A to the Power Reduction Amendment, the work performed by Qwest under the Power
1260 Reduction offering includes: changing fuses at the BDFB, changing breakers at the power
1261 plant, re-engineering smaller power cables and various other detailed engineering work
1262 aimed at re-engineering a CLEC's power *distribution* infrastructure. Qwest has proposed
1263 non-recurring charges for Power Reduction of \$787 and \$1,028 if power cabling changes
1264 are not necessary and ICB-based rates for power cabling changes. Apparently, Qwest has
1265 offered the Power Reduction offering in order for CLECs to reduce the fused amp
1266 capacity of their DC power *distribution* infrastructure (i.e., fuses and power cables).

1268 Q. YOU EXPLAIN ABOVE THAT QWEST'S POWER REDUCTION OFFERING
1269 PERTAINS TO RESIZING DC POWER *DISTRIBUTION* INFRASTRUCTURE.
1270 DOESN'T THE PRIMARY DISPUTE IN THIS PROCEEDING PERTAIN TO

²⁸ Qwest DC Power Reduction Amendment, Attachment 1, Section 4.0.

1271 **QWEST’S RATES RELATED TO ITS DC POWER *PLANT* – NOT**

1272 **DISTRIBUTION – CHARGES?**

1273 A. Yes, and this underscores the inapplicability of the Power Reduction Amendment and its
1274 inability to solve the problem McLeodUSA believed it was solving in signing the Power
1275 Measurement Amendment. That is, Qwest is apparently attempting to resolve an issue
1276 pertaining to its billing of DC power *plant* charges by creating a process (and a costly one
1277 at that) for the CLEC to resize its DC power *distribution* infrastructure.

1278 Qwest’s position is that the Power Reduction offering will allow CLECs to more
1279 closely align their “as ordered” capacity in their DC power distribution arrangements and
1280 their “as consumed” DC power usage, such that the CLEC could theoretically lower its
1281 DC power plant charges. While Mr. Starkey will address the appropriate charges for DC
1282 power plant, from an engineering standpoint, the possibility of reducing power charges
1283 through the Power Reduction process is riddled with flaws and is not a suitable substitute
1284 for assessing DC power plant charges on an “as consumed” basis.

1285

1286 **Q. WHAT ARE THE PROBLEMS WITH QWEST’S POWER REDUCTION**
1287 **OFFERING?**

1288 A. First and foremost, a CLEC does not want to align its “as ordered” capacity for DC
1289 power distribution with the “as consumed” amperage of the DC power plant, which is the
1290 stated objective of Qwest’s Power Reduction offering. As discussed above, there is no
1291 relationship between DC power distribution capacity and DC power plant investment,
1292 and Qwest should not attempt to create such a relationship through the Power Reduction
1293 offering because doing so could result in refusing DC power distribution arrangements
1294 below the level recommended by manufacturers and safety standards. As a result, the

1295 most evident problem is that it does nothing to address the problem with the manner in
1296 which Qwest assesses its DC power plant charge. Under Qwest's proposal, it would
1297 continue to bill the DC power plant charge on an "as ordered" capacity instead of "as
1298 consumed" – though the "as ordered" level could theoretically be lowered after the
1299 resizing of DC power distribution occurs. For example, if a CLEC resizes its power
1300 distribution arrangement from 60 Amps to 20 Amps, but only uses 8 Amps of DC power,
1301 the CLEC is still overpaying for DC power by 12 Amps (instead of the higher
1302 overpayment of 52 Amps). Such a situation is still inconsistent with the manner in which
1303 DC power plant is sized and would still result in overcharges to McLeodUSA.
1304 Furthermore, Qwest's Power Reduction is unnecessary, potentially dangerous, service-
1305 affecting and costly.

1306

1307 **Q. PLEASE ELABORATE ON WHY QWEST'S POWER REDUCTION OFFERING**
1308 **IS UNNECESSARY, POTENTIALLY DANGEROUS, SERVICE-AFFECTING**
1309 **AND COSTLY?**

1310 A. Qwest's power reduction offering is unnecessary because the CLECs to which this
1311 offering is geared have already engineered and installed power distribution infrastructure
1312 and fused that equipment based on the proper engineering criteria described above.
1313 Hence, to subsequently resize the power cables and fuses serves no real useful purpose.
1314 For instance, if a CLEC's power cables and fuses are sized for 60 Amps, it makes no
1315 sense to reduce the fuse size to 20 Amps, such that the CLEC's power feeds are 60 Amps
1316 while the fuses that protect them are 20 Amps. And since power distribution
1317 infrastructure is sized for ultimate demand, if a CLEC reduces the rated amperage of its
1318 power cables through Qwest's Power Reduction offering (and incurs the costs to resize),

1319 the CLEC may find itself in a situation where it must add capacity in the future. This
1320 constant resizing of DC power distribution infrastructure based on existing demand is
1321 unnecessary and does not comport with good engineering practice.

1322 Such resizing of DC power distribution infrastructure can also be dangerous and
1323 service-affecting. Any time power is augmented in the central office for a collocation
1324 arrangement, there is a risk of losing power altogether to that collocation arrangement,
1325 which, in turn, risks service outages for CLEC customers. For instance, I have explained
1326 that CLECs engineer redundancy into their collocation power leads, wherein a
1327 collocation arrangement is served by both an “A” lead and a backup “B” lead. If the
1328 power for that collocation is switched over to the “B” lead while augmenting the “A”
1329 lead or associated fuses, power could be lost in the transition. Further, augmenting power
1330 cables within the cable racks in the central office, as would be performed under Qwest’s
1331 power reduction offering, poses operational risks related to technicians.

1332 Qwest’s Power Reduction offering is also costly. According to Qwest, this
1333 offering poses both administrative (e.g., Quote Preparation Fee) and engineering costs,
1334 and can exceed \$1,000 to change a fuse and potentially thousands of dollars to change out
1335 a power cable.²⁹ This is in addition to the costs that CLECs would incur to make these
1336 changes. Additionally, the CLEC would place their collocation sites at risk for large,
1337 additional power charges each time equipment additions are made to the collocation site.
1338 In sum, instead of assisting CLECs in managing their power costs, Qwest’s Power
1339 Reduction offering would likely result in very large power charges to the CLEC for
1340 changing power requirements to meet ongoing equipment changes and augments within a

²⁹ Qwest proposes individual case basis (ICB)-based pricing for this option, so the pricing is not actually known. However, it is reasonable to assume that it will significantly exceed the charges for changing fuses.

1341 particular CLEC collocation site, while at the same time providing no assistance relative
1342 to the underlying problem, i.e., Qwest will continue to bill power plant-related charges
1343 inappropriately on an “as ordered” as opposed to an “as consumed” basis.
1344

1345 **Q. DO YOU HAVE OTHER CONCERNS WITH THE POWER REDUCTION**
1346 **AMENDMENT?**

1347 A. Yes. Qwest’s Power Reduction would force the CLEC to bear all risk associated with
1348 this unnecessary and costly work. Section 2.6 of Qwest’s DC Power Reduction
1349 Amendment states: “CLEC assumes all responsibility for outages and/or impacts to
1350 CLEC-provided service and equipment due to the reduction in DC Power.” As explained
1351 above, there is potential risk of service-affecting problems due to changing out
1352 fuses/breakers and replacing power cables – all of which is unnecessary given that the
1353 power infrastructure is already in place and working properly – and Qwest’s Amendment
1354 provides no recourse for a CLEC should a Qwest mistake result in the CLEC’s customers
1355 being without service. Further, given the power problem would be localized to BDFBs or
1356 power cables dedicated specifically to the CLEC (as opposed to the DC power plant
1357 shared by the entire central office), the service-affecting problems would only be
1358 experienced by the customers of that particular CLEC – not by Qwest’s customers or the
1359 customers of other carriers.

1360
1361 **Q. DID QWEST’S AFFILIATE EXPRESS SIMILAR CONCERNS RELATED TO A**
1362 **“RE-FUSING” PROPOSAL OF AT&T/SBC ILLINOIS?**

1363 A. Yes. In the same Illinois case mentioned above, AT&T/SBC Illinois apparently modified
1364 a fusing proposal such that instead of fusing at 125% of the ordered amount, it would

1365 fuse at 100% of the ordered amount provided that the fuse size is not more than 200%
1366 greater than the CLEC's actual usage. Qwest witness Hunnicutt-Bishara's testimony
1367 explained Qwest's concerns related to AT&T/SBC's fusing proposal as follows:

1368 **Q. WHAT ARE YOUR CONCERNS WITH SBC'S MOST RECENT**
1369 **FUSING PROPOSAL?**

1370 A. I have three major concerns, among others, with SBC's most recent
1371 fusing proposal. These concerns are legal, financial and operational.
1372 First, if the DC power arrangements are fused based upon the usage at
1373 any point in time, and not the List 2 drain of the load, it is probable that
1374 the fusing would not be in compliance with NFPA 70-2005, Article
1375 215.3. As a result, the fusing would violate Administrative Code Part
1376 785.20(b)(1), which obligates companies to abide by NFPA 70. In other
1377 words, collocators will be forced to either ignore SBC's fusing
1378 limitations or ignore the Commission's electrical and fire safety
1379 requirements.

1380
1381 Second, on a financial level, changes in a collocator's power draw (for
1382 instance, because it adds cards to an existing, but under-utilized,
1383 multiplexer) will require the collocator to pay SBC to re-fuse the
1384 collocator's collocation power arrangement. For each power delivery
1385 arrangement (a single collocation arrangement may include multiple
1386 power delivery arrangements), SBC would charge the collocator an
1387 Order Charge of \$300.50 (physical caged and shared) or \$115.26
1388 (cageless and virtual) and a Power Delivery charge of \$1,802.03.
1389 Regular or periodic re-fusing – which is unnecessary from a safety
1390 perspective and, in fact, inconsistent with national fire protection
1391 standards and the Commission's rules – will obviously prove quite
1392 expensive for collocators.

1393
1394 Third, on an operational level, the low fusing amperage will make
1395 unnecessary and harmful overloads more likely and more common. An
1396 overload is an overcurrent that is confined to normal current paths and
1397 could occur when a single high amperage device is on a circuit that is
1398 marginally sized for the demand. The purpose of overcurrent protection
1399 devices is to prevent conductor insulation failure caused by overloads or
1400 short circuits. An overload condition would be the result of a marginally
1401 fused power feed during a power outage.

1402
1403 **Q. WHAT ARE THE IMPACTS OF A BLOWN FUSE TO QWEST**
1404 **COMMUNICATIONS CORPORATION ("QCC")?**

1405 A. The impacts of power outages due to a blown fuse are numerous,
1406 including but not limited to equipment damage, economic loss due to lost
1407 production, and irreparable damage to the reputation of QCC with
1408 respect to service reliability.

1409
1410 **Q. COULD A BLOWN FUSE REALLY DO DAMAGE TO DIGITAL**
1411 **TELECOMMUNICATIONS EQUIPMENT?**

1412 A. Absolutely. Years ago, equipment was not as susceptible to power
1413 outages as is the sensitive digital equipment of today. Any equipment
1414 containing microprocessors, such as computers and telecommunications
1415 equipment, is especially vulnerable to power down via a blown fuse.
1416 The May 24, 1999 article in Telephony Magazine Online “CIRCUIT
1417 PROTECTION RUNS DEEP” by Dan O’Shea speaks to this issue
1418 specifically:

1419
1420 “The telecom industry’s migration to digital networking
1421 has taken several years but is now nearly worldwide.
1422 The shift to digital networks triggers numerous benefits
1423 that affect network efficiency, performance, capacity and
1424 reliability. However, one side effect of this trend is the
1425 fact that distributed electronics are more sensitive to fuse
1426 outages. Also, the migration to new network
1427 architectures and equipment means that different
1428 network elements are constantly being replaced or
1429 installed, brought on-line or taken off-line. This type of
1430 situation is conducive to fuse overloads and other
1431 potential problems.” (footnotes omitted)
1432

1433 The above excerpt from Qwest’s testimony in Illinois is relevant because it shows that
1434 Qwest’s affiliate possesses the same concerns related to AT&T/SBC Illinois’ re-fusing
1435 proposal (i.e. such proposal is unnecessary, costly, may result in service outages, etc.) as I
1436 have about Qwest’s re-fusing proposal. Indeed, Ms. Hunnicutt-Bishara recognizes the
1437 disproportionate impacts such re-fusing proposals could have on competitors of the
1438 incumbent as follows: “SBC’s own equipment – used to serve *its* own retail customers –
1439 will likely remain unaffected given that SBC fuses based on List 2 drain, according to
1440 SBC’s own technical publication.” (pg. 9).

1441

1442 **Q. WOULD THESE COSTS AND RISKS ASSOCIATED WITH QWEST’S POWER**
1443 **REDUCTION OFFERING OCCUR IF THE COMMISSION ADOPTS**
1444 **MCLEODUSA’S RECOMMENDATION WITH REGARD TO THE DC POWER**
1445 **PLANT CHARGE?**

1446 A. No. McLeodUSA believes it has already addressed this issue by signing the Power
1447 Measurement Amendment. If the Commission requires Qwest to abide by the terms of
1448 that Amendment and apply its DC power plant charge on an “as consumed” basis, the
1449 risks, costs and futility of power reduction activities would be avoided.

1450
1451 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

1452 A. Yes, at this time.