

**BEFORE THE WASHINGTON  
UTILITIES & TRANSPORTATION COMMISSION**

WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION,

Complainant,

v.

CASCADIA WATER, LLC

Respondent.

---

DOCKET UW-240151

**CROSS-EXAMINATION EXHIBIT OF MATTHEW J. ROWELL AND  
CULLEY J. LEHMAN  
ON BEHALF OF THE  
WASHINGTON STATE OFFICE OF THE ATTORNEY GENERAL  
PUBLIC COUNSEL UNIT**

---

**EXHIBIT MJR-CJL-\_\_X**

Cascadia Discovery Response to WCAW DR No. 36, Attachment 3  
[Excerpt], “2009-14CALWSP”

**February 6, 2025**

**CAL WATERWORKS**  
**Lehman Enterprises, Inc.**  
**PO Box 549**  
**Freeland, WA 98249**

**WA DOH PWS ID #31040**

# **2009 TO 2014**

# **WATER SYSTEM PLAN**

George Bratton, P.E.  
Civil Engineer  
1252 S. Farragut Drive  
Coupeville, WA 98239  
(360) 678-4552

February 2009

## Table of Contents

I.	PURPOSE.....	Page 1
II.	BACKGROUND.....	Page 2
III.	DESCRIPTION OF SYSTEM.....	Page 3
IV.	1995 PLAN REVIEW.....	Page 7
V.	PLANNING.....	Page 8
VI.	DESIGN CRITERIA.....	Page 11
VII.	SYSTEM EVALUATION.....	Page 15
VIII.	RECOMMENDED IMPROVEMENTS.....	Page 17
IX.	CAPITAL FACILITIES PLAN.....	Page 18
X.	FINANCES.....	Page 18
XI.	OPERATION & MAINTENANCE.....	Page 19
XII.	STANDARD SPECIFICATIONS.....	Page 20
	WATER MAINS	

## Calculations

Summary of System Information & Allowable Number of ERUs  
Reservoir Sizing  
Network Hydraulic Analysis  
Booster pump sizing (with proposed pump curves)  
Hydropneumatic Tank Sizing  
Budget Cost Estimate

## Tables

Table 1	Wells
Table 2	Water Rights
Table 3	Source Water Quality Summary, IOCs
Table 4	Distribution System Inventory – Mains
Table 5	Distribution System Inventory - Appurtenances
Table 6	Status of 1995 Twenty-Year Plan
Table 7	Six-Year Capital Improvement Budget
Table 8	Routine Distribution System Maintenance and Inspection

## Appendices

- A. Recent correspondence with WA DOH, WA DOE, County
- B. Water Right Permits
- C. Well site approval
- D. Well pump curves
- E. Well logs
- F. Declaration of covenants/restrictive covenants
- G. Well pump test results
- H. Booster pump curves
- I. County franchise agreement
- J. Easements
- K. County Service Area Agreement
- L. Standard Construction Specifications
- M. Water Conservation Plan
- N. Water Shortage Response Plan
- O. Cross Connection Control Program
- P. Wellhead Protection Plan
- Q. Water Quality Monitoring Plan
- R. Emergency Plan
- S. Financial Viability Assessment
- T. Service Policies
- U. Water Supply and Demand Forecast, Water Right Self-Assessment and WSP Consistency Statement Checklist
- V. Wholesale Service Agreement

## Drawings

- Water Distribution System – Comprehensive Map
- Water Distribution System – Retail and Wholesale Service Area
- Water Distribution System – System Schematic
- Water Distribution System – Computer Schematic

With Standard Construction Specifications (see Appendix L)

- |     |                                   |
|-----|-----------------------------------|
| W-1 | Trench Details                    |
| W-2 | Thrust Blocks Details             |
| W-3 | Fire Hydrants Details             |
| W-4 | Gate Valve Details                |
| W-5 | Flushing and Disinfection Details |
| W-6 | Blow-off Details                  |
| W-7 | Residential Service Details       |
| W-8 | Air Release Valve Details         |
| W-9 | Road Casing Pipe Details          |

W-10	Service Connection - Residential
W-11	Service Connection - Commercial
W-12	Service Separation Details
W-13	RPBA Details
W-14	DCVA Details
W-15	Fire Line DCDA Details
W-16	RPBA Details for Construction Water
W-17	General Cross Connection Control Details
E-1 to 3	Erosion Control - Water Main Installation

With Wellhead Protection Program (see Appendix P)

WH-1	Calculated fixed Radius
------	-------------------------

With Water Quality Monitoring Program (see Appendix Q)

WQ-1	Routine Sample Locations
------	--------------------------

### **Reference Documents**

Management & Operations Manual (to be updated with new booster pump station)

## CAL WATERWORKS 2009 – 2014 WATER SYSTEM PLAN

### I. PURPOSE

The purposes of this *Water System Plan* are to provide:

1. An inventory of the major water system facilities.
2. A summary of the improvements made to the system since the approval of the 1995 *Water System Plan* prepared by Trepanier Engineering.
3. An evaluation and capacity analysis of the present system.
4. Recommendations for improvements necessary for the system to comply with the Washington Department of Health (WA DOH) guidelines.
5. Budget-level cost estimates for recommended system improvements.
6. A report on the status of various management and operation programs required by the WA DOH.

This Plan includes the following:

- (1) Standard specifications and construction details for the extension and replacement of water mains.
- (2) Cross Connection Control Program.
- (3) Water Conservation Plan and Water Shortage Response Plan.
- (4) Wellhead Protection Plan.
- (5) Water Quality Monitoring Plan (e.g., Coliform Monitoring Plan).
- (6) Emergency Plan.
- (7) Six-year and twenty-year capital improvement programs.
- (8) Financial Viability Assessment.

The operating programs and plans updated for this *Water System Plan* are also incorporated into the Cal Waterworks *Management and Operations Manual*.

With approval of the Plan, approval is requested to supply 131 ERUs. The limiting factor is the volume of water storage, based on providing the recommended minimum 200 gpd/ERU in standby storage. Approval is also requested for a wholesale intertie to the Goss Lakeridge Acres water system. The approval to supply 131 ERUs will allow the system to supply the 15 current customers in the Goss Lakeridge Acres system plus 17 ERUs for growth until additional storage is provided.

A project report was submitted at the same time as the submittal of this *Water System Plan*. The project report is for the upgrade of the pumping facilities recommended in the six-year capital program. The upgrade of the pumping facilities includes the installation of an emergency generator.

A separate project report will be submitted for the construction of a second storage reservoir. A project report will be submitted by Goss Lakeridge Acres for the improvements need to receive and distribute wholesale water.

## II. BACKGROUND

The CAL Waterworks system (WA DOH ID #310406) is owned by Lehman Enterprises, Inc., a for-profit corporation incorporated in the State of Washington. The Group A system is located on the south end of Whidbey Island approximately one mile northeast of the community of Freeland, WA. The service area is shown in the accompanying drawing Water Service Area.

CAL Waterworks, hereinafter referred to as the Purveyor, currently supplies or has commitments to supply 99 equivalent single-family residential connections (ERUs). The system currently has 95 active accounts.

The WA DOH currently approves the system for supply of 99 ERUs.

Because Lehman Enterprises, Inc. owns multiple water systems, with a combined number of customers greater than 100, the CAL Waterworks system is regulated by the WA Utilities and Utilities Commission.

The standard plans and specifications for water main installation are common to all Lehman Enterprises, Inc. owned water systems. The operating programs and plans are provided in two parts. Part I is common to all Lehman Enterprises, Inc. owned water systems; Part 2 provides specific information for each water system.

The Goss Lakeridge Acres Water Association has voted to purchase water (wholesale supply) from the CAL Waterworks system as an alternative to installing a reservoir, booster pump station and water treatment to remove arsenic, iron and manganese. The purchase of wholesale water was included in the Association's Drinking Water State Revolving Fund Loan scope of work

The capacity analysis and system design in this *Water System Plan* includes the 27 ultimate ERUs in the Goss Lakeridge Acres retail service area.

The Purveyor's mailing address is:

P. O. Box 549  
Freeland, WA 98249

Tel. (360) 331-7388

The water system day-to-day management and operation, as well as system maintenance are assigned to the following contract certified operator:

Terry Lehman  
B & W Pump Company  
P. O. Box 55  
Freeland, WA 98249

Tel: (360) 331-4016

Certif. No. 004920 BTO, CCS, WDM3

### III. DESCRIPTION OF SYSTEM

The general configuration of the water system is shown in the drawings in the appendices to this Plan. For the purposes of discussion, the facilities have been grouped into areas of supply; water quality and treatment; storage, pumping and pressure reduction; and distribution.

References to documents denoted with an asterisk [\*] were previously submitted in the approved 1995 Water System Plan.

#### Sources of Supply

The system has two wells located on the Purveyor's owned lot containing a storage reservoir and a booster pump station. The following table summarizes the well information.

**Table 1  
WELLS**

	<b>Casing Diameter</b>	<b>Year Drilled</b>	<b>Depth</b>	<b>Pump Size</b>	<b>Pumping Rate</b>
<b>Well No. 1 (SO 1)</b>	6"	1963	178 feet	3 hp	45 gpm
<b>Well No. 2 (SO 2)</b>	6"	1984	179 feet	3 hp	45 gpm
				<b>Total</b>	<b>90 gpm</b>

A well field was designated in 1994 for the purpose of water quality monitoring (See Appendix E [\*]).

The wells have the following water rights:

**Table 2  
WATER RIGHTS**

	<b>Certificate [C] or Permit [P]</b>	<b>Withdrawal Rate (Qi)</b>	<b>Annual Withdrawal (Qa)</b>
<b>Well No. 1</b>	G1-00032C, Dec. 1971	55 gpm	27.5 acre-feet
<b>Well No. 2</b>	G1-27478P, June 1994	35 gpm	26.5 acre-feet
	<b>Total</b>	<b>90 gpm</b>	<b>54.0 acre-feet</b>

Copies of the WA Department of Ecology's (WA DOE) Water Right Certificates and most recent Report of Examination are included in Appendix B. The water rights are additive.



Well No. 1 is located within the building containing the booster pumps for the system. Well No. 2 is located adjacent to the building.

The 100-foot sanitary control radii for both wells extend beyond the well lot.

The Declaration of Covenant and Restrictive Covenants for the sanitary control areas are included in Appendix F. Not all adjacent property owners have signed restrictive Covenants. All adjacent property owners within the sanitary control radii have been requested to sign a Restrictive Covenants.

The well pump curves for the wells are included in Appendix D.

Well pumping test results are included in Appendix G. The WA DOE Report of Examination in Appendix B provides the hydrogeology assessment of the well pumping test.

A Wellhead Protection plan is included in the Appendix P. The WA DOH “Ground Water Susceptibility Assessment Survey” forms for Well Nos. 1 and 2 have been completed and submitted to WA DOH. [\*]

A water right self-assessment is included in the Appendix U.

The wells have been assessed as a low risk for seawater intrusion. Confirmation of the risk assessment from the Island County Health Department is included in Appendix A.

**Water Quality and Treatment**

Appendix Q provides the recent results of tests for Inorganic Chemicals, Volatile Organic Chemicals and Radionuclide.

The following is a summary of the major Inorganic Chemicals (2008 report):

**Table 3  
SOURCE WATER QUALITY SUMMARY  
INORGANIC CHEMICALS**

<b>Parameter</b>	<b>Units</b>	<b>MCL</b>	<b>Results (2005)</b>
Arsenic	Mg/L	0.01	0.0025
Iron	Mg/L	0.30	ND
Manganese	Mg/L	0.05	0.011
Total Nitrate/Nitrite	Mg/L	10.0	3.54
Chloride	Mg/L	250	25
Hardness (3)	Mg/L		183
Electrical Conductivity	umhos/cm	700	436
Color (3)	Color Units	15	ND

No treatment is currently provided. The water is not chlorinated to provide a precautionary residual at the ends of the distributions system.

A hypochlorinator is provided (on a stand-by basis) in the pump house for use if a problem is detected from routine coliform monitoring.

Water quality monitoring programs are included in Appendix Q. The monitoring programs include:

- Coliform monitoring plan
- Lead and copper monitoring plan

### **Storage, Pumping and Pressure Reduction Facilities**

Storage is provided in one, 40,000 gallon (nominal volume) Everett Brothers octagon concrete reservoir located on the well lot. The reservoir has a combined inlet and outlet. Electrodes in the reservoir control the two wells.

The booster pump station is located on the well lot adjacent to the reservoir. Water is supplied to the entire service area through booster pumps. Twin 5 hp pumps supply the entire system. Twin 1.5 hp pumps supplied from discharge of the 5 hp pumps supply a high elevation pressure zones. Fire flow is not provided.

The twin 5 hp booster pump motors are protected from frequent on-off cycling by three 315 gallon vertical hydropneumatic tanks. The twin 1.5 hp booster pump motors are protected from frequent on-off cycling by two 220 gallon vertical hydropneumatic tanks. Data on ASME certification of the tanks was not found.

The operating pressure range of the booster pumps for Pressure Zone 1 is 45 psi to 65 psi. The operating pressure range of the booster pumps for Pressure Zone 2 is 75 psi to 95 psi.

The booster pump building is of wood frame construction. Piping within the building is primarily galvanized steel. The amount of equipment in the building leaves little working room.

The drawing System Schematic summarizes the above information on supply, storage and pumping. The drawing Comprehensive Map shows the area covered by the two pressure zones.

The booster pump station is not equipped with an auto-dialer/alarm monitor that has the telephone number of the operator in the computer program.

An emergency generator is not provided for the booster pumps.

A security fence is not provided around the building, reservoir and Well No. 2.

**Distribution System**

The distribution system is shown in the accompanying drawing Comprehensive Map. The following tables summarizes distribution system inventory:

**Table 4  
DISTRIBUTION MAINS**

	<b>Length (feet)</b>						<b>Total</b>
	<b>&lt; 2"</b>	<b>2" &amp; 2.5"</b>	<b>3"</b>	<b>4"</b>	<b>6"</b>	<b>8"</b>	
Ductile Iron	0	0	0	0	0	0	0
PVC or HDPE	0	931	2,165	321	161	0	3,578
Asbestos Cement	0	0	0	0	0	0	0
Steel	0	0	0	0	0	0	0
Galv. Steel	0	0	0	0	0	0	0
Cast Iron	0	0	0	0	0	0	0
total							3,578

**Table 5  
VALVES, HYDRANTS & METER INVENTORY**  
Excludes Reservoir, Wellheads, & Pump Station

<b>DESCRIPTION</b>	<b>NUMBER</b>
Isolating valves (excluding hydrant valves)	6
Fire hydrants c/w isolating valves	0
Air release valves	0
Blow-off assemblies	4
Services c/w meters	76
Services w/o meters	23
Backflow prevention assemblies	0

The program of installing water meters is scheduled for completion in 2009.

**IV. REVIEW OF 1995 PLAN**

The status of the planned improvements in the 1995 *Water System Plan* is summarized in the following table:

**Table 6  
STATUS OF 1995 TWENTY-YEAR PLAN**

<b>Category</b>	<b>Project</b>	<b>Status</b>
Supply	Replace existing well pumps	Completed
Treatment	None	
Storage	Add 37,000 gallon storage tanks	Not done
Pumping	Emergency generator	Not done
	Two 5 hp pumps to low pressure zone	Completed
	Upgrade pump suction pipe from reservoir	Not done
	Added one 452 gallon hydropneumatic tank to low pressure zone	Not done
	Add one 436 gallon hydropneumatic tank to high pressure zone	Not done
PRV Stations	None	
Distribution	Upgrade 430 feet of main from pump house to East Harbor Road.	Not done

## V. PLANNING

### **Present and Future Service Area**

The present service area is shown in the accompanying drawings Comprehensive Map and Water Service Area. Except for the wholesale supply to Goss Lakeridge Acres as noted previously, expansion of the service area is not planned. The service area is bordered to the south and east by other public water systems and to the west by Holmes Harbor. The area to the north and northeast contains large parcels that could request an expansion of the service area to obtain service.

The water rights of 90 gpm are adequate to supply a service area with 216 ERUs, based on meeting a 600 gpd/ERU water conservation goal. Booster pump and storage facilities would need to be expanded for any major expansion of the service area.

The *Consistency Statement Checklist* signed by the County is included in Appendix S.

### **Service Area Agreement**

The signed service area agreement is included Appendix K.

### **County Franchise**

The Island County franchise agreement is included in Appendix I.

### **System Interties**

An emergency intertie to an adjoining system has not been made.

An emergency intertie with the Freeland Water District is feasible. A request to make the intertie has not been made.

### **Water Supply and Demand Forecast**

[Appendix U](#)

A copy of the Water Supply and Demand Forecast is included in Appendix S. Also included in this appendix is the Water Right Self-Assessment.

### **Water Demand**

A record of daily source meter readings is maintained by CAL Waterworks. The record of maximum day demand (MDD) and annual demand is provided in the Calculation section of this Plan and in Appendix S. The highest MDD per connection of 388 gpd/ERU occurred in 2004.

For long-term distribution system design, and water storage requirements the WA DOH recommended maximum day demand of 800 gpd/ERU was assumed.

### **Water Conservation & Water Shortage Response Plan**

Consistent with the Island County Coordinated Water System Plan, the Purveyor has adopted a water conservation program and water shortage response plan. Copies of these plans are included in the appendices. The water conservation plan includes the requisite WA DOH "Water Use Data Collection Requirements Checklist" and "Demand Forecast Requirements Checklist".

Although the Municipal Law does not currently apply to CAL Waterworks because it is not a government body, the guidelines are adopted voluntarily. The water use efficiency measures are included in Appendix U.

The short-term water conservation goal for the maximum day demand (MDD) is 600 gpd/ERU. The long-term (20-year) goal is the same (600 gpd/ERU). The current average day demand (ADD) is 258 gpd/ERU. The long-term ADD water conservation goal is 268 gpd/ERU (0.3 acre-feet/year/ERU).

### **Emergency Plan**

An emergency plan is included in the Appendix R.

### **System Vulnerability**

The most vulnerable system component is the failure of a well. The second most vulnerable component of the system that could have a major impact on customer service is a water main break. There are an adequate number of isolating valves to limit the number of customers out of service for repairs.

The wellhead protection plan addresses the potential contamination of a source of supply. There is adequate undeveloped land in the area to secure a replacement well site.

### **Service Policies**

A copy of the adopted service policies are provided in Appendix U. The policies were adopted in the format for WA Utility and Transportation Commission approval.

### **Community Participation**

The record of community participation in the preparation of the Water System Plan is included in Appendix A. As a temporary measure until an additional storage reservoir is constructed, the record of community acceptance of less than the WA DOH recommended standby storage is included in Appendix A.

### **Review Comments**

A copy of the Water System Plan has been submitted to the Island County Health Department and Goss Lakeridge Acres Association for review and comment. The Freeland Water District and Ridgeview Estates, through their water system operator, were notified of the availability of the plan for their review. A copy of the Water System Plan is available for review by customers.

## VI. DESIGN CRITERIA

The design criteria utilized for the evaluation and/or design of the Purveyor's system, includes the major design requirements of the Washington Department of Health (WA DOH *Water System Design Manual*, August 2001) and WAC 246-290. The wording of the WA DOH regulations and design criteria may have been abbreviated herein for this summary. An explanation is provided where more stringent design criterion are utilized than the current WA DOH criteria.

### Distribution

1. The system shall provide a minimum of 30 psi (preferably higher) operating pressure to all customers during peak hour demand (PHD) conditions, with the equalizing component of storage depleted. <sup>(1)</sup>{WAC 246-290-230(5), applicable to for new systems or additions to new systems} The calculation of PHD shall be based on WA DOH guidelines. <sup>(2)</sup>
2. The system shall provide maximum day demand (MDD) plus fire flow at a minimum of 20 psi at all points throughout the distribution system, with the fire suppression and equalizing storage depleted. {WAC 246-290-230(6)} The calculation of MDD shall be based on WA DOH guidelines.

The 2007 *Water Use Efficiency Rule* changes to the WA DOH regulations {WAC 246-290-420(3)} states that 20 psi shall be provided at the operating hydrant and at least positive pressure throughout the system. The maintenance of a minimum of 20 psi at all points in the distribution system during fire flow is the safety factor for prevention of backflow due to backsiphonage in the customer's service line. The Purveyor is responsible (and legally liable) for any contaminant that enters the Purveyor's distributions system due to backflow.

The 2007 *Water Use Efficiency Rule* changes {WAC 246-290-420(2)} states that during normal operating conditions, for both average and peak hour demand periods, water pressure at the service meter shall be maintained at the approved design pressure, but in no case less than 20 psi. Customers usually complain about pressures as low as 30 psi.

---

<sup>1</sup> The revision to WAC 246-290 effective April 9, 1999 changed the design criterion for calculating minimum system pressure. Previously, the 30 psi requirement was based on the depletion of standby storage; now it is based on the depletion of equalizing storage.

<sup>2</sup> The previous WAC 246-290 referred to PHD as maximum instantaneous demand (MID). The June 1999 WA DOH guideline "Water System Design Manual" changed the distribution system criterion for the flow rate (gpm) used in hydraulic analysis.



3. All new or expanding water systems shall provide fire hydrants in residential areas at a maximum spacing of 900 ft., or maximum hose lay of 500 ft., whichever is the lesser, and shall provide a basic fire flow from any one hydrant of 500 gpm. This requirement does not apply to rural lots 2.5 acres or larger, or as otherwise provided through alternate fire protection methods in County Code.
4. For new or expanding systems, the minimum water main size shall be 6-inch, except into cul-de-sacs or other locations where further expansion is very improbable, where lines shall not be less than 2-inch.
5. The system shall be equipped with adequate isolating valves, air release valves, blow-off assemblies, etc., for proper system operation and maintenance.
6. An individual service booster pump is allowed as an interim measure (less than six years) where distribution system pressure is deficient.

### **Supply**

7. The minimum production capacity shall equal the maximum day demand (MDD).
8. The establishment of a water conservation program. The program should follow the latest edition of "Water Conservation Planning Handbook for Public water Systems", and "Guidelines and Requirements for Public Water Systems Regarding Water Use Reporting, Demand Forecasting Methodology, and Conservation Programs".
9. A Step-Drawdown Test and a 24 hour Constant-Rate Test conforming to WA DOH guidelines shall be made to support the source's ability to reliably provide a safe yield. Low water demand sources in high production aquifers may continue the Step-Drawdown Test to stabilization, and forego the subsequent 24 hour Constant-Rate Test.

### **Storage**

10. The minimum standby (i.e., emergency) storage shall be equal to the maximum day demand (MDD). Where multiple sources of supply are available, the standby storage may be reduced by the existing pumping capacity of the wells, assuming the highest capacity well is out of service. A minimum standby storage of 200 gpd/ERU, should be provided regardless of the number of, and/or excess capacity of, the sources available.
11. The minimum equalizing storage shall be provided based on the formula:  $150 \text{ min.} \times (\text{PHD}-Q)$ , where 'Q' is the sum of the capacities of the active sources of supply.
12. The minimum fire protection storage for single-family residences shall be based on a fire flow of 500 gpm for 30 minutes (15,000 gallons). Standby storage may be used for fire protection storage.

Equalizing storage is defined as the volume of storage needed to supplement supply of consumers when the peak hourly demand exceeds the total source pumping capacity. Standby storage is defined as the volume of stored water available for use during a loss of source capacity, power or similar short-term emergency.

A reduction in the requirement for production capacity and standby storage may be requested if adequate water use data is available to demonstrate that the actual average per customer maximum day demand is lower than that specified in the WA DOH Design Guidelines, and that conservation measures can be relied upon to limit new customers to this average water usage. Daily data collected over a two-year period is usually adequate, provided the summer months are typical of warm weather patterns.

The provision of standby storage is a recommendation (not a requirement) of the Design Guidelines. The amount of standby storage may be reduced below the recommended level in the Design Guidelines if "community expectations are amenable to a lesser standby storage capacity".

### **Pressurization of System**

13. The operating cycle of any booster pump shall not exceed 6 cycles per hour.
14. The booster pumps shall have capacity to supply peak hour demand (PHD), preferably with the highest capacity pump out of service for reliability. The average day demand (ADD) shall be met with the largest capacity pump out of service.
15. The booster pumps shall have capacity to supply fire flow plus maximum day demand (MDD).
16. Hydropneumatic tanks shall be ASME approved (labeled) and equipped with a ASME relief valve. Small (up to 120 gallons), non-approved ASME tanks may be used if equipped with an ASME relief valve.
17. Hydropneumatic tanks shall be sized in accordance with WA DOH guidelines.
18. Back-up power shall be provided (i.e., emergency electrical generator) for systems dependent upon booster pumps as the sole source of supply. The electrical generator shall be operated by an automatic transfer switch, except where manual transfer may be completed in a reasonable time.

### **Treatment for Manganese & Iron**

19. All iron and manganese facilities must be pilot plant tested at the site (or full scale tested after installation).
20. The maximum filter unit application rate and minimum backwash application rate shall be 5 gpm/sq.ft. and 12 gpm/sq.ft. unless otherwise approved by the WA Department of Health.

21. Documentation must be provided that the method of waste disposal [backwash] is acceptable to the WA Department of Ecology.

**Chlorination**

22. A WA DOH Hypochlorination Facilities for Small Systems submittal checklist shall be submitted where chlorination is provided.

**Service Meters**

23. Meters must be installed on all existing service connections by January 2017.

24. Meters must be installed on all new service connections beginning in January 2007.

## VII. SYSTEM EVALUATION

The system evaluation is based on the design criteria given in Section VI. Calculations to support the evaluation are provided in the appendices. The major points in the system evaluation are summarized below:

### Sources of Supply

The water right annual withdrawal, water right rate of withdrawal, and well pumping capacity are adequate to supply the maximum day demand (MDD) for ultimate number of customers in the combined retail and wholesale service area.

### Water Quality and Treatment

The water quality meets current US EPA guidelines.

The Purveyor has not experienced a history of positive coliform test results.

The Purveyor obtains water samples for routine coliform monitoring from residences. It is desirable to obtain routine samples from curbside water sample station connected to the distribution system.

With extension of the distribution system to supply Goss Lakeridge Acres, it is desirable to provide a free chlorine residual at the end of the distribution system.

### System Hydraulics

The computer analysis of the distribution system is included in the Calculation section of this Plan. The drawing Computer Schematic shows the assigned node numbers, pipes number and flow distribution used with the computer model.

The distribution system design is based on the following:

1. With the extension to Goss Lakeridge Acres, the system will be divided into three pressure zones:
  - a. Zone 1 – 123 ERUs Along and west of East Harbor Road, plus 5 ERUs supplied direct to Goss Lakeridge Acres low elevation area.
  - b. Zone 2 – 10 ERUs in east of East Harbor Road.
  - c. Zone 3 – 22 ERUs supplied by Goss Lakeridge Acres pump station.
2. The Peak Hour Demand (PHD) for 155 ERUs, assuming Maximum Day Demand (MDD) of 800 gpd/ERU is 232 gpm.
3. When a second reservoir is constructed to provide increased standby storage, and the long-range water conservation goal of 600 gpd/ERU is achieved, the system would be able to supply 208 ERUs. The PHD for 208 ERUs assuming a MDD of 600 gpd/ERU is 223 gpm. To be conservative, the system design was based on a PHD of 232 gpm.

4. The fire flow for retail customers is 500 gpm, coincidental with 40% of PHD.
5. Fire flow will only be provided to CAL Waterworks Pressure Zone 1. Fire flow will not be supplied to the Goss Lakeridge Acres wholesale service area or CAL Waterworks Pressure Zone 2.
6. A meter and double check valve assembly will be installed at the intertie to Goss Lakeridge Acres.

The following is a summary of the analysis results:

[a]	Existing CAL Distribution System	Distribution Pressures (psi):	
	Existing CAL Booster Pumps	Zone	Minimum
	New GLA Booster Pumps	1	41.6
	Peak Hour Demand	2	31.7
	Existing CAL water mains	3	33.1
[b]	Upgraded CAL Distribution System	Distribution Pressures (psi):	
	New CAL Booster Pumps	Zone	Minimum
	New GLA Booster Pumps	1	47.2
	Fire Flow of 500 gpm at Node 12 (Ravenridge Dirve)	2	44.6
		3	39.2
	Upgraded CAL water mains	Hydrant Residual Pressure: 53.7 psi	
[c]	Upgraded CAL Distribution System	Distribution Pressures (psi):	
	New CAL Booster Pumps	Zone	Minimum
	New GLA Booster Pumps	1	51.4
	Peak Hour Demand	2	44.1
		3	41.9

The above “a” scenario shows that the existing booster pumps and distribution system are adequate to supply the 155 ultimate connections in the combined retail and wholesale service areas. This assessment assumes a MDD for calculation of PHD of 800 gpd/ERU.

The existing pumps are not adequate to supply fire flow. The “b” and “c” scenarios show the adequacy of the proposed booster pumps for fire flow.

Although the existing booster pumps are adequate to supply the ultimate PHD, the hydropneumatic tank storage volume is slightly inadequate (1,023 gallons required versus 945 gallons available). Since new pumping facilities are scheduled for construction in 2009, this slight difference in hydropneumatic storage volume should not result in excessive wear on the pump motors. The CAL Waterworks recorded maximum day demand is significantly less than 800 gpd/ERU.

## VIII. RECOMMENDED IMPROVEMENTS

The following major system improvements are recommended.

### Short-term (six-years)

1. Replace the booster pump station. The station will provide pumps for fire flow in Pressure Zone 1. The pumps for Pressure Zone 2 will be supplied from the reservoir and not from Pressure Zone 1. The pump station work includes:
  - a. Installing an emergency generator for the pump station.
  - b. Installing a hypochlorinator to provide a precautionary residual to the ends of the distribution system.
  - c. Installing a security fence around the storage tank, pump station, wells and emergency generator.
  - d. Replacing the yard piping to/from the existing storage reservoir to provide dedicated inlet and outlet pipes.
2. For fire flow, replace the 4-inch water mains with 8-inch mains from the pump station to and 6-inch mains along East Harbor Road.
3. Install curb-side water sample stations.
4. Install air-release valves at high points.
5. For fire flow, replace the 3-inch water mains on Beachwood Drive and Ravenridge Drive.
6. Construct second storage reservoir.

### Long-range (20 years)

7. Replace glued-joint 2-inch and 3-inch PVC water mains.

The cost for the extension of the system to supply wholesale water to Goss Lakeridge Acres will be borne by the applicant. No improvements to the CAL Waterworks system are scheduled for this extension.

### Administrative Tasks

Once Goss Lakeridge Acres is supplied with water, make application to the WA Department of Ecology for increased water rights in the amount required to supply the ultimate number of customers (27 ERUs) in Goss Lakeridge Acres.

**IX. CAPITAL FACILITIES PLAN**

The following table summarizes the capital improvements for this *Water System Plan*. All costs are in current-year dollars.

**Table 7  
SIX-YEAR CAPITAL FACILITIES PLAN**

<b>Project</b>	<b>Year</b>	<b>Budget Estimate (2008 dollars)</b>
1) Booster pump station	2009	\$ 252,700
2) Water main replacement – E. Harbor Dr.	2009	\$ 175,500
3) Curb-side water sample stations (4)	2010	\$ 6,000
4) Air release valve assemblies (2)	2010	\$ 4,000
5) Water main replacement – Brentwood Dr. Water main replacement – Ravenridge Dr.	2010	\$ 158,500
6) Second storage reservoir	2012	\$ 91,800

The total six-year capital program is \$ 688,500. The Calculation section of this Plan includes the details of the cost estimate for each project.

The replacement cost of the existing distribution system (11,305 feet) is \$ 1,017,500 (in 2008 dollars), assuming average cost of \$90 per foot with service replacement.

**X. FINANCES**

A financial viability assessment, developed in accordance with the Washington Department of Health Financial Viability Manual, March 1995, is provided in the Appendix T. This assessment is provided as a guide for application to the WA Utilities and Transportation Commission for the setting of water rates and charges.

Funding is obtained for the operation of the water system from the WA UTC approved water rates and charges (copy in Appendix T). The connection to the Goss Lakeridge Acres water system to provide a wholesale supply is funded solely by wholesale customers.

The current financial plan assumes that all future major water system improvements will be financed by borrowing.

Any surplus funds from water rates and connection fees are allocated to a capital reserve fund. These funds will be used for capital improvements whenever possible.

## **XI. OPERATION AND MAINTENANCE**

Details on the following operation programs and plans are included in appendices and in the M. & O. Manual.

- Cross Connection Control Program
- Water Conservation Plan
- Water Shortage Response Plan
- Wellhead Protection Program
- Water Quality Monitoring Plan (including lead and copper monitoring)
- Corrosion Control Plan
- Emergency Plan

A safety program has not been developed. The Purveyor relies upon contract certified operator (B & W Pump Company) for system maintenance and operation. The contract operator is responsible for the preparation of a safety program, training of personnel, etc.

The following status reports on the implementation and operation of the above noted programs and plans are provided. In addition a summary of the routine distribution system preventative maintenance programs is provided.

### **Cross Connection Control Program**

All elements for initiation of the program have been completed with the exception of the periodic distribution of the residential survey questionnaire for risk assessment.

### **Water Conservation Plan**

The unaccounted-for water cannot be calculated until the last of the residential meters are installed.

### **Water Shortage Response Plan**

The water shortage response plan has not been needed. No modifications to the plan were necessary. With the current low recorded maximum day demand, and multiple sources of supply, the likelihood of needing to implement the plan is low.

### **Wellhead Protection Program**

The task has not been scheduled to refine the delineation of the wellhead protection areas from the fixed radius method assumed initially. With the land up-gradient (inland) being mostly undeveloped, this task is not needed for the foreseeable future.

### **Emergency Plan**

It has not been necessary to implement the emergency plan.



**Water Quality Monitoring Plan**

The Purveyor is on schedule for sampling for inorganic chemicals, volatile organic compounds and applying for monitoring waivers.

**Routine Distribution System Maintenance Program**

The routine preventative maintenance task schedule for the distribution system is summarized in the following table.

**Table 8  
ROUTINE DISTRIBUTION SYSTEM MAINTENANCE  
AND INSPECTION SCHEDULE**

<b>Description</b>	<b>Schedule</b>	<b>Status</b>
a) Hydrant inspection and exercising	Annual	None installed at present
b) Line valve inspection and exercising	Annual	Scheduled annually
c) Blow-off inspection and exercising	Annual	Periodic, limited number currently in system
d) Air release valve inspection	Annual	None installed at present
e) Source meters testing and maintenance /calibration	Every 2 years	Approximately every two years
f) Small customer meter testing and replacement		Not currently scheduled. Meters on 15-year replacement schedule
g) Water main flushing	Annually	Each fall
h) Pump Station	Twice weekly	General inspection
i) Reservoir	Monthly	General sanitation, e.g., hatch, overflow
j) PRV Stations	Monthly	None installed at present
k) Wells	Monthly	Static and pumping levels

Reservoir cleaning is scheduled when needed. Iron and manganese in the source water is well below the MCL.

**XII. STANDARD SPECIFICATIONS - WATER MAIN**

For any future extension or replacement of water mains, the appendices include standard specifications and construction plans for water mains 2 to 12-inch in diameter.

## CALCULATIONS

CAL WATERWORKS

CALCULATIONS

SUMMARY OF SYSTEM INFORMATION

WA DOH approved connections:	99	ERUs	
Current number of customers:	99	ERUs	With 4 committed water availability
Previous assumed ultimate number of lot	147	ERUs	From previous Water System Plan
Counted number of lots:	128	ERUs	With current combined lots
Counted lots with wholesale customers:	155	ERUs	15 active / 27 ultimate customers in Goss Lakeridge Acres
Number of lots assumed for design:	208	ERUs	Based on adding 2nd storage tank
Recorded Maximum Day Demand:	<del>208</del> <sup>2008</sup> 305		Saturday August 23 <sup>rd</sup>
2007	318	gpd/ERU	Monday Sept 3 <sup>rd</sup>
2006	276	gpd/ERU	Friday, July 7th
2005	289	gpd/ERU	Saturday, August 20th
2004	388	gpd/ERU	Thursday, July 29th
MDD without conservation:	800	gpd/ERU	assumed without recorded MDD
MDD long-term goal (20-years):	600	gpd/ERU	
Recorded annual production:	<sup>2008</sup> 4,800,950		
2007	5,226,817	gallons	
2006	6,894,240	gallons	21.2 acre-feet
2005	7,082,510	gallons	
2004	8,286,960	gallons	← Started meter installation on services
2003	9,645,300	gallons	
2002	10,293,400	gallons	
ADD based on WA DOE allowance:	268	gpd/ERU	(0.3 acre-ft/year/ERU)
ADD long-term goal (20-years):	268	gpd/ERU	
ADD based on record use, 2004 to 2006	240	gpd/ERU	0.27 acre-ft/year/ERU
Water rights:			
Well No. 1	G1-00032C	55 gpm	27.5 acre-feet Dec. 1971
Well No. 2	G1-27478P	35 gpm	26.5 acre-feet * Jun. 1994
		90 gpm	54.0 acre-feet *
			(* WR are additive)
Well production:	Well No. 1	45 gpm	Flow rates from WA DOE
	Well No. 2	45 gpm	Report of Examination for 4-hour test
		90 gpm	
Well construction:	Well No. 1	178 ft of 6"Ø	3 hp pump 1963
	Well No. 2	179 ft of 6"Ø	3 hp pump 1985
Well pumps:	Well No. 1	3 hp	Flint & Wallings, 7 stage, 55 gpm @ 165 ft TDH
	Well No. 2	3 hp	Flint & Wallings, 7 stage, 55 gpm @ 165 ft TDH

CAL WATERWORKS

CALCULATIONS

Summary of System Information (continued)

Water quality: (combined sources)	Iron	0.10	mg/L	Manganese	0.013	mg/L
	Arsenic	0.002	mg/L	Chloride	24	mg/L
	Hardness	171	mg/L	Nitrates	3.03	mg/L
Treatment plant capacity:		0	gpm	No treatment necessary		
Treatment plant backwash:		0	gpd			
Hypochlorinators:	Well No. 1		gpd	Chlorination not provided		
	Well No. 2		gpd			
Storage:						
Existing tank	40,000	gallons (nominal)	Everett Brothers octagon			
Booster pumps:						
Low elevation service area						
#1 Sta-Rite DJH	5	hp	140	gpm at	104	feet TDH
#2 Sta-Rite DJH	5	hp	140	gpm at	104	feet TDH
High elevation service area						
#3 Sta-Rite HMSF	1.5	hp	30	gpm at	132	feet TDH
#4 Sta-Rite HMSF	1.5	hp	30	gpm at	132	feet TDH

Note: High elevating service area supplied from low elevation service area, not from reservoir.

Hydropneumatic tank:

Low elevation service area						
3 Galv steel tanks	315	gallon, 36"Ø x 60" (80"± o.a.) vertical	945	total gallons		
	45	psi to 65 psi operating range				
High elevation service area						
2 Steel tanks	220	gallon, 30"Ø x 72" vertical	440	total gallons		
	75	psi to 95 psi operating range				

Note: Make and pressure rating of tanks are unknown

Pressure reducing valve stations: None in system

Distribution system inventory:

8"Ø	0	feet	} 11,305 feet all mains are PVC	Service meters (Nov. 07):	76
6"Ø	1,760	feet		Gate valves:	6
4"Ø	540	feet		Fire hydrants:	0
3"Ø	5,935	feet		Air release valves:	0
2.5"Ø	0			Blow-off assemblies:	4
2"Ø	3,070	feet		Backflow assemblies:	0
<2"Ø	0	feet		Curbside sample sta.:	0

CAL WATERWORKS

CALCULATIONS

**Summary of System Information (continued)**

Static Water Level Elevation for Island County  
Seawater Intrusion Risk Category Assessment

	Well No. 1 ID# AGA928	Well No. 2 ID# AGA927	
Top of Casing Elevation	(feet)	(feet)	
NAVD 88 Datum *	161.85	163.45	
MSL Datum	158.18	159.78	-3.67 correction
Static Water Depth **	147.79	148.66	used for
Static Water Elevation (MSL Datum)	10.39	11.12	MSL datum

\* Survey by Thatcher & Morrison

\*\* From WA DOE Report of Examination

---

**ALLOWABLE NUMBER OF CONNECTIONS (ERUs)**

The following is a summary of the calculated number of equivalent single-family residential connections (ERUs) that the system may supply, based on various design criteria.

**Water Rights:**

- 162 ERUs Based on the current water right rate of production, assuming 800 gpd/ERU Maximum Day Demand (no water conservation).
- 180 ERUs Based on the current water right annual withdrawal, assuming WA DOE standard allocation of 0.3 acre-feet/year/ERU (268 gpd/ERU).
- 216 ERUs Based on the current water right rate of production, assuming 600 gpd/ERU Maximum Day Demand (moderate water conservation).

**Well Production:** See above calculations for water rights; well production equals water right rate of production

**Water Treatment:** Not Required

**Water Storage:**

- 112 ERUs Based on current storage, assuming 800 gpd/ERU for standby storage and calculation of Peak Hour Demand, reduction for operating and dead storage, current well production, credit for multiple sources.
- 131 ERUs Based on current storage, assuming 600 gpd/ERU for standby storage and calculation of Peak Hour Demand, reduction for operating and dead storage, current well production, credit for multiple sources.

Standby storage is a recommendation of the WA DOH Design Guidelines. The community may vote to accept less than the recommended standby storage. Fire storage is a requirement (where hydrants are installed).

**SUMMARY OF SYSTEM INFORMATION, - WHOLESALE SUPPLY TO  
GOSS LAKERIDGE ACRES**

WA DOH approved connections:		19	ERUs			
Current number of customers:		15	ERUs			
Ultimate number of customers:		27	ERUs			
Water rights:						
	Well Nos. 1 & 2	8811 P	50	gpm	25	acre-feet Mar. 1966
Well production:						
	Well No. 1		50	gpm	Second well is for redundancy	
	Well No. 2		50	gpm	in lieu of storage	
Well construction:						
	Well No. 1		210	ft of 6"Ø	1963	
	Well No. 2		210	ft of 6"Ø	1997	
Well pumps:						
	Well No: 1		5 hp	Flint & Wallings, 16 stage, 40 gpm @ 325 ft TDH		
	Well No. 2		5 hp	Flint & Wallings, 16 stage, 40 gpm @ 325 ft TDH		
Water quality:						
	(combined sources)	Iron	0.68	mg/L	Manganese	0.47 mg/L
		Arsenic	0.028	mg/L	Chloride	< 20 mg/L
		Hardness	148	mg/L	Nitrates	< 0.5 mg/L
Hydropneumatic tank:						
		4	119 gallon bladder tanks			

CAL WATERWORKS

CALCULATIONS

[a] RESERVOIR SIZING

Allowable number of connections based on existing reservoirs, no water conservation, (MDD of 800 gpd/ERU), current well production (at water right), no water treatment, credit towards storage requirement for multiple sources of supply, and criteria in the WA DOH August 2001 "Water System Design Guidelines".

Allowable number of service connections:			112	
Number of wells:			2	
Well production capacities (current, throttled to match water rights):			90	gpm
Peak Hour Demand (PHD):			184	gpm
Maximum Day Demand (MDD) based on	800	gpd/ERU	89,600	gal/day
Required minimum continuous well production			62	gpm (avg)
Minimum standby storage based on MDD			89,600	gal
800 gal/connection [D.O.H.]				
Credit for multiple well source		less	79,200	gal
55 gpm (each well produces 55 gpm)				
Equalizing storage: whenever source pumping capacity cannot meet peak demands [D.O.H.]			14,117	gal
E.S. = (PHD-Q)(150)				
Q = source production in gpm				
Added for fire storage (500 gpm for 30 minutes) for single-family residential homes			4,600	gal
Add min. standby storage based on	200	gpd/ERU	7,400	gal
Total required storage		[1+2+3]	36,517	gal
Allowance for filter backwash		add	0	gal
Allowance for operating and dead storage (1 ft)		add	3,333	gal
		TOTAL	39,850	gal
Existing storage				
1 Everett Brothers octagon, 12 ft height			40,000	gal



CAL WATERWORKS

CALCULATIONS

**[b] RESERVOIR SIZING**

**Allowable number of connections based on existing reservoirs, water conservation goal (MDD of 600 gpd/ERU), current well production (at water right), no water treatment, credit towards storage requirement for multiple sources of supply, and criteria in the WA DOH August 2001 "Water System Design Guidelines".**

Allowable number of service connections:			131	
Number of wells:			2	
Well production capacities (current, throttled to match water rights):			90	gpm
Peak Hour Demand (PHD):			158	gpm
Maximum Day Demand (MDD) based on	600	gpd/ERU	78,600	gal/day
Required minimum continuous well production			55	gpm (avg)
Minimum standby storage based on MDD			78,600	gal
600 gal/connection [D.O.H.]				
Credit for multiple well source		less	78,600	gal
55 gpm (each well produces 55 gpm)				
Equalizing storage: whenever source pumping capacity cannot meet peak demands [D.O.H.]			10,263	gal
E.S. = (PHD-Q)(150)				
Q = source production in gpm				
Added for fire storage (500 gpm for 30 minutes) for single-family residential homes			15,000	gal
Add min. standby storage based on	200	gpd/ERU	11,200	gal
Total required storage .....		[1+2+3]	36,463	gal
Allowance for filter backwash .....		add	0	gal
Allowance for operating and dead storage (1 ft) .....		add	3,333	gal
TOTAL			39,796	gal
Existing storage				
1	Everett Brothers octagon, 12 ft height		40,000	gal

CAL WATERWORKS

CALCULATIONS

[c] RESERVOIR SIZING

Required storage for ultimate number of customers in retail and wholesale service area, assumed 800 gpd/ERU MDD (no water conservation), credit from multiple sources of supply and criteria in the WA DOH August 2001 "Water System Design Guidelines".

Ultimate number of service connections:			155	
Number of wells:			2	
Well production capacities (current, throttled to match water rights):			90	gpm
Peak Hour Demand (PHD):			232	gpm
Maximum Day Demand (MDD) based on	800	gpd/ERU	124,000	gal/day
Required minimum continuous well production			86	gpm (avg)
Minimum standby storage based on MDD			124,000	gal
800 gal/connection [D.O.H.]				
Credit for multiple well source		less	79,200	gal
55 gpm (each well produces 55 gpm)				
Equalizing storage: whenever source pumping capacity cannot meet peak demands [D.O.H.]			21,283	gal
E.S. = (PHD-Q)(150)				
Q = source production in gpm				
Added for fire storage (500 gpm for 30 minutes) for single-family residential homes			0	gal
Add min. standby storage based on	200	gpd/ERU	0	gal
Total required storage		[1+2+3]	66,083	gal
Allowance for filter backwash		add	0	gal
Allowance for operating and dead storage (1 ft)		add	3,333	gal
		TOTAL	69,417	gal
Existing storage				
1 Everett Brothers octagon, 12 ft height			40,000	gal
Required added storage:			29,417	gal

CAL WATERWORKS

CALCULATIONS

[d] RESERVOIR SIZING

Required storage for ultimate number of customers in retail and wholesale service area, assumed 800 gpd/ERU MDD (no water conservation), credit towards standby storage from multiple sources of supply and emergency intertie with Freeland Water District, and criteria in the WA DOH August 2001 "Water System Design Guidelines".

Allowable number of service connections:			155	
Number of wells:			2	
Well production capacities (current, throttled to match water rights):			90	gpm
Peak Hour Demand (PHD):			232	gpm
Maximum Day Demand (MDD) based on	800	gpd/ERU	124,000	gal/day
Required minimum continuous well production			86	gpm (avg)
Minimum standby storage based on MDD			124,000	gal
800 gal/connection [D.O.H.]				
Credit for multiple well source		less	124,000	gal
90 gpm (with emergency intertie)				
Equalizing storage: whenever source pumping capacity cannot meet peak demands [D.O.H.]			21,283	gal
E.S. = (PHD-Q)(150)				
Q = source production in gpm				
Added for fire storage (500 gpm for 30 minutes) for single-family residential homes			15,000	gal
Add min. standby storage based on	200	gpd/ERU	16,000	gal
Total required storage		[1+2+3]	52,283	gal
Allowance for filter backwash		add	0	gal
Allowance for operating and dead storage (1 ft)		add	3,333	gal
		TOTAL	55,617	gal
Existing storage				
1 Everett Brothers octagon, 12 ft height			40,000	gal
Required added storage:			15,617	gal

CAL WATERWORKS


CALCULATIONS

**[a] BOOSTER PUMP SIZING - PROPOSED SYSTEM, CAL + GLA ZONE 1, 145 ERUs**

Number of ERUs:	145	Number of pumps to meet PHD:	2	
Recorded MDD:	800 gpd/ERU	PHD based on MDD:	221	gpm
		[ PHD = (MDD/1440)*(C*N+F)+18 ]		
1) Required capacity			110	gpm
2) Required pressure at pump house (from network analysis)				
Pump "on" pressure	62 psi		143	ft
Minus water level in reservoir (pump 'on'):			-11	ft
Plus equalizing storage allowance:			9	ft
4) Contingency allowance			5	ft
			<hr/>	
Head required at	110 gpm :		146	ft
			63	psi @ pump
6) Pressure range of hydropneumatic tank				
Pump "off" minus pump "on" pressure	20 psi		46	ft
7) Allowance for positive pump shut off			10	ft
			<hr/>	
Shutoff head	0 gpm :		202	ft
Approx. motor size				
[ hp = (Q x H)/(3960 x eff.) ]	6.8	hp @ 60% efficiency		
Existing pump:				
		Head	Flow	
GOULDS 3656, 10 HP, 6.5" Impelle Pump on	175	ft	110	gpm
	185	ft	0	gpm


Notes: See attached pump curve and computer analysis results  
 Pump specifications are included in the Project Report accompanying this WSP

**Performance Curves – 60 Hz, 3500 RPM**  
**Curvas de desempeño – 60 Hz, 3500 RPM**



Optional Impeller Impulsor optativo	
Ordering Code Código de pedido	Dia. Diá.
A	8 1/16"
E	7 3/4"
B	7 1/8"
F	7"
C	6 3/4"
G	6 1/4"
H	6 1/8"
D	5 1/4"

NOTE: Pump will pass a sphere to 7/16" diameter.  
 NOTA: La bomba dejará pasar una esfera de hasta 7/16 de pulgada de diámetro.



Optional Impeller Impulsor optativo	
Ordering Code Código de pedido	Dia. Diá.
A	7 1/16"
B	6 3/8"
C	6 1/16"
D	6"
E	5 1/16"
F	5 7/16"
G	5 3/16"
H	4 3/4"
J	4 1/2"
K	4 1/16"

NOTE: Pump will pass a sphere to 7/16" diameter.  
 NOTA: La bomba dejará pasar una esfera de hasta 7/16 de pulgada de diámetro.

CAL WATERWORKS

CALCULATIONS

**[b] BOOSTER PUMP SIZING - PROPOSED SYSTEM, CAL ZONE 2, 10 ERUs**

Number of ERUs:	10	Number of pumps to meet PHD:	1
Design MDD:	800 gpd/ERU	PHD based on MDD:	35 gpm
		[ PHD = (MDD/1440)*(C*N+F)+18 ]	

1) Required capacity 35 gpm

2) Required pressure at pump house (from network analysis)

Pump "on" pressure	94 psi	217 ft
Minus water level in reservoir (pump "on"):		-11 ft
Plus equalizing storage allowance:		3 ft

4) Contingency allowance 5 ft

Head required at	35 gpm :	214 ft
		93 psi @ pump

6) Pressure range of hydropneumatic tank

Pump "off" minus pump "on" pressure	20 psi	46 ft
-------------------------------------	--------	-------

7) Allowance for positive pump shut off 10 ft

Shutoff head	0 gpm :	270 ft
--------------	---------	--------

Approx. motor size

[ hp = (Q x H)/(3960 x eff.) ] 3.1 hp @ 60% efficiency

Recommended pump:

		Head	Flow
GOULDS 33 GB, 13 stage, 3 hp	Pump on	220 ft	35 gpm
		400 ft	0 gpm



Notes: See attached pump curve.  
 Pump specifications are included in the Project Report accompanying this WSP



**ITT**

**GOULDS PUMPS**  
 Residential Water Systems

**33GB PERFORMANCE CURVES**



CAL WATERWORKS

CALCULATIONS

**PEAK HOUR DEMAND AND AVERAGE MAXIMUM DAY DEMAND FOR SYSTEM DESIGN**

- (a) **ERUs** 128 CAL Waterworks current number of counted lots, considering combined lots.  
**MDD** 800 Assumed MDD

$$PHD = (MDD/1440)*(C*N+F)+18 = 201.9 \text{ gpm}$$

Range of ERUs (N)	C	F	C	F
15 to 50	3.0	0	0.0	0
51 to 100	2.5	25	0.0	0
101 to 250	2.0	75	2.0	75
251 to 500	1.8	125	1.8	0
> 500	1.6	225	0.0	0
	for calc. -->		2.0	75

$$\text{Average MDD} = MDD*ERUs/1440 = 71 \text{ gpm} \quad 35\% \text{ of PHD} \quad \text{Say } 40\%$$

- (b) **ERUs** 128 CAL Waterworks current number of counted lots, considering combined lots.  
**MDD** 388 Recorded MDD

$$PHD = (MDD/1440)*(C*N+F)+18 = 107.2 \text{ gpm}$$

$$\text{Average MDD} = MDD*ERUs/1440 = 34 \text{ gpm} \quad 32\% \text{ of PHD}$$

- (c) **ERUs** 155 Ultimate number of lots in CAL Waterworks (128) plus GLA (27)  
**MDD** 800 Assumed MDD

$$PHD = (MDD/1440)*(C*N+F)+18 = 231.9 \text{ gpm}$$

$$\text{Average MDD} = MDD*ERUs/1440 = 86 \text{ gpm} \quad 37\% \text{ of PHD}$$

- (d) **ERUs** 155 Ultimate number of lots in CAL Waterworks (128) plus GLA (27)  
**MDD** 600 Assumed MDD

$$PHD = (MDD/1440)*(C*N+F)+18 = 178.4 \text{ gpm}$$

$$\text{Average MDD} = MDD*ERUs/1440 = 65 \text{ gpm} \quad 36\% \text{ of PHD}$$

- (e) **ERUs** 208 Number of connections for design with CAL Water Rights of 90 gpm and  
**MDD** 600 conservation reducing MDD to long-range conservation goal

$$PHD = (MDD/1440)*(C*N+F)+18 = 222.6 \text{ gpm}$$

$$\text{Average MDD} = MDD*ERUs/1440 = 87 \text{ gpm} \quad 39\% \text{ of PHD}$$



CAL WATERWORKS

CALCULATIONS

**DISTRIBUTION OF DEMAND**

**CAL Waterworks with wholesale supply to Goss Lakeridge Acres**

Platted lots 128 CAL Waterworks Current count with combined lots  
 27 Goss Lakeridge Acres

Peak Hour Demand for 155 ERUs

{i}	231.9	gpm for an assumed Maximum Day Demand of	800	gpm/ERU	100% of {i}
{ii}	178.4	gpm for an assumed Maximum Day Demand of	600	gpm/ERU	77%

Peak Hour Demand for 208 ERUs (for possible future expansion of service area)

{iii}	222.6	gpm for an assumed Maximum Day Demand of	600	gpm/ERU	96%
-------	-------	--	-----	---------	-----

**DEMAND DISTRIBUTION**

**155 ERUs, 232 gpm PHD**

Node	ERUs	Demand (gpm)			
1	0	0	Pressure Zone 1	123	ERUs
2	0	0	Pressure Zone 2	10	ERUs
3	0	0	Pressure Zone 3	22	ERUs
4	0	0			
5	0	0			
6	9	14			
7	0	0			
8	0	0			
9	12	19			
10	23	36			
11	6	9			
12	39	62			
13	0	0			
14	0	0			
15	20	31			
16	5	8			
17	4	6			
51	0	0			
52	0	0			
53	3	5			
54	6	9			
55	1	3			
72	5	5	} GLA 27 lots		
75	7	7			
76	5	5			
77	10	13			
<b>Total</b>	<b>155</b>	<b>232</b>			

**NETWORK ANALYSIS - COMPUTER PROGRAM DATA**  
**Initial Input - November 2007 System**

Program Input Codes:

0	1	0.001	1	1	1	1
2	1	5	1			
24	22					

Pipe Data:

Pipe No.	Between Nodes	Length (feet)	Diameter (inches)	H-W Coefficient		
1	1 2	20	4	140	8"Ø replacement size	
2	2 3	20	4	140	8"Ø replacement size	
3	3 4	10	3	140	Booster pump (Zone 1)	
4	4 5	20	4	140	8"Ø replacement size	
5	5 6	600	2	140		
6	5 7	360	4	140	8"Ø replacement size	
7	7 8	1760	6	140		
8	8 9	160	4	140	6"Ø replacement size	
9	9 13	1550	3	140	6"Ø replacement size	
10	9 10	570	3	140	6"Ø replacement size	
11	10 11	125	3	140		
12	10 12	180	3	140	6"Ø replacement size	
13	13 12	1500	3	140		
14	13 14	200	3	140	6"Ø replacement size	
15	14 15	1450	3	140		
16	12 15	200	3	140		
17	15 16	160	3	140		
18	14 17	420	2	140		
51	4 51	10	2	140		
52	51 52	10	2	140	Booster pump (Zone 2; now supplied from Zone 1)	
53	52 53	840	2	140		
54	53 54	820	2	140		
55	53 55	390	2	140		
70	14 70	3050	6	140.1	} Proposed extension for intertie	
71	70 71	10	2	99.1		} Meter & DCVA
72	71 72	565	4	140.1	} Proposed supply to pump station	
73	72 73	685	4	140.1		
74	73 74	10	2	140.1	Proposed pump station (Zone 3)	
75	74 75	980	4	140	} Existing water mains	
76	75 76	635	4	140		
77	75 77	970	3	140		
99	52 54	9999	0.5	99	Pseudo pipe	

CAL WATERWORKS

CALCULATIONS

Input Data (continued)

Node No.	Demand (gpm)	Elevation (feet)	Notes:	Note:	
1	0	150	Reservoir	H-W Coefficient ending in 0.1 indicates new water main	
2	0	150			
3	0	150		Assumed H-W Coefficients	
4	0	150			140 PVC & Lined DI pipe
5	0	150			120 Asbestos cement pipe
6	14	145			100 Unlined CI, Galv Stl or unknown
7	0	135			
8	0	140			99 Pseudo pipe
9	19	140			140.1 New water mains
10	36	120			140.2 Replacement water mains
11	9	120			
12	62	120			
13	0	145			
14	0	145			
15	31	120			
16	8	120			
17	6	130			
51	0	150	} Pressure zone 2		
52	0	150			
53	5	155			
54	9	250			
55	3	170			
70	0	145	} Pressure zone 3		
71	0	145			
72	0	165			5
73	0	205			0
74	0	205			0
75	0	215			7
76	0	165			5
77	0	320			13
				} Goss Lakeridge Acres	
Total	202			Total	30

CAL WATERWORKS

CALCULATIONS

Input Data (continued)

Program Input Codes:

1        2        0        0        0  
 3

Source Pump Data:

1	1	Reservoir		Node No.; No. of Pump (Operating as reservoir)
	0	100	1000	Flow (gpm)
	11	11	11	Head (feet), height of water in 12 ft high reservoir
3	1	Ex. Booster pump to Zone 1		Pipe No.; No. of Pumps operating
	0	100	140	Flow (gpm) Ex. STA-RITE DHJ 5 HP
	162	135	105	Head (feet)
52	1	Ex. Booster pump to Zone 2		Pipe No.; No. of Pumps operating
	0	20	40	Flow (gpm) STA-RITE HMS 1.5 HP
	170	150	110	Head (feet)
74	1	Proposed GLA pump station		Pipe No.; No. of Pumps operating
	0	50	100	Flow (gpm)
	160	160	160	Head (feet), assumed pump "on" pressure

Note: Ex. Pump to Zone 2 is supplied from discharge of pump to Zone 1.

CAL Waterworks, Existing Distribution System Inventory:

	Length of Mains (feet)						total
	< 2"	2" & 2.5"	3"	4"	6"	8"	
Ductile Iron	0	0	0	0	0	0	0
PVC or HDPE	0	3,070	5,935	540	1,760	0	11,305
Asbestos Cement	0	0	0	0	0	0	0
Steel	0	0	0	0	0	0	0
Galv. Steel	0	0	0	0	0	0	0
Cast Iron	0	0	0	0	0	0	0
Sub-total	0	3,070	5,935	540	1,760	0	
							total 11,305

CAL WATERWORKS

CALCULATIONS

NETWORK ANALYSIS

7/29/2008

[a] PHD for 155 ERUs, EX. CAL BOOSTER PUMPS, NEW GLA BOOSTER PUMPS  
 EX. CAL DISTRIBUTION SYSTEM, NEW WHOLESALE INTERTIE TO GLA  
 EX. GLA DISTRIBUTION SYSTEM DOWNSTREAM OF BOOSTER PUMPS

File: J601ay

Source Reservoir:

Node No.	No. of Pumps	Elev. of Pumps	Pumps Flows and Related Heads (height of water in reservoir)			
			0	100	1000	Reservoir
1	1	150	11	11	11	Height of water (full)

Booster Pumps:

Pipe No.	No. of Pumps	Pumps Flows and Related Heads (pump curve)			
		0	100	140	Booster Pump, Pressure Zone 1
3	2	162	135	105	STA-RITE DHJ 5 HP
		0	20	40	Booster Pump, Pressure Zone 2
52	1	170	150	110	STA-RITE HMS 1.5 HP
		0	50	100	Booster Pump, Pressure Zone 3 GLA
74	1	175	175	175	Required "pump on" TDH

Pressure Reducing Valves:

PRV No.	Pipe No.	Ref. Node	Downstream HGL	K-value	CV feature
none					

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
4	1	2	1	232.0	0.6	5.9	161.0	
4	2	3	2	232.0	0.6	5.9	160.4	
3	3	4	3	232.0	-121.7	10.5	159.8	Pump
4	4	5	4	215.0	0.5	5.5	281.5	(Zone 1)
2	5	6	5	14.0	3.0	1.4	280.9	
4	5	7	6	201.0	8.6	5.1	280.9	
6	7	8	7	201.0	5.9	2.3	272.3	
4	8	9	8	201.0	3.8	5.1	266.4	
3	9	13	9	67.7	20.1	3.1	262.6	
3	9	10	10	114.3	19.5	5.2	262.6	
3	10	11	11	9.0	0.0	0.4	243.1	
3	10	12	12	69.3	2.4	3.2	243.1	
3	13	12	13	18.9	1.8	0.9	242.5	

CAL WATERWORKS

CALCULATIONS

[a] PHD for 155 ERUs, EX. CAL BOOSTER PUMPS, NEW GLA BOOSTER PUMPS

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
3	13	14	14	48.8	1.4	2.2	242.5	
3	14	15	15	12.8	0.9	0.6	241.1	
3	12	15	16	26.2	0.5	1.2	240.7	
3	15	16	17	8.0	0.0	0.4	240.2	
2	14	17	18	6.0	0.4	0.6	241.1	
2	4	51	51	17.0	0.1	1.7	281.5	
2	51	52	52	17.0	-152.9	1.7	281.4	Pump
2	52	53	53	16.9	6.0	1.7	434.3	(Zone 2)
2	53	54	54	8.9	1.8	0.9	428.3	
2	53	55	55	3.0	0.1	0.3	428.3	
6	14	70	70	30.0	0.3	0.3	241.1	
2	70	71	71	30.0	19.6	3.1	240.8	Meter/DCVA
4	71	72	72	30.0	0.4	0.8	221.1	
4	72	73	73	25.0	0.4	0.6	220.7	
2	73	74	74	25.0	-174.9	2.6	220.4	Pump
4	74	75	75	25.0	0.5	0.6	395.2	(Zone 3)
4	75	76	76	5.0	0.0	0.1	394.8	
3	75	77	77	13.0	0.6	0.6	394.8	
0.5	52	54	99	0.1	8.0	0.2	434.3	

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)		Static Pressure	
						Pump on (psi)	Pump off (psi)
1	150	-232.0	161.0	4.8	Reservoir	NA	NA
2	150	0.0	160.4	4.5		NA	NA
3	150	0.0	159.8	4.2		NA	NA
4	150	0.0	281.5	56.9	Booster Pump	45.0	65.0
5	150	0.0	280.9	56.7		45.0	65.0
6	145	14.0	277.9	57.5		47.2	67.2
7	135	0.0	272.3	59.4		51.5	71.5
8	140	0.0	266.4	54.7		49.3	69.3
9	140	19.0	262.6	53.1		49.3	69.3
10	120	36.0	243.1	53.3		58.0	78.0
11	120	9.0	243.1	53.3		58.0	78.0
12	120	62.0	240.7	52.2		58.0	78.0
13	145	0.0	242.5	42.2		47.2	67.2
14	145	0.0	241.1	41.6		47.2	67.2
15	120	31.0	240.2	52.0		58.0	78.0
16	120	8.0	240.2	52.0		58.0	78.0
17	130	6.0	240.6	47.9		53.7	73.7

CAL WATERWORKS

CALCULATIONS

[a] PHD for 155 ERUs, EX. CAL BOOSTER PUMPS, NEW GLA BOOSTER PUMPS

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)		Static Pressure	
						Pump on (psi)	Pump off (psi)
51	150	0.0	281.4	56.9		45.0	65.0
52	150	0.0	434.3	123.1	Booster Pump	75.0	95.0
53	155	5.0	428.3	118.3	} see pump "on" & "off" pressure settings	72.8	92.8
54	250	9.0	426.4	76.3		31.7	51.7
55	170	3.0	428.2	111.8		66.3	86.3
70	145	0.0	240.8	41.5		47.2	67.2
71	145	0.0	221.1	33.0	Meter & DCVA	47.2	67.2
72	165	5.0	220.7	24.1		38.5	58.5
73	205	0.0	220.4	6.7	GLA pump suction	21.2	41.2
74	205	0.0	395.2	82.4	Required discharge	83.0	103.0
75	215	7.0	394.8	77.8		78.7	98.7
76	165	5.0	394.7	99.5		100.3	120.3
77	320	13.0	394.2	32.1		33.2	53.2

Maximum unbalanced head in any loop      0.1762      In loop # 1

**NETWORK ANALYSIS**

7/31/2008

**[b] 500 GPM FIRE FLOW AT NODE 12, UPGRADED CAL BOOSTER PUMPS, NEW GLA** File: J601bx  
**BOOSTER PUMPS, UPGRADED CAL DISTRIBUTION SYSTEM, NEW WHOLESALE INTERTIE**  
**TO GLA, EX. GLA DISTRIBUTION SYSTEM DOWNSTREAM OF BOOSTER PUMPS**

Source Reservoir:

Node No.	No. of Pumps	Elev. of Pumps	Pumps Flows and Related Heads (height of water in reservoir)			
			0	100	1000	
1	1	150	5	5	5	Reservoir Height of water (1/2 full)

Booster Pumps:

Pipe No.	No. of Pumps	Pumps Flows and Related Heads (pump curve)			
		0	150	200	
3	4	185	155	112	Booster Pump, Pressure Zone 1 Goulds 3656 10 HP, 6.5" Impeller
52	1	200	200	200	Booster Pump, Pressure Zone 2 Assumed pump on pressure (90 psi)
74	1	175	175	175	Booster Pump, Pressure Zone 3 GLA Required "pump on" TDH

Pressure Reducing Valves:

PRV No.	Pipe No.	Ref. Node	Downstream HGL	K-value	CV feature
none					

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
8	1	2	1	592.8	0.1	3.8	155.0	
8	2	3	2	586.0	0.1	3.7	154.9	
3	3	4	3	586.0	-148.6	26.6	154.8	Pump
8	4	5	4	586.0	0.1	3.7	303.4	(Zone 1)
2	5	6	5	5.6	0.6	0.6	303.3	
8	5	7	6	580.4	2.1	3.7	303.3	
6	7	8	7	580.4	41.7	6.6	301.2	
6	8	9	8	580.4	3.8	6.6	259.4	
6	9	13	9	107.7	1.6	1.2	255.7	
6	9	10	10	465.1	9.0	5.3	255.7	
3	10	11	11	3.6	0.0	0.2	246.7	
6	10	12	12	447.1	2.6	5.1	246.7	
3	13	12	13	47.1	10.0	2.1	254.0	



CAL WATERWORKS

CALCULATIONS

[b] 500 GPM FIRE FLOW AT NODE 12, UPGRADED CAL BOOSTER PUMPS, NEW GLA

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
6	13	14	14	60.6	0.1	0.7	254.0	
3	14	15	15	46.2	9.3	2.1	254.0	
3	12	15	16	-30.6	-0.6	-1.4	244.1	
3	15	16	17	3.2	0.0	0.2	244.7	
2	14	17	18	2.4	0.1	0.3	254.0	
2	2	51	51	6.8	0.0	0.7	154.9	
2	51	52	52	6.8	-200.0	0.7	154.9	Pump
2	52	53	53	6.8	1.1	0.7	354.9	(Zone 2)
2	53	54	54	3.6	0.3	0.4	353.8	
2	53	55	55	1.2	0.0	0.1	353.8	
6	14	70	70	12.0	0.1	0.1	254.0	
2	70	71	71	12.0	18.0	1.2	253.9	Meter/DCVA
4	71	72	72	12.0	0.1	0.3	235.9	
4	72	73	73	10.0	0.1	0.3	235.8	
2	73	74	74	10.0	-175.0	1.0	235.8	Pump
4	74	75	75	10.0	0.1	0.3	410.8	(Zone 3)
4	75	76	76	2.0	0.0	0.1	410.7	
3	75	77	77	5.2	0.1	0.2	410.7	
0.5	52	54	99	0.0	2.0	0.1	354.9	

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)	
1	150	-592.8	155.0	2.2	Reservoir
2	150	0.0	154.9	2.1	
3	150	0.0	154.8	2.1	
4	150	0.0	303.4	66.4	Booster Pump
5	150	0.0	303.3	66.4	
6	145	5.6	302.7	68.3	
7	135	0.0	301.2	71.9	
8	140	0.0	259.4	51.7	
9	140	7.6	255.7	50.1	
10	120	14.4	246.7	54.9	
11	120	3.6	246.7	54.9	
12	120	524.8	244.1	53.7	← Fire Flow
13	145	0.0	254.0	47.2	
14	145	0.0	254.0	47.2	
15	120	12.4	244.7	54.0	
16	120	3.2	244.7	54.0	
17	130	2.4	253.9	53.6	

CAL WATERWORKS

CALCULATIONS

[b] 500 GPM FIRE FLOW AT NODE 12, UPGRADED CAL BOOSTER PUMPS, NEW GLA

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)	
51	150	0.0	154.9	2.1	
52	150	0.0	354.9	88.7	Booster Pump
53	155	2.0	353.8	86.0	
54	250	3.6	352.9	44.6	
55	170	1.2	353.7	79.5	
70	145	0.0	253.9	47.1	
71	145	0.0	235.9	39.4	Meter & DCVA
72	165	2.0	235.8	30.7	
73	205	0.0	235.8	13.3	GLA pump suction
74	205	0.0	410.8	89.1	Required discharge
75	215	2.8	410.7	84.7	
76	165	2.0	410.7	106.3	
77	320	5.2	410.6	39.2	

Maximum unbalanced head in any loop                      0.5246    In loop # 1

CAL WATERWORKS

CALCULATIONS

**NETWORK ANALYSIS**

7/31/2008

**[c] PHD FOR 155 ERUs, UPGRADED CAL BOOSTER PUMPS (1 of 4 pumping), NEW GLA** File: J601cz  
**BOOSTER PUMPS, UPGRADED CAL DISTRIBUTION SYSTEM, NEW WHOLESALE INTERTIE**  
**TO GLA, EX. GLA DISTRIBUTION SYSTEM DOWNSTREAM OF BOOSTER PUMPS**

Source Reservoir:

Node No.	No. of Pumps	Elev. of Pumps	Pumps Flows and Related Heads (height of water in reservoir)			
			0	100	1000	Reservoir
1	1	150	10	10	10	Height of water (full)

Booster Pumps:

Pipe No.	No. of Pumps	Pumps Flows and Related Heads (pump curve)			
		0	150	200	Booster Pump, Pressure Zone 1
3	1	185	155	112	Goulds 3656 10 HP, 6.5" Impeller
		0	20	40	Booster Pump, Pressure Zone 2
52	1	200	200	200	Assumed pump on pressure (90 psi)
		0	50	100	Booster Pump, Pressure Zone 3 GLA
74	1	175	175	175	Required "pump on" TDH

Pressure Reducing Valves:

PRV No.	Pipe No.	Ref. Node	Downstream HGL	K-value	CV feature
none					

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
8	1	2	1	232.0	0.0	1.5	160.0	
8	2	3	2	215.0	0.0	1.4	160.0	
3	3	4	3	215.0	-110.9	9.8	160.0	Pump
8	4	5	4	215.0	0.0	1.4	270.9	(Zone 1)
2	5	6	5	14.0	3.0	1.4	270.8	
8	5	7	6	201.0	0.3	1.3	270.8	
6	7	8	7	201.0	5.9	2.3	270.5	
6	8	9	8	201.0	0.5	2.3	264.7	
6	9	13	9	56.8	0.5	0.6	264.2	
6	9	10	10	125.2	0.8	1.4	264.2	
3	10	11	11	9.0	0.0	0.4	263.4	
6	10	12	12	80.2	0.1	0.9	263.4	
3	13	12	13	8.3	0.4	0.4	263.7	

CAL WATERWORKS

CALCULATIONS

[c] PHD FOR 155 ERUs, UPGRADED CAL BOOSTER PUMPS (1 of 4 pumping), NEW GLA

Pipe Flows:

Pipe Dia. (inches)	Upstrm. Node	Dnstrm. Node	Pipe No.	Flow (gpm)	Head loss (feet)	Velocity (fps)	Upstrm. HGL (feet)	
6	13	14	14	48.4	0.1	0.6	263.7	
3	14	15	15	12.4	0.8	0.6	263.6	
3	12	15	16	26.6	0.5	1.2	263.3	
3	15	16	17	8.0	0.0	0.4	262.8	
2	14	17	18	6.0	0.4	0.6	263.6	
2	2	51	51	17.0	0.1	1.7	160.0	
2	51	52	52	17.0	-199.9	1.7	159.9	Pump
2	52	53	53	16.9	6.0	1.7	359.8	(Zone 2)
2	53	54	54	8.9	1.8	0.9	353.8	
2	53	55	55	3.0	0.1	0.3	353.8	
6	14	70	70	30.0	0.3	0.3	263.6	
2	70	71	71	30.0	19.6	3.1	263.3	Meter/DCVA
4	71	72	72	30.0	0.4	0.8	243.7	
4	72	73	73	25.0	0.4	0.6	243.3	
2	73	74	74	25.0	-174.9	2.6	242.9	Pump
4	74	75	75	25.0	0.5	0.6	417.8	(Zone 3)
4	75	76	76	5.0	0.0	0.1	417.3	
3	75	77	77	13.0	0.6	0.6	417.3	
0.5	52	54	99	0.1	8.0	0.2	359.8	

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)	
1	150	-232.0	160.0	4.3	Reservoir
2	150	0.0	160.0	4.3	
3	150	0.0	160.0	4.3	
4	150	0.0	270.9	52.3	Booster Pump
5	150	0.0	270.8	52.3	
6	145	14.0	267.8	53.2	
7	135	0.0	270.5	58.7	
8	140	0.0	264.7	54.0	
9	140	19.0	264.2	53.8	
10	120	36.0	263.4	62.1	
11	120	9.0	263.3	62.1	
12	120	62.0	263.3	62.0	
13	145	0.0	263.7	51.4	
14	145	0.0	263.6	51.4	
15	120	31.0	262.8	61.8	
16	120	8.0	262.8	61.8	
17	130	6.0	263.2	57.7	

CAL WATERWORKS

CALCULATIONS

[c] PHD FOR 155 ERUs, UPGRADED CAL BOOSTER PUMPS (1 of 4 pumping), NEW GLA

Node Pressures:

Node No.	Elevation (feet)	Demand (gpm)	HGL (feet)	Pressure (psi)	
51	150	0.0	159.9	4.3	
52	150	0.0	359.8	90.8	Booster Pump
53	155	5.0	353.8	86.1	
54	250	9.0	351.9	44.1	
55	170	3.0	353.7	79.5	
70	145	0.0	263.3	51.2	
71	145	0.0	243.7	42.7	
72	165	5.0	243.3	33.9	Meter & DCVA
73	205	0.0	242.9	16.4	GLA pump suction
74	205	0.0	417.8	92.1	
75	215	7.0	417.3	87.6	
76	165	5.0	417.3	109.2	
77	320	13.0	416.7	41.9	

Maximum unbalanced head in any loop      0.1762      In loop # 1

CAL WATERWORKS

CALCULATIONS

[c] BOOSTER PUMP SIZING CHECK - EXISTING SYSTEM, CAL 99 ERUs

Number of ERUs:	99	Number of pumps to meet PHD:	1	
Recorded MDD:	388 gpd/ERU	PHD based on MDD:	91	gpm
		[ PHD = (MDD/1440)*(C*N+F)+18 ]		
1) Required capacity			91	gpm
2) Required pressue at pump house (from network analysis)				
Pump "on" pressure	45 psi		104	ft
Minus water level in reservoir (pump 'on'):			-11	ft
Plus equalizing storage allowance:			3	ft
4) Contingency allowance			<u>5</u>	ft
	Head required at	91 gpm :	101	ft
			44	psi @ pump
6) Pressure range of hydropneumatic tank				
Pump "off" minus pump "on" pressu	20 psi		46	ft
7) Allowance for positive pump shut off			<u>10</u>	ft
	Shutoff head	0 gpm :	157	ft
Approx. motor size				
[ hp = (Q x H)/(3960 x eff.) ]		3.9 hp @ 60% efficiency		
Existing pump:				
STA-RITE Model DJH 5 hp	Pump on	Head	Flow	
		101 ft	145 gpm	
		162 ft	0 gpm	

Notes: See pump curve in Appendix H

CAL WATERWORKS

CALCULATIONS

**[d] BOOSTER PUMP SIZING CHECK - EXISTING SYSTEM, CAL + GLA 114 ERUs**

Number of ERUs:	114	Number of pumps to meet PHD:	1
Design MDD:	600 gpd/ERU	PHD based on MDD:	144 gpm
		[ PHD = (MDD/1440)*(C*N+F)+18 ]	

1) Required capacity 144 gpm

2) Required pressure at pump house (from network analysis)

Pump "on" pressure	45 psi	104 ft
Minus water level in reservoir (pump "on"):		-11 ft
Plus equalizing storage allowance:		3 ft

4) Contingency allowance 5 ft

Head required at	144 gpm :	101 ft
		44 psi @ pump

6) Pressure range of hydropneumatic tank

Pump "off" minus pump "on" pressure	20 psi	46 ft
-------------------------------------	--------	-------

7) Allowance for positive pump shut off 10 ft

Shutoff head	0 gpm :	157 ft
--------------	---------	--------

Approx. motor size  
 [ hp = (Q x H)/(3960 x eff.) ] 6.1 hp @ 60% efficiency

Existing pump:

		Head	Flow
STA-RITE Model DJH 5 hp	Pump on	101 ft	145 gpm
		162 ft	0 gpm

Notes: The Goss Lakeridge Acres 2001 record of daily summer source meter meter readings showed a MDD of 756 gpd/ERU (See submittal of December 10, 2001 to WA DOH). The weighted average of the CAL Waterworks MDD (388 gpd/ERU for 96 ERUs) and Goss Lakeridge Acres MDD, would be 426 gpd/ERU. To be conservative, a MDD of 600 gpd/ERU was assumed.

See pump curve in Appendix H

**[a] HYDROPNEUMATIC TANK SIZING, CHECK FOR EXISTING PUMP**  
**Twin STA-RITE DHJ 5 hp**

**Horizontal Tank Formula:**

$$V_t = \frac{[P1 + 14.7]}{[P1 - P2]} * \frac{15}{N} * Q_p * M_f$$

**Vertical Tank (non-bladder) Formula:**

$$V_t = \frac{[P1 + 14.7]}{[P1 - P2]} * \frac{15}{N} * Q_p * M_f + 0.024D^2$$

**Bladder Tank Formula:**

$$T_s * V_b = \frac{15 * (P1 + 14.7) * (P2 + 14.7)}{(P1 - P2) * (P2 + 9.7)} * \frac{Q_p}{N}$$

- Vt total volume of tank (gallons)
- P1 pump off setting (psi)
- P2 pump on setting (psi)
- N pump operating cycle of 6 per hour per pump
- Qp pump delivery capacity at midpoint of pressure range (gpm)
- Mf multiplying factor related to tank size
- D tank diameter (inches)
- Vb volume of individual bladder tank (gallons)
- Ts number of bladder tanks of size Vb

**Design Parameters:**

P1 = 65 psi    P2 = 45 psi    Qp = 200 gpm  
 150 ft    104 ft    100 gpm each pump

N = 12    Mf = 1.13    for tank diameter 36 inches  
 (alternating)

**Required Capacity:**

Horizontal		Vertical
Vt :	1,126 gallons	Vt : 1,023 gallons
Bladder		Individual bladder tank volume
Ts*Vb :	1,087 gallons	not to exceed 120 gallons

**Existing tanks:**    three    315 gallon 36"Ø x 60" (80" o.a.)    945 gallons







CAMANO HILLS WATER COMPANY

BUDGET COST ESTIMATE

**REPLACEMENT BOOSTER PUMP STATION**

Two pumped zones, 500 gpm fire flow in zone 1

ITEM	QUANTITY	UNIT COST	COST
1 Mobilization, demolization	1 ea	\$ 55,000	\$ 55,000
2 Wood frame buildings, 22 ft x 20 ft	440 sf	\$ 80	\$ 35,200
3 Piping within building	[a] 1 job	\$ 2,600	\$ 2,600
4 5 hp Pumps for Zone 1	[b] 4 ea	\$ 2,850	\$ 11,400
5 3 hp Pumps for Zone 2	[b] 2 ea	\$ 2,500	\$ 5,000
6 2,050 gallon hydropneumatic tank (Zone 1)	1 ea	\$ 12,000	\$ 12,000
7 119 gallon bladder tanks (Zone 2)	3 ea	\$ 960	\$ 2,880
8 Miscellaneous valves & gauges	[a] 1 job	\$ 3,100	\$ 3,100
9 Installation 3 to 8	1 job	\$ 10,000	\$ 10,000
10 Electrical within building	1 job	\$ 7,000	\$ 7,000
11 Electrical generator with propane tank	1 job	\$ 31,000	\$ 31,000
12 New PSE power supply from E. Harbor Rd	1 job	\$ 5,000	\$ 5,000
13 Yard piping materials & installation	1 job	\$ 8,000	\$ 8,000
14 New Utility Vault well enclosure, Well # 1	1 ea	\$ 2,400	\$ 2,400
15 New source meters in pump house	[b] 2 ea	\$ 650	\$ 1,300
16 New hypochlorinator	[b] 1 ea	\$ 900	\$ 900
17 Yard security fence	370 ft	\$ 18	\$ 6,660
18 County, WA DOH & WA L&I fees	allowance		\$ 2,000
Sub-total			\$ 201,440
Tax			8.3% \$ 16,720
Contingency			15% \$ 30,216
Inspection			\$ 1,000
Project Report			\$ 3,500
			<b>\$ 252,876</b>

Notes:

- [a] From 2007 Skagit Co. W.D. No. 1 project
- [b] From Camano Hills Water Co 2008 project
- [c] H. D. Fowler, August 2008

CAMANO HILLS WATER COMPANY

BUDGET COST ESTIMATE

**WATER MAIN REPLACEMENT, TO & ALONG E. HARBOR ROAD**

ITEM	QUANTITY	UNIT COST	COST
1 Mobilization, demolition	1 job	\$ 6,000	\$ 6,000
2 Traffic control and trench safety	1 job	\$ 3,200	\$ 3,200
3 8" PVC pipe c/w sand bedding, native backfill	360 ft	\$ 54	\$ 19,440
4 6" PVC pipe c/w sand bedding, native backfill	1,980 ft	\$ 45	\$ 89,100
5 Granular backfill (allow 10% of length in fog line)	43.3 cy	\$ 9	\$ 390
6 8" gate valve c/w valve box	1 ea	\$ 1,500	
7 6" gate valve c/w valve box	2 ea	\$ 1,200	\$ 2,400
8 6 & 8" DI fittings	383 lbs	\$ 3	\$ 1,149
9 Air release valve assemblies	1 ea	\$ 1,250	\$ 1,250
10 Blow-off assemblies	0 ea	\$ 1,250	\$ -
11 Fire hydrant	2 ea	\$ 3,500	\$ 7,000
12 Pavement cut & replacement (road X-ings)	72 sf	\$ 15	\$ 1,080
13 Road X-ing casing pipe c/w spacers	24 ft	\$ 80	\$ 1,920
14 CDF for casing pipe road crossings	4.4 cy	\$ 85	\$ 378
15 Service replacement to existing meter	0 ea	\$ 550	\$ -
16 Pressure test and disinfection	1 job	\$ 2,500	\$ 2,500

Notes:

Unit costs from low bid to Del Mar, 2007 with adjustment for 8" PVC pipe at \$11.19/ft vs 8" DI at \$24.22/ft: prices from H.D. Fowler Aug-08

Sub-total		\$ 135,807
Tax	8.3%	\$ 11,272
Contingency	15%	\$ 20,371
Surveyor (for base plan)		\$ 4,000
Construction plans		\$ 2,000
Inspection		\$ 2,000
		<b>\$ 175,450</b>

cost per foot \$ 74.98

CAMANO HILLS WATER COMPANY

BUDGET COST ESTIMATE

**WATER MAIN REPLACEMENT, BEACHWOOD DRIVE & RAVENRIDGE DRIVE**

ITEM	QUANTITY	UNIT COST	COST
1 Mobilization, demolization	1 job	\$ 6,000	\$ 6,000
2 Traffic control and trench safety	1 job	\$ 3,200	\$ 3,200
3 8" PVC pipe c/w sand bedding, native backfill	0 ft	\$ 54	\$ -
4 6" PVC pipe c/w sand bedding, native backfill	1,730 ft	\$ 45	\$ 77,850
5 Granular backfill (allow 10% of length in fog line)	32.0 cy	\$ 9	\$ 288
6 8" gate valve c/w valve box	0 ea	\$ 1,500	
7 6" gate valve c/w valve box	3 ea	\$ 1,200	\$ 3,600
8 6 & 8" DI fittings	218 lbs	\$ 3	\$ 654
9 Air release valve assemblies	1 ea	\$ 1,250	\$ 1,250
10 Blow-off assemblies	0 ea	\$ 1,250	\$ -
11 Fire hydrant	1 ea	\$ 3,500	\$ 3,500
12 Pavement cut & replacement (road X-ings)	72 sf	\$ 15	\$ 1,080
13 Road X-ing casing pipe c/w spacers	24 ft	\$ 80	\$ 1,920
14 CDF for casing pipe road crossings	4.4 cy	\$ 85	\$ 378
15 Service replacement to existing meter	39 ea	\$ 550	\$ 21,450
16 Pressure test and disinfection	1 job	\$ 2,500	\$ 2,500

Notes:

Unit costs from low bid to Del Mar, 2007 with adjustment for 8" PVC pipe at \$11.19/ft vs 8" DI at \$24.22/ft: prices from H.D. Fowler Aug-08

Sub-total		\$ 123,670
Tax	8.3%	\$ 10,265
Contingency	15%	\$ 18,551
Surveyor (for base plan)		\$ 2,000
Construction plans		\$ 2,000
Inspection		\$ 2,000
		<b>\$ 158,485</b>

cost per foot \$ 91.61