

Exh. KG-4
Docket UG-240008
Witness: Konstantine Geranios

**BEFORE THE WASHINGTON
UTILITIES AND TRANSPORTATION COMMISSION**

**WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION,**

Complainant,

v.

**CASCADE NATURAL GAS
CORPORATION,**

Respondent

DOCKET UG-240008

**EXHIBIT TO
RESPONSE TESTIMONY
OF**

KONSTANTINE GERANIOS

**STAFF OF
WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION**

CNGC Response to UTC Staff Data Request No. 11

September 25, 2024

BEFORE THE WASHINGTON UTILITIES AND TRANSPORTATION COMMISSION

**Docket UG-240008
Cascade Natural Gas Corporation
2024 General Rate Case**

WUTC STAFF DATA REQUEST NO. 11:

Re: South Kennewick

The testimony of Patrick Darras states that the current location of the South Kennewick Gate is in an “undesirable location.” Darras, Exh. PCD-1T at 55:18. Please elaborate on why the location is undesirable (e.g. what makes the gate location undesirable long term)?

Response:

The Kennewick gate is in an undesirable location because it is being encroached upon by commercial development and cannot be expanded. The existing site is crowded and for maintenance activities, sections of the fence must be taken down. The site is also challenging to get odorant deliveries into due to the limited room around the site to get an odorant truck (semi size) positioned for transferring odorant. This site is also challenging to blow down for maintenance activities. Due to the proximity of commercial and residential development, the facility also gets odor calls. Below is a Google Earth street view of the gate.

