



3401 Industrial Way • PO Box 188 • Longview, WA 98632-7117

Re Docket PG-080002

March 25, 2009

David W. Danner  
Executive Director and Secretary  
Washington Utilities and Transportation Commission  
1300 S. Evergreen Park Dr. S.W.  
Olympia, WA 98504-7250

RECEIVED

MAR 25 2009

WUTC  
Pipeline Safety Division

Dear Mr. Danner

In response to your letter dated February 11, 2009 regarding the findings of the 2009 pipeline integrity management inspection audit of the Weyerhaeuser-Ostrander pipeline, Weyerhaeuser takes no exception to the audit findings and commits to the following actions;

Finding 1, Anomalies

Weyerhaeuser will revise the facility Integrity Management Program to include the requirements of ASME B31.8S, Section 6.3.4 regarding the examination of failures with respect to the threat the test was intended to address.

Finding 2, Quality Assurance Process

Weyerhaeuser will revise the facility Integrity Management Program to include the requirements of ASME B31.8S, Section 12.2(2) regarding the quality assurance of outside contractors used to conduct examinations.

Weyerhaeuser has a planned 2009 revision of the facility integrity management program to include the results of upcoming baseline assessment activities. This revision will be issued in by the end of September 2009 and will address the findings discussed above.

Sincerely

Tim Haynes  
Vice President, Manufacturing  
Weyerhaeuser Company

cc: Cosentino Consulting Inc.