OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Air Liquide Industrial, U.S. L.P **Date(s):** March 25, 2009

Unit: Kalama Plant

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
Emerald Plant		2-inch	-1.333 V						
Rail crossing		2-inch	-1.125 V	-1.057 V					Vent –0.504 V
Kalama River Road		2-inch	-1.548 V						
Emerald Safety Valve		2-inch							Operated OK
Steel Scape Line		2-inch	-1.924 V						Unregulated line