

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

A completed **Standard Inspection Checklist, OQ Field Validation Protocol form and Cover Letter/Field Report** are to be submitted to the Chief Engineer within **30 days** from completion of the inspection.

Inspection Report			
Docket Number	Docket PG-110045		
Inspector Name & Submit Date	Lex Vinsel, 11/10/2011		
Chief Eng Name & Review/Date	Joe Subsits, 11/14/2011		
Operator Information			
Name of Operator:	Avista Utilitites Corporation	OP ID #:	31232
Name of Unit(s):	Goldendale & Stevenson		
Records Location:	Goldendale, WA		
Date(s) of Last (unit) Inspection:	June 9-13, 2008	Inspection Date(s):	September 26-29, 2011

<p>Inspection Summary:</p> <p>Inspection Starts 1:30 PM on Monday.</p> <p>Exit interview on Sept 29, 23011 in Goldendale office.</p>

<p>HQ Address: 1411 East Mission P.O. Box 3727 Spokane, WA 99220-3727</p>	<p>System/Unit Name & Address: Mike Rowland Avista Utilities 150 W. Main – PO Box 248 Goldendale, WA 98620</p>
<p>Co. Official: Don Kopczynski, VP-Operations Phone No.: 509.495.4877 Fax No.: 509.495.4070 Emergency Phone No.: 800.727.9170</p>	<p>Phone No.: 509.773.4833 Fax No.: 509.495.4070 Emergency Phone No.: 800.727.9170</p>

Persons Interviewed	Title	Phone No.
Randy K. Bareither, PE	Pipeline Safety Engineer	509.495.8716
Tim Mair	Spokane Gas Assistant Manager	509.495.8946
Sonia Johnson	Compliance Tech/ Compliance Dispatch	509.495.4959
Robert Larson	CP Technician	509.981.4748
Randy Chandler	Sr. Manger Operations – Gas	509.495.4683
Mark Rowland	Local Gas Representative	509.773.4833
Shawn Gallagher	Pipeline Services Program Administration	509.495.2060
Rich Inouye	Pressure Controlman	509.994.9652

<p>WUTC staff conducted an abbreviated procedures inspection on 192 O&M and WAC items that changed since the last inspection. This checklist focuses on Records and Field items per a routine standard inspection.</p> <p style="text-align: center;">(check one below and enter appropriate date)</p>		
<input checked="" type="checkbox"/>	Team inspection was performed (Within the past five years.) or,	Date: 5/2007

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

<input type="checkbox"/>	Other WUTC Inspector reviewed the O & M Manual (Since the last yearly review of the manual by the operator.)	Date:	
--------------------------	--	--------------	--

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

GAS SYSTEM OPERATIONS			
Gas Supplier	Williams		
Services	Goldendale/Stevenson - Residential 1075 Commercial 196 Industrial 0 Other 1		
Number of reportable safety related conditions last year	0	Number of deferred leaks in system	0
Number of <u>non-reportable</u> safety related conditions last year	0	Number of third party hits last year	0
Miles of transmission pipeline within unit (total miles and miles in class 3 & 4 areas)	None	Miles of main within inspection unit (total miles and miles in class 3 & 4 areas)	40.3/37.6 NO Class 4
Operating Pressure(s):		MAOP (Within last year)	Actual Operating Pressure (At time of Inspection)
Feeder:	139 psi Goldendale 275 psi Stevenson 275 psi Stevenson	809 Inlet 809 Inlet	
Town:	35 psi Goldendale 55 psi Stevenson		
Other:			
Does the operator have any transmission pipelines?	None in this district.		
Compressor stations? Use Attachment I.	None in this district		

Pipe Specifications:			
Year Installed (Range)	Goldendale 1959-2010 Stevenson 1963-2010	Pipe Diameters (Range)	½-4" PE/3/4-4" STL
Material Type	PE and Steel	Line Pipe Specification Used	ASTM 2406/API 5L
Mileage	Main 40.3 miles	SMYS %	9%

Operator Qualification Field Validation
Important: Per OPS, the OQ Field Inspection Protocol 9 Form 15(Rev 03/21/2011) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA OQ Database (OQDB) located at http://primis.phmsa.dot.gov/oqdb/home.oq Date Completed 11/09/2011

Integrity Management Field Validation
Important: Per PHMSA, Gas IMP Field Verification Form 16(Rev 03/21/2011 through Amdt. 192-116) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA IM Database (IMDB) located at http://primis.phmsa.dot.gov/gasimp/home.gim Date Completed: N/A No transmission pipelines in this district

PART 199 Drug and Alcohol Testing Regulations and Procedures				S	U	NA	NC
Subparts A - C	Drug & Alcohol Testing & Misuse Prevention Program – Use PHMSA Form #13, Rev. 03/22/11 through Final Rule of 1/16/2009. Do not ask the company to have a drug and alcohol expert available for this portion of your inspection. E mailed to DOT 11/9/2011.			X			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
1.	49 U.S.C. 60132, Subsection (b)	For Gas Transmission Pipelines and LNG Plants. Submission of Data to the National Pipeline Mapping System Under the Pipeline Safety Improvement Act of 2002 Updates to NMPS: Operators are required to make update submissions every 12 months if any system modifications have occurred. If no modifications have occurred since the last complete submission (including operator contact information), send an email to opsgis@rspa.dot.gov stating that fact. Include operator contact information with all updates. Updates sent 6/18/2008//4/21/2009//2/4/2010	X			
2.	RCW 81.88.080	Pipeline Mapping System: Has the operator provided accurate maps (or updates) of pipelines, operating over two hundred fifty pounds per square inch gauge, to specifications developed by the commission sufficient to meet the needs of first responders? Updates sent 3/31/2010	X			
3.	191.5	Immediate Notice of certain incidents to NRC (800) 424-8802, or electronically at http://www.nrc.uscg.mil/nrchp.html , and additional report if significant new information becomes available. Operator must have a written procedure for calculating an initial estimate of the amount of product released in an accident. Ok Reviewed Forms	X			
4.	191.7	Reports (except SRCR and offshore pipeline condition reports) must be submitted electronically to PHMSA at https://opsweb.phmsa.dot.gov at unless an alternative reporting method is authorized IAW with paragraph (d) of this section. None	X			
5.	191.15(a)	30-day follow-up written reports to PHMSA (Form F7100.2) Submittal must be electronically to http://pipelineonlinereporting.phmsa.dot.gov No Transmission in District			X	
6.	191.15(c)	Supplemental report (to 30-day follow-up) No Transmission in District			X	
7.	191.17	Complete and submit DOT Form PHMSA F 7100-2.1 by March 15 of each calendar year for the preceding year. (NOTE: June 15, 2011 for the year 2010).	X			
8.	191.22	Each operator must obtain an OPID, validate its OPIDs, and notify PHMSA of certain events at https://opsweb.phmsa.dot.gov . Validated 9/23/2011/None	X			
9.	191.23	Filing the Safety Related Condition Report (SRCR) None			X	
10.	191.25	Filing the SRCR within 5 days of determination, but not later than 10 days after discovery None			X	
11.	.605(d)	Instructions to enable operation and maintenance personnel to recognize potential Safety Related Conditions O+M Manual Sec 4.12 p 1,2,3	X			
12.	191.27	Offshore pipeline condition reports – filed within 60 days after the inspections None			X	
13.	192.727(g)	Abandoned facilities offshore, onshore crossing commercially navigable waterways reports None			X	
14.	480-93-200(1)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9146 (Within 2 hours) for events which results in;				
15.	480-93-200(1)(a)	A fatality or personal injury requiring hospitalization; None			X	
16.	480-93-200(1)(b)	Damage to property of the operator and others of a combined total exceeding fifty thousand dollars; None			X	
17.	480-93-200(1)(c)	The evacuation of a building, or high occupancy structures or areas; None			X	
18.	480-93-200(1)(d)	The unintentional ignition of gas; None			X	
19.	480-93-200(1)(e)	The unscheduled interruption of service furnished by any operator to twenty five or more distribution customers;	X			
20.	480-93-200(1)(f)	A pipeline pressure exceeding the MAOP plus ten percent or the maximum pressure allowed by proximity considerations outlined in WAC 480-93-020; None			X	
21.	480-93-200(1)(g)	Is significant, in the judgment of the operator, even though it does not meet the criteria of (a) through (f) of this subsection; None			X	
22.	480-93-200(2)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9146 (Within 24 hours) for;				
23.	480-93-200(2)(a)	The uncontrolled release of gas for more than two hours;	X			
24.	480-93-200(2)(b)	The taking of a high pressure supply or transmission pipeline or a major distribution supply gas pipeline out of service; None			X	

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
25.	480-93-200(2)(c)	A gas pipeline operating at low pressure dropping below the safe operating conditions of attached appliances and gas equipment; or None			X	
26.	480-93-200(2)(d)	A gas pipeline pressure exceeding the MAOP None			X	
27.	480-93-200(4)	Did written incident reports (within 30 days of telephonic notice) include the following				
28.	480-93-200(4)(a)	Name(s) and address(es) of any person or persons injured or killed, or whose property was damaged; None			X	
29.	480-93-200(4)(b)	The extent of injuries and damage; None			X	
30.	480-93-200(4)(c)	A description of the incident or hazardous condition including the date, time, and place, and reason why the incident occurred. If more than one reportable condition arises from a single incident, each must be included in the report;	X			
31.	480-93-200(4)(d)	A description of the gas pipeline involved in the incident or hazardous condition, the system operating pressure at that time, and the MAOP of the facilities involved;	X			
32.	480-93-200(4)(e)	The date and time the gas pipeline company was first notified of the incident;	X			
33.	480-93-200(4)(f)	The date and time the ((operator's)) gas pipeline company's first responders arrived on-site;	X			
34.	480-93-200(4)(g)	The date and time the gas ((facility)) pipeline was made safe;	X			
35.	480-93-200(4)(h)	The date, time, and type of any temporary or permanent repair that was made;	X			
36.	480-93-200(4)(i)	The cost of the incident to the ((operator)) gas pipeline company;	X			
37.	480-93-200(4)(j)	Line type;	X			
38.	480-93-200(4)(k)	City and county of incident; and	X			
39.	480-93-200(4)(l)	Any other information deemed necessary by the commission. None			X	
40.	480-93-200(5)	Supplemental report if required information becomes available after 30 day report submitted None			X	
41.	480-93-200(6)	Written report within 5 days of receiving the failure analysis of any incident or hazardous condition due to construction defects or material failure None			X	
42.	480-93-200(7)	Annual Reports filed with the commission no later than March 15 for the proceeding calendar year				
43.	480-93-200(7)(a)	A copy of PHMSA F-7100.1-1 and F-7100.2-1 annual report required by U.S. Department of Transportation, PHMSA/Office of Pipeline Safety	X			
44.	480-93-200(7)(b)	Damage Prevention Statistics Report including the following;				
45.	480-93-200(7)(b)(i)	Number of gas-related one-call locate requests completed in the field; 30,349*	X			
46.	480-93-200(7)(b)(ii)	Number of third-party damages incurred; and 2008(291*), 2009(312*), 2010(266*)	X			
47.	480-93-200(7)(b)(iii)	Cause of damage, where cause of damage is classified as one of the following: (A) Inaccurate locate; (B) Failure to use reasonable care; (C) Excavated prior to a locate being conducted; or (D) Other.	X			
48.	480-93-200(7)(c)	Reports detailing all construction defects and material failures resulting in leakage. Categorizing the different types of construction defects and material failures. The report must include the following: (i) Types and numbers of construction defects; and (ii) Types and numbers of material failures.	X			
49.	480-93-200(8)	Providing updated emergency contact information to the commission and appropriate officials of all municipalities where gas pipeline companies have facilities	X			
50.	480-93-200(9)	Providing by email, reports of daily construction and repair activities no later than 10:00 a.m.	X			
51.	480-93-200(10)	Submitting copy of DOT Drug and Alcohol Testing MIS Data Collection Form when required Reviewed 2008, 2009, 2010	X			

Comments:

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Items 45-46 - Damage prevention statistics for Goldendale/Stevenson are included in Spokane District. Avista does NOT break it out by district.

CUSTOMER and EXCESS FLOW VALVE INSTALLATION NOTIFICATION			S	U	N/A	N/C
52.	192.16	Customer notification - Customers notified, within 90 days , of their responsibility for those service lines not maintained by the operator	X			
53.	192.381	Does the excess flow valve meet the performance standards prescribed under §192.381?	X			
54.	192.383	Does the operator have an installation and reporting program for excess flow valves and does the program meet the requirements outlined in §192.383? Are records adequate?	X			

Comments:

#53 See Sec 3.16 of O+M Manual

CONSTRUCTION RECORDS			S	U	N/A	N/C
55.	480-93-013	OQ records for personnel performing New Construction covered tasks	X			
56.	192.225	Test Results to Qualify Welding Procedures Reviewed Weld Test Records	X			
57.	192.227	Welder Qualification	X			
58.	480-93-080(1)(b)	Appendix C Welders re-qualified 2/Yr (7.5Months) None			X	
59.	480-93-080(2)	Plastic pipe joiners re-qualified 1/Yr (15 Months)	X			
60.	480-93-080(2)(b)	Plastic pipe joiners re-qualified if no production joints made during any 12 month period Avista re-qualifies joiners annually.	X			
61.	480-93-080(2)(c)	Tracking Production Joints or Re-qualify joiners 1/Yr (12Months) Avista re-qualifies joiners annually.	X			
62.	480-93-115(2)	Test leads on casings (without vents) installed after 9/05/1992 Yes two in district	X			
63.	480-93-115(3)	Sealing ends of casings or conduits on transmission lines and mains Yes Sec #3.42 p5	X			
64.	480-93-115(4)	Sealing ends (nearest building wall) of casings or conduits on services Yes Sec #3.16 p8	X			
65.	192.241(a)	Visual Weld Inspector Training/Experience OQ Visual inspection – Mark Rowland	X			
66.	192.243(b)(2)	Nondestructive Technician Qualification No Transmission in district			X	
67.	192.243(c)	NDT procedures No Transmission in district			X	
68.	192.243(f)	Total Number of Girth Welds No Transmission in district			X	
69.	192.243(f)	Number of Welds Inspected by NDT No Transmission in district			X	
70.	192.243(f)	Number of Welds Rejected No Transmission in district			X	
71.	192.243(f)	Disposition of each Weld Rejected No Transmission in district			X	
72.	.273/.283	Qualified Joining Procedures Including Test Results Reviewed 3.22, 3.23, 3.24, 3.25	X			
73.	192.303	Construction Specifications Reviewed	X			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CONSTRUCTION RECORDS			S	U	N/A	N/C
74.	192.325 WAC 480-93-178(4)(5)	Underground Clearances	X			
75.	192.327	Amount, location, cover of each size of pipe installed Reviewed as built	X			
76.	480-93-160(1)	Report filed 45 days prior to construction or replacement of <u>transmission pipelines</u> ≥ 100 feet in length No transmission			X	
77.	480-93-160(2)	Did report describe the proposed route and the specifications for the pipeline and must include, but is not limited to the following items: No transmission			X	
78.	480-93-160(2)(a)	Description and purpose of the proposed pipeline; No transmission			X	
79.	480-93-160(2)(b)	Route map showing the type of construction to be used throughout the length of the line, and delineation of class location as defined in 49 CFR Part 192.5, and incorporated boundaries along the route. No transmission			X	
80.	480-93-160(2)(c)	Location and specification of principal valves, regulators, and other auxiliary equipment to be installed as a part of the pipeline system to be constructed No transmission			X	
81.	480-93-160(2)(d)	MAOP for the gas pipeline being constructed: No transmission			X	
82.	480-93-160(2)(e)	Location and construction details of all river crossings or other unusual construction requirements encountered en route. No transmission			X	
83.	480-93-160(2)(f)	Proposed corrosion control program to be followed inc specs for coating and wrapping, and method to ensure the integrity of the coating using holiday detection equipment: No transmission			X	
84.	480-93-160(2)(g)	Welding specifications; and No transmission			X	
85.	480-93-160(2)(h)	Bending procedures to be followed if needed. No transmission			X	
86.	480-93-170(1)	Commission notified 2 days prior to pressure testing pipelines with an MAOP producing a hoop stress $\geq 20\%$ SMYS? No transmission			X	
87.	480-93-170(7)	Pressure tests records at a minimum include required information listed under 480-93-170(a-h) Reviewed as built	X			
88.	480-93-170(9)	Individual pressure test records maintained for single installations where multiple pressure tests were performed?	X			
89.	480-93-170(10)	Pressure Testing Equipment checked for accuracy/intervals (Manufacturers Rec or Operators schedule) Checked pressure gauges in the field.	X			
90.	480-93-175(2)	Study prepared and approved prior to moving and lowering of metallic pipelines > 60 psig None			X	
91.	480-93-175(4)	Leak survey within 30 days of moving or lowering pipelines ≤ 60 psig None			X	

Comments:

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
92.	192.517(a)	Pressure Testing (operates at or above 100 psig) – useful life of pipeline None			X	
93.	192.517(b)	Pressure Testing (operates below 100 psig, service lines, plastic lines) – 5 years	X			
94.	192.605(a)	Procedural Manual Review – Operations and Maintenance (1 per yr/15 months) Note: Including review of OQ procedures as <u>suggested</u> by PHMSA - ADB-09-03 dated 2/7/09	X			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
95.	192.605(b)(3)	Availability of construction records, maps, operating history to operating personnel	X			
96.	480-93-018(3)	Records, including maps and drawings updated within 6 months of completion of construction activity? Reviewed thirteen mapping locations from previous crew sheets more than 6 month old and found 1 that was not mapped on current maps.		X		
97.	192.605(b)(8)	Periodic review of personnel work – effectiveness of normal O&M procedures	X			
98.	192.605(c)(4)	Periodic review of personnel work – effectiveness of abnormal operation procedures Review of Trouble Orders by managers.	X			
99.	192.609	Class Location Study (If applicable) All Avista facilities are designed to Class 4			X	
100.	192.611	Confirmation or revision of MAOP All Avista facilities are designed to Class 4			X	
101.		Damage Prevention (Operator Internal Performance Measures)				
102.		Does the operator have a quality assurance program in place for monitoring the locating and marking of facilities? Do operators conduct regular field audits of the performance of locators/contractors and take action when necessary? (CGA Best Practices v. 6.0, Best Practice 4-18. Recommended only, not required)	X			
103.		Does operator including performance measures in facility locating services contracts with corresponding and meaningful incentives and penalties? Avista crew perform all gas locates in this district.			X	
104.		Do locate contractors address performance problems for persons performing locating services through mechanisms such as re-training, process change, or changes in staffing levels?			X	
105.	192.614	Does the operator periodically review the Operator Qualification plan criteria and methods used to qualify personnel to perform locates? Annual Review includes OQ	X			
106.		Review operator locating and excavation procedures for compliance with state law and regulations. O&M Section 4.13 p1-5	X			
107.		Are locates are being made within the timeframes required by state law and regulations? Examine record sample. Reviewed sample	X			
108.		Are locating and excavating personnel properly <u>qualified</u> in accordance with the operator's Operator Qualification plan and with federal and state requirements?	X			
109.		Follow-up inspection performed on the pipeline where there is reason to believe the pipeline could be damaged .614(c) (6) 1. Is the inspection the done as frequently as necessary during and after the activities to verify the integrity of the pipeline? 2. In the case of blasting, does the inspection include leakage surveys? O&M Section 4.13	X			
110.		Informational purposes only. Not Required. Does the pipeline operator voluntarily submit pipeline damage statistics into the UTC Damage Information Reporting Tool (DIRT)? Operator may register at https://identity.damagereporting.org/cgareg/control/login.do Y X N				

Comments:

Item #98 – Review of Trouble Orders by managers.

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

111.		Emergency Response Plans	S	U	N/A	N/C																										
112.	192.603(b)	Prompt and effective response to each type of emergency .615(a)(3) Note: Review operator records of previous accidents and failures including third-party damage and leak response	X																													
113.	192.615(b)(1)	Location Specific Emergency Plan	X																													
114.	192.615(b)(2)	Emergency Procedure training, verify effectiveness of training 7/14/2008 – Mock Emergency	X																													
115.	192.615(b)(3)	Employee Emergency activity review, determine if procedures were followed. 7/14/2008 – Mock Emergency	X																													
116.	192.615(c)	Liaison Program with Public Officials 7/14/2008 – Mock Emergency	X																													
117.	192.616	Public Awareness Program																														
118.	192.616(e&f)	Documentation properly and adequately reflects implementation of operator's Public Awareness Program requirements - Stakeholder Audience identification, message type and content, delivery method and frequency, supplemental enhancements, program evaluations, etc. (i.e. contact or mailing rosters, postage receipts, return receipts, audience contact documentation, etc. for emergency responder, public officials, school superintendents, program evaluations, etc.). See table below: See #121 Comment	X																													
119.		Operators in existence on June 20, 2005, must have completed their written programs no later than June 20, 2006. See 192.616(a) and (j) for exceptions. Reviewed third party evaluation	X																													
120.		API RP 1162 Baseline* Recommended Message Deliveries																														
121.		<table border="1"> <thead> <tr> <th align="center">Stakeholder Audience (LDC's)</th> <th align="center">Baseline Message Frequency (starting from effective date of Plan)</th> </tr> </thead> <tbody> <tr> <td>Residence Along Local Distribution System</td> <td>Annual</td> </tr> <tr> <td>LDC Customers</td> <td>Twice annually</td> </tr> <tr> <td>One-Call Centers</td> <td>As required of One-Call Center</td> </tr> <tr> <td>Emergency Officials</td> <td>Annual</td> </tr> <tr> <td>Public Officials</td> <td>3 years (2 years)</td> </tr> <tr> <td>Excavator and Contractors</td> <td>Annual</td> </tr> <tr> <th align="center">Stakeholder Audience (Transmission line operators)</th> <th align="center">Baseline Message Frequency (starting from effective date of Plan)</th> </tr> <tr> <td>Residence Along Local Distribution System</td> <td>2 years</td> </tr> <tr> <td>One-Call Centers</td> <td>As required of One-Call Center</td> </tr> <tr> <td>Emergency Officials</td> <td>Annual</td> </tr> <tr> <td>Public Officials</td> <td>3 years</td> </tr> <tr> <td>Excavator and Contractors</td> <td>Annual</td> </tr> </tbody> </table>	Stakeholder Audience (LDC's)	Baseline Message Frequency (starting from effective date of Plan)	Residence Along Local Distribution System	Annual	LDC Customers	Twice annually	One-Call Centers	As required of One-Call Center	Emergency Officials	Annual	Public Officials	3 years (2 years)	Excavator and Contractors	Annual	Stakeholder Audience (Transmission line operators)	Baseline Message Frequency (starting from effective date of Plan)	Residence Along Local Distribution System	2 years	One-Call Centers	As required of One-Call Center	Emergency Officials	Annual	Public Officials	3 years	Excavator and Contractors	Annual				
Stakeholder Audience (LDC's)	Baseline Message Frequency (starting from effective date of Plan)																															
Residence Along Local Distribution System	Annual																															
LDC Customers	Twice annually																															
One-Call Centers	As required of One-Call Center																															
Emergency Officials	Annual																															
Public Officials	3 years (2 years)																															
Excavator and Contractors	Annual																															
Stakeholder Audience (Transmission line operators)	Baseline Message Frequency (starting from effective date of Plan)																															
Residence Along Local Distribution System	2 years																															
One-Call Centers	As required of One-Call Center																															
Emergency Officials	Annual																															
Public Officials	3 years																															
Excavator and Contractors	Annual																															
122.		* Refer to API RP 1162 for additional requirements, including general program recommendations, supplemental requirements, recordkeeping, program evaluation, etc.																														
123.	192.616(g)	The program conducted in English and any other languages commonly understood by a significant number of the population in the operator's area. Spanish included	X																													
124.	.616(h)	I AW API RP 1162, the operator's program should be reviewed for effectiveness within four years of the date the operator's program was first completed. <u>For operators in existence on June 20, 2005</u> , who must have completed their written programs no later than June 20, 2006, the first evaluation is due no later than June 20, 2010 . .616(h)	X																													

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

125.	192.616(j)	Operators of a Master Meter or petroleum gas system – public awareness messages 2 times annually: (1) A description of the purpose and reliability of the pipeline; (2) An overview of the hazards of the pipeline and prevention measures used; (3) Information about damage prevention; (4) How to recognize and respond to a leak; and (5) How to get additional information. No Master Meters in district.				X	
126.	192.617	Review operator records of accidents and failures including laboratory analysis where appropriate to determine cause and prevention of recurrence .617 Note: Including excavation damage and leak response records (PHMSA area of emphasis) (NTSB B.10) Reviewed trouble calls for district.	X				

Comments:

Item 114-116 - Mock Emergency 7/14/2008 included District 7 Fire, 911, and Washington State Patrol

Item 121 – All Stakeholders for LDC have the correct baseline frequency or better. No transmission in this district.

127.	192.619/621/623	Maximum Allowable Operating Pressure (MAOP) Note: New PA-11 design criteria is incorporated into 192.121 & .123 (Final Rule Pub. 12/24/08)	X				
128.	480-93-015(1)	Odorization of Gas – Concentrations adequate	X				
129.	480-93-015(2)	Monthly Odorant Sniff Testing	X				
130.	480-93-015(3)	Prompt action taken to investigate and remediate odorant concentrations not meeting the minimum requirements All odorant readings meet requirement.	X				
131.	480-93-015(4)	Odorant Testing Equipment Calibration/Intervals (Annually or Manufacturers Recommendation)	X				
132.	480-93-124(3)	Pipeline markers attached to bridges or other spans inspected? 1/yr(15 months) Inspected Quarterly	X				
133.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days?	X				
134.	480-93-140(2)	Service regulators and associated safety devices tested during initial turn-on	X				
135.	480-93-155(1)	Up-rating of system MAOP to >60 psig? Procedures and specifications submitted 45 days prior? None during time period.	X				
136.	480-93-185(1)	Reported gas leaks promptly investigated? Graded in accordance with 480-93-186? Records retained? Reviewed approximately ten leak surveys	X				
137.	480-93-185(3)(a)	Leaks originating from a foreign source. Take appropriate action to protect life and property regarding the pipeline company's own facilities, and; None				X	
138.	480-93-185(3)(b)	Leaks originating from a foreign source reported promptly/notification by mail. Records retained? None				X	
139.	480-93-186(3)	Leak evaluations: Are follow-up inspections performed within 30 days of a leak repair?	X				
140.	480-93-186(4)	Leak evaluations: Grade 1 and 2 leaks (if any), downgraded once to a grade 3 without physical repair? None				X	
141.	480-93-187	Gas leak records: at a minimum include required information listed under 480-93-187(1-13)	X				
142.	480-93-188(1)	Gas leak surveys Annual	X				
143.	480-93-188(2)	Gas detection instruments tested for accuracy/intervals (Mfct recommended or monthly not to exceed 45 days) CGI tested once per month.	X				

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

144.	480-93-188(3)	Leak survey frequency (Refer to Table Below) Business Districts and High Occupancy Structures surveyed annually.	X															
<table border="1"> <tr> <td>Business Districts (implement by 6/02/07)</td> <td>1/yr (15 months)</td> </tr> <tr> <td>High Occupancy Structures</td> <td>1/yr (15 months)</td> </tr> <tr> <td>Pipelines Operating ≥ 250 psig</td> <td>1/yr (15 months)</td> </tr> <tr> <td>Other Mains: CI, WI, copper, unprotected steel</td> <td>2/yr (7.5 months)</td> </tr> </table>							Business Districts (implement by 6/02/07)	1/yr (15 months)	High Occupancy Structures	1/yr (15 months)	Pipelines Operating ≥ 250 psig	1/yr (15 months)	Other Mains: CI, WI, copper, unprotected steel	2/yr (7.5 months)				
Business Districts (implement by 6/02/07)	1/yr (15 months)																	
High Occupancy Structures	1/yr (15 months)																	
Pipelines Operating ≥ 250 psig	1/yr (15 months)																	
Other Mains: CI, WI, copper, unprotected steel	2/yr (7.5 months)																	
145.	480-93-188(4)(a)	Special leak surveys - Prior to paving or resurfacing, following street alterations or repairs None			X													
146.	480-93-188(4)(b)	Special leak surveys - areas where substructure construction occurs adjacent to underground gas facilities, and damage could have occurred None			X													
147.	480-93-188(4)(c)	Special leak surveys - Unstable soil areas where active gas lines could be affected None			X													
148.	480-93-188(4)(d)	Special leak surveys - areas and at times of unusual activity, such as earthquake, floods, and explosions None			X													
149.	480-93-188(4)(e)	Special leak surveys - After third-party excavation damage to services, operators must perform a gas leak survey from the point of damage to the service tie-in	X															
150.	480-93-188(5)	Gas Survey Records (Min 5 yrs) and at a minimum include required information listed under 480-93-188 (5) (a-f)	X															
151.	480-93-188(6)	Leak program - Self Audits 2008/2009/2010	X															
152.	192.709	Patrolling (Transmission Lines) (Refer to Table Below) .705 None in district			X													
<table border="1"> <tr> <td>Class Location</td> <td>At Highway and Railroad Crossings</td> <td>At All Other Places</td> </tr> <tr> <td>1 and 2</td> <td>2/yr (7½ months)</td> <td>1/yr (15 months)</td> </tr> <tr> <td>3</td> <td>4/yr (4½ months)</td> <td>2/yr (7½ months)</td> </tr> <tr> <td>4</td> <td>4/yr (4½ months)</td> <td>4/yr (4½ months)</td> </tr> </table>							Class Location	At Highway and Railroad Crossings	At All Other Places	1 and 2	2/yr (7½ months)	1/yr (15 months)	3	4/yr (4½ months)	2/yr (7½ months)	4	4/yr (4½ months)	4/yr (4½ months)
Class Location	At Highway and Railroad Crossings	At All Other Places																
1 and 2	2/yr (7½ months)	1/yr (15 months)																
3	4/yr (4½ months)	2/yr (7½ months)																
4	4/yr (4½ months)	4/yr (4½ months)																
153.	192.709	Leak Surveys (Transmission Lines) (Refer to Table Below) .706 None in district			X													
<table border="1"> <tr> <td>Class Location</td> <td>Required</td> <td>Not Exceed</td> </tr> <tr> <td>1 and 2</td> <td>1/yr</td> <td>15 months</td> </tr> <tr> <td>3</td> <td>2/yr</td> <td>7½ months</td> </tr> <tr> <td>4</td> <td>4/yr</td> <td>4½ months</td> </tr> </table>							Class Location	Required	Not Exceed	1 and 2	1/yr	15 months	3	2/yr	7½ months	4	4/yr	4½ months
Class Location	Required	Not Exceed																
1 and 2	1/yr	15 months																
3	2/yr	7½ months																
4	4/yr	4½ months																
154.	192.603(b)	Patrolling Business District (4 per yr/4½ months) .721(b)(1) Reviewed 2008, 2009, & 2010	X															
155.	192.603(b)	Patrolling Outside Business District (2 per yr/7½ months) 192.721(b)(2) Reviewed 2008, 2009, & 2010	X															
156.	192.603(b)	Leakage Survey - Outside Business District (5 years) 192.723(b)(1) Performed in 2007 not due till 2012.			X													
157.	192.603(b)	Leakage Survey 192.723(b)(2) <ul style="list-style-type: none"> Outside Business District (5 years) Cathodically unprotected distribution lines (3 years) Performed in 2007 not due till 2012. 			X													
158.	192.603(b)	Tests for Reinstating Service Lines 192.725 Reviewed trouble orders	X															
159.	192.603(b)/.727(g)	Abandoned Pipelines; Underwater Facility Reports 192.727 None			X													
160.	192.709	Pressure Limiting and Regulating Stations (1 per yr/15 months) .739 Reviewed records for regulators 145/150/144	X															
161.	192.709	Pressure Limiting and Regulator Stations – Capacity (1 per yr/15 months) .743 144*	X															
162.	192.709	Valve Maintenance – Transmission (1 per yr/15 months) .745 None			X													
163.	192.709	Valve Maintenance – Distribution (1 per yr/15 months) .747	X															

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

164.	480-93-100(3)	Service valve maintenance (1 per yr/15 months) OK	X			
165.	192.709	Vault maintenance (≥200 cubic feet)(1 per yr/15 months) .749 None			X	
166.	192.603(b)	Prevention of Accidental Ignition (hot work permits) .751 Std 3.17 p1			X	
167.	192.603(b)	Welding – Procedure 192.225(b)	X			
168.	192.603(b)	Welding – Welder Qualification 192.227/.229	X			
169.	192.603(b)	NDT – NDT Personnel Qualification .243(b)(2) No Transmission in district.			X	
170.	192.709	NDT Records (pipeline life) .243(f) No Records			X	
171.	192.709	Repair: pipe (pipeline life); Other than pipe (5 years) No Records			X	
172.	192.905(c)	Periodically examining their transmission line routes for the appearance of newly identified area's (HCA's) None			X	

Comments:

Item # 161 – Regulator 144* - Only 144 regulator operates with a relief. All others in district are worker - monitors.

CORROSION CONTROL RECORDS			S	U	N/A	N/C
173.	192.455(a)(1)	Pipeline coatings meet requirements of 192.461 (for buried pipelines installed after 7/31/71) Section 2.32 Page 5	X			
174.	192.455(a)(2)	CP system installed on and operating within 1 yr of completion of pipeline construction (after 7/31/71) Section 2.32 Page 5	X			
175.	192.465(a)	Annual Pipe-to-soil Monitoring (1 per yr/15 months) for short sections (10% per year; all in 10 years) None in Goldendale/Risers on Gate Stations are Isolated	X			
176.	192.491	Test Lead Maintenance .471 Section 2.32 Pages 8,9,10	X			
177.	192.491	Maps or Records .491(a)	X			
178.	192.491	Examination of Buried Pipe when exposed .459 Yes	X			
179.	480-93-110(8)	CP test reading on all exposed facilities where coating has been removed	X			
180.	192.491	Annual Pipe-to-soil monitoring (1 per yr/15 months) .465(a)	X			
181.	192.491	Rectifier Monitoring (6 per yr/2½ months) .465(b) Only one, every two months.	X			
182.	192.491	Interference Bond Monitoring – Critical (6 per yr/2½ months) .465(c) None			X	
183.	192.491	Interference Bond Monitoring – Non-critical (1 per yr/15 months) .465(c) None			X	
184.	480-93-110(2)	Remedial action taken within 90 days (Up to 30 additional days if other circumstances. Must document) .465(d) Reviewed 2 instances.	X			
185.	480-93-110(3)	CP equipment/ instrumentation maintained, tested for accuracy, calibrated, and operated in accordance with manufactures recommendations, or at appropriate schedule determined by gas company if no recommendation.	X			
186.	192.491	Unprotected Pipeline Surveys, CP active corrosion areas (1 per 3 cal yr/39 months) .465(e) None			X	
187.	192.491	Electrical Isolation (Including Casings) .467 Test leads on all pipes and casings.	X			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL RECORDS			S	U	N/A	N/C
188.	480-93-110(5)	Casings inspected/tested annually not to exceed fifteen months One shorted - P/S - 1.892 V.	X			
189.	480-93-110(5)(a)	Casings w/no test leads installed prior to 9/05/1992. Demonstrate other acceptable test methods None			X	
190.	480-93-110(5)(b)	Possible shorted conditions – Perform confirmatory follow-up inspection within 90 days One Shorted	X			
191.	480-93-110(5)(c)	Casing shorts cleared when practical OK One cannot be cleared. Have 2 total.	X			
192.	480-93-110(5)(d)	Shorted conditions leak surveyed within 90 days of discovery. Twice annually/7.5 months	X			
193.	192.491	Interference Currents .473 None			X	
194.	192.491	Internal Corrosion: Corrosive Gas Investigation .475(a) None			X	
195.	192.491	Internal Corrosion: Internal Surface Inspection: Pipe Replacement .475(b) As required	X			
196.	192.491	Internal Corrosion Control Coupon Monitoring (2 per yr/7½ months) .477 None			X	
197.	192.491	Atmospheric Corrosion Control Monitoring (1 per 3 cal yr/39 months onshore; 1 per yr/15 months offshore) .481	X			
198.	192.491	Remedial: Replaced or Repaired Pipe; coated and protected; corrosion evaluation and actions .483/.485	X			

Comments:

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
199.	192.161	Supports and anchors	X			
200.	480-93-080(1)(d)	Welding procedures located on site where welding is performed?	X			
201.	480-93-080(1)(b)	Use of testing equipment to record and document essential variables	X			
202.	480-93-080(2)(a)	Plastic procedures located on site where welding is performed?	X			
203.	480-93-080(3)	Identification and qualification cards/certificates w/name of welder/joiner, their qualifications, date of qualification and operator whose qualification procedures were followed.	X			
204.	480-93-013	Personnel performing “New Construction” covered tasks OQ qualified?	X			
205.	480-93-015(1)	Odorization	X			
206.	480-93-018(3)	Updated records, inc maps and drawings made available to appropriate operations personnel?	X			
207.	192.179	Valve Protection from Tampering or Damage	X			
208.	192.455	Pipeline coatings meet requirements of 192.461 (<i>for buried pipelines installed after 7/31/71</i>)	X			
209.	192.463	Levels of cathodic protection	X			
210.	192.465	Rectifiers	X			
211.	192.467	CP - Electrical Isolation	X			
212.	192.476	Systems designed to reduce internal corrosion No Transmission			X	
213.	192.479	Pipeline Components exposed to the atmosphere	X			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
214.	192.481	Atmospheric Corrosion: monitoring	X			
215.	192.491	Test Stations – Sufficient Number .469	X			
216.	480-93-115(2)	Casings – Test Leads (casings w/o vents installed after 9/05/1992)	X			
217.	480-93-115(2)	Mains or transmission lines installed in casings/conduit. Are casing ends sealed?	X			
218.	480-93-115(4)	Service lines installed in casings/conduit. Are casing ends nearest to building walls sealed?	X			
219.	192.605(a)	Appropriate parts of manuals kept at locations where O&M activities are conducted	X			
220.	192.605	Knowledge of Operating Personnel	X			
221.	480-93-124	Pipeline markers	X			
222.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days?	X			
223.	192.719	Pre-pressure Tested Pipe (Markings and Inventory)	X			
224.	192.195	Overpressure protection designed and installed where required?	X			
225.	192.739/743	Pressure Limiting and Regulating Devices (Mechanical/Capacities)	X			
226.	192.741	Telemetry, Recording Gauges (Telemetry in Stevenson)	X			
227.	192.751	Warning Signs	X			
228.	192.355	Customer meters and regulators. Protection from damage	X			
229.	192.355(c)	Pits and vaults: Able to support vehicular traffic where anticipated. No Vaults			X	
230.	480-93-140	Service regulators installed, operated and maintained per state/fed regs and manufacturers recommended practices?	X			
231.	480-93-178(2)	Plastic Pipe Storage facilities – Maximum Exposure to Ultraviolet Light (2yrs)	X			
232.	480-93-178(4)	Minimum Clearances from other utilities. For parallel lines a minimum of twelve inches. Where a minimum twelve inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards. None Observed			X	
233.	480-93-178(5)	Minimum Clearances from other utilities. For perpendicular lines a minimum of six inches of separation from the other utilities. Where a minimum six inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards None Observed			X	
234.	480-93-178(6)	Are there Temporary above ground PE pipe installations currently? Yes No X				
235.	480-93-178(6)(a)	If yes, is facility monitored and protected from potential damage? None			X	
236.	480-93-178(6)(b)	If installation exceeded 30 days, was commission staff notified prior to exceeding the deadline? None			X	
237.	192.745	Valve Maintenance (Transmission) None			X	
238.	192.747	Valve Maintenance (Distribution)	X			

Facility Sites Visited:

Facility Type	Facility ID Number	Location
Odorant Test Site		WDOT Yard
Emergency Valve	GOS59522	Poly valve, Grant & Collins
Emergency Valve	GOS304	Railroad & Columbus
Odorant Test Site		Railroad

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C
S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Comments:

Recent Gas Pipeline Safety Advisory Bulletins: (Last 2 years)

<u>Number</u>	<u>Date</u>	<u>Subject</u>
ADB-09-01	May 21, 2009	Potential Low and Variable Yield and Tensile Strength and Chemical Composition Properties in High Strength Line Pipe

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection – Form C

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

ADB-09-02	Sept 30, 2009	Weldable Compression Coupling Installation
ADB-09-03	Dec 7, 2009	Operator Qualification Program Modifications
ADB-09-04	Jan 14, 2010	Reporting Drug and Alcohol Test Results for Contractors and Multiple Operator Identification Numbers
ADB-10-02	Feb 3, 2010	Implementation of Revised Incident/Accident Report Forms for Distribution Systems, Gas Transmission and Gathering Systems, and Hazardous Liquid Systems
ADB-10-03	March 24, 2010	Girth Weld Quality Issues Due to Improper Transitioning, Misalignment, and Welding Practices of Large Diameter Line Pipe
ADB-10-04	April 29, 2010	Pipeline Safety: Implementation of Electronic Filing for Recently Revised Incident/Accident Report Forms for Distribution Systems, Gas Transmission and Gathering Systems, and Hazardous Liquid Systems
ADB-10-05	June 28, 2010	Pipeline Safety: Updating Facility Response Plans in Light of Deepwater Horizon Oil Spill
ADB-10-06	August 3, 2010	Pipeline Safety: Personal Electronic Device Related Distractions
ADB-10-07	August 31, 2010	Liquefied Natural Gas Facilities: Obtaining Approval of Alternative Vapor-Gas Dispersion Models
ADB-10-08	November 3, 2010	Pipeline Safety: Emergency Preparedness Communications
ADB-11-01	January 4, 2011	Pipeline Safety: Establishing Maximum Allowable Operating Pressure or Maximum Operating Pressure Using Record Evidence, and Integrity Management Risk Identification, Assessment, Prevention, and Mitigation
ADB-11-02	February 9, 2011	Dangers of Abnormal Snow and Ice Build-up on Gas Distribution Systems

For more PHMSA Advisory Bulletins, go to <http://phmsa.dot.gov/pipeline/regs/advisory-bulletin>

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

239.		.605(b)		COMPRESSOR STATION PROCEDURES			S	U	N/A	N/C
240.		.605(b)(6)	Maintenance procedures, including provisions for isolating units or sections of pipe and for purging before returning to service						X	
241.		.605(b)(7)	Starting, operating, and shutdown procedures for gas compressor units						X	
242.		.731	Inspection and testing procedures for remote control shutdowns and pressure relieving devices (1 per yr/15 months), prompt repair or replacement						X	
243.		.735	(a) Storage of excess flammable or combustible materials at a safe distance from the compressor buildings						X	
244.			(b) Tank must be protected according to NFPA #30						X	
245.		.736	Compressor buildings in a compressor station must have fixed gas detection and alarm systems (must be performance tested), unless:						X	
246.			• 50% of the upright side areas are permanently open, or						X	
247.			• It is an unattended field compressor station of 1000 hp or less						X	

Comments:

Items 239-247 No Compressors In District

COMPRESSOR STATION O&M PERFORMANCE AND RECORDS				S	U	N/A	N/C
248.	.709	.731(a)	Compressor Station Relief Devices (1 per yr/15 months)				X
249.		.731(c)	Compressor Station Emergency Shutdown (1 per yr/15 months)				X
250.		.736(c)	Compressor Stations – Detection and Alarms (Performance Test)				X

Comments:

Items 248-250 No Compressors In District

COMPRESSOR STATIONS INSPECTION (Field)				S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")							
251.	.163	(c)	Main operating floor must have (at least) two (2) separate and unobstructed exits				X
252.			Door latch must open from inside without a key				X
253.			Doors must swing outward				X
254.		(d)	Each fence around a compressor station must have (at least) 2 gates or other facilities for emergency exit				X
255.			Each gate located within 200 ft of any compressor plant building must open outward				X
256.			When occupied, the door must be opened from the inside without a key				X
257.		(e)	Does the equipment and wiring within compressor stations conform to the National Electric Code, ANSI/NFPA 70?				X
258.	.165	(a)	If applicable, are there liquid separator(s) on the intake to the compressors?				X
259.		(b)	Do the liquid separators have a manual means of removing liquids?				X

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field)			S	U	N/A	N/C	
(Note: Facilities may be "Grandfathered")							
260.		If slugs of liquid could be carried into the compressors, are there automatic dumps on the separators, Automatic compressor shutdown devices, or high liquid level alarms?			X		
261.	.167 (a)	ESD system must:					
262.		- Discharge blowdown gas to a safe location			X		
263.		- Block and blow down the gas in the station			X		
264.		- Shut down gas compressing equipment, gas fires, electrical facilities in compressor building and near gas headers			X		
265.		- Maintain necessary electrical circuits for emergency lighting and circuits needed to protect equipment from damage			X		
266.		ESD system must be operable from at least two locations, each of which is:					
267.	.167	- Outside the gas area of the station			X		
268.		- Not more than 500 feet from the limits of the station			X		
269.		- ESD switches near emergency exits?			X		
270.		(b) For stations supplying gas directly to distribution systems, is the ESD system configured so that the LDC will not be shut down if the ESD is activated?			X		
271.		(c)	Are ESDs on platforms designed to actuate automatically by...				
272.			- For unattended compressor stations, when:				
273.			▪ The gas pressure equals MAOP plus 15%?			X	
274.			▪ An uncontrolled fire occurs on the platform?			X	
275.			- For compressor station in a building, when				
276.			▪ An uncontrolled fire occurs in the building?			X	
277.	▪ Gas in air reaches 50% or more of LEL in a building with a source of ignition (facility conforming to NEC Class 1, Group D is not a source of ignition)?			X			
278.	.171	(a) Does the compressor station have adequate fire protection facilities? If fire pumps are used, they must not be affected by the ESD system.			X		
279.		(b) Do the compressor station prime movers (other than electrical movers) have over-speed shutdown?			X		
280.		(c) Do the compressor units alarm or shutdown in the event of inadequate cooling or lubrication of the unit(s)?			X		
281.		(d) Are the gas compressor units equipped to automatically stop fuel flow and vent the engine if the engine is stopped for any reason?			X		
282.		(e) Are the mufflers equipped with vents to vent any trapped gas?			X		
283.	.173	Is each compressor station building adequately ventilated?			X		
284.	.457	Is all buried piping cathodically protected?			X		
285.	.481	Atmospheric corrosion of aboveground facilities			X		
286.	.603	Does the operator have procedures for the start-up and shut-down of the station and/or compressor units?			X		
287.		Are facility maps current/up-to-date?			X		
288.	.615	Emergency Plan for the station on site?			X		
289.	.619	Review pressure recording charts and/or SCADA			X		
290.	.707	Markers			X		
291.	.731	Overpressure protection – relief's or shutdowns			X		
292.	.735	Are combustible materials in quantities exceeding normal daily usage, stored a safe distance from the compressor building?			X		

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field) (Note: Facilities may be "Grandfathered")			S	U	N/A	N/C
293.		Is aboveground oil or gasoline storage tanks protected in accordance with NFPA standard No. 30?			X	
294.	.736	Gas detection – location			X	

Comments:
 Items 251-294 No Compressors In District