

First Revision of Sheet No. 80-cc
Canceling
Original Sheet No. 80-cc

WN U-60

**PUGET SOUND ENERGY
Electric Tariff G**

**SCHEDULE 80
GENERAL RULES AND PROVISIONS
(Continued)**

- (b) The provisions of this section 32 of Schedule 80 do not apply to Interconnection Customers who enter into Interconnection agreements subject to FERC jurisdiction or to Interconnection Customers that operate PURPA qualifying facilities subject to the provisions of chapter 480-107⁽¹⁾ WAC.
- (c) The Interconnection Customer shall obtain all applicable permits, shall comply with all applicable codes for safe and reliable operation and Standards relating to power quality, and the Company's Standards for Interconnection, including Company standard 6325.4000⁽¹⁾. Many of the codes and Standards are referred to in WAC 480-108-020(d)⁽¹⁾. Following reasonable notice, the Company may verify compliance to all applicable codes and Standards at any time.

- (2) Disconnect Switch – The Interconnection Customer shall furnish and install on the Interconnection Customer's side of the PCC a UL®-approved visible-break disconnect switch which meets Company standards and is capable of fully disconnecting the Generating Facility from the Company's system. All visible-break disconnect switches must be located adjacent to the Company's electric meter(s) or other location specified by the Company and must be accessible to the Company at all times. Such visible-break disconnect switches must have the capability to be locked with a padlock installed by the Company.

(N)
|
|
|
|
|
(N)

The Company may waive this requirement if:

- (a) the Interconnection Customer provides Interconnection Facilities that performs internal physical disconnection of the Generating Facility and can demonstrate to the satisfaction of the Company its effectiveness; and
- (b) the Interconnection Customer agrees that Electric Service may be disconnected entirely if the Generating Facility must be physically disconnected for any reason. This agreement constitutes a waiver of the Customer's rights of notice as provided in WAC 480-100-128(3)⁽¹⁾.

- (3) Disconnection Of Generating Facility – The Company shall have the right to disconnect any Generating Facility at the PCC under the following circumstances: (i) to maintain electrical operating conditions, (ii) if the Generating Facility does not meet required Standards or codes, (iii) if the Generating Facility at any time adversely affects or endangers any person, the property of any person, the Company's operation of its electric system or the quality of electric service to any other Customer, or (iv) the Interconnection Customer Interconnects with the Company's system without entering into an Interconnection agreement or without the Company's written approval. Disconnection may occur without notice. Where no disconnect switch is provided this will result in disconnection of Electric Service.

⁽¹⁾ See "Source of Information" on sheet 80-ii or request a copy of this document from the Company

Issued: April 8, 2011
Advice No.: 2011-10

Effective: May 9, 2011

Issued By Puget Sound Energy

By: Tom DeBoer Tom DeBoer

Title: Director, Rates & Regulatory Affairs