OPTIONAL FIELD DATA COLLECTION FORM FOR INTRASTATE INSPECTORS

NOTES-FIELD INSPECTION

Company: Swissport Fueling

Date(s): April 7, 2009-April 9, 2009

Unit: SeaTac Tank Farm

Field Readings									
Line & Location	Line		CP Volts		Rectifier		Pressures		Remarks
	Size	In.	P/S	Casing	Volts	Amps	Set	Actual	
Tank 115 west			-1.18 V						Facility very clean-well coated
Pipe @ Oly		12-inch	-1.15 V						