

Utilities and Transportation Commission

Standard Inspection Report for Intrastate Gas Distribution Systems

Records Review and Field Inspection

A completed **Standard Inspection Checklist, OQ Field Validation Protocol form and Cover Letter/Field Report** are to be submitted to the Chief Engineer within **30 days** from completion of the inspection.

Inspection Report			
Docket Number	110030, King County West - Standard Inspection		
Inspector Name & Submit Date	Patti Johnson, submitted 7-13-2011		
Chief Eng Name & Review/Date	Joe Subsits, 8/17/2011		
Operator Information			
Name of Operator:	Puget Sound Energy	OP ID #:	22189
Name of Unit(s):	W King County		
Records Location:	Bellevue and Georgetown		
Date(s) of Last (unit) Inspection:	April 1, 2009 through June 27, 2009	Inspection Date(s):	June 20, 2011 thru July 6, 2011

Inspection Summary:

PSE plat 190.68C are services to the water. Address at Pier 69, 2701 Alaskan Way south of Clay, then 2820 Alaskan N of clay near Broad is 2801 Alaska Pier 70. Master Meter maybe.

HEADS UP for PSE : Many WNG meters without PSE stickers

HQ Address: PO Box 90868 M/S: EST-07W Bellevue, WA 98009-0868	System/Unit Name & Address: W King county PO Box 90868 M/S: EST-07W Bellevue, WA 98009-0868	
Co. Official: Sue McLain Phone No.: (425) 462-3696 Fax No.: (425) 462-3770 Emergency Phone No.: (425) 882-4692	Phone No.: (425) 462-3877 Fax No.: (425) 462-3770 Emergency Phone No.: (425) 882-4692	
Persons Interviewed	Title	Phone No.
Alan Mulkey	Consulting Engineer	425-462-3889
Brandon Severson	Customer Field Service Tech	206-793-1104
Carl Blythe	Pressure Control	206-571-0281
Cathy Koch	Director	425-462-3877
Cheryl McGrath	Manager	425-462-3207
Darryl Hong	Coordinator	425-766-3388
Dave Montgomery	Corrosion Control Technician	206-571-7905
Dave Schneider	Corrosion Control Technician	206-571-8143
Debbie Larsen	Supervisor	206-766-6803
Don Frieze	Engineer	425-462-3862
Ed Voogt	Corrosion Technologist	425-748-6336
Elaine Griffith	Coordinator (H2RL)	206-766-6783
Gary Swanson	Coordinator (leaks)	206-766-6811
Jerry Games	Engineering Assistant	253-476-6224
John Matchell	Gas Worker Trainee III	253-326-1828
Josie Conzemius	Supervisor	425-456-2181
Justin Wahlborg	Sr Engineer	425-462-3977

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

Ken Brown	Supervisor	206-766-6797
Mark Maass	Manager	425-462-3047
Philip Puzon	Associate Engineer	425-462-3306
Roger Scheetz	Supervisor	206-766-6766
Roy McOmber	Pressure Control	253-377-2293
Sam Gallaway	Pressure Control	206-571-2511
Soon Dye	Sr Engineer	425-462-3863
Stephanie Silva	Consulting Engineer	425-462-3923
Steve Mitchell	Heath Consultants	
Toni Imad	Consulting Engineer	425-456-2970
Trenia Duncan	Coordinator (bridges)	206-766-6784
Duane Henderson	Director Operations Services	425- 462-3974

WUTC staff conducted an abbreviated procedures inspection on 192 O&M and WAC items that changed since the last inspection. This checklist focuses on Records and Field items per a routine standard inspection.

(check one below and enter appropriate date)

<input checked="" type="checkbox"/>	Team inspection was performed (Within the past five years.) or, Docket 100019, November 2010 an O&M review was conducted (Not a team inspection)	Date:	11-2010
<input checked="" type="checkbox"/>	Other WUTC Inspector reviewed the O & M Manual (Since the last yearly review of the manual by the operator.) Docket 100019, November 2010 an O&M review was conducted.	Date:	11-2010

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

GAS SYSTEM OPERATIONS

Gas Supplier	Williams		
Services:	<i>Residential 250,000 estimate Commercial Industrial 2,637 Other</i>		
Number of reportable safety related conditions last year There were no reportable safety related conditions in 2010 in W King	Number of deferred leaks in system 2688 Total for all PSE districts end of 2010		
Number of <u>non-reportable</u> safety related conditions last year Darryl is <u>None</u>	Number of third party hits last year 824 for 2010		
Miles of transmission pipeline within unit (total miles and miles in class 3 & 4 areas) 2,400 ft	Miles of main within inspection unit (total miles and miles in class 3 & 4 areas) 1,839		
Operating Pressure(s):	MAOP (Within last year)	Actual Operating Pressure (At time of Inspection)	
Feeder various			
Town various			
Other various			
Does the operator have any transmission pipelines?	Yes		
Compressor stations? Use Attachment 1.	No		

Pipe Specifications:			
Year Installed (Range)	1925-2011	Pipe Diameters (Range)	½ - 20inch
Material Type	WI, copper, STW, Bare steel, HDPE, MDPE	Line Pipe Specification Used	various
Mileage	1839 approximate	SMYS %	Less than 29%

Operator Qualification Field Validation

Important: Per OPS, the OQ Field Inspection Protocol Form (Rev 3, Feb 08) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA OQ Database (OQDB) located at <http://primis.phmsa.dot.gov/oqdb/home.oq> **Date Completed 6-28 & 29, 2011**

Integrity Management Field Validation

Important: Per PHMSA, IMP Field Verification Form (Rev 3, March 09) shall be used by the inspector as part of this standard inspection. When completed, the inspector will upload this information into the PHMSA IM Database (IMDB) located at <http://primis.phmsa.dot.gov/gasimp/home.gim> **Date Completed: 8-28-2011 Completed as Headquarters Mini inspections**

PART 199 Drug and Alcohol Testing Regulations and Procedures		S	U	NA	NC
Subparts A - C	Drug & Alcohol Testing & Misuse Prevention Program – Use PHMSA Form #13, Rev 3/19/2010. Do not ask the company to have a drug and alcohol expert available for this portion of your inspection. Completed as Headquarters Mini inspections from – Violation will be written under 2011 PSE Sumas inspection		x		

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
1.	49 U.S.C. 60132, Subsection (b)	For Gas Transmission Pipelines and LNG Plants. Submission of Data to the National Pipeline Mapping System Under the Pipeline Safety Improvement Act of 2002 Updates to NMPS: Operators are required to make update submissions every 12 months if any system modifications have occurred. <u>If no modifications have occurred since the last complete submission (including operator contact information), send an email to opsgis@rspa.dot.gov stating that fact.</u> Include operator contact information with all updates.	x			
2.	RCW 81.88.080	Pipeline Mapping System: Has the operator provided accurate maps (or updates) of pipelines, operating over two hundred fifty pounds per square inch gauge, to specifications developed by the commission sufficient to meet the needs of first responders? Last submission 2/22/2011	x			
3.	191.5	Immediate Notice of certain incidents to NRC (800) 424-8802, or electronically at http://www.nrc.uscg.mil/nrchp.html , and additional report if significant new information becomes available. Operator must have a written procedure for calculating an initial estimate of the amount of product released in an accident. PSE has process in place, it is an internal procedure, and the new definition is in Gas Operating Standard 2400.1000. They are continuing to improve process Procedure is – call to dispatch, dispatch dispatches broken and blowing, crew lets them know the size of pipe, they do reporting and part of reporting is to system planning who does calculations. Reviewed Soon Dye's email for guidelines for Response Planning Engineer in re: to 191.3 Uncontrolled Gas Release of 3MMCF or more. Reviewed Gas Loss Calculation The PSE crew reporting procedure does not change because they always report broken and blowing gas and the size of the pipe and dispatch will follow up. Only dispatches procedures changed Reviewed Emergency Plan 2425.2300. and Gas Field Procedures 0100.1040	x			
4.	191.7	Reports (except SRCR and offshore pipeline condition reports) must be submitted electronically to PHMSA at https://opsweb.phmsa.dot.gov at unless an alternative reporting method is authorized IAW with paragraph (d) of this section. PSE reports electronically	x			
5.	191.15(a)	30-day follow-up written reports to PHMSA (Form F7100.2) Submittal must be electronically to http://pipelineonlinereporting.phmsa.dot.gov PSE reports electronically	x			
6.	191.15(c)	Supplemental report (to 30-day follow-up) PSE reports electronically	x			
7.	191.17	Complete and submit DOT Form PHMSA F 7100-2.1 by March 15 of each calendar year for the preceding year. (NOTE: June 15, 2011 for the year 2010). Completely electronic reporting	x			
8.	191.22	Each operator must obtain an OPID, validate its OPIDs, and notify PHMSA of certain events at https://opsweb.phmsa.dot.gov For both Jackson Prairie OPIS #22189 unit 33875 and PSE Distribution the OPID # 22189	x			
9.	191.23	Filing the Safety Related Condition Report (SRCR) None in 2010	x			
10.	191.25	Filing the SRCR within 5 days of determination, but not later than 10 days after discovery	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
11.	.605(d)	Instructions to enable operation and maintenance personnel to recognize potential Safety Related Conditions Field personnel keep Gas Operating Standard with them (Manual 2425.1200). Tail Gate meeting and RPE (Response plan and Engineering) and in mock training for emergency procedure training which may include or if escalated could turn into a safety related conditions. Reviewed 2010 scenario test and OQ test for broken service. This is found in emergency procedure training, it is in OQ and employees are given written test on scenario.	x			
12.	191.27	Offshore pipeline condition reports – filed within 60 days after the inspections No offshore	x			
13.	192.727(g)	Abandoned facilities offshore, onshore crossing commercially navigable waterways reports	x			
14.	480-93-200(1)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9146 (Within 2 hours) for events which results in;				
15.	480-93-200(1)(a)	A fatality or personal injury requiring hospitalization; Reporting, none in 2010	x			
16.	480-93-200(1)(b)	Damage to property of the operator and others of a combined total exceeding fifty thousand dollars; Reporting, none in 2010	x			
17.	480-93-200(1)(c)	The evacuation of a building, or high occupancy structures or areas; Reporting, none in 2010	x			
18.	480-93-200(1)(d)	The unintentional ignition of gas; Reporting, none in 2010	x			
19.	480-93-200(1)(e)	The unscheduled interruption of service furnished by any operator to twenty five or more distribution customers; Reporting, none in 2010	x			
20.	480-93-200(1)(f)	A pipeline pressure exceeding the MAOP plus ten percent or the maximum pressure allowed by proximity considerations outlined in WAC 480-93-020; One in 2010	x			
21.	480-93-200(1)(g)	Is significant, in the judgment of the operator, even though it does not meet the criteria of (a) through (f) of this subsection; Reporting, none in 2010, one in 2011 for damaged 16" in Seattle	x			
22.	480-93-200(2)	Telephonic Reports to UTC Pipeline Safety Incident Notification 1-888-321-9146 (Within 24 hours) for;				
23.	480-93-200(2)(a)	The uncontrolled release of gas for more than two hours;	x			
24.	480-93-200(2)(b)	The taking of a high pressure supply or transmission pipeline or a major distribution supply gas pipeline out of service;	x			
25.	480-93-200(2)(c)	A gas pipeline operating at low pressure dropping below the safe operating conditions of attached appliances and gas equipment; or	x			
26.	480-93-200(2)(d)	A gas pipeline pressure exceeding the MAOP	x			
27.	480-93-200(4)	Did written incident reports (within 30 days of telephonic notice) include the following				
28.	480-93-200(4)(a)	Name(s) and address(es) of any person or persons injured or killed, or whose property was damaged;	x			
29.	480-93-200(4)(b)	The extent of injuries and damage;	x			
30.	480-93-200(4)(c)	A description of the incident or hazardous condition including the date, time, and place, and reason why the incident occurred. If more than one reportable condition arises from a single incident, each must be included in the report;	x			
31.	480-93-200(4)(d)	A description of the gas pipeline involved in the incident or hazardous condition, the system operating pressure at that time, and the MAOP of the facilities involved;	x			
32.	480-93-200(4)(e)	The date and time the gas pipeline company was first notified of the incident;	x			
33.	480-93-200(4)(f)	The date and time the ((operators')) gas pipeline company's first responders arrived on-site;	x			
34.	480-93-200(4)(g)	The date and time the gas ((facility)) pipeline was made safe;	x			
35.	480-93-200(4)(h)	The date, time, and type of any temporary or permanent repair that was made;	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

REPORTING RECORDS			S	U	N/A	N/C
36.	480-93-200(4)(i)	The cost of the incident to the ((operator)) gas pipeline company;	x			
37.	480-93-200(4)(j)	Line type;	x			
38.	480-93-200(4)(k)	City and county of incident; and	x			
39.	480-93-200(4)(l)	Any other information deemed necessary by the commission.	x			
40.	480-93-200(5)	Supplemental report if required information becomes available after 30 day report submitted	x			
41.	480-93-200(6)	Written report within 5 days of receiving the failure analysis of any incident or hazardous condition due to construction defects or material failure PSE sends internal failure analysis to UTC within 5 days of completion.	x			
42.	480-93-200(7)	Annual Reports filed with the commission no later than March 15 for the proceeding calendar year				
43.	480-93-200(7)(a)	A copy of PHMSA F-7100.1-1 and F-7100.2-1 annual report required by U.S. Department of Transportation, PHMSA/Office of Pipeline Safety	x			
44.	480-93-200(7)(b)	Damage Prevention Statistics Report including the following;				
45.	480-93-200(7)(b)(i)	Number of gas-related one-call locate requests completed in the field;	x			
46.	480-93-200(7)(b)(ii)	Number of third-party damages incurred; and	x			
47.	480-93-200(7)(b)(iii)	Cause of damage, where cause of damage is classified as one of the following: (A) Inaccurate locate; (B) Failure to use reasonable care; (C) Excavated prior to a locate being conducted; or (D) Other.	x			
48.	480-93-200(7)(c)	Reports detailing all construction defects and material failures resulting in leakage. Categorizing the different types of construction defects and material failures. The report must include the following: (i) Types and numbers of construction defects; and (ii) Types and numbers of material failures.	x			
49.	480-93-200(8)	Providing updated emergency contact information to the commission and appropriate officials of all municipalities where gas pipeline companies have facilities	x			
50.	480-93-200(9)	Providing by email, reports of daily construction and repair activities no later than 10:00 a.m.	x			
51.	480-93-200(10)	Submitting copy of DOT Drug and Alcohol Testing MIS Data Collection Form when required	x			

Comments:

CUSTOMER and EXCESS FLOW VALVE INSTALLATION NOTIFICATION			S	U	N/A	N/C
52.	192.16	Customer notification - Customers notified, within 90 days , of their responsibility for those service lines not maintained by the operator	x			
53.	192.381	Does the excess flow valve meet the performance standards prescribed under §192.381?	x			
54.	192.383	Does the operator have an installation and reporting program for excess flow valves and does the program meet the requirements outlined in §192.383? Are records adequate?	x			

Comments:

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

--

CONSTRUCTION RECORDS			S	U	N/A	N/C
55.	480-93-013	OQ records for personnel performing New Construction covered tasks Reviewed IP job#109047032. Reviewed Donald Durand welding/fusion records for entire job. Ok. this is a wrought iron main replacement job. PSE replaced existing 4" wrought iron with 8" IP pe. 60 MAOP. Reviewed air test of the 2500 feet at one time to 96psig for 8 hours. Testing information is found in O&M 2525 3300 Section 5 table 5.1 Job Located on E Marginal Way S. installed 2500 feet of 8" pe. Reviewed Pipeline Qualification Evaluation Completion Form for Pierce	x			
56.	192.225	Test Results to Qualify Welding Procedures	x			
57.	192.227	Welder Qualification	x			
58.	480-93-080(1)(b)	Appendix C Welders re-qualified 2/Yr (7.5Months)	x			
59.	480-93-080(2)	Plastic pipe joiners re-qualified 1/Yr (15 Months)	x			
60.	480-93-080(2)(b)	Plastic pipe joiners re-qualified if no production joints made during any 12 month period O&M 2700.1600.Section 6 and 7 PSE does not track every joint. PSE does have test done on a production joint in field and signs their qualification data card, or tested at union hall. This is procedure even if fuser has done joint every day, joints are not tracked. Contractor doing the same. . Reviewed crew sheets for the 3 construction jobs reviewed. The information links how to get welder fuser linked to job since their name does not appear on the job. It shows who was on the job. Going forward welder fuser will sign off for each fuse on form	x			
61.	480-93-080(2)(c)	Tracking Production Joints or Re-qualify joiners 1/Yr (12Months) No, always retest. If practical, test is done in field on job by welding test person	x			
62.	480-93-115(2)	Test leads on casings (without vents) installed after 9/05/1992 PSE only installs casing under special circumstances. Since 1992 all casing installed have test leads.	x			
63.	480-93-115(3)	Sealing ends of casings or conduits on transmission lines and mains Yes, per PSE O&M standards	x			
64.	480-93-115(4)	Sealing ends (nearest building wall) of casings or conduits on services	x			
65.	192.241(a)	Visual Weld Inspector Training/Experience Reviewed Visual Inspector Qualifications Dates	x			
66.	192.243(b)(2)	Nondestructive Technician Qualification	x			
67.	192.243(c)	NDT procedures NDT on over 40% SYMS, PSE also does visual on all welds and fusions, O&M 2700.1200.	x			
68.	192.243(f)	Total Number of Girth Welds	x			
69.	192.243(f)	Number of Welds Inspected by NDT	x			
70.	192.243(f)	Number of Welds Rejected	x			
71.	192.243(f)	Disposition of each Weld Rejected	x			
72.	.273/.283	Qualified Joining Procedures Including Test Results	x			
73.	192.303	Construction Specifications	x			
74.	192.325 WAC 480-93-178(4)(5)	Underground Clearances	x			
75.	192.327	Amount, location, cover of each size of pipe installed	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CONSTRUCTION RECORDS			S	U	N/A	N/C
76.	480-93-160(1)	Report filed 45 days prior to construction or replacement of transmission pipelines ≥ 100 feet in length	x			
77.	480-93-160(2)	Did report describe the proposed route and the specifications for the pipeline and must include, but is not limited to the following items:	x			
78.	480-93-160(2)(a)	Description and purpose of the proposed pipeline;	x			
79.	480-93-160(2)(b)	Route map showing the type of construction to be used throughout the length of the line, and delineation of class location as defined in 49 CFR Part 192.5, and incorporated boundaries along the route.	x			
80.	480-93-160(2)(c)	Location and specification of principal valves, js, and other auxiliary equipment to be installed as a part of the pipeline system to be constructed	x			
81.	480-93-160(2)(d)	MAOP for the gas pipeline being constructed;	x			
82.	480-93-160(2)(e)	Location and construction details of all river crossings or other unusual construction requirements encountered en route.	x			
83.	480-93-160(2)(f)	Proposed corrosion control program to be followed inc specs for coating and wrapping, and method to ensure the integrity of the coating using holiday detection equipment;	x			
84.	480-93-160(2)(g)	Welding specifications; and	x			
85.	480-93-160(2)(h)	Bending procedures to be followed if needed.	x			
86.	480-93-170(1)	Commission notified 2 days prior to pressure testing pipelines with an MAOP producing a hoop stress $\geq 20\%$ SMYS?	x			
87.	480-93-170(7)	Pressure tests records at a minimum include required information listed under 480-93-170(a-h) Reviewed Report of Pressure Test on New Main for HP Job 109044323	x			
88.	480-93-170(9)	Individual pressure test records maintained for single installations where multiple pressure tests were performed? The last W King inspection was conducted in 2009. Reviewed 2010 up rates for both Pierce and W King. There were none in W King. There will be probable violation of WAC 480-93-155 (b) and 192 subpart K in Pierce inspection for not having original pressure test in information. There were no uprates in W King county	x			
89.	480-93-170(10)	Pressure Testing Equipment checked for accuracy/intervals (Manufacturers Rec or Operators schedule) Calibration dates on each pressure test as well as calibration history	x			
90.	480-93-175(2)	Study prepared and approved prior to moving and lowering of metallic pipelines > 60 psig PSE Engineering does not lower pipe	x			
91.	480-93-175(4)	Leak survey within 30 days of moving or lowering pipelines ≤ 60 psig	x			

Comments:

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
92.	192.517(a)	Pressure Testing (operates at or above 100 psig) – useful life of pipeline	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
93.	192.517(b)	Pressure Testing (operates below 100 psig, service lines, plastic lines) – 5 years	x			
94.	192.605(a)	Procedural Manual Review – Operations and Maintenance (1 per yr/15 months) Note: Including review of OQ procedures as <u>suggested</u> by PHMSA - ADB-09-03 dated 2/7/09 Every standard number and every procedure is reviewed, O&M and Field Procedure is individually reviewed annually. Specifically reviewed OQ #7600,1000.	x			
95.	192.605(b)(3)	Availability of construction records, maps, operating history to operating personnel Yes, computer maps are updated and 1st responders can sign onto system and see. To streamline procedure for 1st responders they are given a CD and upload them so they can view on desktop. Reviewed form titled Notification 10837264 Once a month all crews given a disc to update computer maps. Some PSE employees prefer to use hard copy maps and those maps are only updated once a year.	x			
96.	480-93-018(3)	Records, including maps and drawings updated within 6 months of completion of construction activity? Yes, Mark explained process, Every 2 months Mapping review pressure test completion date and job completion date and update map at that time. Completion date starts the 6 months. Occasionally a job gets held up in mapping and they have to get job from billing to complete within 6 months. HEATH found potential mapping error. 6-27-2011 reviewed mapping history with mapping, mapping personnel Mark and Jessie are going to see if Heath notified them of mapping error any time since 1980. Heath did not notify of this error. No PV since combination of old errors and Heath did mark the error on the map. History: Service at 1424 was originally installed 1965. The main was replaced in 1980 and the service became a stub and was left on map, actually the service has been totally removed and should have been taken off the map when the cast iron main was replaced with pe. In 1999 a new service was installed at 1424 1st and it was mapped incorrectly on 3rd instead of on 1st, this made the incorrectly mapped stub an active service. This service should not have been on the map since 1980.	x			
97.	192.605(b)(8)	Periodic review of personnel work – effectiveness of normal O&M procedures Reviewed Quality Insurance Report. Conducted on all HP work and random intermediate work.	x			
98.	192.605(c)(4)	Periodic review of personnel work – effectiveness of abnormal operation procedures Reviewed Quality Insurance Report. Conducted on all HP work and random intermediate work.	x			
99.	192.609	Class Location Study (If applicable) NA in W King	x			
100.	192.611	Confirmation or revision of MAOP	x			
101.	192.614	Damage Prevention (Operator Internal Performance Measures) A Headquarters inspection for Damage Prevention to be conducted 7-26 thru 7-28, 2011				
102.		Does the operator have a quality assurance program in place for monitoring the locating and marking of facilities? Do operators conduct regular field audits of the performance of locators/contractors and take action when necessary? (CGA Best Practices v. 6.0, Best Practice 4-18. Recommended only, not required)	x			
103.		Does operator including performance measures in facility locating services contracts with corresponding and meaningful incentives and penalties?	x			
104.		Do locate contractors address performance problems for persons performing locating services through mechanisms such as re-training, process change, or changes in staffing levels?	x			
105.		Does the operator periodically review the Operator Qualification plan criteria and methods used to qualify personnel to perform locates?	x			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

OPERATIONS and MAINTENANCE RECORDS			S	U	N/A	N/C
106.		Review operator locating and excavation <u>procedures</u> for compliance with state law and regulations.	x			
107.		Are locates are being made within the timeframes required by state law and regulations? Examine record sample.	x			
108.		Are locating and excavating personnel properly <u>qualified</u> in accordance with the operator's Operator Qualification plan and with federal and state requirements?	x			
		Follow-up inspection performed on the pipeline where there is reason to believe the pipeline could be damaged .614(c) (6) 1. Is the inspection the done as frequently as necessary during and after the activities to verify the integrity of the pipeline? 2. In the case of blasting, does the inspection include leakage surveys?	x			
109.		Informational purposes only. Not Required. Does the pipeline operator voluntarily submit pipeline damage statistics into the UTC Damage Information Reporting Tool (DIRT)? Operator may register at https://identity.damagereporting.org/cgareg/control/login.do Y x N	x			

Comments:

Emergency Response Plans			S	U	N/A	N/C
110.						
111.	192.603(b)	Prompt and effective response to each type of emergency .615(a)(3) Note: Review operator records of previous accidents and failures including third-party damage and leak response	x			
112.	192.615(b)(1)	Location Specific Emergency Plan	x			
113.	192.615(b)(2)	Emergency Procedure training, verify effectiveness of training	x			
114.	192.615(b)(3)	Employee Emergency activity review, determine if procedures were followed.	x			
115.	192.615(c)	Liaison Program with Public Officials	x			
116.	192.616	Public Awareness Program				
117.	192.616(e&f)	Documentation properly and adequately reflects implementation of operator's Public Awareness Program requirements - Stakeholder Audience identification, message type and content, delivery method and frequency, supplemental enhancements, program evaluations, etc. (i.e. contact or mailing rosters, postage receipts, return receipts, audience contact documentation, etc. for emergency responder, public officials, school superintendents, program evaluations, etc.). See table below:	x			
118.		Operators in existence on June 20, 2005, must have completed their written programs no later than June 20, 2006. See 192.616(a) and (j) for exceptions.	x			
119.		API RP 1162 Baseline* Recommended Message Deliveries	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

120.		Stakeholder Audience (LDC's)	Baseline Message Frequency (starting from effective date of Plan)	x			
		Residence Along Local Distribution System	Annual				
		LDC Customers	Twice annually				
		One-Call Centers	As required of One-Call Center				
		Emergency Officials	Annual				
		Public Officials	3 years				
		Excavator and Contractors	Annual				
		Stakeholder Audience (Transmission line operators)	Baseline Message Frequency (starting from effective date of Plan)				
		Residence Along Local Distribution System	2 years				
		One-Call Centers	As required of One-Call Center				
		Emergency Officials	Annual				
		Public Officials	3 years				
		Excavator and Contractors	Annual				
		121.					
122.	192.616(g)	The program conducted in English and any other languages commonly understood by a significant number of the population in the operator's area.		x			
123.	.616(h)	IAW API RP 1162, the operator's program should be reviewed for effectiveness within four years of the date the operator's program was first completed. For operators in existence on June 20, 2005, who must have completed their written programs no later than June 20, 2006, the first evaluation is due no later than June 20, 2010 . .616(h)		x			
124.	192.616(j)	Operators of a Master Meter or petroleum gas system – public awareness messages 2 times annually: (1) A description of the purpose and reliability of the pipeline; (2) An overview of the hazards of the pipeline and prevention measures used; (3) Information about damage prevention; (4) How to recognize and respond to a leak; and (5) How to get additional information. This is a master meter responsibility not the LDCs				x	
125.	192.617	Review operator records of accidents and failures including laboratory analysis where appropriate to determine cause and prevention of recurrence .617 Note: Including excavation damage and leak response records (PHMSA area of emphasis) (NTSB B.10) Internal analysis sent to UTC. No failures sent out to laboratories. Joe stated review of internal records will be special inspection.		x			

Comments:

126.	192.619/621/623	Maximum Allowable Operating Pressure (MAOP) Note: New PA-11 design criteria is incorporated into 192.121 & .123 (Final Rule Pub. 12/24/08) At this time does not use PA-11 and no plans to use in immediate future	x				
------	-----------------	---	---	--	--	--	--

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

127.	480-93-015(1)	Odorization of Gas – Concentrations adequate O&M 2650.1000 7.4, 8 test sites in W King County – Yes, adequate Reviewed SAP Odor Test Site Monthly reads for all eight sites for 2009 and 2010.	x			
128.	480-93-015(2)	Monthly Odorant Sniff Testing Yes, adequate Reviewed SAP Odor Test Site Monthly reads for all eight sites for 2009 and 2010	x			
129.	480-93-015(3)	Prompt action taken to investigate and remediate odorant concentrations not meeting the minimum requirements None but if there were they would follow O&M 2650.1000 8.3	x			
130.	480-93-015(4)	Odorant Testing Equipment Calibration/Intervals (Annually or Manufacturers Recommendation) Reviewed SAP Odorator calibration for 2009 and 2010	x			
131.	480-93-124(3)	Pipeline markers attached to bridges or other spans inspected? 1/yr(15 months) Are inspected on the Bridge and Slide Patrols quarterly or 2x a year depending on location	x			
132.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days? Replace when found missing if possible.	x			
133.	480-93-140(2)	Service regulators and associated safety devices tested during initial turn-on Documented on Meter Information Tag	x			
134.	480-93-155(1)	Up-rating of system MAOP to >60 psig? Procedures and specifications submitted 45 days prior?	x			
135.	480-93-185(1)	Reported gas leaks promptly investigated? Graded in accordance with 480-93-186? Records retained? Leak found during Heath OQ at 5113 116th St SE was above ground seep. Heath called it an A leak, called 1st Response. 1st response called no hazardous above ground release of gas, they rebuilt meter, checked inside house, checked at foundation etc. They did not fill out a leak work order (leak not graded just repaired), just made repair on CLX order #419611473. 2010 PHMSA required the reporting of above ground non hazardous release of gas reporting (Not called leak because fixed by pipe dope, O&M 2625.1300 Section 4.3)	x			
136.	480-93-185(3)(a)	Leaks originating from a foreign source. Take appropriate action to protect life and property regarding the pipeline company's own facilities, and; Reviewed foreign leak at 1080 W Ewing St and heath is sent with their equipment that detects ethane. Test proves it does not have ethane and therefore is not natural gas. Leak Survey personnel gets report back to employee who reported it.	x			
137.	480-93-185(3)(b)	Leaks originating from a foreign source reported promptly/notification by mail. Records retained? Reviewed letter on computer	x			
138.	480-93-186(3)	Leak evaluations: Are follow-up inspections performed within 30 days of a leak repair?	x			
139.	480-93-186(4)	Leak evaluations: Grade 1 and 2 leaks (if any), downgraded once to a grade 3 without physical repair? The Leak Management system only allows leak to be downgraded once time. Then if someone tries system will not allow. When system does not allow it to be downgraded a second time the person doing the entering makes a comment to that effect and referencing the standard., Reviewed letter on computer that is sent if no adult home	x			
140.	480-93-187	Gas leak records: at a minimum include required information listed under 480-93-187(1-13) Verified on form	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

141.	480-93-188(1)	<p>Gas leak surveys Prior to 2010 PSE documented equipment SN on form titled Leakage Survey Report. Was reported weekly that included the SN. PSE could not prove which instrument was used for leak survey. SN not directly related to plat leak survey maps. This would have been probable violation however, in 2010 as part of the leak survey audit and quality assurance internal inspection PSE starting using document titled Leakage Survey Documentation and it does include SN of instrument used for each plat.</p> <p>Process is for every leak found on plat a Heath fills out Heath Consultant Leakage Control Report Field Survey. Reviewed 3 forms for leaks found on plat 190.068A</p> <p>Reviewed leak survey plat 190.68A. Heath found 3 leaks and did one reevaluation of existing leak (grade c)</p> <p>Also, On plat 190.68A there was a reevaluate leak that was not checked. A form titled Primary recheck All with reevaluation on it was filled out at time of leak survey. These forms are sent with operations map (not plat)</p> <p>2nd leak survey map buss dist inspection. Reviewed plat 190-68C, completed 9/21/2009. Reviewed associated leak N0034187. Also Reviewed 30 day recheck for 30 day checks for 10/21,2009;11/20/2009 and 12/17/2009. Good</p> <p>Reviewed plat 190-68F, no leaks found. A mobile unit was used.</p> <p>During field inspection with Heath, Noted OMD as SN 1017. This is a mobile Optical Methane detector (OMD) Steve J Mitchell on 11/12/2009. Conducted OMD calibration OQ test on 1-28-2011</p>	x			
142.	480-93-188(2)	<p>Gas detection instruments tested for accuracy/intervals (Mfct recommended or monthly not to exceed 45 days) Reviewed calibration including preformed a oq test on the mobile calibration</p>	x			
143.	480-93-188(3)	Leak survey frequency (Refer to Table Below)	x			
		Business Districts (implement by 6/02/07)				
		High Occupancy Structures				1/yr (15 months)
		Pipelines Operating ≥ 250 psig				1/yr (15 months)
		Other Mains: CI, WI, copper, unprotected steel				2/yr (7.5 months)
WAC 480-93-188(3)(d) Gas leak surveys						
Copper service leak survey., 2008 follow up, 42 service , they are on several different maps. Not all in W king, of the 42 four of them are in different districts. Reviewed spreadsheet of copper services; spreadsheet made from plat review per agreed in 2009 inspection: . Reviewed map 198065, it has 2 services, both on 42 nd and on map that twice annually leak surveys maps (isolated, wrapped steel, etc.) Reviewed map 197-65A one copper service on this map; reviewed map 196.064, three on this map; on maps marked as cu or copper; two on map ?plat number; Plat 197-64C has one service and one cu service removed; Plat 197064C has 3 services. Have copy of copper service. Of original 42 service, in King county 2 have been removed or replace. New total is 38.						
144.	480-93-188(4)(a)	Special leak surveys - Prior to paving or resurfacing, following street alterations or repairs NONE IN W KING	X			
145.	480-93-188(4)(b)	Special leak surveys - areas where substructure construction occurs adjacent to underground gas facilities, and damage could have occurred NONE IN W KING	X			
146.	480-93-188(4)(c)	Special leak surveys - Unstable soil areas where active gas lines could be affected NONE IN W KING	X			
147.	480-93-188(4)(d)	Special leak surveys - areas and at times of unusual activity, such as earthquake, floods, and explosions NONE IN W KING	X			
148.	480-93-188(4)(e)	Special leak surveys - After third-party excavation damage to services, operators must perform a gas leak survey from the point of damage to the service tie-in NONE IN W KING	X			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

149.	480-93-188(5)	Gas Survey Records (Min 5 yrs) and at a minimum include required information listed under 480-93-188 (5) (a-f) Outside buss district leak survey COMPLETED 9/22/08. Heath leak survey map had services crossed out and notes. Requested history. 6-27-2011 reviewed mapping history with mapping, mapping personnel Mark and Jessie History: Service at 1424 was originally installed 1965. The main was replaced in 1980 and the service became a stub and was left on map, actually the service has been totally removed and should have been taken off the map when the cast iron main was replaced with pe. In 1999 a new service was installed at 1424 1st and it was mapped incorrectly on 3rd instead of on 1st, this made the incorrectly mapped stub an active service. This service should not have been on the map since 1980.	x															
150.	480-93-188(6)	Leak program - Self Audits Reviewed 2010 Continuing Surveillance Annual report. Then this information goes to new Gas System Integrity, dept made of maint planning, system planning, corrosion and DIMP employees.	x															
151.	192.709	Patrolling (Transmission Lines) (Refer to Table Below) .705	x															
<table border="1"> <thead> <tr> <th>Class Location</th> <th>At Highway and Railroad Crossings</th> <th>At All Other Places</th> </tr> </thead> <tbody> <tr> <td>1 and 2</td> <td>2/yr (7½ months)</td> <td>1/yr (15 months)</td> </tr> <tr> <td>3</td> <td>4/yr (4½ months)</td> <td>2/yr (7½ months)</td> </tr> <tr> <td>4</td> <td>4/yr (4½ months)</td> <td>4/yr (4½ months)</td> </tr> </tbody> </table> <p>Transmission Patrols only 7 miles in entire system. In w king only 2400 feet. Reviewed Transmission Patrol Report Located at Renton on SW10th. Patrolled quarterly, and 2 annual leak surveys. Reviewed Transmission Patrol Report on 7/24/2011. They found uprooted / also noted appropriate dept that digging going on in r/w on 12/16/10. Also once a year do HCA evacuation with the patrol. (q 172)</p>							Class Location	At Highway and Railroad Crossings	At All Other Places	1 and 2	2/yr (7½ months)	1/yr (15 months)	3	4/yr (4½ months)	2/yr (7½ months)	4	4/yr (4½ months)	4/yr (4½ months)
Class Location	At Highway and Railroad Crossings	At All Other Places																
1 and 2	2/yr (7½ months)	1/yr (15 months)																
3	4/yr (4½ months)	2/yr (7½ months)																
4	4/yr (4½ months)	4/yr (4½ months)																
152.	192.709	Leak Surveys (Transmission Lines) (Refer to Table Below) .706	x															
<table border="1"> <thead> <tr> <th>Class Location</th> <th>Required</th> <th>Not Exceed</th> </tr> </thead> <tbody> <tr> <td>1 and 2</td> <td>1/yr</td> <td>15 months</td> </tr> <tr> <td>3</td> <td>2/yr</td> <td>7½ months</td> </tr> <tr> <td>4</td> <td>4/yr</td> <td>4½ months</td> </tr> </tbody> </table>							Class Location	Required	Not Exceed	1 and 2	1/yr	15 months	3	2/yr	7½ months	4	4/yr	4½ months
Class Location	Required	Not Exceed																
1 and 2	1/yr	15 months																
3	2/yr	7½ months																
4	4/yr	4½ months																
153.	192.603(b)	Patrolling Business District (4 per yr/4½ months) .721(b)(1) O&M 2575. 3100 PSE does do bridge and slides patrols O&M 2575.3100 3.1.1. PSE informed this will be looked at extensively in Pierce inspection	x															
		Transmission Patrols only 7 miles in entire system. In w king only 2400 feet. Reviewed Transmission Patrol Report Located at Renton on SW10th. Patrolled quarterly, and 2 annual leak surveys. Reviewed Transmission Patrol Report on 7/24/2011. They found uprooted / also noted appropriate dept that digging going on in r/w on 12/16/10. Also once a year do HCA evacuation with the patrol. (q 172) Review Mobile Home Park Patrol for Horseshoe Acres Mobile Homes at 1540 Maple LN completed 3/9/2009. Mapping reviewed, was updated for 2009 inspection. New atmospheric corrosion plan into effect 2009, O&M, Field and documentation not connected. PSE informed this will be looked at extensively in Pierce	x															
		Review Mobile Home Park Patrol for Horseshoe Acres Mobile Homes at 1540 Maple LN completed 3/9/2009. Mapping reviewed, was updated from 2009 inspection. Transmission Patrols only 7 miles in entire system. In w king only 2400 feet. Reviewed Transmission Patrol Report Located at Renton on SW10th. Patrolled quarterly, and 2 annual leak surveys. Reviewed Transmission Patrol Report on 7/24/2011. They found uprooted / also noted appropriate dept that digging going on in r/w on 12/16/10. Also once a year do HCA evacuation with the patrol. (q 172)	x															

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

154.	192.603(b)	Patrolling Outside Business District (2 per yr/7½ months) 192.721(b)(2) All patrols are called Bridge and Slide patrols. They are done quarterly or 2x a year.	x			
155.	192.603(b)	Leakage Survey - Outside Business District (5 years) 192.723(b)(1) Reviewed 4 plats off of operation map 188.068: first plat is 188.068, done by W Jeff Morphis were isolated services. Then reviewed same map 5 year survey	x			
156.	192.603(b)	Leakage Survey 192.723(b)(2) <ul style="list-style-type: none"> • Outside Business District (5 years) reviewed Map 188.068A done by John Pinkston on 9/22 and 9/23/2008. Next 5 year scheduled in Aug 2011. On report there were 3 unprotected located (circled on map means semiannual leak survey) 111 Tower place, 1421 2 Ave N, and a stub located on 3rd Ave N. <p>Reviewed Can't get in locations and copy (have copy) of letter titled Inspection Notice: that is sent to customer to get in. for leaks Heath is responsible - similar process for atmospheric corrosion</p> <ul style="list-style-type: none"> • PSE provided list called "hard to reach location program. See O&M 2600.1800 3.1.2. These are areas where meter is hard to get to for both atmospheric and leak survey and special arrangements are made every year for entry. • A separate list for hard to reach locations that require special equipment. It is in bridge and slide program • Catholically unprotected distribution lines (3 years) Reviewed plat 188.068A had 2 unprotected services leak survey in 9/2009. • <p>To verify that HOS out of buss dist are leak surveyed billing code tells if new HOS, this list goes to Heath and Heath confirms whether or not it is an HOS and if in or out of buss dist. Heath reports back to confirm that the list is actually HOSS. And from that list every year they do HOS outside buss district leak surveys. NOTE: NAICS and billing code are the same thing. NAICS is used for turning valves</p>	X			
157.	192.603(b)	Tests for Reinstating Service Lines 192.725	x			
158.	192.603(b)/.727(g)	Abandoned Pipelines; Underwater Facility Reports 192.727 none			x	
159.	192.709	Pressure Limiting and Regulating Stations (1 per yr/15 months) .739 Reviewed Gas System Supply MAOP Map	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

160.	192.709	<p>Pressure Limiting and Regulator Stations – Capacity (1 per yr/15 months) .743 To determine if parameters are the same review, Review SAP components, orifice, as-built and anything new added; MAOP records in and out, check for uprates; in rare cases get information from field. Reviewed Master Relief List</p> <p>Capacity review documentation as required in 2575.1000, and showing doc parameters have not changed or new calculation Reviewed 2010 Relief Review Cover Sheet that lists the capacity review and what was checked to verify that the parameters of the system have not changed</p> <p>W King have 600 plus in whole system. W King about 150 reg stations.</p> <p>Reviewed and have list of reg stations and inspection times.</p> <p>Reviewed RS-0378 station, and all associated valves. Reviewed RS 0463 annual done 11-5-10 and it was also painted then. Note: on by valves that are not with station but in street usually have to go back on Sunday am to check because of traffic RS 0724 failed lock up so replaced boots and had good lock up when left, this one has historic problem with debri, could be from main. : valve turned hard but was turned RS0792 all ok RS1083, farm tap all ok, special provisions to know how to read RS1200 has second valve that needs number. Valve numbers are requested by email from engr. This RS now has 2 outlet valves because a second main was installed. Now this RS has 2 valve numbers.</p> <p>Farm taps that are not district regulators are checked every 3 years by pressure control. They are checked out as much as possible. If they have by pass pressure control tests the pressure.</p> <p>Reviewed Reg stations The ones that are filled with water. 277th and W Valley Hwy</p> <p>LOCK UP ALWAYS 3 LBS UNDER MOP REGARDLESS OF THE MAOP.</p> <p>THEY DO COLD WEATHER FROM TRUCK AND OTHERS DO LNG. PLANNING KNOWS LOW PRESSURE AND INJECTION SITES ARE PRE BUILT AND THEN THEY HOOK UP TO INJECTION SITE. USE 2 INCH HOSE</p>	x			
161.	192.709	<p>Valve Maintenance – Transmission (1 per yr/15 months) .745 W King has transmission over 20%</p>	x			
162.	192.709 PV see question 157	<p>Valve Maintenance – Distribution (1 per yr/15 months) .747 O&M states HOS for valves impractical to list all HOS valves–PSE explained that the systems do not talk to one another. New systems being implemented. After research PSE found that the billing code for HOS structures is the same and NAICS code. Since they use the same list the O&M will be updated.</p> <p>Reviewed EOP valves. Dist EOP valves turned done by 1st responders.</p>	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

163.	480-93-100(3)	Service valve maintenance (1 per yr/15 months) FOR HOS PSE only turns valves on HOS that are hard to evacuate per O&M 2575.1200 3.2.6 NAICS (American Industry Classifications System) codes (this is PSE system that tells which are HOS) these codes classify any structure ::: then look at PSE definition in 2575.1200 3.2.6.1 “:add new ones as determined by CLX::: check both service valve and riser valve :::: contractor gets list annually in past from CLX going forward from SAP to do survey and in past printed from access data base (information held there):: there are due dates in CLX . Review W king county service valves for 2009 and 2010.	x			
164.	192.709	Vault maintenance (≥200 cubic feet)(1 per yr/15 months) .749 No vaults over 200 cubic feet	x			
165.	192.603(b)	Prevention of Accidental Ignition (hot work permits) .751 The pump in air, let control know location, have fire ext by vault	x			
166.	192.603(b)	Welding – Procedure 192.225(b)	x			
167.	192.603(b)	Welding – Welder Qualification 192.227/.229	x			
168.	192.603(b)	NDT – NDT Personnel Qualification .243(b)(2)	x			
169.	192.709	NDT Records (pipeline life) .243(f)	x			
170.	192.709	Repair: pipe (pipeline life); Other than pipe (5 years)	x			
171.	192.905(c)	Periodically examining their transmission line routes for the appearance of newly identified area’s (HCA’s) Transmission Patrols only 7 miles in entire system. In w king only 2400 feet. Reviewed Transmission Patrol Report Located at Renton on SW10th. Patrolled quarterly, and 2 annual leak surveys. Reviewed Transmission Patrol Report on 7/24/2011. They found uprooted / also noted appropriate dept that digging going on in r/w on 12/16/10. Also once a year do HCA evacuation with the patrol.	x			

Comments:

CORROSION CONTROL RECORDS			S	U	N/A	N/C
172.	192.455(a)(1)	Pipeline coatings meet requirements of 192.461 (for buried pipelines installed after 7/31/71)	x			
173.	192.455(a)(2)	CP system installed on and operating within 1 yr of completion of pipeline construction (after 7/31/71)	x			
174.	192.465(a)	Annual Pipe-to-soil Monitoring (1 per yr/15 months) for short sections (10% per year; all in 10 years)	x			
175.	192.491	Test Lead Maintenance .471	x			
176.	192.491	Maps or Records .491(a)	x			
177.	192.491	Examination of Buried Pipe when exposed .459	x			
178.	480-93-110(8)	CP test reading on all exposed facilities where coating has been removed	x			
179.	192.491	Annual Pipe-to-soil monitoring (1 per yr/15 months) .465(a) Reviewed and did OQ on the 3 casing crossing 1-5 in W King	x			
180.	192.491	Rectifier Monitoring (6 per yr/2½ months) .465(b) Reviewed	x			
181.	192.491	Interference Bond Monitoring – Critical (6 per yr/2½ months) .465(c)	x			

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL RECORDS			S	U	N/A	N/C
182.	192.491	Interference Bond Monitoring – Non-critical (1 per yr/15 months) .465(c)	x			
183.	480-93-110(2)	Remedial action taken within 90 days (Up to 30 additional days if other circumstances. Must document) .465(d) yes	x			
184.	480-93-110(3)	CP equipment/ instrumentation maintained, tested for accuracy, calibrated, and operated in accordance with manufactures recommendations, or at appropriate schedule determined by gas company if no recommendation.	x			
185.	192.491	Unprotected Pipeline Surveys, CP active corrosion areas (1 per 3 cal yr/39 months) .465(e) Bare steel replacement program. All bare to be replaced by 2014. This was reviewed during E King County inspections.	x			
186.	192.491	Electrical Isolation (Including Casings) .467 Reviewed query of SAP showing casings.	x			
187.	480-93-110(5)	Casings inspected/tested annually not to exceed fifteen months Reviewed query of SAP showing casings.	x			
188.	480-93-110(5)(a)	Casings w/no test leads installed prior to 9/05/1992. Demonstrate other acceptable test methods Steel wrap inserted in cast iron in Seattle, Everett and Tacoma. Used cast as casing so didn't have to dig for replacement. Approx 20 odd sites.	x			
189.	480-93-110(5)(b)	Possible shorted conditions – Perform confirmatory follow-up inspection within 90 days PSE defines shorted casing as less that 100mv shift between the carrier and casing. None as of inspection date in W King.	x			
190.	480-93-110(5)(c)	Casing shorts cleared when practical	x			
191.	480-93-110(5)(d)	Shorted conditions leak surveyed within 90 days of discovery. Twice annually/7.5 months Following relate to steel wrapped in cast iron pipe. PSE calls them casings. TS042243 failed the 2-2009 resistance test, passed in 3-2010. Test lead wires on the coupling had failed, wires replaced so they could get true read. TS042266 failed 12-2009 the resistance test, passed 2-2010. Test lead wires on the coupling had failed, wires replaced so they could get true read. TS042270 failed in 8-2010, in 9-2010 passed. 6 -27-201 resulted from water short and PSE had to offset the 4" steel wrap main around the water main	x			
192.	192.491	Interference Currents .473 No stray currents or bonds in W King. No known locations. . By Seattle waterfront in2010 found and remediated stray current. (it was city rectifier causing problem)x	x			
193.	192.491	Internal Corrosion; Corrosive Gas Investigation .475(a)	x			
194.	192.491	Internal Corrosion; Internal Surface Inspection; Pipe Replacement .475(b)	x			
195.	192.491	Internal Corrosion Control Coupon Monitoring (2 per yr/7½ months) .477 none	x			
196.	192.491	Atmospheric Corrosion Control Monitoring (1 per 3 cal yr/39 months onshore; 1 per yr/15 months offshore) .481 PSE changed their atmospheric corrosion inspection process in 2009. This will be looked at in detail in the Pierce inspection The way that PSE personnel interpret the O&M and Field Manual is a rating of 1 is perfect, a rating of 2 is anything except pitting, a rating of 3 is pitting, a rating of 4 is so bad if you touch pipe it falls apart.	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

CORROSION CONTROL RECORDS			S	U	N/A	N/C
197.	192.491	Remedial: Replaced or Repaired Pipe; coated and protected; corrosion evaluation and actions .483/.485 PSE's new program, does not do atmospheric corrosion remedial action if it will not fail before the next atmospheric corrosion inspection. PSE must check interfaces regardless – this is being looked at in detail in the Pierce inspection	x			

Comments:

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
198.	192.161	Supports and anchors	x			
199.	480-93-080(1)(d)	Welding procedures located on site where welding is performed?	x			
200.	480-93-080(1)(b)	Use of testing equipment to record and document essential variables	x			
201.	480-93-080(2)(a)	Plastic procedures located on site where welding is performed?	x			
202.	480-93-080(3)	Identification and qualification cards/certificates w/name of welder/joiner, their qualifications, date of qualification and operator whose qualification procedures were followed.	x			
203.	480-93-013	Personnel performing "New Construction" covered tasks OQ qualified?	x			
204.	480-93-015(1)	Odorization	x			
205.	480-93-018(3)	Updated records, inc maps and drawings made available to appropriate operations personnel?	x			
206.	192.179	Valve Protection from Tampering or Damage	x			
207.	192.455	Pipeline coatings meet requirements of 192.461 <i>(for buried pipelines installed after 7/31/71)</i>	x			
208.	192.463	Levels of cathodic protection	x			
209.	192.465	Rectifiers	x			
210.	192.467	CP - Electrical Isolation	x			
211.	192.476	Systems designed to reduce internal corrosion	x			
212.	192.479	Pipeline Components exposed to the atmosphere	x			
213.	192.481	Atmospheric Corrosion: monitoring	x			
214.	192.491	Test Stations – Sufficient Number .469	x			
215.	480-93-115(2)	Casings – Test Leads (casings w/o vents installed after 9/05/1992)	x			
216.	480-93-115(2)	Mains or transmission lines installed in casings/conduit. Are casing ends sealed?	x			
217.	480-93-115(4)	Service lines installed in casings/conduit. Are casing ends nearest to building walls sealed?	x			
218.	192.605(a)	Appropriate parts of manuals kept at locations where O&M activities are conducted	x			
219.	192.605	Knowledge of Operating Personnel	x			
220.	480-93-124	Pipeline markers	x			
221.	480-93-124(4)	Markers reported missing or damaged replaced within 45 days?	x			
222.	192.719	Pre-pressure Tested Pipe (Markings and Inventory)	x			
223.	192.195	Overpressure protection designed and installed where required?	x			
224.	192.739/743	Pressure Limiting and Regulating Devices (Mechanical/Capacities)	x			
225.	192.741	Telemetry, Recording Gauges	x			

**Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection**

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

PIPELINE INSPECTION (Field)			S	U	N/A	N/C
226.	192.751	Warning Signs	x			
227.	192.355	Customer meters and regulators. Protection from damage	x			
228.	192.355(c)	Pits and vaults: Able to support vehicular traffic where anticipated. No vaults over 220 cu ft. standard vaults 4 ft and less. 1st test with gas monitor for co gas and for o2 and hcs. 2nd 4-6 ft deep monitor air and have air blower blowing outside air into vault. Over 6 ft have tripod, monitor for 4 gas, blow in air.	x			
229.	480-93-140	Service regulators installed, operated and maintained per state/fed regs and manufacturers recommended practices?	x			
230.	480-93-178(2)	Plastic Pipe Storage facilities – Maximum Exposure to Ultraviolet Light (2yrs)	x			
231.	480-93-178(4)	Minimum Clearances from other utilities. For parallel lines a minimum of twelve inches. Where a minimum twelve inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards.	x			
232.	480-93-178(5)	Minimum Clearances from other utilities. For perpendicular lines a minimum of six inches of separation from the other utilities. Where a minimum six inches of separation is not possible, must take adequate precautions, such as inserting the plastic pipeline in conduit, to minimize any potential hazards	x			
233.	480-93-178(6)	Are there Temporary above ground PE pipe installations currently? Yes No x	x			
234.	480-93-178(6)(a)	If yes, is facility monitored and protected from potential damage?	x			
235.	480-93-178(6)(b)	If installation exceeded 30 days, was commission staff notified prior to exceeding the deadline?	x			
236.	192.745	Valve Maintenance (Transmission)	x			
237.	192.747	Valve Maintenance (Distribution)	x			

Facility Sites Visited:		
Facility Type	Facility ID Number	Location

Comments:

Utilities and Transportation Commission
Standard Inspection Report for Intrastate Gas Distribution Systems
Records Review and Field Inspection

S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

Recent Gas Pipeline Safety Advisory Bulletins: (Last 2 years)

<u>Number</u>	<u>Date</u>	<u>Subject</u>
ADB-09-01	May 21, 2009	Potential Low and Variable Yield and Tensile Strength and Chemical Composition Properties in High Strength Line Pipe
ADB-09-02	Sept 30, 2009	Weldable Compression Coupling Installation
ADB-09-03	Dec 7, 2009	Operator Qualification Program Modifications
ADB-09-04	Jan 14, 2010	Reporting Drug and Alcohol Test Results for Contractors and Multiple Operator Identification Numbers
ADB-10-02	Feb 3, 2010	Implementation of Revised Incident/Accident Report Forms for Distribution Systems, Gas Transmission and Gathering Systems, and Hazardous Liquid Systems
ADB-10-03	March 24, 2010	Girth Weld Quality Issues Due to Improper Transitioning, Misalignment, and Welding Practices of Large Diameter Line Pipe
ADB-10-04	April 29, 2010	Pipeline Safety: Implementation of Electronic Filing for Recently Revised Incident/Accident Report Forms for Distribution Systems, Gas Transmission and Gathering Systems, and Hazardous Liquid Systems
ADB-10-05	June 28, 2010	Pipeline Safety: Updating Facility Response Plans in Light of Deepwater Horizon Oil Spill
ADB-10-06	August 3, 2010	Pipeline Safety: Personal Electronic Device Related Distractions
ADB-10-07	August 31, 2010	Liquefied Natural Gas Facilities: Obtaining Approval of Alternative Vapor-Gas Dispersion Models
ADB-10-08	November 3, 2010	Pipeline Safety: Emergency Preparedness Communications
ADB-11-01	January 4, 2011	Pipeline Safety: Establishing Maximum Allowable Operating Pressure or Maximum Operating Pressure Using Record Evidence, and Integrity Management Risk Identification, Assessment, Prevention, and Mitigation
ADB-11-02	February 9, 2011	Dangers of Abnormal Snow and Ice Build-up on Gas Distribution Systems

For more PHMSA Advisory Bulletins, go to <http://phmsa.dot.gov/pipeline/regs/advisory-bulletin>

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

238.		.605(b)		COMPRESSOR STATION PROCEDURES		S	U	N/A	N/C
239.		.605(b)(6)	Maintenance procedures, including provisions for isolating units or sections of pipe and for purging before returning to service					x	
240.		.605(b)(7)	Starting, operating, and shutdown procedures for gas compressor units					x	
241.		.731	Inspection and testing procedures for remote control shutdowns and pressure relieving devices (1 per yr/15 months), prompt repair or replacement					x	
242.		.735	(a) Storage of excess flammable or combustible materials at a safe distance from the compressor buildings					x	
243.			(b) Tank must be protected according to NFPA #30					x	
244.		.736	Compressor buildings in a compressor station must have fixed gas detection and alarm systems (must be performance tested), unless:					x	
245.			• 50% of the upright side areas are permanently open, or					x	
246.			• It is an unattended field compressor station of 1000 hp or less					x	

Comments:
 No compressor stations in unit

COMPRESSOR STATION O&M PERFORMANCE AND RECORDS				S	U	N/A	N/C
247.	.709	.731(a)	Compressor Station Relief Devices (1 per yr/15 months)			x	
248.		.731(c)	Compressor Station Emergency Shutdown (1 per yr/15 months)			x	
249.		.736(c)	Compressor Stations – Detection and Alarms (Performance Test)			x	

Comments:
 No compressor stations in unit

COMPRESSOR STATIONS INSPECTION (Field)				S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")							
250.	.163	(c)	Main operating floor must have (at least) two (2) separate and unobstructed exits			x	
251.			Door latch must open from inside without a key				
252.			Doors must swing outward			x	
253.		(d)	Each fence around a compressor station must have (at least) 2 gates or other facilities for emergency exit			x	
254.			Each gate located within 200 ft of any compressor plant building must open outward			x	
255.			When occupied, the door must be opened from the inside without a key			x	
256.		(e)	Does the equipment and wiring within compressor stations conform to the National Electric Code, ANSI/NFPA 70?			x	
257.	.165	(a)	If applicable, are there liquid separator(s) on the intake to the compressors?			x	
258.		(b)	Do the liquid separators have a manual means of removing liquids?			x	

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field)			S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")						
259.		If slugs of liquid could be carried into the compressors, are there automatic dumps on the separators, Automatic compressor shutdown devices, or high liquid level alarms?			x	
260.	.167 (a)	ESD system must:				
261.		- Discharge blowdown gas to a safe location			x	
262.		- Block and blow down the gas in the station			x	
263.		- Shut down gas compressing equipment, gas fires, electrical facilities in compressor building and near gas headers			x	
264.		- Maintain necessary electrical circuits for emergency lighting and circuits needed to protect equipment from damage			x	
265.		ESD system must be operable from at least two locations, each of which is:				
266.	.167	- Outside the gas area of the station			x	
267.		- Not more than 500 feet from the limits of the station			x	
268.		- ESD switches near emergency exits?			x	
269.	(b)	For stations supplying gas directly to distribution systems, is the ESD system configured so that the LDC will not be shut down if the ESD is activated?			x	
270.	(c)	Are ESDs on platforms designed to actuate automatically by...				
271.		- For unattended compressor stations, when:				
272.		▪ The gas pressure equals MAOP plus 15%?			x	
273.		▪ An uncontrolled fire occurs on the platform?			x	
274.		- For compressor station in a building, when				
275.		▪ An uncontrolled fire occurs in the building?			x	
276.		▪ Gas in air reaches 50% or more of LEL in a building with a source of ignition (facility conforming to NEC Class I, Group D is not a source of ignition)?			x	
277.	.171 (a)	Does the compressor station have adequate fire protection facilities? If fire pumps are used, they must not be affected by the ESD system.			x	
278.	(b)	Do the compressor station prime movers (other than electrical movers) have over-speed shutdown?			x	
279.	(c)	Do the compressor units alarm or shutdown in the event of inadequate cooling or lubrication of the unit(s)?			x	
280.	(d)	Are the gas compressor units equipped to automatically stop fuel flow and vent the engine if the engine is stopped for any reason?			x	
281.	(e)	Are the mufflers equipped with vents to vent any trapped gas?			x	
282.	.173	Is each compressor station building adequately ventilated?			x	
283.	.457	Is all buried piping cathodically protected?			x	
284.	.481	Atmospheric corrosion of aboveground facilities			x	
285.	.603	Does the operator have procedures for the start-up and shut-down of the station and/or compressor units?			x	
286.		Are facility maps current/up-to-date?			x	
287.	.615	Emergency Plan for the station on site?			x	
288.	.619	Review pressure recording charts and/or SCADA			x	
289.	.707	Markers				
290.	.731	Overpressure protection – relief's or shutdowns			x	
291.	.735	Are combustible materials in quantities exceeding normal daily usage, stored a safe distance from the compressor building?			x	

Attachment 1

Distribution Operator Compressor Station Inspection

Unless otherwise noted, all code references are to 49CFR Part 192. S – Satisfactory U – Unsatisfactory N/A – Not Applicable N/C – Not Checked
 If an item is marked U, N/A, or N/C, an explanation must be included in this report.

COMPRESSOR STATIONS INSPECTION (Field)			S	U	N/A	N/C
(Note: Facilities may be "Grandfathered")						
292.		Is aboveground oil or gasoline storage tanks protected in accordance with NFPA standard No. 30?			x	
293.	.736	Gas detection – location			x	

Comments:
 No compressor stations in unit