

April 12, 2011

***VIA ELECTRONIC FILING
AND OVERNIGHT DELIVERY***

Washington Utilities & Transportation Commission
1300 S. Evergreen Park Drive SW
P.O. Box 47250
Olympia, WA 98504-7250

RE: Modification to PacifiCorp's Annual Electric Reliability Monitoring and Reporting Plan pursuant to WAC 480-100-393

Dear Mr. Danner:

On April 8, 2011, pursuant to WAC 480-100-393, PacifiCorp, d.b.a. Pacific Power ("Company") submitted to the Washington Utilities and Transportation Commission ("Commission") modifications to the Company's Annual Electric Reliability Monitoring and Reporting Plan ("Reporting Plan"). In its modified plan, the Company demonstrated its reliability history and identified that its baseline performance was established in 2003. Unfortunately the chart on page 10 of the Reporting Plan highlighted the performance experienced in Washington during 2003, rather than providing the calculated values developed jointly with Commission Staff in 2003 and approved by the Commission in UE-981627. As such, the Company submits a revised page 10 to the proposed Reporting Plan that provides the reliability history, with explicit notation of the approved baselines.

Please direct any informal questions to me at (503) 813-6043, or Heidi Caswell, Director, Network Performance, at (503) 813-6216.

Sincerely,

Andrea L. Kelly

Andrea L. Kelly
Vice President, Regulation

Enclosures

c: Deborah Reynolds – WUTC

7.0 Appendix A: Baselines and History Through 2010

Year	Major Events Included ¹		SAIDI Based Major Events Excluded 2.5 beta		SAIFI Based Major Events Excluded 10% Op Area		Major Events Excluded As Reported (2.5 beta effective 2005)		Normalized Historic Performance ²	
	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI	SAIDI	SAIFI
2001	110	0.741	53	0.483	54	0.303	78	0.628	53	0.303
2002	183	0.881	86	0.691	109	0.726	107	0.795	86	0.691
2003	Baselines Identified in UE-981627 ³								150	0.975
2003	126	1.062	91	0.933	89	0.539	98	0.954	89	0.539
2004	172	1.024	87	0.712	119	0.726	123	0.851	87	0.712
2005	128	0.851	110	0.811	121	0.763	111	0.812	110	0.763
2006	242	1.259	121	0.982	187	0.894	122	0.985	121	0.894
2007	146	1.169	122	1.115	114	0.852	122	1.115	114	0.852
2008	329	1.756	131	1.332	129	0.899	131	1.331	129	0.899
2009	182	1.128	162	1.044	162	0.861	161	1.044	162	0.861
2010	107	0.862	107	0.862	97	0.601	103	0.688	97	0.601

¹Customer requested and pre-arranged outages are not reported in these metrics

²Normalized performance is the result of applying both SAIDI and SAIFI-based major events to establish underlying performance

³In 2003 PacifiCorp established its baselines, pursuant to UE-981627 and to 480-100-393

(Blue highlighted row signifies baselines identified.)

