

**Exh. RS-5
Docket UW-170924
Witness: Rachel Stark**

**BEFORE THE WASHINGTON
UTILITIES AND TRANSPORTATION COMMISSION**

SARAH HAND,

Complainant,

v.

RAINIER VIEW WATER CO., INC.,

Respondent.

DOCKET UW-170924

**EXHIBIT TO
TESTIMONY OF**

Rachel Stark

**STAFF OF
WASHINGTON UTILITIES AND
TRANSPORTATION COMMISSION**

*Email string between Rachel Stark and Bob Blackman,
dated December 6 through December 8, 2016*

May 3, 2018

From: Bob Blackman
To: [Stark, Rachel \(UTC\)](#)
Subject: RE: FW: WA UTC Complaint CAS-19946-L3N4X0 for Sarah Hand CRM:0008083
Date: Thursday, December 8, 2016 3:22:28 PM
Attachments: [Silver Creek.pdf](#)
[185th.pdf](#)
[Tannenbaum Well Field.pdf](#)
[Fir Meadows Well Field 03-08-2016.pdf](#)
[Fir Meadows well 4 04-20-2016.pdf](#)
[Fir Meadows wells 1,2 & 4 11-18-2016.pdf](#)
[Fir Meadows Fe-Mn Pilot Study \(2\).pdf](#)
[Silver Creek.pdf](#)

Good Afternoon Rachel,

I have attached Iron (Fe) and Manganese(Mn) testing for the wells within the pressure zone that serves the Springwood Development. The Fir Meadows Wells are the closest to the development, which would have the largest impact on water quality. The Pilot Study (3rd page, Table 4) shows the Mn levels, pretreatment (avg. .123 mg/l) and post-treatment (avg. .006 mg/l) . The purpose of the pilot study is to verify that this type of treatment will remove the Mn to levels below the MCL of .05 mg/l.

Hope this is helpful and if you have any questions please contact me.

Bob Blackman
General Manager
(253) 537-6634 X1213
www.rainieriewater.com

From: Stark, Rachel (UTC) [mailto:rstark@utc.wa.gov]
Sent: Tuesday, December 06, 2016 3:09 PM
To: Bob Blackman; Stark, Rachel (UTC)
Subject: RE: FW: WA UTC Complaint CAS-19946-L3N4X0 for Sarah Hand CRM:0008083

Hi Bob,

A couple of last things, was the company required by DOH to do the testing on these systems or was these test a customer service level set by the company?

Please provide me the test results of these systems for the past three years.

Thank you for your help with these questions Bob; I really appreciate it.

Rachel

From: [Stark, Rachel \(UTC\)](#)
To: Bob@RainierViewWater.com; [Stark, Rachel \(UTC\)](#)
Subject: RE: FW: WA UTC Complaint CAS-19946-L3N4X0 for Sarah Hand CRM:0008083
Date: Tuesday, December 6, 2016 3:08:40 PM

Hi Bob,

A couple of last things, was the company required by DOH to do the testing on these systems or was these test a customer service level set by the company?

Please provide me the test results of these systems for the past three years.

Thank you for your help with these questions Bob; I really appreciate it.

Rachel