

Table of Contents

<i>Summary of Permit Report Submittals</i>	4
<i>Special Conditions</i>	6
S1. Discharge Limits	6
S1.A. Process Wastewater Discharges	6
S1.B. Mixing Zone Authorization.....	7
S2. Monitoring Requirements	7
S2.A. Monitoring Schedule	7
S2.B. Stormwater Prohibitions and Monitoring Requirements – Outfall 002B.....	9
S2.C. Sampling and Analytical Procedures	11
S2.D. Flow Measurement, Field Measurement, and Continuous Monitoring Devices.....	11
S2.E. Laboratory Accreditation	12
S2.F. Request for Reduction in Monitoring (Stormwater)	12
S3. Reporting and Recording Requirements	12
S3.A. Discharge Monitoring Reports	12
S3.B. Permit Submittals and Schedules	14
S3.C. Records Retention	14
S3.D. Recording of Results	15
S3.E. Additional Monitoring by the Permittee	15
S3.F. Reporting Permit Violations.....	15
S3.G. Other Reporting.....	16
S3.H. Maintaining a Copy of this Permit	17
S4. Operation and Maintenance	17
S4.A. Operations and Maintenance (O&M) Manual.....	17
S4.B. Bypass Procedures.....	19
S5. Solid Wastes	20
S5.A. Solid Waste Handling.....	20
S5.B. Leachate	20
S5.C. Solid Waste Control Plan	20
S6. Application for Permit Renewal or Modification for Facility Changes	21
S6.A. Application for Permit Renewal.....	21
S6.B. Modification for Facility Changes	21
S7. Spill Control Plan	21
S7.A. Spill Control Plan Submittals and Requirements	21
S7.B. Spill Control Plan Components.....	21
S8. Outfall Evaluation	21
S9. Acute Toxicity	22
S9.A. Effluent Characterization	22
S9.B. Effluent Limit for Acute Toxicity	23
S9.C. Compliance with the Effluent Limit for Acute Toxicity	23
S9.D. Compliance Testing for Acute Toxicity	23
S9.E. Response to Noncompliance with the Effluent Limit for Acute Toxicity.....	24
S9.F. Testing When There is no Permit Limit for Acute Toxicity	25
S9.G. Sampling and Reporting Requirements.....	26

S10. Chronic Toxicity	27
S10.A. Effluent Characterization	27
S10.B. Effluent Limit for Chronic Toxicity	28
S10.C. Compliance with the Effluent Limit for Chronic Toxicity.....	28
S10.D. Compliance Testing for Chronic Toxicity.....	28
S10.E. Response to Noncompliance with the Effluent Limit for Chronic Toxicity	29
S10.F. Testing When There is no Permit Limit for Chronic Toxicity.....	30
S11. Receiving Water Study	31
S12. Pollutant Minimization	32
<i>General Conditions</i>	33
G1. Signatory Requirements	33
G2. Right of Inspection and Entry	34
G3. Permit Actions	34
G4. Reporting Planned Changes	34
G5. Plan Review Required	35
G6. Compliance with Other Laws and Statutes	35
G7. Transfer of This Permit	35
G8. Reduced Production for Compliance	35
G9. Removed Substances	35
G10. Duty to Provide Information	35
G11. Other Requirements of 40 CFR	35
G12. Additional Monitoring	36
G13. Payment of Fees	36
G14. Penalties for Violating Permit Conditions	36
G15. Upset	36
G16. Property Rights	37
G17. Duty to Comply	37
G18. Toxic Pollutants	37
G19. Penalties for Tampering	37
G20. Reporting Requirements Applicable to Existing Manufacturing, Commercial, Mining, and Silvicultural Dischargers	37
G21. Compliance Schedules	38
APPENDIX A	39

Summary of Permit Report Submittals

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S3.A.	Discharge Monitoring Report (DMR)	Monthly	August 15, 2019
S3.A.	Discharge Monitoring Report (DMR)	Quarterly	November 15, 2019
S3.A.	Priority Pollutant Data - Single Sample Discharge Monitoring Report	Annually	April 15, 2020
S3.F.	Reporting Permit Violations	As necessary	
S4.A.a.1	Operations and Maintenance Manual Update	1/permit cycle	January 1, 2020
S4.A.a.2	Operations and Maintenance Manual Review Confirmation Letter	Annually	January 1, 2021
S4.A.c	Treatment System Operating Plan	1/permit cycle	With the permit renewal application by January 1, 2024
S4.B.	Reporting Bypasses	As necessary	
S5.C.	Solid Waste Control Plan Update	1/permit cycle	July 1, 2021
S5.C.	Modification to Solid Waste Plan	As necessary	
S6.A.	Application for Permit Renewal	1/permit cycle	January 1, 2024
S6.B.	Modification for Facility Changes	As necessary	
S7.A.	Spill Plan Update	1/permit cycle, other updates submitted as necessary	July 1, 2021
S8.	Outfall Evaluation Inspection Report	Every other year	Within 90 days of conducting inspection and no later than October 1, 2021
S9.A.2	Acute Toxicity: Characterization Written Report	Quarterly for one year	May 15, 2020

Permit Section	Submittal	Frequency	First Submittal Date
S9.D.3	Acute Toxicity: Compliance Monitoring Reports	As necessary	
S9.E.	Acute Toxicity: Response to noncompliance reporting	As necessary	
S9.E.	Acute Toxicity: TI/TRE Plan	As necessary	
S9.F.4	Acute Toxicity Effluent Test Results - Submit with Permit Renewal Application	Once	January 1, 2024
S10.A.2	Chronic Toxicity: Characterization Written Report	Quarterly for one year	May 15, 2020
S10.D.3	Chronic Toxicity: Compliance Monitoring Reports	As necessary	
S10.E.	Chronic Toxicity: Response to noncompliance reporting	As necessary	
S10.E	Chronic Toxicity: TI/TRE Plan	As necessary	
S10.F.	Chronic Toxicity Effluent Test Results with Permit Renewal Application	Once	January 1, 2024
S11.1	Receiving Water Study Sampling and Quality Assurance Plan	1/permit cycle	June 30, 2021
S11.4	Receiving Water Study Sampling Report	1/permit cycle	January 1, 2024
S12.	Pollutant Minimization Evaluation and Review	At least annually	KEEP RECORDS ON-SITE FOR REVIEW
G1.3	Notice of Change in Authorization	As necessary	
G4.3	Permit Application for Substantive Changes to the Discharge	As necessary	
G5.	Engineering Report for Construction or Modification Activities	As necessary	
G7.2.b	Notice of Permit Transfer	As necessary	
G10.	Duty to Provide Information	As necessary	
G21.	Compliance Schedules	As necessary	

Special Conditions

S1. Discharge Limits

S1.A. Process Wastewater Discharges

All discharges and activities authorized by this permit must be consistent with the terms and conditions of this permit.

The discharge of any of the following pollutants more frequently than, or at a level in excess of that identified and authorized by this permit violates the terms and conditions of this permit.

Beginning on the effective date of this permit, the Permittee is authorized to discharge treated process wastewater to the Chehalis River subject to complying with the following limits:

Effluent Limits: Outfall 001		
Latitude 46.972056 Longitude -123.490528		
Parameter	Average Monthly ^a	Maximum Daily ^b
Temperature	--	16° C
Free Available Chlorine	--	0.2 mg/L
Total Suspended Solids (TSS)	30 mg/L	100 mg/L
Oil and Grease	15 mg/L	20 mg/L
Chromium, Total	--	0.2 mg/L
Priority Pollutants and PCBs	Non-Detect	
	Minimum	Maximum
pH ^d	6.0 standard units	9.0 standard units
a	Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured.	
b	Maximum daily effluent limit is the highest allowable daily discharge. The daily discharge is the average discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. This does not apply to pH or temperature.	
c	Priority pollutants (except copper and zinc) contained in chemicals added for cooling tower maintenance.	
d	When pH is continuously monitored, excursions between 5.0 and 6.0, or 9.0 and 10.0 are not considered violations if no single excursion exceeds 60 minutes in length and total excursions do not exceed 7 hours and 26 minutes per month. Any excursions below 5.0 and above 10.0 for any length of time are violations. The Permittee must report the instantaneous maximum and minimum pH monthly. Do not average pH values.	

S1.B. Mixing Zone Authorization

Mixing Zone for Outfall 001

The paragraph below defines the maximum boundaries of the mixing zones.

Chronic Mixing Zone

The width of the chronic mixing zone is limited to a distance of 65 feet. The length of the chronic mixing zone extends 100 feet upstream and 303 feet downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The concentration of pollutants at the edge of the chronic zone must meet chronic aquatic life criteria and human health criteria.

Acute Mixing Zone

The width of the acute mixing zone is limited to a distance of 6.5 feet in any horizontal direction from the outfall. The length of the acute mixing zone extends 10 feet upstream and 30.3 feet downstream of the outfall. The mixing zone extends from the bottom to the top of the water column. The concentration of pollutants at the edge of the acute zone must meet acute aquatic life criteria.

Available Dilution (dilution factor)	
Acute Aquatic Life Criteria	4
Chronic Aquatic Life Criteria	51
Human Health Criteria - Carcinogen	67
Human Health Criteria - Non-carcinogen	67

S2. Monitoring Requirements

S2.A. Monitoring Schedule

The Permittee must monitor in accordance with the following schedule and the requirements specified in **Appendix A**.

Parameter	Units	Minimum Sampling Frequency	Sample Type
(1) Wastewater Effluent – Outfall 001			
Temperature	Degree Centigrade (°C)	Continuous ^a	Meter
Flow	MGD	Continuous ^a	Meter
pH ^b	Standard Units	Continuous ^a	Meter
Free Available Chlorine	mg/L	Continuous ^a	Meter

Parameter	Units	Minimum Sampling Frequency	Sample Type
Total Suspended Solids (TSS)	mg/L	Monthly ^c	Grab ^d
Oil and Grease	mg/L	Monthly ^c	Grab ^d
Arsenic, Total	µg/L	Monthly ^c	Grab ^d
Chromium, Total	mg/L	Quarterly ^e	Grab ^d
(2) Stormwater Effluent – Outfall 002B			
Copper, Total	µg/L	Quarterly ^e	Grab ^d
Iron, Total	mg/L	Quarterly ^e	Grab ^d
Zinc, Total	µg/L	Quarterly ^e	Grab ^d
Chloride	mg/L	Quarterly ^e	Grab ^d
pH	Standard units	Quarterly ^e	Grab ^d
(3) Priority Pollutants and PCBs – Final Wastewater Effluent			
See Appendix A to identify the specific pollutants in the priority pollutant groups listed below.			
Priority Pollutants (PP) – Total Metals, Ammonia, Iron, Total Residual Chlorine, and Turbidity	µg/L; ng/L for mercury; NTU for turbidity	Annually	Grab ^d
PP – Volatile Organic Compounds	µg/L	Every two years	Grab ^d
PP – Acid-extractable Compounds	µg/L	Every two years	Grab ^d
PP – Base-neutral Compounds	µg/L	Every two years	Grab ^d
PP – Pesticides/PCBs	µg/L	Every two years	Grab ^d
Conventional Pollutants, Nonconventional Pollutants, Cyanide, and Total Phenols	µg/L	Once per permit cycle (with permit renewal application)	Grab ^d
(4) Production			
Production	Megawatts	Monthly Average	
(5) Whole Effluent Toxicity Testing – Final Wastewater Effluent			
Acute Toxicity Testing as specified in Special Condition S9 .			
Chronic Toxicity Testing as specified in Special Condition S10 .			
(6) Receiving Water - as specified in Special Condition S11.			
Notes:			

Parameter	Units	Minimum Sampling Frequency	Sample Type
a	<p>Continuous means uninterrupted except for brief lengths of time for calibration, power failure, or unanticipated equipment repair or maintenance. The time interval for the associated data logger must be no greater than 30 minutes. The Permittee must collect grab samples every 4 hours when continuous monitoring is not possible.</p> <p>Temperature grab sampling must occur when the effluent is at or near its daily maximum temperature, which usually occurs in the late afternoon.</p> <p>If measuring temperature continuously, the Permittee must determine and report a daily maximum from half-hour measurements in a 24-hour period. Continuous monitoring instruments must achieve an accuracy of 0.2 degrees C and the Permittee must verify accuracy annually.</p>		
b	<p>The Permittee must record and report the:</p> <ul style="list-style-type: none"> • Number of minutes the pH value measured between 5.0 and 6.0 and between 9.0 and 10.0 for each day. • Total minutes the pH value measured between 5.0 and 6.0 and between 9.0 and 10.0 for the month. • Monthly instantaneous maximum and minimum pH. <p>If multiple excursions occur during the day, note the duration for each excursion in the notation field in the parameter notes.</p>		
c	<p>Monthly means once every calendar month.</p>		
d	<p>Grab means an individual sample collected over a fifteen (15) minute, or less, period.</p>		
e	<p>Quarterly sampling periods are January through March, April through June, July through September, and October through December. The Permittee must begin quarterly monitoring for the quarter beginning on 7/1/2019 and submit results by 11/15/2019.</p> <p>The Permittee may petition EFSEC to reduce or suspend monitoring for any or all of these parameters when monitoring results for eight (8) consecutive quarters show there is no reasonable potential to exceed groundwater quality standards.</p>		

S2.B. Stormwater Prohibitions and Monitoring Requirements – Outfall 002B

1. Authorized Stormwater Discharges
 Beginning on the effective date of this permit and lasting through its expiration date, the Permittee is authorized to discharge stormwater from the facility to the stormwater retention pond (C-1). All discharges and activities authorized by this permit must be consistent with the terms and conditions of this permit.

2. General Prohibitions

The Permittee must manage all stormwater discharges to prevent the discharge of crude, synthetic or processed oil, or oil-containing products as identified by an oil sheen.

3. Monitoring Requirements

Beginning on the effective date of this permit, the Permittee must monitor stormwater at Outfall 002B for the parameters listed in Permit Condition S2.A.(2).

If there is no discharge during an entire quarter, the Permittee must submit a discharge monitoring report to EFSEC and Ecology stating that no discharge occurred.

The Permittee must sample the stormwater discharge during the first fall storm event each year. "First fall storm event" means the first time after October 1st of each year that precipitation occurs and results in a stormwater discharge from a facility.

The Permittee must collect samples within the first 12 hours of stormwater discharge events. If it is not possible to collect a sample within the first 12 hours of a stormwater discharge event, the Permittee must collect the sample as soon as practicable after the first 12 hours, and keep documentation with the sampling records explaining why they could not collect samples within the first 12 hours.

The Permittee is not required to sample outside of regular environmental staff business hours (Monday-Friday from 8:00am - 5:00pm), during unsafe conditions, or during quarters where there is no discharge.

For each stormwater sample taken, the Permittee must record the following information and retain it on-site for EFSEC and/or Ecology review.

- a. Sample date.
- b. Sample time.
- c. A notation describing if the Permittee collected the sample within the first 12 hours of stormwater discharge events.
- d. An explanation of why it could not collect a sample within the first 12 hours of a stormwater discharge event, if it was not possible.
- e. Sample location (using SWPPP identifying number).
- f. Method of sampling, and method of sample preservation, if applicable.
- g. Individual who performed the sampling.

Each inspection must include visual observations made at the stormwater sampling locations and areas where the stormwater is discharged off-site. The inspection must include observations for the presence of floating materials, visible sheen, discoloration, turbidity, odor, or presence of illicit discharges. The inspection must include an assessment of all Best Management Practices (BMPs) that have been implemented, the effectiveness of the BMPs, and whether any maintenance or changes in BMPs are needed.

If an illicit discharge is discovered, the Permittee must notify EFSEC and/or Ecology within 7 days. The Permittee must eliminate the illicit discharge within 30 days.

The Permittee must record the results of each inspection including:

- a. Time and date of the inspection
- b. Locations inspected.
- c. Any observations of non-compliance and the remedial actions the Permittee plans to take.
- d. Name, title, and signature of the person conducting the inspection.

The Permittee must submit the results of quarterly stormwater monitoring and monthly visual inspections to EFSEC and/or Ecology by the due dates below:

Reporting Period	Months	Quarterly Results
1st Quarter	January, February, and March	May 15
2nd Quarter	April, May, and June	August 15
3rd Quarter	July, August, and September	November 15
4th Quarter	October, November, and December	February 15

S2.C. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit must conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 (or as applicable in 40 CFR subchapters N [Parts 400–471] or O [Parts 501-503]) unless otherwise specified in this permit. EFSEC may only specify alternative methods for parameters without limits and for those parameters without an EPA approved test method in 40 CFR Part 136.

S2.D. Flow Measurement, Field Measurement, and Continuous Monitoring Devices

The Permittee must:

1. Select and use appropriate flow measurement, field measurement, and continuous monitoring devices and methods consistent with accepted scientific practices.
2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard, the manufacturer’s recommendation, and approved O&M manual procedures for the device and the wastestream.
3. Calibrate continuous monitoring instruments (pH, chlorine, and temperature) at least monthly and (flow) at least annually. The Permittee:
 - a. Must calibrate apparatus for continuous monitoring of dissolved oxygen by air calibration.
 - b. Must calibrate continuous pH measurement instruments with standard buffers.
 - c. Must calibrate continuous chlorine measurement instruments with standard buffers.

4. Calibrate micro-recording temperature devices, known as thermistors, using protocols from Ecology's Quality Assurance Project Plan Development Tool (*Standard Operating Procedures for Continuous Temperature Monitoring of Fresh Water Rivers and Streams Version 1.0 10/26/2011*). This document is available online at: <https://fortress.wa.gov/ecy/publications/documents/1803205.pdf>

Calibration as specified in this document is not required if the Permittee uses recording devices certified by the manufacturer.

5. Use field measurement devices as directed by the manufacturer and do not use reagents beyond their expiration dates.
6. Maintain calibration records for at least three years.

S2.E. Laboratory Accreditation

The Permittee must ensure that all monitoring data required by EFSEC for permit specified parameters is prepared by a laboratory registered or accredited under the provisions of chapter 173-50 WAC, *Accreditation of Environmental Laboratories*. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. The Permittee must obtain accreditation for conductivity and pH if it must receive accreditation or registration for other parameters.

S2.F. Request for Reduction in Monitoring (Stormwater)

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring or eight (8) consecutive quarters for stormwater. EFSEC will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request to EFSEC and Ecology.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

S3. Reporting and Recording Requirements

The Permittee must monitor and report in accordance with the following conditions. Falsification of information submitted to Ecology and/or EFSEC is a violation of the terms and conditions of this permit.

S3.A. Discharge Monitoring Reports

The first monitoring period begins on the effective date of the permit (unless otherwise specified). The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic discharge monitoring report (DMR) form provided by Ecology within the Water Quality Permitting Portal. Include data for each of the parameters tabulated in Special Condition S2 and as required by the form.

Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.

To find out more information and to sign up for the Water Quality Permitting Portal go to: <http://ecyapwq/wqwebportal/>

2. Ensure that DMRs are electronically submitted no later than the dates specified below, unless otherwise specified in this permit.
3. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below.

The Permittee must:

- a. Submit **monthly** DMRs by the 15th day of the following month.
 - b. Submit **quarterly DMRs**, unless otherwise specified in the permit, by the 15th day of the month following the monitoring period. Quarterly sampling periods are January through March, April through June, July through September, and October through December. The Permittee must submit the first quarterly DMR on November 15 for the quarter beginning on 7/1/2019.
 - c. Submit **single sample DMRs**, unless otherwise specified in the permit, by April 15 for the previous calendar year.
4. Enter the “No Discharge” reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.
 5. Report single analytical values below detection as “less than the detection level (DL)” by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and quantitation level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.
 6. Report single analytical values between the detection level (DL) and the quantitation level (QL) by entering the estimated value, the code for estimated value/below quantitation limit (j) and any additional information in the comments. Submit a copy of the laboratory report as an attachment using WQWebDMR.
 7. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in **Appendix A**.
 8. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
 - a. The reported numeric value for all parameters measured between the detection value and the quantitation value for the sample analysis.
 - b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.

- c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
9. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WQWebDMR form and include: sample date, concentration detected, detection limit (DL) (as necessary), and laboratory quantitation level (QL) (as necessary).

The Permittee must also submit an electronic copy of the laboratory report as an attachment using WQWebDMR. The contract laboratory reports must also include information on the chain of custody, QA/QC results, and documentation of accreditation for the parameter.

10. In addition to reporting through WQWebDMR, permittee must submit a copy of the DMR to EFSEC at the following address:

EFSEC
P.O. Box 43172
Olympia, WA 98504-7250

S3.B. Permit Submittals and Schedules

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all other written permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard-copy) report, the Permittee must ensure that it is postmarked or received by Ecology and EFSEC no later than the dates specified by this permit. Send these paper reports to Ecology at:

Water Quality Permit Coordinator
Department of Ecology
Industrial Section
PO Box 47706
Olympia, WA 98504-7600

And to EFSEC at:

EFSEC
PO Box 43172
Olympia, WA 98504-3172

S3.C. Records Retention

The Permittee must retain records of all monitoring information for a minimum of three (3) years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by EFSEC.

S3.D. Recording of Results

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.
2. The individual who performed the sampling or measurement.
3. The dates the analyses were performed.
4. The individual who performed the analyses.
5. The analytical techniques or methods used.
6. The results of all analyses.

S3.E. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Special Condition S2.

S3.F. Reporting Permit Violations

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology and EFSEC within thirty (30) days of sampling.

a. Immediate Reporting

The Permittee must immediately report to EFSEC, the Department of Ecology, and the Department of Health, Drinking Water Program (at the numbers listed below), all:

- Collection system overflows discharging to a water body used as a source of drinking water.
- Plant bypasses discharging to a waterbody used as a source of drinking water.

EFSEC	360-664-1345
Ecology Industrial Section	360-407-6955
Department of Health,	800-521-0323 (business hours)
Drinking Water Program	877-481-4901 (after business hours)
Grays Harbor County Health	360-249-4222 (business hours)

b. Twenty-Four-Hour Reporting

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology and EFSEC at the telephone numbers listed above, within 24 hours from the time the Permittee becomes aware of any of the following circumstances:

1. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
2. Any unanticipated bypass that causes an exceedance of any effluent limit in the permit (See Part S4.B., "Bypass Procedures").

3. Any upset that causes an exceedance of an effluent limit in the permit (See G.15, “Upset”).
4. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Section S1.A of this permit.
5. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit. This requirement does not include industrial process wastewater overflows to impermeable surfaces which are collected and routed to the treatment works.

c. Report Within Five Days

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above. The report must contain:

1. A description of the noncompliance and its cause.
2. The period of noncompliance, including exact dates and times.
3. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
5. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

d. Waiver of Written Reports

EFSEC may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

e. All Other Permit Violation Reporting

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for S3.A ("Reporting"). The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

S3.G. Other Reporting

a. Spills of Oil or Hazardous Materials

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of RCW 90.56.280 and chapter 173-303-145. You can obtain further instructions at the following website:

<https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>.

The Permittee must also notify EFSEC at the telephone number listed in S3.F.a within 24 hours.

b. Failure to Submit Relevant or Correct Facts

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to EFSEC and Ecology, it must submit such facts or information promptly.

S3.H. Maintaining a Copy of this Permit

The Permittee must keep a copy of this permit at the facility and make it available upon request to EFSEC and/or Ecology inspectors.

S4. Operation and Maintenance

The Permittee must, at all times, properly operate and maintain all facilities or systems of treatment and control (and related appurtenances), which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes keeping a daily operation logbook (paper or electronic), adequate laboratory controls, and appropriate quality assurance procedures. This provision of the permit requires the Permittee to operate backup or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of this permit.

The Permittee must schedule any facility maintenance, which might require interruption of wastewater treatment and degrade effluent quality, during non-critical water quality periods and carry this maintenance out according to the approved O&M manual or as otherwise approved by EFSEC.

S4.A. Operations and Maintenance (O&M) Manual

a. O&M Manual Submittal and Requirements

The Permittee must:

1. Submit an updated O&M Manual that meets the requirements of 173-240-150 WAC to EFSEC for approval by **January 1, 2020**.
2. Review the O&M Manual at least annually and confirm this review by letter to EFSEC by the **1st day** of each year.
3. Submit to EFSEC for review and approval substantial changes or updates to the O&M Manual whenever it incorporates them into the manual.
4. Keep the approved O&M Manual at the permitted facility.
5. Follow the instructions and procedures of this manual.

b. O&M Manual Components

In addition to the requirements of WAC 173-240-150, the O&M Manual must be consistent with the guidance in Table G1-3 in the *Criteria for Sewage Works Design* (Orange Book) 2008. The O&M Manual must include:

1. Emergency procedures for plant shutdown and cleanup in the event of a wastewater system upset or failure.
2. A review of system components which if failed could pollute surface water or could impact human health. Provide a procedure for a routine schedule of checking the function of these components.

3. Wastewater system maintenance procedures that contribute to the generation of process wastewater.
4. Any directions to maintenance staff when cleaning, or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (for example, defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine).
5. Wastewater sampling protocols and procedures for compliance with the sampling and reporting requirements in the wastewater discharge permit.
6. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
7. Specify other items on case-by-case basis such as O&M for any pump stations, lagoon liners, etc.

c. Treatment System Operating Plan

The Permittee must summarize the following information in the initial chapter of the O&M Manual entitled the “Treatment System Operating Plan.”

For the purposes of this permit, a Treatment System Operating Plan (TSOP) is a concise summary of specifically defined elements of the O&M Manual.

The Permittee must submit an updated Treatment System Operating Plan to EFSEC by **January 1, 2024** (with the application for renewal). The Permittee must update and submit this plan, as necessary, to include requirements for any major modifications of the treatment system.

The TSOP must not conflict with the O&M Manual and must include the following information:

1. A baseline operating condition, which describes the operating parameters and procedures, used to meet the effluent limits of S1 at the production levels used in developing these limits.
2. In the event of production rates below the baseline levels used to establish these limits, the plan must describe the operating procedures and conditions needed to maintain design treatment efficiency. The monitoring and reporting must be described in the plan.
3. In the event of an upset due to plant maintenance activities, severe stormwater events, startups or shut downs, or other causes, the plan must describe the operating procedures and conditions employed to mitigate the upset. The monitoring and reporting must be described in the plan.
4. A description of any regularly scheduled maintenance or repair activities at the facility which would affect the volume or character of the wastes discharged to the wastewater treatment system and a plan for monitoring and treating/controlling the discharge of maintenance-related materials (such as cleaners, degreasers, solvents, etc.).

S4.B. Bypass Procedures

A bypass is the intentional diversion of waste streams from any portion of a treatment facility. This permit prohibits all bypasses except when the bypass is for essential maintenance, as authorized in special condition S4.B.1, or is approved by EFSEC as an anticipated bypass following the procedures in S4.B.2.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

This permit allows bypasses for essential maintenance of the treatment system when necessary to ensure efficient operation of the system. The Permittee may bypass the treatment system for essential maintenance only if doing so does not cause violations of effluent limits. The Permittee is not required to notify EFSEC when bypassing for essential maintenance. However the Permittee must comply with the monitoring requirements specified in special condition S2.B.

2. Anticipated bypasses for non-essential maintenance

EFSEC may approve an anticipated bypass under the conditions listed below. This permit prohibits any anticipated bypass that is not approved through the following process.

- a. If a bypass is for non-essential maintenance, the Permittee must notify EFSEC, if possible, at least ten (10) days before the planned date of bypass. The notice must contain:
 - A description of the bypass and the reason the bypass is necessary.
 - An analysis of all known alternatives which would eliminate, reduce, or mitigate the potential impacts from the proposed bypass.
 - A cost-effectiveness analysis of alternatives.
 - The minimum and maximum duration of bypass under each alternative.
 - A recommendation as to the preferred alternative for conducting the bypass.
 - The projected date of bypass initiation.
 - A statement of compliance with SEPA.
 - A request for modification of water quality standards as provided for in WAC 173-201A-410, if an exceedance of any water quality standard is anticipated.
 - Details of the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify EFSEC of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific engineering report as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.

- c. EFSEC will determine if the Permittee has met the conditions of special condition S4.B.2 a and b and consider the following prior to issuing a determination letter, an administrative order, or a permit modification as appropriate for an anticipated bypass:
- If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.
 - If the bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 - If feasible alternatives to the bypass exist, such as:
 - The use of auxiliary treatment facilities.
 - Retention of untreated wastes.
 - Stopping production.
 - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance.
 - Transport of untreated wastes to another treatment facility.

S5. Solid Wastes

S5.A. Solid Waste Handling

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

S5.B. Leachate

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters.

S5.C. Solid Waste Control Plan

The Permittee must submit all proposed revisions or modifications to the solid waste control plan to EFSEC for review at least 30 days prior to implementation. The Permittee must comply with the approved solid waste control plan and any modifications once approved. The Permittee must submit an update of the solid waste control plan by **July 1, 2021**.

S6. Application for Permit Renewal or Modification for Facility Changes

S6.A. Application for Permit Renewal

The Permittee must submit an application for renewal of this permit to EFSEC by **January 1, 2024**.

S6.B. Modification for Facility Changes

The Permittee must also submit a new application or addendum at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

S7. Spill Control Plan

S7.A. Spill Control Plan Submittals and Requirements

The Permittee must:

1. Submit to EFSEC an update to the existing spill control plan consistent with the timeline identified in the site certification agreement by **July 1, 2021**.
2. Review the plan at least annually and update it at intervals no longer than every two years.
3. Send changes to the plan to EFSEC.
4. Follow the plan and any supplements throughout the term of the permit.

S7.B. Spill Control Plan Components

The spill control plan must include the following:

1. A list of all oil and petroleum products and other materials used and/or stored on-site, which when spilled, or otherwise released into the environment, designate as Dangerous Waste (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070. Include other materials used and/or stored on-site which may become pollutants or cause pollution in stormwater runoff or upon reaching state's waters.
2. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.
3. A description of the reporting system the Permittee will use to alert responsible managers and legal authorities in the event of a spill.
4. A description of operator training to implement the plan.

The Permittee may submit plans and manuals required by 40 CFR Part 112, contingency plans required by Chapter 173-303 WAC, or other plans required by other agencies, which meet the intent of this section.

S8. Outfall Evaluation

The Permittee must inspect the submerged portion of the outfall line and diffuser to document its integrity and continued function, every other year of the permit term. If conditions allow for a photographic verification, the Permittee must include such verification in the report.

The Permittee must submit the inspection report to EFSEC and Ecology through the Water Quality Permitting Portal – Permit Submittals application within 90 days of conducting the inspection.

The Permittee must submit hard-copies of any video files to Ecology and EFSEC as required by Permit Condition S3.B. The Portal does not support submittal of video files.

The inspector must at a minimum:

- Assess the physical condition of the outfall pipe, diffuser, and associated couplings.
- Determine the extent of sediment accumulation in the vicinity of the diffuser.
- Ensure diffuser ports are free of obstructions and are allowing uniform flow.
- Confirm physical location (latitude/longitude) and depth at mean lower low water (MLLW) of the diffuser section of the outfall.
- Assess physical condition of the submarine line.
- Assess physical condition of anchors used to secure the submarine line.

S9. Acute Toxicity

S9.A. Effluent Characterization

The Permittee must:

1. Conduct quarterly acute toxicity testing on the final effluent for one year starting in 1st Quarter 2020. Quarters means January through March, April through June, July through September, and October through December. If no discharge occurs during the required quarter, the Permittee must notify Ecology and EFSEC by the end of the quarter and conduct sampling on the next representative discharge that occurs in the following quarter.
2. Submit a written report to Ecology and EFSEC within 45 days of sampling and starting no later than May 15th. Each subsequent report is due on August 15th, November 15th, and February 15th of each year. Further instructions on testing conditions and test report content are in Section G below.
3. Use a dilution series consisting of a minimum of five concentrations and a control. The five concentrations should include the acute critical effluent concentration (ACEC) of 20% effluent.
4. Conduct the following **two** acute toxicity tests on each sample:

Acute Toxicity Tests	Species	Method
Fathead minnow 96-hour static-renewal test	<i>Pimephales promelas</i>	EPA-821-R-02-012
Daphnid 48-hour static test	<i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i> , or <i>Daphnia magna</i>	EPA-821-R-02-012

5. The effluent limit for acute toxicity listed in Section B below applies if after one year of effluent characterization:
 - The median survival of any species in 100% effluent is below 80%.
 - Any one test of any species exhibits less than 65% survival in 100% effluent.

If the limit applies, then the Permittee must immediately follow the instructions in Sections B, C, D, E, and G. If the limit does not apply, then the Permittee must follow the instructions in Sections F and G.

S9.B. Effluent Limit for Acute Toxicity

The effluent limit for acute toxicity is:

No acute toxicity detected in a test concentration representing the ACEC.

The ACEC means the maximum concentration of effluent during critical conditions at the boundary of the acute mixing zone, defined in Section S1.B. of this permit. The ACEC equals 20% effluent.

S9.C. Compliance with the Effluent Limit for Acute Toxicity

Compliance with the effluent limit for acute toxicity means the results of the testing specified in Section D show no statistically significant difference in survival between the control and the ACEC.

If the test results show a statistically significant difference in survival between the control and the ACEC, and Ecology has not determined the test result to be anomalous under Section E, and the test is otherwise valid, the result is a violation of the effluent limit for acute toxicity. The Permittee must immediately conduct the additional testing described in Section E.

The Permittee must determine the statistical significance by conducting a hypothesis test at the 0.05 level of significance (Appendix H, EPA/600/4-89/001). If the difference in survival between the control and the ACEC is less than 10%, the Permittee must conduct the hypothesis test at the 0.01 level of significance.

S9.D. Compliance Testing for Acute Toxicity

The Permittee must:

1. Perform the acute toxicity tests with 100% effluent, the ACEC, and a control, or with a full dilution series.
2. Conduct quarterly acute toxicity testing on the final effluent if characterization determines that the effluent limit for acute toxicity applies.

Testing must begin by January 1, 2020. Quarters means January through March, April through June, July through September, and October through December. If no discharge occurs during the required quarter, the Permittee must notify Ecology and EFSEC by the end of the quarter and conduct sampling on the next representative discharge that occurs in the following quarter.

3. Submit a quarterly written report to Ecology and EFSEC within 45 days of sampling and starting no later than April 30th. Each subsequent report is due on April 30th, July 30th, October 30th, and January 30th of each year. Further instructions on testing conditions and test report content are in Section G below.
4. The Permittee must perform compliance tests using each of the species and protocols listed below on a rotating basis:

Acute Toxicity Tests	Species	Method
Fathead minnow 96-hour static-renewal test	<i>Pimephales promelas</i>	EPA-821-R-02-012
Daphnid 48-hour static test	<i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i> , or <i>Daphnia magna</i>	EPA-821-R-02-012

S9.E. Response to Noncompliance with the Effluent Limit for Acute Toxicity

If a toxicity test conducted under Section D determines a statistically significant difference in response between the ACEC and the control, using the statistical test described in Section C, the Permittee must begin additional testing within one week from the time of receiving the test results. The Permittee must:

1. Test the next four discharge events using the same test and species as the failed compliance test.
2. Test at least five effluent concentrations and a control to determine appropriate point estimates. One of these effluent concentrations must equal the ACEC. The results of the test at the ACEC will determine compliance with the effluent limit for acute toxicity as described in Section C.
3. Return to the original monitoring frequency in Section D after completion of the additional compliance monitoring.

Anomalous test results: If a toxicity test conducted under Section D indicates noncompliance with the acute toxicity limit and the Permittee believes that the test result is anomalous, the Permittee may notify Ecology that the compliance test result may be anomalous. The Permittee may take one additional sample for toxicity testing and wait for notification from Ecology before completing the additional testing. The Permittee must submit the notification with the report of the compliance test result and identify the reason for considering the compliance test result to be anomalous.

If Ecology determines that the test result was not anomalous, the Permittee must complete all of the additional monitoring required in this section. Or,

If the one additional sample fails to comply with the effluent limit for acute toxicity, then the Permittee must complete all of the additional monitoring required in this section. Or,

If Ecology determines that the test result was anomalous, the one additional test result will replace the anomalous test result for the purpose of determining compliance with the acute toxicity limit.

If all of the additional testing in S9.E.1 complies with the permit limit, the Permittee must submit a report to Ecology and EFSEC on possible causes and preventive measures for the transient toxicity event, which triggered the additional compliance monitoring. This report must include a search of all pertinent and recent facility records, including:

- Operating records
- Monitoring results
- Inspection records
- Spill reports
- Weather records
- Production records
- Raw material purchases
- Pretreatment records, etc.

If the additional testing in this section shows another violation of the acute toxicity limit, the Permittee must submit a Toxicity Identification/Reduction Evaluation (TI/RE) plan to Ecology and EFSEC within sixty (60) days after the sample date (WAC 173-205-100(2)).

S9.F. Testing When There is no Permit Limit for Acute Toxicity

The Permittee must:

1. Conduct acute toxicity testing on final effluent once in the last summer and once in the last winter prior to submission of the application for permit renewal.
2. Conduct acute toxicity testing on a series of at least five concentrations of effluent, including 100% effluent and a control.
3. Use each of the following species and protocols for each acute toxicity test:

Acute Toxicity Tests	Species	Method
Fathead minnow 96-hour static-renewal test	<i>Pimephales promelas</i>	EPA-821-R-02-012
Daphnid 48-hour static test	<i>Ceriodaphnia dubia</i> , <i>Daphnia pulex</i> , or <i>Daphnia magna</i>	EPA-821-R-02-012

4. Submit the results to Ecology and EFSEC by **January 1, 2024** (with the permit renewal application).

S9.G. Sampling and Reporting Requirements

1. The Permittee must submit all reports for toxicity testing in accordance with the most recent version of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. Reports must contain toxicity data, bench sheets, and reference toxicant results for test methods. In addition, the Permittee must submit toxicity test data in electronic format (CETIS export file preferred) for entry into Ecology's database.
2. The Permittee must collect grab samples for toxicity testing. The Permittee must cool the samples to 0 - 6 degrees Celsius during collection and send them to the lab immediately upon completion. The lab must begin the toxicity testing as soon as possible but no later than 36 hours after sampling was completed.
3. The laboratory must conduct water quality measurements on all samples and test solutions for toxicity testing, as specified in the most recent version of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*.
4. All toxicity tests must meet quality assurance criteria and test conditions specified in the most recent versions of the EPA methods listed in Subsection C and the Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. If Ecology determines any test results to be invalid or anomalous, the Permittee must repeat the testing with freshly collected effluent.
5. The laboratory must use control water and dilution water meeting the requirements of the EPA methods listed in Section A or pristine natural water of sufficient quality for good control performance.
6. The Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
7. The Permittee must chemically dechlorinate final effluent samples for whole effluent toxicity testing with sodium thiosulfate just prior to test initiation. Do not add more sodium thiosulfate than is necessary to neutralize the chlorine. Provide in the test report the calculations to determine the amount of sodium thiosulfate necessary to just neutralize the chlorine in the sample.
8. The Permittee must collect effluent samples for whole effluent toxicity testing just prior to the chlorination step in the treatment process.
9. The Permittee may sample receiving water at the same time as the effluent and instruct the lab to measure the hardness of both and increase the hardness of the effluent sample to match the hardness of the receiving water sample prior to beginning the toxicity test. Otherwise, the Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
10. The Permittee may choose to conduct a full dilution series test during compliance testing in order to determine dose response. In this case, the series must have a minimum of five

effluent concentrations and a control. The series of concentrations must include the ACEC. The ACEC equals 20% effluent.

11. All whole effluent toxicity tests, effluent screening tests, and rapid screening tests that involve hypothesis testing must comply with the acute statistical power standard of 29% as defined in WAC 173-205-020. If the test does not meet the power standard, the Permittee must repeat the test on a fresh sample with an increased number of replicates to increase the power.

S10. Chronic Toxicity

S10.A. Effluent Characterization

The Permittee must:

1. Conduct quarterly chronic toxicity testing on the final effluent for one year starting in 1st Quarter 2020. Quarters means January through March, April through June, July through September, and October through December. If no discharge occurs during the required quarter, the Permittee must notify Ecology and EFSEC by the end of the quarter and conduct sampling on the next representative discharge that occurs in the following quarter.
2. Submit a written report to Ecology and EFSEC for within 45 days of sampling and starting no later than May 15th. Each subsequent report is due on August 15th, November 15th, and February 15th of each year. Further instructions on testing conditions and test report content are in Section G below.
3. Conduct chronic toxicity testing during effluent characterization on a series of at least five concentrations of effluent and a control. This series of dilutions must include the ACEC.

The ACEC equals 20% effluent. The series of dilutions should also contain the chronic critical effluent concentration (CCEC) of 2% effluent.

4. Conduct the following **two** chronic toxicity tests on each sample:

Freshwater Chronic Test	Species	Method
Fathead minnow survival and growth	<i>Pimephales promelas</i>	EPA-821-R-02-013
Water flea survival and reproduction	<i>Ceriodaphnia dubia</i>	EPA-821-R-02-013

5. The effluent limit for chronic toxicity listed in Section B below applies if after one year of effluent characterization any test shows a significant difference between the control and the ACEC at the 0.05 level of significance using hypothesis testing (Appendix H, EPA/600/4-89/001).

- If the limit applies, then the Permittee must immediately follow the instructions in Sections B, C, D, E, and G. If the limit does not apply, then the Permittee must follow the instructions in Sections F and G.

S10.B. Effluent Limit for Chronic Toxicity

**The Effluent Limit for Chronic Toxicity is:
No toxicity detected in a test concentration representing the CCEC.**

The CCEC means the maximum concentration of effluent during critical conditions at the boundary of the mixing zone, defined in Section S1.B. of this permit. The CCEC equals 2% effluent.

S10.C. Compliance with the Effluent Limit for Chronic Toxicity

Compliance with the effluent limit for chronic toxicity means the results of the testing specified in Subsection D. show no statistically significant difference in response between the control and the CCEC.

If the test results show a statistically significant difference in survival between the control and the CCEC, and Ecology has not determined the test result to be anomalous under Section E, and the test is otherwise valid, the result is a violation of the effluent limit for chronic toxicity. The Permittee must immediately conduct the additional testing described in Section E.

The Permittee must determine the statistical significance by conducting a hypothesis test at the 0.05 level of significance (Appendix H, EPA/600/4-89/001). If the difference in response between the control and the CCEC is less than 20%, the Permittee must conduct the hypothesis test at the 0.01 level of significance.

Ecology will reevaluate the need for the chronic toxicity limit in future permits.

Therefore, the Permittee must also conduct this same hypothesis test

(Appendix H, EPA/600/4-89/001) to determine whether a statistically significant difference in response exists between the ACEC and the control.

S10.D. Compliance Testing for Chronic Toxicity

The Permittee must:

1. Perform the chronic toxicity tests using the CCEC, the ACEC, and a control, or with a full dilution series.
2. Conduct quarterly chronic toxicity testing on the final effluent if characterization determines that the effluent limit for chronic toxicity applies. Testing must begin by January 1, 2020. Quarters means January through March, April through June, July through September, and October through December. If no discharge occurs during the required quarter, the Permittee must notify Ecology and EFSEC by the end of the quarter and conduct sampling on the next representative discharge that occurs in the following quarter.

3. Submit a quarterly written report to Ecology and EFSEC within 45 days of sampling and starting no later than April 30th, 2020. Each subsequent report is due on April 30th, July 30th, October 30th, and January 30th of each year. Further instructions on testing conditions and test report content are in Section G below.
4. Perform compliance tests using the following species on a rotating basis and the most recent version of the following protocols:

Freshwater Chronic Test	Species	Method
Fathead minnow survival and growth	<i>Pimephales promelas</i>	EPA-821-R-02-013
Water flea survival and reproduction	<i>Ceriodaphnia dubia</i>	EPA-821-R-02-013

S10.E. Response to Noncompliance with the Effluent Limit for Chronic Toxicity

If a toxicity test conducted under Subsection D determines a statistically significant difference in response between the CCEC and the control using the statistical test described in Subsection C, the Permittee must begin additional testing within one week from the time of receiving the test results. The Permittee must:

1. Test the next three discharge events using the same test and species as the failed compliance test.
2. Use a series of at least five effluent concentrations and a control to determine appropriate point estimates. One of these effluent concentrations must equal the CCEC. The results of the test at the CCEC will determine compliance with the effluent limit for chronic toxicity as described in Subsection B.
3. Return to the original monitoring frequency in Subsection D after completion of the additional compliance monitoring.

Anomalous test results: If a toxicity test conducted under Subsection D indicates noncompliance with the chronic toxicity limit and the Permittee believes that the test result is anomalous, the Permittee may notify Ecology that the compliance test result may be anomalous. The Permittee may take one additional sample for toxicity testing and wait for notification from Ecology before completing the additional testing. The Permittee must submit the notification with the report of the compliance test result and identify the reason for considering the compliance test result to be anomalous.

If Ecology determines that the test result was not anomalous, the Permittee must complete all of the additional monitoring required in this section. Or,

If the one additional sample fails to comply with the effluent limit for chronic toxicity, then the Permittee must complete all of the additional monitoring required in this section. Or,

If Ecology determines that the test result was anomalous, the one additional test result will replace the anomalous test result for the purpose of determining compliance with the chronic toxicity limit.

If all of the additional testing required in S10.E.1 complies with the permit limit, the Permittee must submit a report to Ecology and EFSEC on possible causes and preventive measures for the transient toxicity event, which triggered the additional compliance monitoring. This report must include a search of all pertinent and recent facility records, including:

- Operating records
- Monitoring results
- Inspection records
- Spill reports
- Weather records
- Production records
- Raw material purchases
- Pretreatment records, etc.

If the additional testing required by this section shows another violation of the chronic toxicity limit, the Permittee must submit a Toxicity Identification/Reduction Evaluation (TI/RE) plan to Ecology and EFSEC within 60 days after the sample date (WAC 173-205-100(2)).

S10.F. Testing When There is no Permit Limit for Chronic Toxicity

The Permittee must:

1. Conduct chronic toxicity testing on final effluent once in the last winter and once in the last summer prior to submission of the application for permit renewal.
2. Conduct chronic toxicity testing on a series of at least five concentrations of effluent and a control. This series of dilutions must include the aACEC. The ACEC equals 25% effluent. The series of dilutions should also contain the CCEC of 2% effluent.
3. Compare the ACEC to the control using hypothesis testing at the 0.05 level of significance as described in Appendix H, EPA/600/4-89/001.
4. Submit the results to Ecology and EFSEC by **January 1, 2024** (with the permit renewal application).
5. Perform chronic toxicity tests with all of the following species and the most recent version of the following protocols:

Freshwater Chronic Test	Species	Method
Fathead minnow survival and growth	<i>Pimephales promelas</i>	EPA-821-R-02-013
Water flea survival and reproduction	<i>Ceriodaphnia dubia</i>	EPA-821-R-02-013

S10.G. Sampling and Reporting Requirements

1. The Permittee must submit all reports for toxicity testing in accordance with the most recent version of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. Reports must contain toxicity data, bench sheets, and reference toxicant results for test methods. In addition, the Permittee must submit toxicity test data in electronic format (CETIS export file preferred) for entry into Ecology's database.
2. The Permittee must collect grab samples for toxicity testing. The Permittee must cool the samples to 0 - 6 degrees Celsius during collection and send them to the lab immediately upon completion. The lab must begin the toxicity testing as soon as possible but no later than 36 hours after sampling was completed.
3. The laboratory must conduct water quality measurements on all samples and test solutions for toxicity testing, as specified in the most recent version of Ecology Publication No. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*.
4. All toxicity tests must meet quality assurance criteria and test conditions specified in the most recent versions of the EPA methods listed in Section C. and the Ecology Publication no. WQ-R-95-80, *Laboratory Guidance and Whole Effluent Toxicity Test Review Criteria*. If Ecology determines any test results to be invalid or anomalous, the Permittee must repeat the testing with freshly collected effluent.
5. The laboratory must use control water and dilution water meeting the requirements of the EPA methods listed in Subsection C. or pristine natural water of sufficient quality for good control performance.
6. The Permittee must conduct whole effluent toxicity tests on an unmodified sample of final effluent.
7. The Permittee may choose to conduct a full dilution series test during compliance testing in order to determine dose response. In this case, the series must have a minimum of five effluent concentrations and a control. The series of concentrations must include the CCEC and the ACEC. The CCEC and the ACEC may either substitute for the effluent concentrations that are closest to them in the dilution series or be extra effluent concentrations. The CCEC equals 2% effluent. The ACEC equals 25% effluent.
8. All whole effluent toxicity tests that involve hypothesis testing must comply with the chronic statistical power standard of 39% as defined in WAC 173-205-020. If the test does not meet the power standard, the Permittee must repeat the test on a fresh sample with an increased number of replicates to increase the power.

S11. Receiving Water Study

The Permittee must collect receiving water information necessary to determine if the effluent has a reasonable potential to cause a violation of the water quality standards. If reasonable potential exists, Ecology will use the study information to calculate effluent limits.

The Permittee must:

1. Submit a Sampling and Quality Assurance Plan for EFSEC and/or Ecology review and approval by **June 30, 2021**. Prepare all quality assurance plans in accordance with the guidelines given in *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies* (Ecology Publication No. 04-03-030). This document is available at: <https://fortress.wa.gov/ecy/publications/documents/0403030.pdf>
2. Conduct all sampling and analysis in accordance with the approved sampling and quality assurance plan.
 - a. Locate the receiving water sampling locations outside the zone of influence of the effluent.
 - b. Use sampling station accuracy requirements of ± 20 meters.
 - c. Time the sampling as close as possible to the critical period for the receiving water.
 - d. Follow the clean sampling techniques (Method 1669: *Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels*, EPA Publication No. 821-R-95-034, April 1995).
 - e. Collect at least ten receiving water samples from the Chehalis River and analyze the samples for both the total and dissolved fractions for copper and zinc.
 - f. Analyze samples for the list of total metals and conventional parameters from the 2012 Receiving Water Study.
 - g. Conduct all chemical analysis using the methods and the detection levels identified in Appendix A.
3. Submit data to Ecology's Environmental Information Management system (EIM). Data must be submitted to EIM according to the instructions on the EIM website. The data submittal portion of the EIM website (<https://ecology.wa.gov/Research-Data/Data-resources/Environmental-Information-Management-database/EIM-submit-data>) provides information and help on formats and requirements for submitting tabular data. Specific questions about data submittal may be directed to the EIM Data Coordinator.
4. Submit the final report, summarizing the results of the study to EFSEC and Ecology by **January 1, 2024**. The final report must document when the data was successfully loaded into EIM.

Any subsequent sampling and analysis must also meet these requirements. The Permittee may conduct a cooperative receiving water metals study with other NPDES Permittees discharging in the same vicinity.

S12. Pollutant Minimization

The Permittee must continue to review and implement BMPs to reduce pollutant loading to the Chehalis River at Outfall 001 with emphasis on arsenic, mercury, and phosphorus. The Permittee must evaluate contributions from chemicals used in cooling tower maintenance and review quality assurance reports from bulk chemical suppliers at least annually to ensure that there are no significant changes to arsenic, mercury, and phosphorus levels in the effluent and to look for ways to reduce those levels.

General Conditions

G1. Signatory Requirements

1. All applications submitted to EFSEC must be signed and certified.
 - a. In the case of corporations, by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
 - A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation, or
 - The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
 - b. In the case of a partnership, by a general partner.
 - c. In the case of sole proprietorship, by the proprietor.
 - d. In the case of a municipal, state, or other public facility, by either a principal executive officer or ranking elected official.

Applications for permits for domestic wastewater facilities that are either owned or operated by, or under contract to, a public entity shall be submitted by the public entity.

2. All reports required by this permit and other information requested by EFSEC must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above and submitted to EFSEC.
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
3. Changes to authorization. If an authorization under paragraph G1.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph G1.2, above, must be submitted to EFSEC prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this section must make the following certification:

“I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

G2. Right of Inspection and Entry

The Permittee must allow an authorized representative of EFSEC and/or Ecology, upon the presentation of credentials and such other documents as may be required by law:

1. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
2. To have access to and copy, at reasonable times and at reasonable cost, any records required to be kept under the terms and conditions of this permit.
3. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
4. To sample or monitor, at reasonable times, any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

G3. Permit Actions

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon EFSEC’s initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 463-76-055(2) according to the procedures of 40 CFR 124.5 and WAC 463-76-062 as applicable.

G4. Reporting Planned Changes

The Permittee must, as soon as possible, but no later than one hundred eighty (180) days prior to the proposed changes, give notice to EFSEC of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in:

1. The permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b).
2. A significant change in the nature or an increase in quantity of pollutants discharged.

3. A significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation.

G5. Plan Review Required

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to EFSEC for approval in accordance with chapter 463-76 WAC. Engineering reports, plans, and specifications must be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by EFSEC. Facilities must be constructed and operated in accordance with the approved plans.

G6. Compliance with Other Laws and Statutes

Nothing in this permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. Transfer of This Permit

Transfer of coverage may only be authorized by the EFSEC Council.

G8. Reduced Production for Compliance

The Permittee, in order to maintain compliance with its permit, must control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

G9. Removed Substances

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

G10. Duty to Provide Information

The Permittee must submit to EFSEC and Ecology, within a reasonable time, all information which EFSEC may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to EFSEC and/or Ecology upon request, copies of records required to be kept by this permit.

G11. Other Requirements of 40 CFR

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

G12. Additional Monitoring

EFSEC may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

G13. Payment of Fees

The Permittee must submit payment of fees for costs incurred associated with this permit as assessed by EFSEC.

G14. Penalties for Violating Permit Conditions

Enforcement actions for violations of this permit, including the issuance of penalties, shall be consistent with RCW 80.50.150, RCW 80.50.155, RCW 90.48, WAC 463-70 and WAC 463-76. Any person who is found guilty of willfully violating the terms and conditions of this permit is deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit may incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is deemed to be a separate and distinct violation.

G15. Upset

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limits if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1. An upset occurred and that the Permittee can identify the cause(s) of the upset.
2. The permitted facility was being properly operated at the time of the upset.
3. The Permittee submitted notice of the upset as required in Special Condition S3.F.
4. The Permittee complied with any remedial measures required under S3.F of this permit.

In any enforcement action the Permittee seeking to establish the occurrence of an upset has the burden of proof.

G16. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

G17. Duty to Comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

G18. Toxic Pollutants

The Permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

G19. Penalties for Tampering

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$25,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

G20. Reporting Requirements Applicable to Existing Manufacturing, Commercial, Mining, and Silvicultural Dischargers

The Permittee belonging to the categories of existing manufacturing, commercial, mining, or silviculture must notify EFSEC as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following "notification levels:"
 - a. One hundred micrograms per liter (100 µg/L).
 - b. Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony.
 - c. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7).
 - d. The level established by the Director in accordance with 40 CFR 122.44(f).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following "notification levels:"
 - a. Five hundred micrograms per liter (500µg/L).
 - b. One milligram per liter (1 mg/L) for antimony.

- c. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7).
- d. The level established by the Director in accordance with 40 CFR 122.44(f).

G21. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than fourteen (14) days following each schedule date.

APPENDIX A

LIST OF POLLUTANTS WITH ANALYTICAL METHODS, DETECTION LIMITS AND QUANTITATION LEVELS

The Permittee must use the specified analytical methods, detection limits (DLs) and quantitation levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136.

If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a quantitation limit (QL) to EFSEC with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

EFSEC added this appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122.), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit's Appendix A list does not include those parameters. The list also includes pulp and paper pollutants identified in 40 CFR Part 430 and the dioxin and furan congeners identified using EPA Method 1613.

CONVENTIONAL POLLUTANTS

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
Biochemical Oxygen Demand		SM5210-B		2 mg/L
Biochemical Oxygen Demand, Soluble		SM5210-B ³		2 mg/L
Fecal Coliform		SM 9221E,9222	N/A	Specified in method - sample aliquot dependent
Oil and Grease (HEM) (Hexane Extractable Material)		1664 A or B	1,400	5,000
pH		SM4500-H ⁺ B	N/A	N/A
Total Suspended Solids		SM2540-D		5 mg/L

NONCONVENTIONAL POLLUTANTS

Pollutant & CAS No. (if available)	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
Alkalinity, Total		SM2320-B		5 mg/L as CaCO ₃
Aluminum, Total	7429-90-5	200.8	2.0	10
Ammonia, Total (as N)		SM4500-NH ₃ -B and C/D/E/G/H		20
Barium Total	7440-39-3	200.8	0.5	2.0
BTEX (benzene +toluene + ethylbenzene + m,o,p xylenes)		EPA SW 846 8021/8260	1	2
Boron, Total	7440-42-8	200.8	2.0	10.0
Chemical Oxygen Demand		SM5220-D		10 mg/L
Chloride		SM4500-Cl B/C/D/E and SM4110 B		Sample and limit dependent
Chlorine, Total Residual		SM4500 Cl G		50.0
Cobalt, Total	7440-48-4	200.8	0.05	0.25
Color		SM2120 B/C/E		10 color units
Dissolved oxygen		SM4500-OC/OG		0.2 mg/L
Flow		Calibrated device		
Fluoride	16984-48-8	SM4500-F E	25	100
Hardness, Total		SM2340B		200 as CaCO ₃
Iron, Total	7439-89-6	200.7	12.5	50
Magnesium, Total	7439-95-4	200.7	10	50
Manganese, Total	7439-96-5	200.8	0.1	0.5
Molybdenum, Total	7439-98-7	200.8	0.1	0.5

NONCONVENTIONAL POLLUTANTS

Pollutant & CAS No. (if available)	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
Nitrate + Nitrite Nitrogen (as N)		SM4500-NO3- E/F/H		100
Nitrogen, Total Kjeldahl (as N)		SM4500-N _{org} B/C and SM4500NH ₃ -B/C/D/EF/G/H		300
NWTPH Dx ⁴		Ecology NWTPH Dx	250	250
NWTPH Gx ⁵		Ecology NWTPH Gx	250	250
Phosphorus, Total (as P)		SM 4500 PB followed by SM4500-PE/PF	3	10
Salinity		SM2520-B		3 practical salinity units or scale (PSU or PSS)
Settleable Solids		SM2540 -F		Sample and limit dependent
Soluble Reactive Phosphorus (as P)		SM4500-P E/F/G	3	10
Sulfate (as mg/L SO ₄)		SM4110-B		0.2 mg/L
Sulfide (as mg/L S)		SM4500-S ² F/D/E/G		0.2 mg/L
Sulfite (as mg/L SO ₃)		SM4500-SO3B		2 mg/L
Temperature (max. 7-day avg.)		Analog recorder or Use micro-recording devices known as thermistors		0.2° C
Tin, Total	7440-31-5	200.8	0.3	1.5
Titanium, Total	7440-32-6	200.8	0.5	2.5
Total Coliform		SM 9221B, 9222B, 9223B	N/A	Specified in method - sample aliquot dependent
Total Organic Carbon		SM5310-B/C/D		1 mg/L
Total dissolved solids		SM2540 C		20 mg/L

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ <i>µg/L unless specified</i>	Quantitation Level (QL)² <i>µg/L unless specified</i>
METALS, CYANIDE & TOTAL PHENOLS					
Antimony, Total	114	7440-36-0	200.8	0.3	1.0
Arsenic, Total	115	7440-38-2	200.8	0.1	0.5
Beryllium, Total	117	7440-41-7	200.8	0.1	0.5
Cadmium, Total	118	7440-43-9	200.8	0.05	0.25
Chromium (hex) dissolved	119	18540-29-9	SM3500-Cr C	0.3	1.2
Chromium, Total	119	7440-47-3	200.8	0.2	1.0
Copper, Total	120	7440-50-8	200.8	0.4	2.0
Lead, Total	122	7439-92-1	200.8	0.1	0.5
Mercury, Total	123	7439-97-6	1631E	0.0002	0.0005
Nickel, Total	124	7440-02-0	200.8	0.1	0.5
Selenium, Total	125	7782-49-2	200.8	1.0	1.0
Silver, Total	126	7440-22-4	200.8	0.04	0.2
Thallium, Total	127	7440-28-0	200.8	0.09	0.36
Zinc, Total	128	7440-66-6	200.8	0.5	2.5
Cyanide, Total	121	57-12-5	335.4	5	10
Cyanide, Weak Acid Dissociable	121		SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	121		SM4500-CN G	5	10
Phenols, Total	65		EPA 420.1		50

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ <i>µg/L unless specified</i>	Quantitation Level (QL)² <i>µg/L unless specified</i>
ACID COMPOUNDS					
2-Chlorophenol	24	95-57-8	625.1	3.3	9.9
2,4-Dichlorophenol	31	120-83-2	625.1	2.7	8.1
2,4-Dimethylphenol	34	105-67-9	625.1	2.7	8.1
4,6-dinitro-o-cresol (2-methyl-4,6,-dinitrophenol)	60	534-52-1	625.1/1625B	24	72
2,4 dinitrophenol	59	51-28-5	625.1	42	126
2-Nitrophenol	57	88-75-5	625.1	3.6	10.8
4-Nitrophenol	58	100-02-7	625.1	2.4	7.2
Parachlorometa cresol (4-chloro-3-methylphenol)	22	59-50-7	625.1	3.0	9.0
Pentachlorophenol	64	87-86-5	625.1	3.6	10.8
Phenol	65	108-95-2	625.1	1.5	4.5
2,4,6-Trichlorophenol	21	88-06-2	625.1	2.7	8.1

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
VOLATILE COMPOUNDS					
Acrolein	2	107-02-8	624	5	10
Acrylonitrile	3	107-13-1	624	1.0	2.0
Benzene	4	71-43-2	624.1	4.4	13.2
Bromoform	47	75-25-2	624.1	4.7	14.1
Carbon tetrachloride	6	56-23-5	624.1/601 or SM6230B	2.8	8.4
Chlorobenzene	7	108-90-7	624.1	6.0	18.0
Chloroethane	16	75-00-3	624/601	1.0	2.0
2-Chloroethylvinyl Ether	19	110-75-8	624	1.0	2.0
Chloroform	23	67-66-3	624.1 or SM6210B	1.6	4.8
Dibromochloromethane (chlordibromomethane)	51	124-48-1	624.1	3.1	9.3
1,2-Dichlorobenzene	25	95-50-1	624	1.9	7.6
1,3-Dichlorobenzene	26	541-73-1	624	1.9	7.6
1,4-Dichlorobenzene	27	106-46-7	624	4.4	17.6
Dichlorobromomethane	48	75-27-4	624.1	2.2	6.6
1,1-Dichloroethane	13	75-34-3	624.1	4.7	14.1
1,2-Dichloroethane	10	107-06-2	624.1	2.8	8.4
1,1-Dichloroethylene	29	75-35-4	624.1	2.8	8.4
1,2-Dichloropropane	32	78-87-5	624.1	6.0	18.0
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) ⁶	33	542-75-6	624.1	5.0	15.0
Ethylbenzene	38	100-41-4	624.1	7.2	21.6
Methyl bromide (Bromomethane)	46	74-83-9	624/601	5.0	10.0
Methyl chloride (Chloromethane)	45	74-87-3	624	1.0	2.0
Methylene chloride	44	75-09-2	624.1	2.8	8.4
1,1,2,2-Tetrachloroethane	15	79-34-5	624.1	6.9	20.7
Tetrachloroethylene	85	127-18-4	624.1	4.1	12.3
Toluene	86	108-88-3	624.1	6.0	18.0
1,2-Trans-Dichloroethylene (Ethylene dichloride)	30	156-60-5	624.1	1.6	4.8
1,1,1-Trichloroethane	11	71-55-6	624.1	3.8	11.4
1,1,2-Trichloroethane	14	79-00-5	624.1	5.0	15.0
Trichloroethylene	87	79-01-6	624.1	1.9	5.7
Vinyl chloride	88	75-01-4	624/SM6200B	1.0	2.0

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)					
Acenaphthene	1	83-32-9	625.1	1.9	5.7
Acenaphthylene	77	208-96-8	625.1	3.5	10.5

PRIORITY POLLUTANTS	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)					
Anthracene	78	120-12-7	625.1	1.9	5.7
Benzidine	5	92-87-5	625.1	44	132
Benzyl butyl phthalate	67	85-68-7	625.1	2.5	7.5
Benzo(a)anthracene	72	56-55-3	625.1	7.8	23.4
Benzo(b)fluoranthene (3,4-benzofluoranthene) ⁷	74	205-99-2	610/625.1	4.8	14.4
Benzo(j)fluoranthene ⁷		205-82-3	625	0.5	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) ⁷	75	207-08-9	610/625.1	2.5	7.5
Benzo(r,s,t)pentaphene		189-55-9	625	1.3	5.0
Benzo(a)pyrene	73	50-32-8	610/625.1	2.5	7.5
Benzo(ghi)Perylene	79	191-24-2	610/625.1	4.1	12.3
Bis(2-chloroethoxy)methane	43	111-91-1	625.1	5.3	15.9
Bis(2-chloroethyl)ether	18	111-44-4	611/625.1	5.7	17.1
Bis(2-chloroisopropyl)ether	42	39638-32-9	625	0.5	1.0
Bis(2-ethylhexyl)phthalate	66	117-81-7	625.1	2.5	7.5
4-Bromophenyl phenyl ether	41	101-55-3	625.1	1.9	5.7
2-Chloronaphthalene	20	91-58-7	625.1	1.9	5.7
4-Chlorophenyl phenyl ether	40	7005-72-3	625.1	4.2	12.6
Chrysene	76	218-01-9	610/625.1	2.5	7.5
Dibenzo (a,h)acridine		226-36-8	610M/625M	2.5	10.0
Dibenzo (a,j)acridine		224-42-0	610M/625M	2.5	10.0
Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene)	82	53-70-3	625.1	2.5	7.5
Dibenzo(a,e)pyrene		192-65-4	610M/625M	2.5	10.0
Dibenzo(a,h)pyrene		189-64-0	625M	2.5	10.0
3,3-Dichlorobenzidine	28	91-94-1	605/625.1	16.5	49.5
Diethyl phthalate	70	84-66-2	625.1	1.9	5.7
Dimethyl phthalate	71	131-11-3	625.1	1.6	4.8
Di-n-butyl phthalate	68	84-74-2	625.1	2.5	7.5
2,4-dinitrotoluene	35	121-14-2	609/625.1	5.7	17.1
2,6-dinitrotoluene	36	606-20-2	609/625.1	1.9	5.7
Di-n-octyl phthalate	69	117-84-0	625.1	2.5	7.5
1,2-Diphenylhydrazine (as Azobenzene)	37	122-66-7	1625B	5.0	20
Fluoranthene	39	206-44-0	625.1	2.2	6.6
Fluorene	80	86-73-7	625.1	1.9	5.7
Hexachlorobenzene	9	118-74-1	612/625.1	1.9	5.7
Hexachlorobutadiene	52	87-68-3	625.1	0.9	2.7
Hexachlorocyclopentadiene	53	77-47-4	1625B/625	2.0	4.0
Hexachloroethane	12	67-72-1	625.1	1.6	4.8
Indeno(1,2,3-cd)Pyrene	83	193-39-5	610/625.1	3.7	11.1
Isophorone	54	78-59-1	625.1	2.2	6.6
3-Methyl cholanthrene		56-49-5	625	2.0	8.0
Naphthalene	55	91-20-3	625.1	1.6	4.8

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
BASE/NEUTRAL COMPOUNDS (compounds in bold are Ecology PBTs)					
Nitrobenzene	56	98-95-3	625.1	1.9	5.7
N-Nitrosodimethylamine	61	62-75-9	607/625	2.0	4.0
N-Nitrosodi-n-propylamine	63	621-64-7	607/625	0.5	1.0
N-Nitrosodiphenylamine	62	86-30-6	625	1.0	2.0
Perylene		198-55-0	625	1.9	7.6
Phenanthrene	81	85-01-8	625.1	5.4	16.2
Pyrene	84	129-00-0	625.1	1.9	5.7
1,2,4-Trichlorobenzene	8	120-82-1	625.1	1.9	5.7

<i>PRIORITY POLLUTANT</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
DIOXIN					
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD)	129	1746-01-6	1613B	1.3 pg/L	5 pg/L

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
PESTICIDES/PCBs					
Aldrin	89	309-00-2	608.3	4.0 ng/L	12 ng/L
alpha-BHC	102	319-84-6	608.3	3.0 ng/L	9.0 ng/L
beta-BHC	103	319-85-7	608.3	6.0 ng/L	18 ng/L
gamma-BHC (Lindane)	104	58-89-9	608.3	4.0 ng/L	12 ng/L
delta-BHC	105	319-86-8	608.3	9.0 ng/L	27 ng/L
Chlordane ⁸	91	57-74-9	608.3	14 ng/L	42 ng/L
4,4'-DDT	92	50-29-3	608.3	12 ng/L	36 ng/L
4,4'-DDE	93	72-55-9	608.3	4.0 ng/L	12 ng/L
4,4' DDD	94	72-54-8	608.3	11ng/L	33 ng/L
Dieldrin	90	60-57-1	608.3	2.0 ng/L	6.0 ng/L
alpha-Endosulfan	95	959-98-8	608.3	14 ng/L	42 ng/L
beta-Endosulfan	96	33213-65-9	608.3	4.0 ng/L	12 ng/L
Endosulfan Sulfate	97	1031-07-8	608.3	66 ng/L	198 ng/L
Endrin	98	72-20-8	608.3	6.0 ng/L	18 ng/L
Endrin Aldehyde	99	7421-93-4	608.3	23 ng/L	70 ng/L
Heptachlor	100	76-44-8	608.3	3.0 ng/L	9.0 ng/L
Heptachlor Epoxide	101	1024-57-3	608.3	83 ng/L	249 ng/L
PCB-1242 ⁹	106	53469-21-9	608.3	0.065	0.195
PCB-1254	107	11097-69-1	608.3	0.065	0.195
PCB-1221	108	11104-28-2	608.3	0.065	0.195
PCB-1232	109	11141-16-5	608.3	0.065	0.195
PCB-1248	110	12672-29-6	608.3	0.065	0.195

<i>PRIORITY POLLUTANTS</i>	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
PESTICIDES/PCBs					
PCB-1260	111	11096-82-5	608.3	0.065	0.195
PCB-1016 ⁹	112	12674-11-2	608.3	0.065	0.195
Toxaphene	113	8001-35-2	608.3	240 ng/L	720 ng/L

PULP & PAPER POLLUTANTS (40CFR Part 430)

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
Adsorbable Organic Halides (AOX)		EPA 1650		20
2,3,7,8- Tetrachlorodibenzo- <i>p</i> -dioxin (TCDD) (this is also priority pollutant and is listed above)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
2,3,7,8- Tetrachlorodibenzofuran (TCDF)	51207-31-9	EPA 1613	1.3 pg/L	5 pg/L
Trichlorosyringol		EPA 1653		2.5
3,4,5-Trichlorocatechol		EPA 1653		5.0
3,4,6-Trichlorocatechol		EPA 1653		5.0
3,4,5-Trichloroguaiacol		EPA 1653		2.5
3,4,6-Trichloroguaiacol		EPA 1653		2.5
4,5,6-Trichloroguaiacol		EPA 1653		2.5
2,4,5-Trichlorophenol		EPA 1653		2.5
2,4,6-Trichlorophenol		EPA 1653		2.5
Tetrachlorocatechol		EPA 1653		5.0
Tetrachloroguaiacol		EPA 1653		5.0
2,3,4,6-Tetrachlorophenol		EPA 1653		2.5
Pentachlorphenol (this is also priority pollutant and is listed above)		EPA 1653		5.0

NONCONVENTIONALS – DIOXIN & FURAN CONGENERS

Pollutant	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL)¹ µg/L unless specified	Quantitation Level (QL)² µg/L unless specified
2,3,7,8- Tetrachlorodibenzo- <i>p</i> -dioxin (TCDD) (this is a priority pollutant and is also listed above)	1746-01-6	EPA 1613	1.3 pg/L	5 pg/L
Total TCDD	41903-57-5			
2,3,7,8- Tetrachlorodibenzofuran (TCDF)	51207-31-9		1.3 pg/L	5 pg/L
Total-TCDF	55722-27-5			
1,2,3,7,8- Pentachlorodibenzo- <i>p</i> -dioxin (PeCDD)	40321-76-4			
Total-PeCDD	36088-22-9			
1,2,3,7,8- Pentachlorodibenzofuran (PeCDF)	57117-41-6			
2,3,4,7,8-PeCDF	57117-31-4			
Total-PeCDF	30402-15-4			
1,2,3,4,7,8- Hexachlorodibenzo- <i>p</i> -dioxin (HxCDD)	39227-28-6			
1,2,3,6,7,8-HxCDD	57653-85-7			
1,2,3,7,8,9-HxCDD	19408-74-3			
Total-HxCDD	34465-46-8			
1,2,3,4,7,8- Hexachlorodibenzofuran (HxCDF)	70648-26-9			
1,2,3,6,7,8-HxCDF	57117-44-9			
1,2,3,7,8,9-HxCDF	72918-21-9			
2,3,4,6,7,8-HxCDF	60851-34-5			
Total-HxCDF	55684-94-1			
1,2,3,4,6,7,8- Heptachlorodibenzo- <i>p</i> -dioxin (HpCDD)	35822-46-9			
Total-HpCDD	37871-00-4			
1,2,3,4,6,7,8- Heptachlorodibenzofuran (HpCDF)	67562-39-4			
1,2,3,4,7,8,9-HpCDF	55673-89-7			
Total-HpCDF	38998-75-3			
Octachlorodibenzo- <i>p</i> -dioxin (OCDD)	3268-87-9			
Octachlorodibenzofuran (OCDF)	39001-02-0			

1. Detection level (DL) or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. Quantitation Level (QL) also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to (1, 2, or 5) x 10ⁿ, where n is an integer. (64 FR 30417).

ALSO GIVEN AS:

The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).

3. Soluble Biochemical Oxygen Demand method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 um (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. NWTPH Dx-Northwest Total Petroleum Hydrocarbons Diesel Extended Range – see <https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
5. NWTPH Gx - Northwest Total Petroleum Hydrocarbons Gasoline Extended Range – see <https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
6. 1, 3-dichloroproylene (mixed isomers) You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. Total Benzofluoranthenes - Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.
8. Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 14/42 ng/L.
9. PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.